

OPERATING DATA REPORT

DECKET NO. 50-247
 DATE 7/3/84
 COMPLETED BY M. Blatt
 TELEPHONE 1914/526-5127

OPERATING STATUS

1. Unit Name: Indian Point Unit 2
2. Reporting Period: June, 1984
3. Reported Thermal Power (MW): 0
4. Reported Net Electrical Power (MW): 0
5. Reported Gross Electrical Power (MW): 0
6. Reported Net Electrical Energy (MWH): 0
7. Maximum Reported Net Electrical Power (MW): 0
8. If Changes Occurred in Conditions (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

9. Power Level To Which Restricted, If Any (Net MWe): None
10. Reasons For Restrictions, If Any: None

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	720	4367	87672
12. Number Of Hours Reactor Was Critical	24.22	3228.68	59175.90
13. Reactor Reserve Shutdown Hours	0	0	2119.73
14. Hours Generator On-Line	24.22	3204.72	57400.42
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Energy Generated (MWH)	44189	8 228 228	149 260 847
17. Gross Electrical Energy Generated (MWH)	12890	2 579 530	46 237 106
18. Net Electrical Energy Generated (MWH)	8678	2 469 121	44 096 213
19. Unit Service Factor	3.4	73.4	65.5
20. Availability Factor	3.4	73.4	65.5
21. Unit Capacity Factor	3.4	73.4	65.5
22. Unit Capacity Factor (Including Reserve)	3.4	73.4	65.5

25. If Shut Down At End Of Report Period, Estimated Date of Startup: Return to service 9/7/84

26. Units In Test Status (Prior to Commercial Operation)

INITIAL CRITICALITY
 INITIAL ELECTRICAL
 COMMERCIAL OPERATION

Forecast	Achieved
N/A	N/A
N/A	N/A
N/A	N/A

AVERAGE DAILY UNIT POWER

POCKET NO. 50-247

UNIT IP Unit #2

DATE 7/3/64

COMPLETED BY M. D. Pitt

TELEPHONE (914) 526-5127

Figure 14-1

DAY	AVERAGE DAILY UNIT POWER (MW)	DAY	AVERAGE DAILY UNIT POWER LEVEL (MWe-Net)
1	0	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	0
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	0
15			
16			

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH JUNE 1984

DOCKET NO. 50-247

UNIT NAME I.P. Unit No. 2

DATE 2/3/86

COMPLETED BY G. Blatt

TELEPHONE (914) 526-5127

No.	Date	Type ¹	Reason ² (Hour)	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
4	84 0602			3	NA	XX	XXXXXXXX	cycle 5/7 refueling outage

¹
F: Forced
S: Scheduled

²
Reason:
A: Equipment Failure (Explain)
B: Maintenance or Test
C: Planned
D: Regulatory Restriction
E: Operator Training & License Examination
F: Administrative
G: Control Room Error (Explain)

³
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

⁴
Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-
0161)

⁵
Exhibit I - Same Source

Summary of Operating Experience

June 1982

Unit 2 was at 60% power at the beginning of the report period. This reduced power level was to accommodate end-of-cycle fuel burnup.

On June 2, at 0013, Unit 2 commenced a shutdown for refueling and a 10 year In Service Inspection, and remained shutdown for the remainder of the month.

MAJOR SAFETY-RELATED
CORRECTIVE MAINTENANCE

<u>MWP No.</u>	<u>DATE</u>	<u>SYSTEM</u>	<u>COMPONENT</u>	<u>DESCRIPTION</u>
05731	2/84	PSS	Valve 95E	Repaired indicator.
05742	2/84	SIS	Valve 95E	Repaired solenoid.
07917	2/84	PUR	22 PUR pump	Changed out rotor/pump shaft assembly on 22 PUR pump.
		PSS	Generator	Plugged steam generator tube.
		PSS	22 PUR pump	Replaced seal.
10299	2/84	PCS	LCV 459	Repacked LCV 459.
11024	2/84	SW	22, 23, 25 PCU's	Refurbished elbow flow measuring taps.
12390	2/84	VC	95 El. Airlock	Repaired 95 El. Airlock inner door.
12710	2/84	VC	95 El. Airlock	Replaced arm assembly on the latch for the outer door.

John D. O'Toole
Vice President

Consolidated Edison Company of New York, Inc.
4 Irving Place, New York, NY 10003
Telephone (212) 462-2533

July 15, 1984


Re: Indian Point Unit No. 2
Docket No. 50-247

Mr. William G. McDonald, Director
Office of Management Information
and Program Control
c/o Distribution Services Branch, DDC, ADM
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. McDonald:

Enclosed you will find two copies of the Monthly Operating Report for
Indian Point Unit No. 2 for the month of June 1984.

Very truly yours,



Encl.
cc:

Mr. Richard DeYoung, Director (40 copies)
Office of Inspection and Enforcement
c/o Distribution Services Branch, DDC, ADM
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dr. Thomas E. Murley, Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
631 Park Ave.
King of Prussia, Pa. 19406

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 38
Buchanan, New York 10511

1524
1/1