

## **Enclosure 1**

**MFN 15-051**

### **GEH Response to Item #10 – Gas Accumulation Locations**

#### **IMPORTANT NOTICE REGARDING CONTENTS OF THIS DOCUMENT Please Read Carefully**

The information contained in this document is furnished solely for the purpose(s) stated in the transmittal letter. The only undertakings of GEH with respect to information in this document are contained in the contracts between GEH and its customers or participating utilities, and nothing contained in this document shall be construed as changing that contract. The use of this information by anyone for any purpose other than that for which it is intended is not authorized; and with respect to any unauthorized use, GEH makes no representation or warranty, and assumes no liability as to the completeness, accuracy, or usefulness of the information contained in this document.

**NRC- Suggested Design Changes Item #10 – Gas Accumulation Locations:**

*Address three major review areas from ISG-019: identification of potential gas accumulation locations and intrusion mechanisms, addition of ITAAC to confirm identification and prevention measures, and development of procedures for surveillance and venting.*

**GEH Response:**

GEH will amend ABWR DCD Tier 1 Section 2.6.1, and Tier 2 Section 5.4, to describe features that mitigate the possible accumulation of gases in important piping systems. GEH will add a COL item to establish a program for surveillance and venting of accumulated gases. This COL item will be added to Tier 2 Table 1.9-1.

To ABWR DCD rev 5 Tier 1 Section 2.6.1, Table 2.6.1, the following text will be added:

| Design Commitments   | Inspections, Tests, Analyses   | Acceptance Criteria   |
|--|--|---|
| 7. RPV Head Spray line will have a high point vent line with the proper slope to prevent buildup of Hydrogen Gas during operation. | 7. Inspections will be performed on the as built CUW piping to confirm proper elevation and slope. | 7. Elevations and slopes of the RWCU System piping are consistent with design drawings. |

To the ABWR DCD rev 5 Section 5.4-8, the following text will be added:

A vent line down to the main steam line is provided at the high point of the RPV head spray line in order to avoid accumulation of hydrogen generated by radiolysis of reactor water during normal reactor operation.

To ABWR DCD rev 5 Section 5.4.15, the following COL action item will be added:

**5.4.15.5 Program for Surveillance and Venting of Accumulated Gases.**

The COL applicant shall develop periodic (monthly) surveillance procedures to ensure the Main Steam Equalizing Valve and the Main Steam Drain Valve are opened for short durations to vent any potential accumulation of hydrogen in the main steam vent and equalizing lines.

This COL Information Item will also be added to Table 1.9-1.

Figure 5.1-3 and Figure 5.4-12 will be updated to show the new vent line modification to the Main Steam and RWCU Head Spray piping.

**Impact on DCD:**

The ABWR DCD Tier 1 Section 2.6.1 and Tier 2 Section 5.4, Table 1.9-1, Figure 5.1-3 and Figure 5.4-12 are being revised. The ABWR DCD R5 marked up pages are provided in Enclosure 2.