

**LaSalle Environmental Audit
Response to Request for Additional Information**

Index #: 034

RAI #: SW-06

Category: Water Resources

Statement of Question:

As referenced in ER Section 2.2.3 relative to the circulating water pumps, clarify and provide the rated capacity of the six circulating water pumps located in the lake screen house.

Response:

Each circulating water pump is rated to provide 205,500 GPM at 31 ft of head.

List of Attachments:

None.