

RULES AND DIRECTIVES
BRANCH
USNRC

As of: 5/27/15 11:32 AM
Received: May 21, 2015
Status: Pending Post
Tracking No. 1jz-8iz5-noxj
Comments Due: May 22, 2015
Submission Type: Web

PUBLIC SUBMISSION 2015 MAY 27 AM 11: 46

Docket: NRC-2009-0337

Notice of Receipt and Availability of Application for a Combined License

Comment On: NRC-2009-0337-0020

Combined License Application for Turkey Point Nuclear Plant, Unit Nos. 6 and 7; Draft Environmental Impact Statement

Document: NRC-2009-0337-DRAFT-0126

Comment on FR Doc # 2015-05099

3/5/2015

QFR 12043

Submitter Information

Name: C Tamburr

128

General Comment

There is no need to build more risk in this hurricane-prone location. In 1992, the two existing nuclear reactors at Turkey Point took a direct hit from Hurricane Andrew.

According to the NRC's report: "The onsite damage included loss of all offsite power for more than 5 days, complete loss of communication systems, closing of the access road, and damage to the fire protection and security

systems and warehouse facilities...the high water tank collapsed onto the fire water system, rendering the fire protection

system inoperable. In addition, the storm threatened safety-related equipment (e.g., potential collapse of the damaged

Unit 1 chimney onto the diesel generator building)." In other words - South Florida dodged a very big bullet in 1992.

SUNSI Review Complete

Template = ADM - 013

E-RIDS= ADM-03

Add= A. Williamson (ARW1)