

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

Docket Nos. 50-269  
50-270  
50-287

MAR 14 1975

Duke Power Company  
ATTN: Mr. Austin C. Thies  
Senior Vice President  
422 South Church Street  
Post Office Box 2178  
Charlotte, North Carolina 28201

Gentlemen:

Although your emergency core cooling systems generally satisfy our requirements with regard to long-term cooling, the system configurations have not been specifically evaluated to show that significant changes in chemical concentrations would not occur during the long term after a loss-of-coolant accident (LOCA) and these potential changes have not been specifically addressed by appropriate operating procedures. Accordingly, you should review your system capabilities and operating procedures to assure that boron precipitation would not compromise long-term core cooling capability following a LOCA. This review should consider all aspects of your design, including component qualification in the LOCA environment in addition to a detailed review of operating procedures. You should examine the vulnerability of your design to single failures that would result in any significant boron precipitation.

You should submit this evaluation and associated operating procedures within 30 days of receipt of this letter. These procedures should be promptly effected to assure that boron precipitation would not interfere with the ability of your facility to conform to Criterion (5) of 10 CFR 50.46(b). We will inform you as to the acceptability of your evaluation and associated operating procedures.

While solute concentrations may be subject to control through operating procedures, equipment modifications may be required or desirable to simplify such procedures. Your submittal should include a plan for completing such modifications within six months of the date of this letter.



ECCS  
(2)

MAR 14 1975

This request for generic information was approved by GAO under a blanket clearance number B-180225 (R0072); this clearance expires July 31, 1977.

Sincerely,

Original signed by  
R. A. Purple

Robert A. Purple, Chief  
Operating Reactors Branch #1  
Division of Reactor Licensing

cc: See next page

DISTRIBUTION

Docket File  
NRC PDR  
Local PDR  
ORB#L Reading  
KRGoller  
RAPurple  
LMcDonough  
TJCarter  
SVarga  
SMSheppard  
OELD  
OI&E (3)  
ACRS (14)

OFFICE ➤	RL:ORB#1	RL:ORB#1				
SURNAME ➤	LMcDonough:dc	RAPurple				
DATE ➤	3/13/75	3/ /75				

Duke Power Company

- 3 -

MAR 14 1975

cc: Mr. William L. Porter  
Duke Power Company  
P. O. Box 2178  
422 South Church Street  
Charlotte, North Carolina 28201

Mr. Troy B. Conner  
Conner, Hadlock & Knotts  
1747 Pennsylvania Avenue, NW  
Washington, D. C. 20006

Oconee Public Library  
201 South Spring Street  
Walhalla, South Carolina 29691