

SCH15-027
CERTIFIED MAIL
RETURN RECEIPT REQUESTED
ARTICLE NUMBER: 7014 1820 0001 0924 7998



Department of Environmental Protection
Division of Water Quality
Bureau of Permit Management
P.O. Box 029
Trenton, N.J. 08625-0029

JUL 21 2015

**NEW JERSEY POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT
SALEM GENERATING STATION
NJPDES PERMIT NJ0005622**

Dear Sir:

Attached is the Discharge Monitoring Report for the Salem Generating Station for the month of June 2015.

This report is required by and prepared specifically for the New Jersey Department of Environmental Protection (NJDEP). It presents only the observed results of measurements and analyses required to be performed by the above agencies. The choice of the measurement devices and analytical methods are controlled by the EPA and the NJDEP, not by the company, and there are limitations on the accuracy of such measurement devices and analytical techniques even when used and maintained as required. Accordingly, this report is not intended as an assertion that any instrument has measured, or that any reading or analytical result represents the true value with absolute accuracy, nor is it an endorsement of the suitability of any analytical or measurement procedure.

If you have any questions concerning this report, please feel free to contact Mark Pyle (856) 339-2331.

Sincerely,


John F. Perry
Site Vice President – Salem

Attachment (12 DMR's)

C Executive Director, DRBC
USNRC - Docket numbers 50-272 & 50-311

IE25
NRR

EXPLANATION OF CONDITIONS

June 2015

The following explanations are included to clarify possible deviation from permit conditions.

General - The columns labeled "No. Ex" on the enclosed DMR tabulate the number of daily discharge values outside the indicated limits.

Data reporting and accuracy reflect the working environment, the design capabilities and reliability of the monitoring instruments and operating equipment.

Deviations from required sampling, analysis monitoring and reporting methods and periodicities are noted on the respective transmittal sheet.

Results reported on the Discharge Monitoring Report forms are consistent with permit limits, data supplied from contract laboratories, the December 2007 revision of the NJDEP DMR Instruction Manual and specific guidance from DEP personnel.

DSN 481A-486A limits for Option 1 and Option 2 are incorrect. Data is entered correctly for Option 1 and Option 2 under their respective rows.


ATTACHMENT:

None

COUNTY OF SALEM
STATE OF NEW JERSEY


I, John F. Perry, of full age, being duly sworn according to law, upon my oath depose and say:

1. I am the Site Vice President – Salem for PSEG Nuclear, and as such am authorized to sign Salem's Discharge Monitoring Reports submitted to the New Jersey Department of Environmental Protection pursuant to the Station's New Jersey Pollutant Discharge Elimination System permit.
2. I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.
3. The signature on the attached Discharge Monitoring Reports is my signature and I am submitting this affidavit in satisfaction of the requirement that my signature be notarized.



John F. Perry
Site Vice President – Salem

Sworn and subscribed before me
this 21 day of July 2015



EXPLANATION OF EXCEEDANCES

JUNE 2015

The following exceedance(s) are included in the attached report and explained below.

EXPLANATION

None

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD						MONITORED LOCATION:	
NJ0005622	Month	Day	Year	To	Month	Day	Year	FACA – SW Outfall FACA
	6	1	2015		6	30	2015	

PERMITTEE:

PSE&G NUCLEAR LLC
80 PARK PLAZA
NEWARK, NJ 07101

LOCATION OF ACTIVITY:

PSEG NUCLEAR LLC SALEM
GENERATING STATION
ALLOWAY CREEK NECK RD
HANCOCKS BRIDGE, NJ 08038

REPORT RECIPIENT:

PSEG NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE: ☐ No Discharge this Monitoring Period ☐ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

John F. Perry, Site Vice President - Salem

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)

John F. Perry

7/21/2015

856-339-3463

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

DATE

AREA CODE/PHONE NUMBER

**For a local agency where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

FACA SW Outfall FACA

6/1/2015 TO 6/30/2015

PSEG NUCLEAR LLC SALEM GENERATIN

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Temperature, oC 00010 G Raw Sew/influent	SAMPLE MEASUREMENT	*****	*****	*****	*****	25.2	27.3	DEG.C	φ	Continuous	Contin
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	REPORT 01DAMX				
	QL	*****	*****		*****	*****	*****				
Temperature, oC 00010 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	33.2	36.7	DEG.C	φ	Continuous	CONTIN
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	46.1 01DAMX				
	QL	*****	*****		*****	*****	*****				
Temperature, oC 00010 2 Effluent Net Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	8.0	9.5	DEG.C	φ	1/Day	CALCTD
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	15.3 01DAMX				
	QL	*****	*****		*****	*****	*****				
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	PA166								
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #				
	QL	*****	*****		*****	*****	*****				

Comments: If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4860 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD	MONITORED LOCATION:												
NJ0005622	<table border="1"><tr><td>Month</td><td>Day</td><td>Year</td></tr><tr><td>6</td><td>1</td><td>2015</td></tr></table> To <table border="1"><tr><td>Month</td><td>Day</td><td>Year</td></tr><tr><td>6</td><td>30</td><td>2015</td></tr></table>	Month	Day	Year	6	1	2015	Month	Day	Year	6	30	2015	FACB – SW Outfall FACB
Month	Day	Year												
6	1	2015												
Month	Day	Year												
6	30	2015												

PERMITTEE:

PSE&G NUCLEAR LLC
80 PARK PLAZA
NEWARK, NJ 07101

LOCATION OF ACTIVITY:

PSEG NUCLEAR LLC SALEM
GENERATING STATION
ALLOWAY CREEK NECK RD
HANCOCKS BRIDGE, NJ 08038

REPORT RECIPIENT:

PSEG NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE:

☐

No Discharge this Monitoring Period

☐

Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.


I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

John F. Perry, Site Vice President - Salem

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)



7/21/2015

856-339-3463

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

DATE

AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

Surface water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

FACB SW Outfall FACB

6/1/2015 TO 6/30/2015

PSEG NUCLEAR LLC SALEM GENERATIN

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Temperature, oC 00010 G Raw Sew/influent	SAMPLE MEASUREMENT	*****	*****	*****	*****	25.2	27.3	DEG.C	φ	Continuous	Contin
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	REPORT 01DAMX				
	QL	*****	*****		*****	*****	*****				
Temperature, oC 00010 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	33.0	35.2	DEG.C	φ	Continuous	Contin
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	46.1 01DAMX				
	QL	*****	*****		*****	*****	*****				
Temperature, oC 00010 2 Effluent Net Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	7.9	8.1	DEG.C	φ	1/Day	CALCTD
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	15.3 01DAMX				
	QL	*****	*****		*****	*****	*****				
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	PA166								
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #				
	QL	*****	*****		*****	*****	*****				

Comments: If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4860 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD						MONITORED LOCATION:	
NJ0005622	Month	Day	Year	To	Month	Day	Year	FACC – SW Outfall FACC
	6	1	2015		6	30	2015	

PERMITTEE:

PSE&G NUCLEAR LLC
80 PARK PLAZA
NEWARK, NJ 07101

LOCATION OF ACTIVITY:

PSEG NUCLEAR LLC SALEM
GENERATING STATION
ALLOWAY CREEK NECK RD
HANCOCKS BRIDGE, NJ 08038

REPORT RECIPIENT:

PSEG NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE:

☐

No Discharge this Monitoring Period

☐

Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

John F. Perry, Site Vice President - Salem

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

DATE

AREA CODE/PHONE NUMBER

**For a local agency where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

FACC SW Outfall FACC

6/1/2015 TO 6/30/2015

PSEG NUCLEAR LLC SALEM GENERATIN

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 G Raw Sew/influent	SAMPLE MEASUREMENT	2860	2881	MGD	*****	*****	*****	*****	φ	1/Day	Calctd
	PERMIT REQUIREMENT	3024 01MOAV	REPORT 01DAMX		*****	*****	*****			1/Day	CALCTD
	QL	*****	*****		*****	*****	*****				
Thermal Discharge Million BTUs per Hr 00015 2 Effluent Net Value	SAMPLE MEASUREMENT	14882	15010	MBTU/HR	*****	*****	*****	*****	φ	1/Day	Calctd
	PERMIT REQUIREMENT	REPORT 01MOAV	30600 01DAMX		*****	*****	*****			1/Day	CALCTD
	QL	*****	*****		*****	*****	*****				
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	PA166								
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP
	QL	*****	*****		*****	*****	*****				

Comments: If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4860 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD						MONITORED LOCATION:	
NJ0005622	Month 6	Day 1	Year 2015	To	Month 6	Day 30	Year 2015	048C – SW Outfall 48C

PERMITTEE:

PSE&G NUCLEAR LLC
80 PARK PLAZA
NEWARK, NJ 07101

LOCATION OF ACTIVITY:

PSEG NUCLEAR LLC SALEM
GENERATING STATION
ALLOWAY CREEK NECK RD
HANCOCKS BRIDGE, NJ 08038

REPORT RECIPIENT:

PSEG NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE:

☐

No Discharge this Monitoring Period

☐

Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

John F. Perry, Site Vice President - Salem

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)

John F. Perry

7/21/2015

856-339-3463

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

DATE

AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

048C SW Outfall 48C

6/1/2015 TO 6/30/2015

PSEG NUCLEAR LLC SALEM GENERATIN

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant	SAMPLE MEASUREMENT	0.2163	0.4010	MGD	*****	*****	*****	*****	1	1/Day	Calctd
50050 1	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****		*****	1/Day	CALCTD
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
Solids, Total Suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****	8	10	MG/L	1	2/Month	Compos
00530 1	PERMIT REQUIREMENT	*****	*****		*****	30 01MOAV	100 01DAMX		*****	2/Month	COMPOS
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
Nitrogen, Ammonia Total (as N)	SAMPLE MEASUREMENT	*****	*****	*****	*****	9	17	MG/L	1	2/Month	Compos
00610 1	PERMIT REQUIREMENT	*****	*****		*****	35 01MOAV	70 01DAMX		*****	2/Month	COMPOS
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
Petroleum Hydrocarbons	SAMPLE MEASUREMENT	*****	*****	*****	*****	<2	<2	MG/L	1	2/Month	Grab
00551 1	PERMIT REQUIREMENT	*****	*****		*****	10 01MOAV	15 01DAMX		*****	2/Month	GRAB
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
Carbon, Tot Organic (TOC)	SAMPLE MEASUREMENT	*****	*****	*****	*****	11	15	MG/L	1	2/Month	Compos
00680 1	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	50 01DAMX		*****	2/Month	COMPOS
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
Lab Certification #	SAMPLE MEASUREMENT	17327	PA166								
99999 99	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP
Lab	QL	*****	*****		*****	*****	*****				

Comments: If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4680 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD	MONITORED LOCATION:												
NJ0005622	<table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>6</td><td>1</td><td>2015</td></tr></table> To <table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>6</td><td>30</td><td>2015</td></tr></table>	Month	Day	Year	6	1	2015	Month	Day	Year	6	30	2015	481A – SW Outfall 481A
		Month	Day	Year										
6	1	2015												
Month	Day	Year												
6	30	2015												

PERMITTEE:

PSE&G NUCLEAR LLC
80 PARK PLAZA
NEWARK, NJ 07101

LOCATION OF ACTIVITY:

PSEG NUCLEAR LLC SALEM
GENERATING STATION
ALLOWAY CREEK NECK RD
HANCOCKS BRIDGE, NJ 08038

REPORT RECIPIENT:


PSEG NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE: ☐ No Discharge this Monitoring Period ☒ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

John F. Perry, Site Vice President - Salem	N/A
NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR	GRADE AND REGISTRY NUMBER (IF APPLICABLE)
	7/21/2015 856-339-3463
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR	DATE AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A	N/A	N/A	N/A
NAME AND TITLE	SIGNATURE	DATE	AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

481A SW Outfall 481A

6/1/2015 TO 6/30/2015

PSEG NUCLEAR LLC SALEM GENERATIN

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	484	484	MGD	*****	*****	*****	*****	φ	1/Day	Calctd
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****			1/Day	CALCTD
	QL	*****	*****		*****	*****	*****				
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	7.3	*****	7.5	SU	φ	1/week	Grab
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX			1/Week	GRAB
	QL	*****	*****		*****	*****	*****				
pH 00400 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****	*****	7.1	*****	8.2	SU	φ	1/week	Grab
	PERMIT REQUIREMENT	*****	*****		REPORT 01DAMN	*****	REPORT 01DAMX			1/Week	GRAB
	QL	*****	*****		*****	*****	*****				
LC50 Statre 96hr Acu Cyprinodon TAN6A 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	Code=N	*****	*****	%EFFL	φ	Code=N	Code=N
	PERMIT REQUIREMENT	*****	*****		50 01DAMN	*****	*****			2/Year	COMPOS
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	Code=N	Code=N	MG/L	φ	Code=N	Code=N
	PERMIT REQUIREMENT	*****	*****		*****	0.3 01MOAV	0.5 01DAMX			3/Week	GRAB
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 2	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	φ	3/week	Grdb
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	0.2 01DAMX			3/Week	GRAB
	QL	*****	*****		*****	*****	*****				

Comments: The permittee is required to perform acute toxicity testing on a minimum of one representative CWS outfall while DSN 48C is being routed to that outfall.

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

481A SW Outfall 481A

6/1/2015 TO 6/30/2015

PSEG NUCLEAR LLC SALEM GENERATIN

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Temperature, oC 00010 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****		*****	33.3	37.6			1/Day	Contin
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	REPORT 01DAMX	DEG.C		1/Day	CONTIN
	QL	*****	*****		*****	*****	*****				
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	PA166								
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP
	QL	*****	*****		*****	*****	*****				

Comments: The permittee is required to perform acute toxicity testing on a minimum of one representative CWS outfall while DSN 48C is being routed to that outfall.

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD						MONITORED LOCATION:	
NJ0005622	Month	Day	Year	To	Month	Day	Year	482A – SW Outfall 482A
	6	1	2015		6	30	2015	

PERMITTEE:

PSE&G NUCLEAR LLC
80 PARK PLAZA
NEWARK, NJ 07101

LOCATION OF ACTIVITY:

PSEG NUCLEAR LLC SALEM
GENERATING STATION
ALLOWAY CREEK NECK RD
HANCOCKS BRIDGE, NJ 08038

REPORT RECIPIENT:


PSEG NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE: ☐ No Discharge this Monitoring Period ☒ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

John F. Perry, Site Vice President - Salem	N/A
NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR	GRADE AND REGISTRY NUMBER (IF APPLICABLE)
	7/21/2015 856-339-3463
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR	DATE AREA CODE/PHONE NUMBER

**For a local agency where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A	N/A	N/A	N/A
NAME AND TITLE	SIGNATURE	DATE	AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

482A SW Outfall 482A

6/1/2015 TO 6/30/2015

PSEG NUCLEAR LLC SALEM GENERATIN

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	507	526	MGD	*****	*****	*****	*****	Φ	1/day	Calctd
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****			1/Day	CALCTD
	QL	*****	*****		*****	*****	*****				
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	7.4	*****	7.6	SU	Φ	1/week	Grab
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX			1/Week	GRAB
	QL	*****	*****		*****	*****	*****				
pH 00400 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****	*****	7.1	*****	8.2	SU	Φ	1/week	Grab
	PERMIT REQUIREMENT	*****	*****		REPORT 01DAMN	*****	REPORT 01DAMX			1/Week	GRAB
	QL	*****	*****		*****	*****	*****				
LC50 Statre 96hr Acu Cyprinodon TAN6A 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	Code=N	*****	*****	%EFFL	Φ	Code=N	Code=N
	PERMIT REQUIREMENT	*****	*****		50 01DAMN	*****	*****			2/Year	COMPOS
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	Code=N	Code=N	MG/L	Φ	Code=N	Code=N
	PERMIT REQUIREMENT	*****	*****		*****	0.3 01MOAV	0.5 01DAMX			3/Week	GRAB
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 2	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	Φ	3/week	Grab
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	0.2 01DAMX			3/Week	GRAB
	QL	*****	*****		*****	*****	*****				

Comments: The permittee is required to perform acute toxicity testing on a minimum of one representative CWS outfall while DSN 48C is being routed to that outfall.

Surface water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

482A SW Outfall 482A

6/1/2015 TO 6/30/2015

PSEG NUCLEAR LLC SALEM GENERATIN

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Temperature, oC 00010 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****		*****	33.3	38.5			1/Day	Contin
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	REPORT 01DAMX	DEG.C		1/Day	CONTIN
	QL	*****	*****		*****	*****	*****				
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	PA166								
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP
	QL	*****	*****		*****	*****	*****				

Comments: The permittee is required to perform acute toxicity testing on a minimum of one representative CWS outfall while DSN 48C is being routed to that outfall.

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD	MONITORED LOCATION:												
NJ0005622	<table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>6</td><td>1</td><td>2015</td></tr></table> To <table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>6</td><td>30</td><td>2015</td></tr></table>	Month	Day	Year	6	1	2015	Month	Day	Year	6	30	2015	483A – SW Outfall 483A
Month	Day	Year												
6	1	2015												
Month	Day	Year												
6	30	2015												

PERMITTEE:

PSE&G NUCLEAR LLC
80 PARK PLAZA
NEWARK, NJ 07101

LOCATION OF ACTIVITY:

PSEG NUCLEAR LLC SALEM
GENERATING STATION
ALLOWAY CREEK NECK RD
HANCOCKS BRIDGE, NJ 08038

REPORT RECIPIENT:

PSEG NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE:

☐

No Discharge this Monitoring Period

☒

Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

John F. Perry, Site Vice President - Salem

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)

John F. Perry

7/21/2015

856-339-3463

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

DATE

AREA CODE/PHONE NUMBER

**For a local agency where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

483A SW Outfall 483A

6/1/2015 TO 6/30/2015

PSEG NUCLEAR LLC SALEM GENERATIN

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	570	570	MGD	*****	*****	*****	*****	φ	1/Day	Calctd
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****				
	QL	*****	*****		*****	*****	*****				
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	7.4	*****	7.6	SU	φ	1/Week	Grab
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX				
	QL	*****	*****		*****	*****	*****				
pH 00400 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****	*****	7.1	*****	8.2	SU	φ	1/Week	Grab
	PERMIT REQUIREMENT	*****	*****		REPORT 01DAMN	*****	REPORT 01DAMX				
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	Code=N	Code=N	MG/L	φ	3/Week	Code=N
	PERMIT REQUIREMENT	*****	*****		*****	0.3 01MOAV	0.5 01DAMX				
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 2	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	φ	3/Week	Grab
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	0.2 01DAMX				
	QL	*****	*****		*****	*****	*****				
Temperature, oC 00010 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	33.0	37.6	DEG.C	φ	1/Day	Cont'n
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	REPORT 01DAMX				
	QL	*****	*****		*****	*****	*****				

Comments: Any questions in regards to the monitoring report form can be directed to S. Rosenwinkel of the BPSP - Region 2 at (609)292-4860.

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

483A SW Outfall 483A

6/1/2015 TO 6/30/2015

PSEG NUCLEAR LLC SALEM GENERATING

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	PA166								
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP
	QL	*****	*****		*****	*****	*****				

Comments: Any questions in regards to the monitoring report form can be directed to S. Rosenwinkel of the BPSP - Region 2 at (609)292-4860.

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD	MONITORED LOCATION:												
NJ0005622	<table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>6</td><td>1</td><td>2015</td></tr></table> To <table border="1"><tr><th>Month</th><th>Day</th><th>Year</th></tr><tr><td>6</td><td>30</td><td>2015</td></tr></table>	Month	Day	Year	6	1	2015	Month	Day	Year	6	30	2015	484A – SW Outfall 484A
Month	Day	Year												
6	1	2015												
Month	Day	Year												
6	30	2015												

PERMITTEE:

PSE&G NUCLEAR LLC
80 PARK PLAZA
NEWARK, NJ 07101

LOCATION OF ACTIVITY:

PSEG NUCLEAR LLC SALEM
GENERATING STATION
ALLOWAY CREEK NECK RD
HANCOCKS BRIDGE, NJ 08038

REPORT RECIPIENT:

PSEG NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE: ☐ No Discharge this Monitoring Period ☒ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

John F. Perry, Site Vice President - Salem

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)

John F. Perry

7/21/2015

856-339-3463

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

DATE

AREA CODE/PHONE NUMBER

**For a local agency where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

Surface water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

484A SW Outfall 484A

6/1/2015 TO 6/30/2015

PSEG NUCLEAR LLC SALEM GENERATIN

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	555	556	MGD	*****	*****	*****	*****	0	1/Day	Calctd
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****				
	QL	*****	*****		*****	*****	*****				
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	7.4	*****	7.6	SU	0	1/Week	Grab
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX				
	QL	*****	*****		*****	*****	*****				
pH 00400 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****	*****	7.1	*****	8.2	SU	0	1/Week	Grab
	PERMIT REQUIREMENT	*****	*****		REPORT 01DAMN	*****	REPORT 01DAMX				
	QL	*****	*****		*****	*****	*****				
LC50 Statre 96hr Acu Cyprinodon TAN6A 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	Code=N	*****	*****	%EFFL	0	2/Year	COMPOS
	PERMIT REQUIREMENT	*****	*****		50 01DAMN	*****	*****				
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	Code=N	Code=N	MG/L	0	3/Week	Grab
	PERMIT REQUIREMENT	*****	*****		*****	0.3 01MOAV	0.5 01DAMX				
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 2	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	0	3/Week	Grab
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	0.2 01DAMX				
	QL	*****	*****		*****	*****	*****				

Comments: The permittee is required to perform acute toxicity testing on a minimum of one representative CWS outfall while DSN 48C is being routed to that outfall.

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

484A SW Outfall 484A

6/1/2015 TO 6/30/2015

PSEG NUCLEAR LLC SALEM GENERATING

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Temperature, oC 00010 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	33.2	36.8	DEG.C	0	1/Day	Contin
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	REPORT 01DAMX			1/Day	CONTIN
	QL	*****	*****		*****	*****	*****				
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	PA166								
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP
	QL	*****	*****		*****	*****	*****				

Comments: The permittee is required to perform acute toxicity testing on a minimum of one representative CWS outfall while DSN 48C is being routed to that outfall.

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD						MONITORED LOCATION:	
NJ0005622	Month 6	Day 1	Year 2015	To	Month 6	Day 30	Year 2015	485A – SW Outfall 485A

PERMITTEE:

PSE&G NUCLEAR LLC
80 PARK PLAZA
NEWARK, NJ 07101

LOCATION OF ACTIVITY:

PSEG NUCLEAR LLC SALEM
GENERATING STATION
ALLOWAY CREEK NECK RD
HANCOCKS BRIDGE, NJ 08038

REPORT RECIPIENT:

PSEG NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE: ☐ No Discharge this Monitoring Period ☒ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

John F. Perry, Site Vice President - Salem

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)

John F. Perry

7/21/2015

856-339-3463

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

DATE

AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

485A SW Outfall 485A

6/1/2015 TO 6/30/2015

PSEG NUCLEAR LLC SALEM GENERATIN

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	488	488	MGD	*****	*****	*****	*****	Φ	1/Day	Calctd
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****				
	QL	*****	*****		*****	*****	*****				
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	7.4	*****	7.6	SU	Φ	1/Week	Grab
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX				
	QL	*****	*****		*****	*****	*****				
pH 00400 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****	*****	7.1	*****	8.2	SU	Φ	1/Week	Grab
	PERMIT REQUIREMENT	*****	*****		REPORT 01DAMN	*****	REPORT 01DAMX				
	QL	*****	*****		*****	*****	*****				
LC50 Statre 96hr Acu Cyprinodon TAN6A 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	>100	*****	*****	%EFFL	Φ	2/year	Compos
	PERMIT REQUIREMENT	*****	*****		50 01DAMN	*****	*****				
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	Code=N	Code=N	MG/L	Φ	3/Week	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	0.3 01MOAV	0.5 01DAMX				
	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants *CPOX 1 Effluent Gross Value Option 2	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	Φ	3/Week	Grab
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	0.2 01DAMX				
	QL	*****	*****		*****	*****	*****				

Comments: The permittee is required to perform acute toxicity testing on a minimum of one representative CWS outfall while DSN 48C is being routed to that outfall.

Surface water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

485A SW Outfall 485A

6/1/2015 TO 6/30/2015

PSEG NUCLEAR LLC SALEM GENERATIN

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Temperature, oC 00010 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	33.0	36.5	DEG.C	0	1/Day	Contin
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	REPORT 01DAMX				
	QL	*****	*****		*****	*****	*****				
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	PA166	*****	CT405					Not Applic	NOT AP
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #				
	QL	*****	*****		*****	*****	*****				

Comments: The permittee is required to perform acute toxicity testing on a minimum of one representative CWS outfall while DSN 48C is being routed to that outfall.

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD						MONITORED LOCATION:	
NJ0005622	Month	Day	Year	To	Month	Day	Year	486A – SW Outfall 486A
	6	1	2015		6	30	2015	

PERMITTEE:

PSE&G NUCLEAR LLC
80 PARK PLAZA
NEWARK, NJ 07101

LOCATION OF ACTIVITY:

PSEG NUCLEAR LLC SALEM
GENERATING STATION
ALLOWAY CREEK NECK RD
HANCOCKS BRIDGE, NJ 08038

REPORT RECIPIENT:

PSEG NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE: ☐ No Discharge this Monitoring Period ☒ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

John F. Perry, Site Vice President - Salem

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)

John F. Perry

7/21/2015

856-339-3463

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

DATE

AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

PI 46814

NJ0005622

486A SW Outfall 486A

6/1/2015 TO 6/30/2015

PSEG NUCLEAR LLC SALEM GENERATING

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant	SAMPLE MEASUREMENT	384	384	MGD	*****	*****	*****	*****	φ	1/Day	CALCTD
50050 1	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****				
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.3	*****	7.5	SU	φ	1/Week	GRAB
00400 1	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX				
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.1	*****	8.2	SU	φ	1/Week	GRAB
00400 7	PERMIT REQUIREMENT	*****	*****		REPORT 01DAMN	*****	REPORT 01DAMX				
Intake From Stream	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants	SAMPLE MEASUREMENT	*****	*****	*****	*****	Code=N	Code=N	MG/L	φ	3/Week	GRAB
*CPOX 1	PERMIT REQUIREMENT	*****	*****		*****	0.3 01MOAV	0.5 01DAMX				
Effluent Gross Value Option 1	QL	*****	*****		*****	*****	*****				
Chlorine Produced Oxidants	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	φ	3/Week	GRAB
*CPOX 1	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	0.2 01DAMX				
Effluent Gross Value Option 2	QL	*****	*****		*****	*****	*****				
Temperature, oC	SAMPLE MEASUREMENT	*****	*****	*****	*****	32.8	36.6	DEG.C	φ	1/Day	CONTIN
00010 1	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	REPORT 01DAMX				
Effluent Gross Value	QL	*****	*****		*****	*****	*****				

Comments: Any questions in regards to the monitoring report form can be directed to S. Rosenwinkel of the BPSP - Region 2 at (609)292-4860.

Surface water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

486A SW Outfall 486A

6/1/2015 TO 6/30/2015

PSEG NUCLEAR LLC SALEM GENERATING

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	PA166								
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP
	QL	*****	*****		*****	*****	*****				

Comments: Any questions in regards to the monitoring report form can be directed to S. Rosenwinkel of the BPSP - Region 2 at (609)292-4860.

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD						MONITORED LOCATION:
NJ0005622	Month 6	Day 1	Year 2015	To	Month 6	Day 30	487B – SW Outfall 487B

PERMITTEE:

PSE&G NUCLEAR LLC
80 PARK PLAZA
NEWARK, NJ 07101

LOCATION OF ACTIVITY:

PSEG NUCLEAR LLC SALEM
GENERATING STATION
ALLOWAY CREEK NECK RD
HANCOCKS BRIDGE, NJ 08038

REPORT RECIPIENT:

PSEG NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE: ☒ No Discharge this Monitoring Period ☐ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

John F. Perry, Site Vice President - Salem

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

DATE

AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

New Jersey Department of Environmental Protection
Division of Water Quality

Surface Water Discharge Monitoring Report Submittal Form

NJPDES PERMIT	MONITORING PERIOD	MONITORED LOCATION:												
NJ0005622	<table border="1"><tr><td>Month</td><td>Day</td><td>Year</td></tr><tr><td>6</td><td>1</td><td>2015</td></tr></table> To <table border="1"><tr><td>Month</td><td>Day</td><td>Year</td></tr><tr><td>6</td><td>30</td><td>2015</td></tr></table>	Month	Day	Year	6	1	2015	Month	Day	Year	6	30	2015	489A – SW Outfall 489A
Month	Day	Year												
6	1	2015												
Month	Day	Year												
6	30	2015												

PERMITTEE:

PSE&G NUCLEAR LLC
80 PARK PLAZA
NEWARK, NJ 07101

LOCATION OF ACTIVITY:

PSEG NUCLEAR LLC SALEM
GENERATING STATION
ALLOWAY CREEK NECK RD
HANCOCKS BRIDGE, NJ 08038

REPORT RECIPIENT:

PSEG NUCLEAR LLC
PO BOX 236/N21
HANCOCKS BRIDGE, NJ 08038

REGION / COUNTY: Southern / Salem County

CHECK IF APPLICABLE: ☐ No Discharge this Monitoring Period ☐ Monitoring Report Comments Attached

WHO MUST SIGN The highest ranking official having day-to-day managerial and operational responsibilities for the discharging facility shall sign the certification or, in his absence a person designated by that person. For a local agency, the highest ranking operator of the treatment works shall sign the certification. Where the highest ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall also sign the second certification at the bottom of this page. If the local agency has contracted with another entity to operate the treatment works, the highest-ranking official of the contracted entity shall sign the certification.


I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments, and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of and/or imprisonment, pursuant to N.J.A.C. 7:14A-6.9(B). The New Jersey water Pollution Control Act provides for penalties up to \$50,000 per violation.

John F. Perry, Site Vice President - Salem

N/A

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

GRADE AND REGISTRY NUMBER (IF APPLICABLE)



7/21/2015

856-339-3463

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER, AUTHORIZED AGENT, OR *LICENSED OPERATOR

DATE

AREA CODE/PHONE NUMBER

**For a local agency where the highest-ranking operator does not have the ability to authorize capital expenditures and hire personnel, a person having that responsibility or person designated by that person shall sign the following certification:*

I certify under penalty of law and in accordance with N.J.S.A. 58:10A-6F(5) that I have reviewed the attached discharge monitoring reports.

N/A

N/A

N/A

N/A

NAME AND TITLE

SIGNATURE

DATE

AREA CODE/PHONE NUMBER

Surface Water Discharge Monitoring Report

PI 46814

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

489A SW Outfall 489A

6/1/2015 TO 6/30/2015

PSEG NUCLEAR LLC SALEM GENERATIN

PARAMETER		QUANTITY OR LOADING		UNITS	QUALITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant	SAMPLE MEASUREMENT	0.0952	0.0952	MGD	*****	*****	*****	*****	0	1/Month	CALCTD
50050 1	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****				
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.5	*****	7.5	SU	0	1/Month	Grab
00400 1	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX				
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
Solids, Total Suspended	SAMPLE MEASUREMENT	*****	*****	*****	5	5	*****	MG/L	0	1/Month	Grab
00530 1	PERMIT REQUIREMENT	*****	*****		100 01DAMX	30 01MOAV	*****				
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
Petroleum Hydrocarbons	SAMPLE MEASUREMENT	*****	*****	*****	*****	<2	<2	MG/L	0	1/Month	Grab
00551 1	PERMIT REQUIREMENT	*****	*****		*****	10 01MOAV	15 01DAMX				
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
Carbon, Tot Organic (TOC)	SAMPLE MEASUREMENT	*****	*****	*****	*****	3	3	MG/L	0	1/Month	Grab
00680 1	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	50 01DAMX				
Effluent Gross Value	QL	*****	*****		*****	*****	*****				
Lab Certification #	SAMPLE MEASUREMENT	17327	PA166								
99999 99	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #				
Lab	QL	*****	*****		*****	*****	*****				

Comments: If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the the BPSP - Region 2 at (609)292-4860 or via email at "srosenwi@dep.state.nj.us".