



Steven D. Capps
Vice President
McGuire Nuclear Station

Duke Energy
MG01VP | 12700 Hagers Ferry Road
Huntersville, NC 28078

o: 980.875.4805
f: 980.875.4809
Steven.Capps@duke-energy.com

DESIGNATED
AS ORIGINAL PER
G. EDWARD MILLER,
McGUIRE PROJECT MANAGER

July 29, 2015
Serial: MNS-15-054

10 CFR 50.90

ATTENTION: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-001

Duke Energy Carolinas, LLC (Duke Energy)
McGuire Nuclear Station, Units 1 and 2
Docket Nos. 50-369 and 50-370
Renewed License Nos. NPF-9 and NPF-17

Subject: Withdrawal of License Amendment Request (LAR) for Technical Specification (TS) 3.7.7 - Nuclear Service Water System (NSWS), TAC NOS. ME8118 AND ME8119

Reference: Letter from Duke Energy to NRC dated February 22, 2012, Agency Wide Document Access and Management System (ADAMS) Accession No. ML12061A008, as supplemented by letters dated November 13, 2012, ADAMS Accession No. ML12340A073 and February 4, 2013, ADAMS Accession No. ML13045A307

The reference letters submitted a LAR to revise TS 3.7.7 for McGuire Units 1 and 2. The LAR would allow the use of the NSWS Pump discharge crossover valves and associated piping to cross-tie Unit 1 and 2 NSW systems for mitigation of a loss of service water event on either unit.

Following the February 4, 2013 submittal, the Nuclear Regulatory Commission staff indicated that additional information would be needed to continue with the review of this LAR. Additional conversations were held with the NRC to better understand the NRC's concerns. These conversations indicated that the concerns probably could not be resolved by the proposed Technical Specification change that was prepared in accordance with the direction given in Generic Letter (GL) 91-13, "Request for Information Related to the Resolution of Generic Issue 130, 'Essential Service Water System Failures at Multi-Unit Sites', Pursuant to 10 CFR 50.54" and response to beyond design basis (BDB) events. Additionally, these conversations indicated that there was clearly no path forward from a purely deterministic approach.

Although there is no requirement for McGuire to include the guidance for cross-tying the NSWS discharge paths in the Emergency Operating Procedures (EOP)s and/or Abnormal Procedures (AP)s, inclusion of this guidance in procedures immediately available to the control room operators rather than in Severe Accident Mitigation Guidelines (SAMG)s will reduce nuclear safety risk.

A-001
NRR

U. S. Nuclear Regulatory Commission
July 29, 2015
Page 2

For this reason, McGuire plans to submit a new LAR for use of the NSW Pump discharge crossover valves and associated piping to cross-tie Unit 1 and 2 NSW systems for mitigation of a loss of service water event on either unit utilizing the NRC-endorsed industry guidance titled "Change Process with respect to BDB applications", ADAMS Accession No. ML14231A535.

Because there is no apparent success path for this LAR under GL 91-13, Duke Energy hereby withdraws the LAR so that the approach described above may be pursued.

This letter contains no new Regulatory Commitments and no revision to existing Regulatory Commitments.

Should you have any questions regarding this submittal, please contact George Murphy at (980) 875-5715.

I declare under penalty of perjury that the foregoing is true and correct. Executed on July 29, 2015.

Sincerely,

A handwritten signature in black ink, appearing to read "S.D. Capps", written in a cursive style.

Steven D. Capps

U. S. Nuclear Regulatory Commission
July 29, 2015
Page 3

xc:

V. M. McCree
Administrator, Region II
U. S. Nuclear Regulatory Commission
Marquis One Tower
245 Peachtree Center Ave., NE Suite 1200
Atlanta, GA 30303-1257

J. Zeiler
NRC Senior Resident Inspector
McGuire Nuclear Station

G. E. Miller, Project Manager
U.S. Nuclear Regulatory Commission
11555 Rockville Pike
Mail Stop O-8 G9A
Rockville, MD 20852-2738

W. L. Cox, III, Section Chief
Division of Environment Health, Radiation Protection Section
North Carolina Department of Environmental and Natural Resources
1645 Mail Service Center
Raleigh, NC 27699-1645