

AUG 4 1977

Docket Nos. 50-269

50-270
and 50-287

Duke Power Company
ATTN: Mr. William O. Parker, Jr.
Vice President - Steam Production
Post Office Box 2178
422 South Church Street
Charlotte, North Carolina 28242

Gentlemen:

By letter dated April 25, 1977, you reported that the Oconee Nuclear Station liquid radioactive releases had exceeded one-half the annual design objective releases in a calendar quarter. The cause of the releases was an inadvertent release of liquid radioactivity from Oconee Unit 1 to the Keowee River in February 1977. In addition, you had another release in May 1977, although of much less magnitude than the first.

In a meeting on June 1, 1977, at the Oconee site, we discussed with you methods of controlling radioactivity in the Oconee Nuclear Station secondary systems. You described your administrative procedural control to contain radioactivity in the secondary side, and we examined with you the turbine building drainage system, the condensate polisher resin disposal system, the waste water collection basins, and the oil collection basin with respect to detecting, containing, and controlling radioactive materials. We noted that a radiation monitor had been installed to monitor the turbine building sump.

As a result of our review of these releases we have concluded that additional monitoring and procedural controls are necessary to keep radioactive releases as low as reasonable achievable in accordance with Appendix I to 10 CFR 50. Therefore, we request that you propose revisions to the Oconee design and its Technical Specifications which will:

1. include the installed turbine building sump monitor with an alarm in the control room,
2. add a composite water sampler at the outfall of the oil collection basin with weekly gamma spectra analysis and quarterly Sr-89, Sr-90 analysis, and

16 MISC
4

OFFICE ➤						
SURNAME ➤						
DATE ➤						

AUG 4 1977

3. add requirements for two independent checks on valve alignment for discharges of radioactive spent resin from the secondary water clean-up system to the receiving tanks to prevent an inadvertent release of highly contaminated resins following steam generator leaks to the waste water collection basin.

These changes have been discussed with you. It is requested that you respond within 45 days of receipt of this letter.

Sincerely,

151

A. Schwencer, Chief
Operating Reactors Branch #1
Division of Operating Reactors

cc: Mr. William L. Porter
Duke Power Company
Post Office Box 2178
422 South Church Street
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esquire
DeBevoise & Liberman
700 Shoreham Building
806-15th Street, NW
Washington, D.C. 20005

Oconee County Library
201 South Spring Street
Walhalla, South Carolina 29691

DISTRIBUTION

Dockets TBABernathy
NRC PDRs JRBuchanna
LOCAL PSR ACRS(16)
ORB#1 Reading
VStello
KRGoller
OELD
GI&E(3)
ASchwencer
DNeighbors
SMSheppard
DEisenhut

OFFICE ➤	DOR:ORB#1	DOR:ORB#1	DOR:OR			
SURNAME ➤	DNeighbors:lb	ASchwencer	KRGoller			
DATE ➤	8/4/77	8/ /77	8/ /77			