



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

August 11, 2015

Mr. Bryan C. Hanson
President and Chief Nuclear Officer (CNO)
Exelon Generation Company, LLC
Exelon Nuclear
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: CLINTON POWER STATION, UNIT 1 - CORRECTION LETTER FOR SAFETY
EVALUATION FOR ALTERNATIVES FROM ASME OM CODE REQUIRED
FREQUENCY (TAC NOS. MF5344 AND MF5345)(RS-14-291 AND RS-14-292)

Dear Mr. Hanson:

By letters dated December 1, 2014, as supplemented by letters dated March 26, and June 3, 2015 (Agencywide Documents Access and Management System (ADAMS) Accession Nos. ML14335A540, ML14335A541, ML15085A458 and ML15154A957, respectively) Exelon Generation Company, LLC (EGC), submitted alternatives to the required refueling outage frequency for cold and refueling shutdown justification valves, and motor operated valves at Clinton Power Station, Unit 1. On July 15, 2015, the U.S. Nuclear Regulatory Commission (NRC) staff issued a safety evaluation (SE) approving the proposed alternatives. On July 23, 2015, Mr. Timothy Byam notified the NRC staff of a minor error in the SE. The Table on page 4 of the SE should be corrected as follows to reflect the appropriate outages for the identified test failures. The changes to the table below are in bold:

Valve (RFJ#)	Test Failure Outage (test type)
1E12-F041B (RFJ-005)	C1R11 (CC)
1E22-F005 (RFJ-005)	C1R11 (CC)
1E51-F066 (RFJ-002)	C1R11 (CC)
1B21-F032A (RFJ-003)	C1R11 (CC)
1E21-F006 (RFJ-005)	C1R12 (CC)
1E22-F005 (RFJ-005)	C1R12 (CC)
1B21-F032B (RFJ-003)	C1R12 (CC)
1E51-F066 (RFJ-002)	C1R13 (CC)
1CM067 (RFJ-013)	C1R14 (CC)
1E51-F066 (RFJ-002)	C1R14 (CC)
1E12-F041B (RFJ-005)	C1R14 (CO)

B. Hanson

- 2 -

These corrections do not alter any findings or conclusions

Sincerely,

/RA/

Eva A. Brown, Senior Project Manager
Plant Licensing III-2 and
Planning and Analysis Branch
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-461

cc w/encl: Distribution via Listserv

B. Hanson

- 2 -

These corrections do not alter any findings or conclusions

Sincerely,

/RA/

Eva A. Brown, Senior Project Manager
Plant Licensing III-2 and
Planning and Analysis Branch
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-461

cc w/encl: Distribution via Listserv

Distribution:

PUBLIC

LPL3-2 R/F

RidsRgn3MailCenter Resource

RidsAcrsAcnw_MailCTR

MFarnan

RidsNrrDorlLpl3-2 Resource

RidsNrrDeEpnb Resource

RidsNrrClinton Resource

KMorgan-Butler, EDO

RidsNrrLASRohrer

ADAMS ACCESSION NUMBER: ML15212A916

NRR-028

OFFICE	LPL3-2/PM	LPL3-2/LA	EPNB/BC	LPL3-2/BC(A)
NAME	EBrown	SRohrer	DAley	BBeasley (BPurnell For)
DATE	8/6/15	8/06/15	8/10/15	8/11/15

OFFICIAL RECORD COPY