

October 2, 1978

Docket No.: 50-270

DISTRIBUTION:

Docket File ✓
NRC PDR
L PDR
ORB#4 Rdg
VStello
KRG BGrimes
TJCarter
Attorney, OELD
OI&E (3)
RReid
MFairtile
RIngram
DEisenhut
TERA, DSB
JRBuchanan
ACRS (16)
Gray File

Mr. William O. Parker, Jr.
Vice President - Steam Production
Duke Power Company
P. O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

Dear Mr. Parker:

V. NOONAN

We have reviewed your responses of August 25, 1978 to our requests for additional information of August 1, 1978, based on your request to use a substitute surveillance tendon in the Oconee Nuclear Station Unit No. 2 containment structure as submitted by Duke Power Company on June 12, 1978. We find that we need a more definitive response to our Question 3 so that we can continue our review of this proposal.

You stated in response to Question 3 that you do not intend to replace tendon 2D28. You did not address the concern expressed by Question 3 regarding the total number of tendons needed, as prescribed by Regulatory Guide 1.35 not only to monitor for periodic material degradation but also to check the prestressing force in the tendon, by lift-off tests. Tendon 2D28, if left in place but not under tension, will neither serve to check for potential material degradation, if due to stress corrosion nor would it be available for lift-off tests. If after review of our above concerns you decide to let 2D28 remain in place, but unloaded, we suggest that you select and identify a sufficient number of tendons, under tension, for lift-off testing, using the criteria of Regulatory Guide 1.35. Kindly inform us of your proposed solution to our concerns of stress corrosion surveillance and lift-off testing.

It is requested that you provide this information to enable us to complete our review. Kindly submit three signed originals and 37 additional copies within 30 days of receipt of this letter.

Sincerely,

Robert W. Reid, Chief
Operating Reactors Branch #4
Division of Operating Reactors

MBF

OFFICE	cc: See next page	ORB#4:DOR	C-ORB#4:DOR	C-ORB#4:DOR
SURNAME		MFairtile:rf	VNoonan	RReid
DATE		9/29/78	9/29/78	9/29/78

Duke Power Company

cc: Mr. William L. Porter
Duke Power Company
P. O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esquire
DeBevoise & Liberman
700 Shoreham Building
806-15th Street, NW.,
Washington, D.C. 20005

Oconee Public Library
201 South Spring Street
Walhalla, South Carolina 29691