

Dockets Nos.: 50-269

SEPTEMBER 6 1978

50-270  
and 50-287

Mr. William O. Parker, Jr.  
Vice President - Steam Production  
Duke Power Company  
P. O. Box 2178  
422 South Church Street  
Charlotte, North Carolina 28242

DISTRIBUTION:  
Docket File (3)  
NRC PDR (3)  
L PDR (3)  
ORB#4 Rdg  
RReid  
RIngram  
MFairtile  
Attorney, OELD  
OI&E (5)  
DEisenhut  
TERA, DSB  
JRBuchanan  
ACRS (16)  
TJCarter  
Gray File

Dear Mr. Parker:

By letter dated April 21, 1978, you informed us of an error in your ECCS Small Break LOCA evaluation model analyses. We authorized continued operation of the Oconee Nuclear Station, Units Nos. 1, 2 and 3, based in part on credit to be taken for prompt operator actions. You were issued an Order dated April 26, 1978, to implement procedures and training necessary to assure that the required operator actions could be initiated within five minutes and completed within ten additional minutes. In addition, you were directed to submit reanalyses along with proposals for long-term modifications to eliminate the need for prompt operator actions including those from inside and from outside the control room.

Your proposal for long-term modifications relies on operator actions. It appears that "prompt" operator action is still required.

The staff position regarding allowable operator actions for which credit may be taken following a Condition III event (small LOCA), is as follows:

1. No credit for operator actions required within ten minutes of the initiating event will be allowed.
2. Credit may be taken for operator action from within the control room after at least ten minutes if adequate information is available and displayed, and if the operator has sufficient time to correctly analyze the situation, recognize any error or malfunction and to take a corrective action. The allowed operator actions are limited to "simple" actions which are characterized by the "pushing of a button" or the "flipping of a switch." Balancing of ECCS flows by adjusting valve positions is not considered a "simple" operator action.

OFFICE →					
SURNAME →					
DATE →					

3. Credit may be taken for more complex operator actions which may be assumed to begin after at least ten minutes. The credit assumed in the ECCS analysis should consider a reasonable time delay after initiation of the operator action for the system to respond to assure that design flows have been achieved. However, the credit for these complex actions cannot be assumed in less than 20 minutes after the accident.

If the emergency core cooling system analysis for your plant, submitted July 14, 1978, does not meet the position stated above, you should either: (1) provide a new analysis which demonstrates that the modification you have proposed will meet the staff position with respect to allowable credit for operator action or (2) propose a new modification and an analysis. If your July 14 submittal does meet one of the above positions, state the position you meet and the basis for your statement.

In your consideration of the above, you should be aware that we have approved use of the simplified FOAM code as proposed by Babcock & Wilcox in their letter dated August 11, 1978.

It is requested that you inform us by telephone, confirmed by letter, within seven days of receipt of this letter which of the options you plan to pursue. This will allow us to determine whether or not to continue our review of the design of your proposed modification. Your response should include your schedule for submittal of the required analysis and/or modification.

Sincerely,

Original Signed By

Robert W. Reid, Chief  
Operating Reactors Branch #4  
Division of Operating Reactors

cc: See next page

OFFICE	ORB#4:DOR	ORB#4:DOR				
SURNAME	MFairtile:rf	RReid				
DATE	9/ /78	9/ /78				

Duke Power Company

cc: Mr. William L. Porter  
Duke Power Company  
P. O. Box 2178  
422 South Church Street  
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esquire  
DeBevoise & Liberman  
700 Shoreham Building  
806-15th Street, NW.,  
Washington, D.C. 20005

Oconee Public Library  
201 South Spring Street  
Walhalla, South Carolina 29691