

2015 Unit 1 Cycled Condensate Storage Tank Tritium Remediation Monitoring

TW-LS-116s Sample Results

Date/Time	Activity (pCi/L)	Water Level (ft)	Well Bottom Level (ft)	Water Column (ft)
1/13/15 8:55	9.21E+03	10.30	17.80	7.50
1/26/15 13:35	8.06E+03	9.30	17.80	8.50
2/3/15 13:20	8.24E+03			
2/7/15 11:33	9.44E+03	9.50	17.90	8.40
2/21/15 10:55	9.24E+03	9.00	17.90	8.90
3/6/15 10:20	7.89E+03	9.00	17.90	8.90
3/26/15 10:31	8.66E+03	8.70	17.90	9.20
3/31/15 8:15	1.24E+04	8.70	17.90	9.20
4/14/15 11:00	7.70E+03	9.30	17.90	8.60
5/12/15 7:55	1.07E+04	9.00	18.00	9.00
5/29/15 10:55	1.19E+04	8.40	17.80	9.40
6/9/15 8:56	1.14E+04	8.80	17.90	9.10

2015 Unit 1 Cycled Condensate Storage Tank Tritium Remediation Monitoring

TW-LS-119s Sample Results

Date/Time	Activity (pCi/L)	Water Level	Well Bottom Level	Water Column
		(ft)	(ft)	(ft)
1/13/15 8:15	< 8.17E+02	6.0	13.8	7.8
1/26/15 13:20	< 9.17E+02	5.8	14.1	8.3
2/3/15 13:10	< 8.18E+02			
2/7/15 10:48	< 1.30E+03	5.4	14.1	8.7
2/21/15 10:20	< 1.30E+03	5.5	14.1	8.6
3/6/15 13:30	< 9.16E+02	6.0	14.3	8.3
3/31/15 10:20	< 8.23E+02	5.1	14.0	8.9
4/14/15 12:53	< 9.20E+02	5.1	14.1	9.0
4/28/15 9:10	< 8.95E+02	5.0	14.1	9.1
5/12/15 8:15	< 8.76E+02	4.6	14.0	9.4
5/29/15 10:45	< 8.75E+02	4.4	14.0	9.6
6/9/15 9:17	< 8.82E+02	4.8	14.0	9.2

2015 Unit 1 Cycled Condensate Storage Tank Tritium Remediation Monitoring

TW-LS-120s Sample Results

Date/Time	Activity (pCi/L)	Water Level	Well Bottom Level	Water Column
		(ft)	(ft)	(ft)
1/13/15 7:45	< 8.17E+02	6.3	11.3	5.0
1/26/15 13:20	< 9.17E+02	6.1	11.3	5.2
2/3/15 13:10	< 8.18E+02			
2/7/15 10:48	< 1.30E+03	5.8	11.3	5.5
2/21/15 10:25	< 1.30E+03	5.9	11.3	5.4
3/6/15 10:25	< 9.64E+02	6.6	11.6	5.0
3/26/15 11:03	< 9.17E+02	6.1	11.3	5.2
3/31/15 10:35	< 8.23E+02	6.1	11.4	5.3
4/14/15 12:59	< 9.20E+02	5.9	11.3	5.4
4/28/15 9:15	< 8.95E+02	5.9	11.4	5.5
5/12/15 8:25	< 8.76E+02	5.5	11.5	6.0
5/29/15 11:15	< 8.75E+02	5.4	11.4	6.0
6/9/15 9:22	< 8.82E+02	5.0	11.3	6.3

2015 Unit 1 Cycled Condensate Storage Tank Tritium Remediation Monitoring

TW-LS-121s Sample Results

<u>Date/Time</u>	<u>Activity (pCi/L)</u>	<u>Water Level (ft)</u>	<u>Well Bottom Level (ft)</u>	<u>Water Column (ft)</u>
1/13/15 8:35	< 8.17E+02	8.3	11.6	3.3
1/27/15 7:35	< 9.17E+02	8.3	11.7	3.4
2/3/15 13:45	< 8.18E+02			
2/7/15 11:06	< 1.30E+03	8.0	12.0	4.0
2/21/15 10:36	< 1.30E+03	8.1	11.8	3.7
3/6/15 9:00	< 9.64E+02	8.5	11.9	3.4
3/26/15 10:21	< 9.17E+02	8.0	11.8	3.8
3/31/15 8:05	< 8.23E+02	8.2	12.0	3.8
4/14/15 11:15	< 9.20E+02	7.8	11.8	4.0
4/28/15 8:25	< 8.95E+02	7.9	11.9	4.0
5/12/15 8:05	< 8.76E+02	7.4	11.8	4.4
5/29/15 10:45	< 8.75E+02	7.5	11.8	4.3
6/9/15 8:45	< 8.82E+02	7.2	11.8	4.6

2015 Unit 1 Cycled Condensate Storage Tank Tritium Remediation Monitoring

Storm Drain Oil Sep Pit Compositor Sample Results

Date/Time	pCi/L
1/13/15 8:30	8.17E+02
1/26/15 11:28	9.17E+02
2/7/15 11:19	1.30E+03
2/21/15 11:50	1.30E+03
3/6/15 9:00	9.64E+02
3/11/15 7:50	9.94E+02
3/26/15 10:16	9.17E+02
3/31/15 7:55	8.23E+02
4/28/15 8:10	8.95E+02
5/12/15 7:25	8.76E+02
5/29/15 10:35	8.75E+02
6/9/15 8:30	8.82E+02