

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9004090378 DOC. DATE: 90/03/26 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H.B. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards 1989 annual radiological environ operating corrections.

DISTRIBUTION CODE: IE48D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 172
 TITLE: 50.36a(a)(2) Semiannual Effluent Release Reports

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 LA	3 3	PD2-3 PD	1 1
	WIENS, L	1 1		
INTERNAL:	ACRS	1 1	AEOD/DSP/TPAB	1 1
	IRM TECH ADV	1 1	NRR/DREP/PRPB11	2 2
	NUDOCS-ABSTRACT	1 1	<u>REG FILE</u> 01	1 1
	RGN2 DRSS/RPB	2 2	RGN2 FILE 02	1 1
EXTERNAL:	BNL TICHLER, J03	1 1	EG&G SIMPSON, F	2 2
	LPDR	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 20

Env-1
WZ

Duke Power Company
P.O. Box 33198
Charlotte, N.C. 28242

HAL B. Tucker
Vice President
Nuclear Production
(704)373-4531



DUKE POWER

March 26, 1990

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Annual Radiological Environmental Operating Report Corrections

Gentlemen:

Attached is a revision to the Annual Liquid and Gaseous Effluent Report for Oconee Nuclear Station for the period January 1, 1989 to December 31, 1989 which was submitted to you by my letter dated April 28, 1990. Please remove the two pages which summarize the annual liquid dose calculation, days 1-365/year 90, and replace them with the attached revised pages which summarize the correct dose calculations, days 1-365/year 89.

Very truly yours,

Hal B. Tucker

RRE112/td

Attachment


cc: Mr. S. D. Ebnetter, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, GA 30323

Mr. P. H. Skinner
NRC Resident Inspector
Oconee Nuclear Station

Mr. D. B. Matthews
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, DC 20555

19004090378 900326
PDR - ADUCK 05000269
R PDC

TE48
11



NRC-OCONEE

Box

NRC_OCONEE_020130_003

Accession

9004090411

OFFSITE DOSE ASSESSMENT

LIQUID CALCULATIONS

STATION CODE : ONS

YEAR : 89

START DATE : 1

STOP DATE : 365

DILUTION VOLUME: 6.64E+11

03/05/90

14:26

9004090411 900326
FDR ADCK 05000269
FDC

03/05/90

SKIN	MAXIMUM DOSE-	3.13D-02 MREM	CRITICAL AGE-	TEEN	CRITICAL PATHWAY-	SHORE
	CO 60	56.84 %				
	AG 110M	21.75 %				
	SB 125	9.80 %				
BONE	MAXIMUM DOSE-	5.33D-01 MREM	CRITICAL AGE-	CHILD	CRITICAL PATHWAY-	FISH
	CS 134	32.11 %				
	CS 137	62.88 %				
LIVER	MAXIMUM DOSE-	8.02D-01 MREM	CRITICAL AGE-	TEEN	CRITICAL PATHWAY-	FISH
	H 3	10.63 %				
	CS 134	40.85 %				
	CS 137	43.37 %				
T. BODY	MAXIMUM DOSE-	6.22D-01 MREM	CRITICAL AGE-	ADULT	CRITICAL PATHWAY-	FISH
	H 3	19.40 %				
	CS 134	42.51 %				
	CS 137	35.17 %				
THYROID	MAXIMUM DOSE-	7.85D-01 MREM	CRITICAL AGE-	INFANT	CRITICAL PATHWAY-	DRINKING
	H 3	19.86 %				
	I 131	79.87 %				
KIDNEY	MAXIMUM DOSE-	3.66D-01 MREM	CRITICAL AGE-	CHILD	CRITICAL PATHWAY-	FISH
	H 3	43.87 %				
	CS 134	23.78 %				
	CS 137	28.59 %				
LUNG	MAXIMUM DOSE-	2.40D-01 MREM	CRITICAL AGE-	CHILD	CRITICAL PATHWAY-	DRINKING
	H 3	67.00 %				
	CS 134	13.06 %				
	CS 137	15.78 %				
GI-LLI	MAXIMUM DOSE-	2.61D+00 MREM	CRITICAL AGE-	ADULT	CRITICAL PATHWAY-	FISH
	NB 95	87.47 %				