

## Whited, Jeffrey

---

**From:** Whited, Jeffrey  
**Sent:** Wednesday, August 05, 2015 1:34 PM  
**To:** 'christopher.wasik@duke-energy.com'  
**Cc:** 'Shingleton, Boyd'; Newman, Stephen (Stephen.Newman@duke-energy.com)  
**Subject:** ONS LAR Identified Information Insufficiencies (TAC Nos. MF6363, MF6364, and MF6365)  
**Attachments:** DRAFT High Flux LAR Supplemental Information Request.pdf

Mr. Wasik,

By letter dated May 19, 2015 (ADAMS Accession No. ML15146A056), Duke Energy Carolinas, LLC, (Duke) submitted a License Amendment Request pursuant to 10 CFR 50.90. This license amendment request proposes to add a Reactor Protective System Nuclear Overpower – High Setpoint trip for three reactor coolant pumper operation to Technical Specification Table 3.3.1-1.

The NRC staff has reviewed the application and concluded that the information delineated in the attachment to this e-mail is necessary to enable the staff to make an independent assessment regarding the acceptability of the proposed license amendment request in terms of regulatory requirements and the protection of public health and safety and the environment.

Please review the DRAFT information in the attachment and contact me to set up a meeting with the NRC staff. In accordance with LIC-109, "Acceptance Review Procedures" this meeting should be held within 5 business days of the date of this e-mail. If you do not feel a conference call is necessary, please inform me, and the NRC staff will issue a letter with the information insufficiencies as attached and request that Duke respond to the letter by August 26, 2015.

Please let me know if you have any questions.

*Jeffrey Whited*

Project Manager  
Plant Licensing Branch II-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
(301)415-4090  
[jeffrey.whited@nrc.gov](mailto:jeffrey.whited@nrc.gov)