

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9606100131 DOC. DATE: 96/06/05 NOTARIZED: NO DOCKET #
 FACIL: 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 AUTH. NAME AUTHOR AFFILIATION
 HAMPTON, J.W. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk) *See Reports*

SUBJECT: Submits results of SG tube ISI performed during Unit 2 EOC
 15 refueling outage. List identifying tubes w/imperfections,
 locations & size & info identifying quantity of tubes
 removed from svc by plugging encl.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 127
 TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code - GL-89-04

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 LA	1 1	PD2-2 PD	1 1
	LABARGE, D.	1 1		
INTERNAL:	ACRS	6 0	AEOD/SPD/RAB	1 1
	FILE CENTER 02	1 1	NRR/DE/ECGB	1 1
	NRR/DE/EMCB	1 1	NRR/DE/EMEB	1 1
	NUDOCS-ABSTRACT	1 1	OGC/HDS2	1 0
	RES/DET/EMMEB	1 1	RES/DSIR/EIB	1 1
EXTERNAL:	LITCO ANDERSON	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 21 ENCL 14

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

Duke Power Company
Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679

J. W. HAMPTON
Vice President
(864)885-3499 Office
(864)885-3564 Fax



DUKE POWER

June 5, 1996

U.S. Nuclear Regulatory Commission
Attention Document Control Desk
Washington, DC 20555

Subject: Duke Power Company
Oconee Nuclear Station, Unit 2
Docket No. 50-270
Steam Generator Inservice Inspection
Steam Generator Tube Plugging and Repair 30 Day Report
Steam Generator Three (3) Month Report

As required by Technical Specifications 4.17.6 (a) and (b), the results of the Steam Generator Tube Inservice Inspection performed during the Unit 2 End of Cycle 15 refueling outage are submitted for review.

1. The following quantity of tubes were inspected from the inlet or outlet of the Steam Generators:

<u>Steam Generator</u>	<u>Quantity</u>	<u>Inspection Method</u>
A	15393	Bobbin
A	1213	MRPC
B	15263	Bobbin
B	2124	MRPC

2. The following information is submitted concerning tube indications of imperfections. (The attached lists identify the tubes with imperfections, their locations, and their size.)

<u>Steam Generator</u>	<u>Attachment</u>	<u>Inspection Method</u>
A	1	Bobbin
B	2	Bobbin
A	3	MRPC
B	4	MRPC

100051

9606100131 960605
PDR ADOCK 05000270
Q PDR

A047
1/1


3. The following information identifies the quantity of tubes removed from service by plugging. (The tubes are identified in the attachments). There were no tubes repaired by sleeving in either steam generator.

<u>Steam Generator</u>	<u>Number of Tubes Removed from Service</u>	<u>Attachment</u>
A	199	5
B	213	6

Duke will provide additional information regarding indications observed in the steam generator tubes inspected by eddy current. Duke will also provide additional information regarding eddy current testing performed on tube samples removed from the steam generators. Currently the test results are being reviewed and compiled. This additional information will be submitted as soon as possible as an addendum to the 3 month steam generator inspection report.

If there are any questions you may contact D. A. Nix at (864) 885-3634.

Very truly yours,


J. W. Hampton *for*
Site Vice-President

Attachments

June 5, 1996

U. S. Nuclear Regulatory Commission

Page 3

xc w/attachment: Mr. S. D. Ebnetter
 Regional Administrator, Region II
 U. S. Nuclear Regulatory Commission

xc w/o att: Mr. P. E. Harmon
 Senior NRC Resident Inspector
 Oconee Nuclear Station

Mr. Max Batavia
Bureau of Radiological Health
SC Dept. of Health & Environmental Control
2600 Bull St.
Columbia, SC 29201

Mr. D. E. LaBarge
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

ATTACHMENT 1

34 Pages

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
1	1	04/96 RFO	Bobbin	ODI	23	0.75	011	+5.83 UTE
1	2	04/96 RFO	Bobbin	ODI	16	0.30	014	-0.48 UTE
1	3	04/96 RFO	Bobbin	ODI	11	0.61	009	+0.72 UTE
1	13	04/96 RFO	Bobbin	ODI	15	0.47	010	+11.97 UTE
1	15	04/96 RFO	Bobbin	WAR	89	0.99	011	+0.00 UTE
1	16	04/96 RFO	Bobbin	NQI		0.65	012	-0.83 UTE
2	1	04/96 RFO	Bobbin	NQI		0.38	015	-0.03 UTE
		04/96 RFO	Bobbin	ODI	10	0.37	011	+0.27 UTE
		04/96 RFO	Bobbin	ODI	16	0.78	014	+33.26 UTE
2	2	04/96 RFO	Bobbin	ODI	15	0.66	012	+4.92 UTE
		04/96 RFO	Bobbin	ODI	18	0.44	012	+4.40 UTE
		04/96 RFO	Bobbin	ODI	38	0.81	014	+33.46 UTE
2	3	04/96 RFO	Bobbin	NQI		0.51	011	+5.49 UTE
		04/96 RFO	Bobbin	NQI		0.52	010	+20.34 UTE
		04/96 RFO	Bobbin	ODI	22	1.00	015	+0.51 UTE
		04/96 RFO	Bobbin	ODI	32	0.44	014	+33.12 UTE
2	4	04/96 RFO	Bobbin	ODI	2	0.56	014	+32.79 UTE
		04/96 RFO	Bobbin	ODI	12	0.67	011	+5.32 UTE
2	9	04/96 RFO	Bobbin	ODI	8	0.51	010	+0.57 UTE
2	11	04/96 RFO	Bobbin	NQI		0.49	010	+16.74 UTE
		04/96 RFO	Bobbin	NQI		0.62	012	+10.49 UTE
		04/96 RFO	Bobbin	NQI		0.72	010	+0.68 UTE
		04/96 RFO	Bobbin	NQI		0.89	013	+10.76 to +28.05 UTE
		04/96 RFO	Bobbin	NQI		1.08	014	+9.56 to +23.61 UTE
2	16	04/96 RFO	Bobbin	ODI	7	0.48	010	+0.51 UTE
2	20	04/96 RFO	Bobbin	NQI		0.30	010	+0.21 UTE
2	22	04/96 RFO	Bobbin	NQI		0.26	014	+33.31 UTE
		04/96 RFO	Bobbin	NQI		0.41	014	+33.04 UTE
		04/96 RFO	Bobbin	ODI	60	0.61	014	+32.13 UTE
2	23	04/96 RFO	Bobbin	NQI		0.41	010	-0.40 UTE
3	1	04/96 RFO	Bobbin	NQI		0.26	014	-0.11 UTE
3	2	04/96 RFO	Bobbin	NQI		0.16	014	-0.43 UTE
		04/96 RFO	Bobbin	NQI		0.52	014	-0.77 UTE
		04/96 RFO	Bobbin	NQI		0.63	011	-0.13 UTE
3	5	04/96 RFO	Bobbin	ODI	5	0.60	009	+0.75 UTE
3	15	04/96 RFO	Bobbin	NQI		0.65	012	-0.86 UTE
3	16	04/96 RFO	Bobbin	NQI		0.42	009	+0.16 UTE
3	18	04/96 RFO	Bobbin	ODI	36	0.20	009	-0.38 UTE
3	20	04/96 RFO	Bobbin	NQI		0.50	010	+0.48 UTE
3	23	04/96 RFO	Bobbin	NQI		0.72	010	+0.64 UTE
3	24	04/96 RFO	Bobbin	NQI		0.54	009	+0.40 UTE
3	26	04/96 RFO	Bobbin	NQI		0.68	007	+35.44 UTE
3	29	04/96 RFO	Bobbin	ODI	6	0.63	008	+33.29 UTE
3	31	04/96 RFO	Bobbin	NQI		0.42	001	+30.34 UTE
3	33	04/96 RFO	Bobbin	ODI	1	0.51	012	-0.81 UTE
4	3	04/96 RFO	Bobbin	NQI		0.40	011	-0.64 UTE
4	5	04/96 RFO	Bobbin	NQI		0.79	010	+0.51 UTE
4	6	04/96 RFO	Bobbin	NQI		0.50	010	+0.59 UTE
4	8	04/96 RFO	Bobbin	NQI		0.79	010	+0.56 UTE
4	10	04/96 RFO	Bobbin	NQI		0.60	009	+0.67 UTE
4	19	04/96 RFO	Bobbin	NQI		0.45	014	+33.17 UTE
4	22	04/96 RFO	Bobbin	NQI		0.45	UTS	+0.91 UTE
4	26	04/96 RFO	Bobbin	NQI		0.50	014	+16.16 UTE
4	27	04/96 RFO	Bobbin	ODI	23	0.32	012	+12.65 UTE
		04/96 RFO	Bobbin	ODI	33	0.71	012	+12.24 UTE
4	30	04/96 RFO	Bobbin	ODI	20	0.43	009	+0.70 UTE
4	31	04/96 RFO	Bobbin	ODI	36	0.65	008	+0.62 UTE
4	35	04/96 RFO	Bobbin	NQI		0.47	008	+34.30 UTE
		04/96 RFO	Bobbin	ODI	18	0.52	012	-0.82 UTE
4	37	04/96 RFO	Bobbin	ODI	6	0.44	008	+31.86 UTE
4	39	04/96 RFO	Bobbin	ODI	26	0.48	010	+0.54 UTE
4	41	04/96 RFO	Bobbin	ODI	18	0.36	010	+0.57 UTE
5	6	04/96 RFO	Bobbin	ODI	9	0.40	010	+0.51 UTE
5	9	04/96 RFO	Bobbin	NQI		0.53	009	+0.69 UTE
5	10	04/96 RFO	Bobbin	ODI	13	0.65	010	+0.51 UTE

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
5	13	04/96 RFO	Bobbin	ODI	11	0.61 009	+0.75	UTE
5	30	04/96 RFO	Bobbin	ODI	32	0.38 015	-0.60	UTE
5	40	04/96 RFO	Bobbin	NQI		0.59 009	-0.33	UTE
5	42	04/96 RFO	Bobbin	NQI		0.53 015	+9.08	UTE
6	3	04/96 RFO	Bobbin	NQI		0.39 015	+12.00	UTE
		04/96 RFO	Bobbin	ODI	36	0.99 010	+0.56	UTE
		04/96 RFO	Bobbin	NQI		0.81 013	+11.29 to +20.40	UTE
		04/96 RFO	Bobbin	NQI		0.86 014	+8.99 to +18.06	UTE
		04/96 RFO	Bobbin	NQI		1.13 011	+4.26 to +29.03	UTE
6	4	04/96 RFO	Bobbin	ODI	30	0.72 010	+0.51	UTE
6	5	04/96 RFO	Bobbin	NQI		0.89 010	+0.59	UTE
		04/96 RFO	Bobbin	NQI		1.28 008	+35.35	UTE
6	6	04/96 RFO	Bobbin	ODI	22	0.50 008	+32.98	UTE
6	11	04/96 RFO	Bobbin	NQI		0.65 009	+0.75	UTE
6	16	04/96 RFO	Bobbin	NQI		0.53 009	+18.44	UTE
6	32	04/96 RFO	Bobbin	ODI	25	0.52 011	+4.65	UTE
		04/96 RFO	Bobbin	ODI	35	0.63 011	+5.41	UTE
		04/96 RFO	Bobbin	ODI	65	0.30 011	+3.40	UTE
6	37	04/96 RFO	Bobbin	NQI		0.35 007	+14.32	UTE
		04/96 RFO	Bobbin	ODI	22	0.42 007	+14.97	UTE
6	38	04/96 RFO	Bobbin	ODI	14	0.24 008	+0.30	UTE
6	39	04/96 RFO	Bobbin	ODI	26	0.92 008	-0.51	UTE
6	51	04/96 RFO	Bobbin	NQI		0.52 015	-0.27	UTE
7	1	04/96 RFO	Bobbin	ODI	22	0.81 012	-0.93	UTE
7	2	04/96 RFO	Bobbin	NQI		1.11 UTS	+0.49	UTE
7	5	04/96 RFO	Bobbin	NQI		0.68 008	+26.37	UTE
7	6	04/96 RFO	Bobbin	ODI	3	0.52 008	+18.15	UTE
		04/96 RFO	Bobbin	ODI	8	0.46 008	+11.80	UTE
7	16	04/96 RFO	Bobbin	ODI	22	0.44 009	+8.71	UTE
7	43	04/96 RFO	Bobbin	ODI	27	0.42 015	-0.46	UTE
7	47	04/96 RFO	Bobbin	ODI	13	0.46 006	+31.52	UTE
7	53	04/96 RFO	Bobbin	NQI		0.57 010	+0.51	UTE
8	9	04/96 RFO	Bobbin	ODI	9	0.40 009	+0.58	UTE
8	52	04/96 RFO	Bobbin	NQI		0.65 015	-0.33	UTE
8	54	04/96 RFO	Bobbin	NQI		0.43 015	+37.09	UTE
8	56	04/96 RFO	Bobbin	NQI		0.71 009	+18.64	UTE
		04/96 RFO	Bobbin	ODI	28	0.31 LTS	+29.13	UTE
9	1	04/96 RFO	Bobbin	NQI		0.90 010	+0.53	UTE
		04/96 RFO	Bobbin	ODI	16	1.17 008	+0.68	UTE
9	5	04/96 RFO	Bobbin	ODI	9	0.72 010	+4.12	UTE
		04/96 RFO	Bobbin	NQI		0.70 015	+5.25 to +31.10	UTE
		04/96 RFO	Bobbin	NQI		0.90 014	+9.87 to +15.20	UTE
		04/96 RFO	Bobbin	NQI		0.95 013	+7.06 to +30.30	UTE
		04/96 RFO	Bobbin	NQI		0.98 012	+6.91 to +26.46	UTE
		04/96 RFO	Bobbin	NQI		1.48 011	+8.77 to +34.19	UTE
9	42	04/96 RFO	Bobbin	ODI	22	0.82 001	+31.65	UTE
9	45	04/96 RFO	Bobbin	ODI	19	0.64 002	+9.58	UTE
		04/96 RFO	Bobbin	ODI	33	0.34 002	+0.43	UTE
9	53	04/96 RFO	Bobbin	ADI		0.77 006	+33.38	UTE
9	54	04/96 RFO	Bobbin	ODI	56	0.57 015	+24.34	UTE
9	61	04/96 RFO	Bobbin	NQI		0.44 010	+7.26	UTE
10	3	04/96 RFO	Bobbin	NQI		0.70 009	+0.40	UTE
10	9	04/96 RFO	Bobbin	NQI		0.22 015	+0.11	UTE
10	26	04/96 RFO	Bobbin	NQI		1.28 UTS	+1.22	UTE
		04/96 RFO	Bobbin	NQI		1.43 UTS	+0.64	UTE
10	53	04/96 RFO	Bobbin	NQI		0.68 UTS	+0.81	UTE
10	54	04/96 RFO	Bobbin	NQI		0.58 015	+33.13 to +37.78	UTE
10	64	04/96 RFO	Bobbin	NQI		0.42 010	+27.22	UTE
		04/96 RFO	Bobbin	ODI	8	0.49 011	+11.85	UTE
11	7	04/96 RFO	Bobbin	NQI		0.35 015	+0.11	UTE
11	8	04/96 RFO	Bobbin	NQI		1.88 UTS	+2.66	UTE
11	15	04/96 RFO	Bobbin	ODI	2	0.42 006	+30.48	UTE
11	37	04/96 RFO	Bobbin	NQI		1.06 LTE	+21.30	UTE
11	45	04/96 RFO	Bobbin	ODI	10	0.37 006	+26.16	UTE
11	64	04/96 RFO	Bobbin	ODI	37	0.61 009	+22.30	UTE

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
11	66	04/96 RFO	Bobbin	ODI	20	0.30	010	+18.01
		04/96 RFO	Bobbin	ODI	26	0.23	010	+17.74
11	67	04/96 RFO	Bobbin	ODI	17	0.48	011	+6.37
12	4	04/96 RFO	Bobbin	ODI	18	0.50	008	+34.56
12	5	04/96 RFO	Bobbin	ODI	21	0.62	008	+16.17
12	17	04/96 RFO	Bobbin	NQI		0.24	007	+0.13
12	22	04/96 RFO	Bobbin	NQI		0.27	007	+0.45
12	50	04/96 RFO	Bobbin	ODI	20	1.26	009	+7.18
12	54	04/96 RFO	Bobbin	NQI		0.19	015	+0.35
12	62	04/96 RFO	Bobbin	ODI	33	0.20	014	+20.93
12	63	04/96 RFO	Bobbin	ODI	16	0.36	009	+0.46
12	65	04/96 RFO	Bobbin	NQI		0.34	015	-0.08
12	68	04/96 RFO	Bobbin	NQI		0.98	015	+15.33
12	69	04/96 RFO	Bobbin	NQI		0.47	011	+0.48
12	70	04/96 RFO	Bobbin	NQI		0.35	012	+3.73
		04/96 RFO	Bobbin	NQI		0.53	012	+3.38
		04/96 RFO	Bobbin	ODI	3	1.14	012	+4.19
		04/96 RFO	Bobbin	ODI	29	0.38	011	+7.31
12	71	04/96 RFO	Bobbin	NQI		0.34	012	+3.81
		04/96 RFO	Bobbin	ODI	12	0.39	012	+4.05
13	8	04/96 RFO	Bobbin	NQI		0.82	007	+32.77
13	11	04/96 RFO	Bobbin	ODI	5	0.91	015	+9.70
		04/96 RFO	Bobbin	ODI	16	0.54	015	+8.77
		04/96 RFO	Bobbin	ODI	17	0.93	015	+35.45
		04/96 RFO	Bobbin	ODI	33	0.78	015	+37.90
		04/96 RFO	Bobbin	ODI	53	0.45	014	+4.71
		04/96 RFO	Bobbin	NQI		0.40	013	+6.83 to +32.29
13	13	04/96 RFO	Bobbin	NQI		0.65	012	+8.85
		04/96 RFO	Bobbin	NQI		1.09	011	+3.78
		04/96 RFO	Bobbin	ODI	14	0.87	011	+26.79
		04/96 RFO	Bobbin	ODI	27	1.56	012	+13.06
		04/96 RFO	Bobbin	ODI	34	0.80	011	+25.56
		04/96 RFO	Bobbin	ODI	41	0.53	010	+14.12
		04/96 RFO	Bobbin	ODI	58	0.74	011	+26.12
		04/96 RFO	Bobbin	ODI	65	0.55	011	+28.40
13	39	04/96 RFO	Bobbin	ADI		5.51	LTS	+31.51
13	49	04/96 RFO	Bobbin	DWI		2.85	LTS	+15.68
13	52	04/96 RFO	Bobbin	NQI		0.20	002	+6.08
		04/96 RFO	Bobbin	NQI		0.21	002	-0.08
		04/96 RFO	Bobbin	ODI	1	0.27	002	+2.28
		04/96 RFO	Bobbin	ODI	3	0.37	002	+3.96
		04/96 RFO	Bobbin	ODI	6	0.21	002	+8.33
13	56	04/96 RFO	Bobbin	ODI	5	1.95	009	+36.96
13	65	04/96 RFO	Bobbin	NQI		0.26	008	+12.22 to +21.89
13	69	04/96 RFO	Bobbin	NQI		0.74	009	+22.54
13	71	04/96 RFO	Bobbin	NQI		0.25	010	+15.24 to +21.08
13	72	04/96 RFO	Bobbin	NQI		0.57	011	+25.84
		04/96 RFO	Bobbin	ODI	17	0.63	010	+15.05
13	73	04/96 RFO	Bobbin	ODI	16	0.45	012	+6.16
13	74	04/96 RFO	Bobbin	NQI		0.42	012	+5.48
		04/96 RFO	Bobbin	NQI		0.54	015	-1.57
		04/96 RFO	Bobbin	ODI	6	1.31	013	+3.62
14	9	04/96 RFO	Bobbin	NQI		0.74	007	+21.04
14	13	04/96 RFO	Bobbin	ODI	10	0.57	013	+15.33
14	22	04/96 RFO	Bobbin	ODI	15	0.32	008	+0.30
14	30	04/96 RFO	Bobbin	NQI		0.43	008	+0.41
14	52	04/96 RFO	Bobbin	NQI		0.26	003	+21.17
14	56	04/96 RFO	Bobbin	ADI		0.43	LTE	+16.99
14	66	04/96 RFO	Bobbin	ODI	23	0.34	004	+14.87
14	70	04/96 RFO	Bobbin	ODI	26	0.98	009	+21.86
14	71	04/96 RFO	Bobbin	NQI		0.78	009	-0.72
14	75	04/96 RFO	Bobbin	NQI		0.60	012	+1.20
15	21	04/96 RFO	Bobbin	NQI		0.25	008	+0.41
15	40	04/96 RFO	Bobbin	ODI	18	1.36	012	+15.50
15	64	04/96 RFO	Bobbin	NQI		0.22	012	+0.30

FTI TUBAN II (Version 2.3) 05/14/1996 08:57:11
 Oconee Nuclear Station - Unit Two
 S/G A
 04/96 RFO
 Bobbin

Page 4 of 34

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
15	66	04/96 RFO	Bobbin	NQI		0.20	003	+8.60
15	73	04/96 RFO	Bobbin	NQI		0.45	009	+23.76
15	77	04/96 RFO	Bobbin	ODI	7	0.55	011	+7.00
16	13	04/96 RFO	Bobbin	NQI		0.49	001	+17.80
16	23	04/96 RFO	Bobbin	ODI	12	0.44	015	+24.15
16	31	04/96 RFO	Bobbin	NQI		0.30	001	+2.76
16	35	04/96 RFO	Bobbin	NQI		0.24	007	-0.41
16	45	04/96 RFO	Bobbin	ADI		4.25	014	+23.78
16	70	04/96 RFO	Bobbin	ODI	14	1.40	014	+13.04
16	71	04/96 RFO	Bobbin	ODI	10	2.71	008	+15.04
		04/96 RFO	Bobbin	ODI	20	0.79	010	+31.04
		04/96 RFO	Bobbin	NQI		0.66	008	+19.00 to +23.94
		04/96 RFO	Bobbin	ADI		2.50	015	+13.83
16	75	04/96 RFO	Bobbin	ODI	9	1.00	010	-0.61
16	76	04/96 RFO	Bobbin	NQI		0.45	015	+35.71
16	79	04/96 RFO	Bobbin	NQI		0.45	015	+3.83
16	81	04/96 RFO	Bobbin	ODI	31	0.41	007	+32.78
17	9	04/96 RFO	Bobbin	NQI		0.51	013	+12.97
17	44	04/96 RFO	Bobbin	NQI		0.64	LTS	+35.64
17	53	04/96 RFO	Bobbin	ODI	10	0.97	001	+7.29
		04/96 RFO	Bobbin	ADI		4.82	007	+19.32
17	70	04/96 RFO	Bobbin	ADI		5.83	004	+32.87
17	72	04/96 RFO	Bobbin	NQI		0.42	015	+33.00
		04/96 RFO	Bobbin	NQI		22.00	LTS	+6.63
		04/96 RFO	Bobbin	NQI		26.21	LTS	+14.67
17	76	04/96 RFO	Bobbin	ODI	29	0.47	009	+23.34
17	78	04/96 RFO	Bobbin	ODI	12	0.54	010	+6.57
17	80	04/96 RFO	Bobbin	ADI		0.89	010	+20.70
		04/96 RFO	Bobbin	NQI		0.56	010	-0.76
18	3	04/96 RFO	Bobbin	NQI		0.63	014	-0.80
18	6	04/96 RFO	Bobbin	ODI	17	0.41	008	+19.22
18	11	04/96 RFO	Bobbin	ODI	38	0.57	014	-0.84
18	19	04/96 RFO	Bobbin	ODI	9	0.46	011	+10.28
		04/96 RFO	Bobbin	ODI	68	0.43	011	+10.06
18	45	04/96 RFO	Bobbin	ADI		7.08	013	+26.66
		04/96 RFO	Bobbin	ADI		13.19	013	+30.25
		04/96 RFO	Bobbin	ODI	39	0.33	006	+30.04
18	57	04/96 RFO	Bobbin	ODI	12	0.33	002	+12.07
18	79	04/96 RFO	Bobbin	NQI	3	0.57	015	-0.54
18	81	04/96 RFO	Bobbin	NQI		0.51	009	+24.02
18	83	04/96 RFO	Bobbin	NQI		0.32	004	+1.56
		04/96 RFO	Bobbin	NQI		0.58	015	+30.14
		04/96 RFO	Bobbin	NQI		0.29	010	+16.43 to +19.99
18	85	04/96 RFO	Bobbin	NQI		0.33	015	+1.38
19	19	04/96 RFO	Bobbin	ODI	34	0.43	013	+22.47
19	46	04/96 RFO	Bobbin	NQI		0.48	015	+41.85
		04/96 RFO	Bobbin	NQI		0.62	015	+18.12
19	66	04/96 RFO	Bobbin	NQI		0.14	013	+0.00
19	74	04/96 RFO	Bobbin	DWI		1.33	015	+24.00
		04/96 RFO	Bobbin	DWI		1.92	015	+29.37
		04/96 RFO	Bobbin	NQI		0.33	012	+21.13
19	75	04/96 RFO	Bobbin	NQI		0.46	008	+15.70
19	76	04/96 RFO	Bobbin	ODI	26	0.41	007	+0.43
19	79	04/96 RFO	Bobbin	ODI	24	0.38	009	+14.14
19	82	04/96 RFO	Bobbin	ODI	28	0.54	009	+19.15
19	84	04/96 RFO	Bobbin	ODI	34	0.75	009	+23.13
19	85	04/96 RFO	Bobbin	ODI	22	0.65	010	+0.62
20	52	04/96 RFO	Bobbin	ODI	19	0.74	LTE	+16.23
20	66	04/96 RFO	Bobbin	DWI		2.32	015	+28.23
		04/96 RFO	Bobbin	DWI		3.80	015	+31.32
		04/96 RFO	Bobbin	DWI		3.82	015	+21.68
20	70	04/96 RFO	Bobbin	ODI	26	0.39	003	+0.05
20	76	04/96 RFO	Bobbin	ODI	16	0.56	014	+7.88
20	82	04/96 RFO	Bobbin	ODI	9	0.45	009	+19.29
21	10	04/96 RFO	Bobbin	ODI	24	0.46	007	-0.27

FTI TUBAN II (Version 2.3) 05/14/1996 08:57:11
Oconee Nuclear Station - Unit Two
S/G A
04/96 RFO
Bobbin

Page 6 of 34

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
28	2	04/96 RFO	Bobbin	NQI		0.61	011	+0.53 UTE
28	5	04/96 RFO	Bobbin	ODI	35	0.26	009	+0.67 UTE
28	99	04/96 RFO	Bobbin	ODI	37	0.41	010	+6.32 UTE
29	18	04/96 RFO	Bobbin	ODI	24	0.48	001	+12.47 UTE
29	84	04/96 RFO	Bobbin	NQI		0.44	006	+30.08 to +35.32 UTE
29	94	04/96 RFO	Bobbin	NQI		0.47	006	+32.97 UTE
		04/96 RFO	Bobbin	NQI		0.51	006	+32.27 UTE
29	102	04/96 RFO	Bobbin	NQI		0.15	015	+0.05 UTE
30	1	04/96 RFO	Bobbin	ODI	5	0.54	010	+3.34 UTE
30	6	04/96 RFO	Bobbin	NQI		0.68	009	+0.53 UTE
31	2	04/96 RFO	Bobbin	WAR	54	0.75	010	+0.56 UTE
31	5	04/96 RFO	Bobbin	ODI	7	0.54	009	+18.54 UTE
31	23	04/96 RFO	Bobbin	NQI		0.27	007	-0.32 UTE
31	36	04/96 RFO	Bobbin	ODI	39	0.54	006	+21.40 UTE
31	59	04/96 RFO	Bobbin	ODI	27	0.18	007	-0.40 UTE
31	67	04/96 RFO	Bobbin	NQI		1.40	013	-0.80 UTE
31	100	04/96 RFO	Bobbin	NQI		1.66	015	+0.72 UTE
32	2	04/96 RFO	Bobbin	NQI		0.60	010	+0.61 UTE
32	8	04/96 RFO	Bobbin	ODI	7	0.65	008	+0.48 UTE
32	23	04/96 RFO	Bobbin	NQI		0.40	006	+31.43 UTE
32	24	04/96 RFO	Bobbin	ODI	2	0.54	009	+9.15 UTE
32	34	04/96 RFO	Bobbin	ODI	10	0.46	006	+24.22 UTE
32	86	04/96 RFO	Bobbin	NQI		0.48	006	+27.79 to +37.15 UTE
33	22	04/96 RFO	Bobbin	NQI		0.54	015	+40.50 UTE
34	2	04/96 RFO	Bobbin	NQI		0.49	010	+0.64 UTE
34	33	04/96 RFO	Bobbin	NQI		0.51	006	+18.32 to +21.84 UTE
35	49	04/96 RFO	Bobbin	ODI	5	1.10	LTS	-0.51 UTE
35	65	04/96 RFO	Bobbin	NQI		0.47	006	+10.67 UTE
35	108	04/96 RFO	Bobbin	NQI		0.50	011	-0.80 UTE
36	17	04/96 RFO	Bobbin	NQI		0.54	006	+33.62 UTE
36	91	04/96 RFO	Bobbin	ODI	35	0.46	006	+28.82 UTE
36	94	04/96 RFO	Bobbin	ODI	35	0.49	006	+29.68 UTE
36	95	04/96 RFO	Bobbin	ODI	21	0.42	006	+31.83 UTE
36	98	04/96 RFO	Bobbin	ODI	11	1.91	003	+10.52 UTE
36	107	04/96 RFO	Bobbin	NQI		0.12	010	+0.16 UTE
36	110	04/96 RFO	Bobbin	ODI	6	0.52	008	+33.37 UTE
36	111	04/96 RFO	Bobbin	ODI	9	0.47	009	-0.24 UTE
		04/96 RFO	Bobbin	ODI	24	0.44	008	+9.71 UTE
36	112	04/96 RFO	Bobbin	NQI		0.53	012	-0.81 UTE
37	1	04/96 RFO	Bobbin	NQI		0.62	013	-0.78 UTE
37	19	04/96 RFO	Bobbin	ODI	10	0.27	006	+32.96 UTE
37	42	04/96 RFO	Bobbin	ODI	36	0.57	012	+21.11 UTE
37	64	04/96 RFO	Bobbin	ODI	12	0.42	006	+8.73 UTE
37	92	04/96 RFO	Bobbin	NQI		0.40	005	+0.65 UTE
		04/96 RFO	Bobbin	ODI	11	0.58	006	+25.89 UTE
37	95	04/96 RFO	Bobbin	ODI	13	0.49	006	+33.15 UTE
38	1	04/96 RFO	Bobbin	WAR	22	0.83	010	+0.00 UTE
38	9	04/96 RFO	Bobbin	ODI	11	0.68	007	+0.64 UTE
38	35	04/96 RFO	Bobbin	NQI		0.40	009	+13.13 UTE
38	59	04/96 RFO	Bobbin	NQI		0.22	006	-0.24 UTE
38	79	04/96 RFO	Bobbin	NQI		0.38	006	+0.05 UTE
38	89	04/96 RFO	Bobbin	ODI	64	0.80	009	+0.65 UTE
38	92	04/96 RFO	Bobbin	ODI	38	0.48	006	+31.96 UTE
38	93	04/96 RFO	Bobbin	ODI	15	0.69	003	+0.70 UTE
38	94	04/96 RFO	Bobbin	ODI	32	0.29	009	+18.29 UTE
38	112	04/96 RFO	Bobbin	ODI	24	0.64	008	+16.37 UTE
39	67	04/96 RFO	Bobbin	NQI		0.53	007	+8.50 UTE
39	93	04/96 RFO	Bobbin	ODI	3	0.63	006	+35.02 UTE
		04/96 RFO	Bobbin	ODI	10	0.30	006	+37.20 UTE
39	99	04/96 RFO	Bobbin	ODI	9	0.83	015	+11.84 UTE
39	100	04/96 RFO	Bobbin	ADI		1.49	006	+32.77 UTE
39	112	04/96 RFO	Bobbin	NQI		0.68	012	-0.76 UTE
		04/96 RFO	Bobbin	ODI	23	0.45	008	+12.85 UTE
39	113	04/96 RFO	Bobbin	ODI	2	0.40	007	+0.27 UTE
39	115	04/96 RFO	Bobbin	ODI	7	0.51	008	+34.00 UTE

FTI TUBAN II (Version 2.3) 05/14/1996 08:57:11
 Oconee Nuclear Station - Unit Two
 S/G A
 04/96 RFO
 Bobbin

Page 7 of 34

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
40	38	04/96 RFO	Bobbin	ODI	14	0.52	009 +23.49	UTE
40	81	04/96 RFO	Bobbin	NQI		0.35	006 +10.97	UTE
40	92	04/96 RFO	Bobbin	NQI		0.30	005 +26.32	UTE
40	93	04/96 RFO	Bobbin	ODI	7	0.35	006 +27.53	UTE
40	99	04/96 RFO	Bobbin	ODI	21	0.34	006 +33.67	UTE
40	107	04/96 RFO	Bobbin	NQI		0.38	006 +32.75	UTE
40	111	04/96 RFO	Bobbin	NQI		0.98	014 -0.84	UTE
40	114	04/96 RFO	Bobbin	ODI	22	0.39	008 -0.38	UTE
40	115	04/96 RFO	Bobbin	ODI	5	0.51	008 +13.14	UTE
		04/96 RFO	Bobbin	ODI	10	0.46	008 +10.88	UTE
41	15	04/96 RFO	Bobbin	NQI		0.54	006 +33.32	UTE
41	24	04/96 RFO	Bobbin	ODI	38	0.40	010 +15.28	UTE
41	40	04/96 RFO	Bobbin	ODI	7	0.60	001 +28.54	UTE
41	47	04/96 RFO	Bobbin	NQI		2.21	015 +28.45	UTE
41	48	04/96 RFO	Bobbin	ODI	1	0.42	004 +1.17	UTE
41	61	04/96 RFO	Bobbin	ODI	31	0.42	006 -0.40	UTE
41	67	04/96 RFO	Bobbin	NQI		0.29	006 -0.27	UTE
41	90	04/96 RFO	Bobbin	ODI	39	0.46	012 +12.27	UTE
41	94	04/96 RFO	Bobbin	ODI	30	1.03	UTS +0.43	UTE
42	1	04/96 RFO	Bobbin	NQI		0.45	010 +0.06	UTE
42	18	04/96 RFO	Bobbin	ODI	9	0.80	006 +33.77	UTE
42	68	04/96 RFO	Bobbin	NQI		0.28	006 +8.71	UTE
42	71	04/96 RFO	Bobbin	NQI		0.82	001 +32.97	UTE
42	90	04/96 RFO	Bobbin	ODI	14	0.55	006 +21.65	UTE
42	91	04/96 RFO	Bobbin	NQI		1.11	015 +33.13	UTE
42	99	04/96 RFO	Bobbin	NQI		0.42	015 +40.00	UTE
42	105	04/96 RFO	Bobbin	NQI		0.99	LTE +4.44	UTE
42	111	04/96 RFO	Bobbin	ODI	6	0.62	014 -0.82	UTE
42	112	04/96 RFO	Bobbin	NQI		0.53	014 -0.79	UTE
42	114	04/96 RFO	Bobbin	WAR	6	1.40	014 +0.00	UTE
42	115	04/96 RFO	Bobbin	NQI		0.94	014 -0.79	UTE
		04/96 RFO	Bobbin	NQI		1.14	LTE +1.76	UTE
43	5	04/96 RFO	Bobbin	ODI	14	0.57	012 -0.84	UTE
		04/96 RFO	Bobbin	WAR	29	1.17	014 +0.00	UTE
43	15	04/96 RFO	Bobbin	NQI		0.55	015 +41.63	UTE
43	38	04/96 RFO	Bobbin	NQI		0.37	009 -1.36	UTE
43	58	04/96 RFO	Bobbin	ODI	4	0.28	006 -0.27	UTE
43	87	04/96 RFO	Bobbin	NQI		0.23	007 -0.32	UTE
43	89	04/96 RFO	Bobbin	ODI	9	0.36	002 -0.81	UTE
43	93	04/96 RFO	Bobbin	ODI	52	0.85	015 +11.42	UTE
43	95	04/96 RFO	Bobbin	ODI	5	0.48	006 +22.29	UTE
43	102	04/96 RFO	Bobbin	ODI	20	0.22	007 +0.08	UTE
43	105	04/96 RFO	Bobbin	NQI		0.21	007 -0.05	UTE
43	114	04/96 RFO	Bobbin	ODI	5	0.65	007 +34.52	UTE
43	115	04/96 RFO	Bobbin	ODI	30	0.69	014 -0.90	UTE
44	1	04/96 RFO	Bobbin	NQI		0.68	013 +0.62	UTE
44	2	04/96 RFO	Bobbin	ODI	11	1.01	013 +8.43	UTE
		04/96 RFO	Bobbin	ODI	24	1.26	013 +9.38	UTE
44	3	04/96 RFO	Bobbin	NQI		0.43	008 +24.03	UTE
44	22	04/96 RFO	Bobbin	NQI		0.42	006 +32.82	UTE
44	25	04/96 RFO	Bobbin	NQI		0.61	LTS +4.65	UTE
44	41	04/96 RFO	Bobbin	NQI		0.31	004 +0.14	UTE
44	69	04/96 RFO	Bobbin	NQI		0.23	005 +30.89	UTE
		04/96 RFO	Bobbin	ODI	9	0.22	005 +30.16	UTE
44	97	04/96 RFO	Bobbin	NQI		0.29	006 +31.17	UTE
		04/96 RFO	Bobbin	ODI	26	0.31	004 -0.79	UTE
44	105	04/96 RFO	Bobbin	NQI		0.77	007 -0.52	UTE
44	113	04/96 RFO	Bobbin	NQI		0.17	014 +0.79	UTE
		04/96 RFO	Bobbin	ODI	24	0.48	014 -0.82	UTE
44	115	04/96 RFO	Bobbin	ODI	38	0.61	014 -0.93	UTE
44	118	04/96 RFO	Bobbin	ODI	6	0.55	007 +32.45	UTE
44	119	04/96 RFO	Bobbin	NQI		0.70	011 -0.81	UTE
45	4	04/96 RFO	Bobbin	ADI		0.59	008 +12.32	UTE
45	26	04/96 RFO	Bobbin	NQI		0.51	009 +36.25	UTE
45	34	04/96 RFO	Bobbin	NQI		0.84	012 -0.03	UTE

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	ODI	20	0.72	010	+18.86
		04/96 RFO	Bobbin	ODI	24	0.54	010	+19.91
45	39	04/96 RFO	Bobbin	NQI		0.74	010	+29.76
		04/96 RFO	Bobbin	NQI		0.83	010	+6.91
		04/96 RFO	Bobbin	ODI	42	1.01	009	+15.10
		04/96 RFO	Bobbin	ODI	50	0.49	008	+33.20
		04/96 RFO	Bobbin	ODI	57	1.09	009	+23.75
		04/96 RFO	Bobbin	ODI	63	0.74	009	+6.19
		04/96 RFO	Bobbin	ODI	76	0.74	014	+21.39
45	50	04/96 RFO	Bobbin	ODI	16	0.43	003	+34.07
45	65	04/96 RFO	Bobbin	ODI	16	0.43	005	+31.57
45	103	04/96 RFO	Bobbin	ODI	29	0.32	006	+30.25
45	117	04/96 RFO	Bobbin	NQI		0.52	007	+22.28
45	119	04/96 RFO	Bobbin	ODI	14	0.41	008	+31.71
46	1	04/96 RFO	Bobbin	NQI		0.53	014	+0.53
46	3	04/96 RFO	Bobbin	NQI		0.45	010	+0.65
		04/96 RFO	Bobbin	NQI		0.51	014	-0.82
		04/96 RFO	Bobbin	NQI		0.67	012	-0.82
		04/96 RFO	Bobbin	NQI		0.96	013	-0.76
46	19	04/96 RFO	Bobbin	ODI	14	0.21	007	-0.39
46	21	04/96 RFO	Bobbin	ODI	30	0.80	010	+4.22
46	33	04/96 RFO	Bobbin	ODI	14	0.25	007	-0.11
46	40	04/96 RFO	Bobbin	NQI		0.48	011	+6.79
		04/96 RFO	Bobbin	ODI	15	0.50	013	+7.46
46	48	04/96 RFO	Bobbin	ODI	32	0.24	004	-0.36
46	49	04/96 RFO	Bobbin	NQI		0.30	005	+0.59
		04/96 RFO	Bobbin	NQI		0.48	006	-0.39
46	61	04/96 RFO	Bobbin	ODI	12	0.31	006	-0.54
46	69	04/96 RFO	Bobbin	DWI		5.42	LTS	-0.14
46	71	04/96 RFO	Bobbin	ADI		0.38	LTS	+33.29
46	91	04/96 RFO	Bobbin	NQI		0.64	001	+14.55
47	1	04/96 RFO	Bobbin	NQI		0.60	012	-0.84
47	2	04/96 RFO	Bobbin	ODI	13	0.68	010	+0.61
		04/96 RFO	Bobbin	ODI	25	0.44	010	+0.97
47	6	04/96 RFO	Bobbin	NQI		0.80	013	+35.20
47	8	04/96 RFO	Bobbin	NQI		0.66	015	+24.62
47	9	04/96 RFO	Bobbin	ODI	30	0.60	011	+19.11
		04/96 RFO	Bobbin	ODI	37	0.45	011	+17.96
47	20	04/96 RFO	Bobbin	NQI		0.83	005	+28.21
47	55	04/96 RFO	Bobbin	NQI		0.32	006	+0.13
47	57	04/96 RFO	Bobbin	ODI	5	0.21	006	-0.27
47	58	04/96 RFO	Bobbin	NQI		0.42	015	+13.85
		04/96 RFO	Bobbin	ODI	4	0.39	014	+16.45
		04/96 RFO	Bobbin	ODI	4	0.60	011	+11.60
		04/96 RFO	Bobbin	ODI	14	0.33	011	+33.62
		04/96 RFO	Bobbin	ODI	24	0.31	006	-0.38
		04/96 RFO	Bobbin	ODI	33	0.42	009	+28.63
		04/96 RFO	Bobbin	ODI	38	0.49	011	+12.22
47	59	04/96 RFO	Bobbin	ODI	3	0.39	006	-0.16
47	64	04/96 RFO	Bobbin	NQI		0.43	006	-0.19
47	66	04/96 RFO	Bobbin	ODI	18	0.22	006	-0.38
47	79	04/96 RFO	Bobbin	DWI		0.69	007	+20.18
47	80	04/96 RFO	Bobbin	NQI		0.48	006	-0.35
47	87	04/96 RFO	Bobbin	ADI		1.20	013	+5.81
47	88	04/96 RFO	Bobbin	NQI		0.27	014	+20.59
47	94	04/96 RFO	Bobbin	NQI		0.36	006	+22.12
47	107	04/96 RFO	Bobbin	ODI	5	0.34	006	+34.70
		04/96 RFO	Bobbin	ODI	22	0.32	006	+32.73
47	108	04/96 RFO	Bobbin	NQI		0.21	007	-0.21
47	121	04/96 RFO	Bobbin	NQI		0.61	015	+23.66
		04/96 RFO	Bobbin	ODI	65	0.49	015	+24.73
48	2	04/96 RFO	Bobbin	NQI		0.49	010	+0.58
48	6	04/96 RFO	Bobbin	NQI		1.08	009	+0.53
48	9	04/96 RFO	Bobbin	ODI	3	0.66	014	-0.81
48	18	04/96 RFO	Bobbin	ODI	22	0.63	006	+30.23

FTI TUBAN II (Version 2.3) 05/14/1996 08:57:11
Ocone Nuclear Station - Unit Two
S/G A
04/96 RFO
Bobbin

Page 9 of 34

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
48	44	04/96 RFO	Bobbin	NQI		0.54	004	+32.19 UTE
48	45	04/96 RFO	Bobbin	ODI	27	1.47	009	+35.31 UTE
48	52	04/96 RFO	Bobbin	ODI	12	0.64	010	+16.28 UTE
48	54	04/96 RFO	Bobbin	ODI	7	0.45	006	-0.21 UTE
48	57	04/96 RFO	Bobbin	ODI	38	0.44	013	+27.88 UTE
48	72	04/96 RFO	Bobbin	NQI		0.69	008	+3.37 UTE
48	75	04/96 RFO	Bobbin	ODI	24	0.40	002	+1.36 UTE
48	76	04/96 RFO	Bobbin	NQI		0.57	002	+24.03 UTE
48	81	04/96 RFO	Bobbin	ODI	11	0.31	006	-0.49 UTE
48	83	04/96 RFO	Bobbin	ODI	15	0.53	006	-0.38 UTE
48	117	04/96 RFO	Bobbin	ODI	39	0.88	014	-0.82 UTE
48	119	04/96 RFO	Bobbin	ODI	4	0.39	007	+0.11 UTE
49	2	04/96 RFO	Bobbin	NQI		0.79	013	-0.75 UTE
		04/96 RFO	Bobbin	ODI	18	0.70	010	+0.50 UTE
49	5	04/96 RFO	Bobbin	NQI		0.52	012	-0.84 UTE
49	33	04/96 RFO	Bobbin	NQI		0.58	012	+32.03 UTE
		04/96 RFO	Bobbin	ODI	27	0.61	012	+29.01 UTE
		04/96 RFO	Bobbin	ODI	59	0.45	012	+33.97 UTE
		04/96 RFO	Bobbin	ODI	70	0.53	012	+34.17 UTE
49	36	04/96 RFO	Bobbin	NQI		0.39	006	+12.20 UTE
49	61	04/96 RFO	Bobbin	ODI	20	0.73	006	-0.14 UTS
49	65	04/96 RFO	Bobbin	ODI	21	1.31	013	+18.74 UTS
49	76	04/96 RFO	Bobbin	ODI	29	0.34	006	-0.24 UTE
49	80	04/96 RFO	Bobbin	NQI		0.36	006	+0.13 UTE
49	114	04/96 RFO	Bobbin	ODI	15	0.80	013	+0.46 UTE
49	116	04/96 RFO	Bobbin	WAR	46	0.97	011	+0.00 UTE
		04/96 RFO	Bobbin	WAR	46	2.10	013	+0.00 UTE
49	117	04/96 RFO	Bobbin	NQI		0.34	013	+0.22 UTE
		04/96 RFO	Bobbin	ODI	20	0.70	011	-0.71 UTE
		04/96 RFO	Bobbin	WAR	24	1.28	013	+0.00 UTE
49	119	04/96 RFO	Bobbin	NQI		0.59	008	+0.50 UTE
		04/96 RFO	Bobbin	ODI	11	0.93	011	-0.71 UTE
50	2	04/96 RFO	Bobbin	NQI		0.56	011	-0.69 UTE
		04/96 RFO	Bobbin	ODI	22	0.62	010	+0.58 UTE
50	5	04/96 RFO	Bobbin	NQI		0.29	007	+25.38 UTE
		04/96 RFO	Bobbin	NQI		0.46	007	+26.50 UTE
50	21	04/96 RFO	Bobbin	ODI	14	0.42	006	+31.29 UTE
50	41	04/96 RFO	Bobbin	ODI	16	0.39	006	-0.42 UTE
50	75	04/96 RFO	Bobbin	NQI		0.21	LTS	+12.28 UTE
50	77	04/96 RFO	Bobbin	NQI		0.48	007	-0.19 UTE
50	96	04/96 RFO	Bobbin	ODI	34	0.21	007	-0.27 UTE
50	113	04/96 RFO	Bobbin	NQI		0.25	007	-0.03 UTE
50	115	04/96 RFO	Bobbin	QDI	6	0.66	015	-0.90 UTE
		04/96 RFO	Bobbin	WAR	51	1.13	014	+0.00 UTE
50	116	04/96 RFO	Bobbin	ODI	15	0.53	014	-0.78 UTE
50	117	04/96 RFO	Bobbin	NQI		0.74	014	+0.74 UTE
50	120	04/96 RFO	Bobbin	NQI		0.60	011	+0.64 UTE
50	123	04/96 RFO	Bobbin	NQI		0.51	011	-0.72 UTE
51	5	04/96 RFO	Bobbin	ODI	1	0.54	012	-0.81 UTE
51	12	04/96 RFO	Bobbin	ODI	31	0.54	LTS	+29.36 UTE
51	18	04/96 RFO	Bobbin	NQI		0.72	015	+38.07 UTE
		04/96 RFO	Bobbin	ODI	19	1.37	015	+20.30 UTE
		04/96 RFO	Bobbin	ODI	30	0.66	015	+41.37 UTE
		04/96 RFO	Bobbin	ODI	35	0.68	015	+42.25 UTE
51	37	04/96 RFO	Bobbin	NQI		0.88	014	+13.50 UTE
		04/96 RFO	Bobbin	NQI		1.13	015	+36.68 UTE
		04/96 RFO	Bobbin	ODI	6	1.06	014	+12.80 UTE
		04/96 RFO	Bobbin	NQI		0.63	013	+28.50 to +31.32 UTE
51	41	04/96 RFO	Bobbin	NQI		0.98	014	+30.11 UTE
51	45	04/96 RFO	Bobbin	NQI		0.71	006	-0.36 UTE
51	49	04/96 RFO	Bobbin	NQI		0.47	006	-0.28 UTE
51	67	04/96 RFO	Bobbin	ODI	8	0.58	006	-0.34 UTS
51	76	04/96 RFO	Bobbin	ADI		2.84	004	+23.67 UTE
		04/96 RFO	Bobbin	NQI		0.38	006	-0.36 UTE
		04/96 RFO	Bobbin	ODI	33	0.35	001	+9.59 UTE

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
51	113	04/96 RFO	Bobbin	ODI	6	0.54	006	+29.39
51	115	04/96 RFO	Bobbin	ODI	38	1.10	013	+0.60
51	119	04/96 RFO	Bobbin	NQI		0.87	012	+0.51
		04/96 RFO	Bobbin	WAR	64	1.34	013	+0.00
51	121	04/96 RFO	Bobbin	NQI		0.25	008	+18.73
52	1	04/96 RFO	Bobbin	DWI		0.27	003	+2.78
52	12	04/96 RFO	Bobbin	ODI	26	0.40	LTS	+4.98
52	47	04/96 RFO	Bobbin	ODI	22	0.28	006	-0.34
52	51	04/96 RFO	Bobbin	ODI	8	0.42	005	+0.42
52	73	04/96 RFO	Bobbin	ADI		1.92	015	+25.05
		04/96 RFO	Bobbin	ADI		2.80	015	+28.07
52	114	04/96 RFO	Bobbin	NQI		0.22	007	-0.14
		04/96 RFO	Bobbin	WAR	44	0.92	014	+0.00
52	115	04/96 RFO	Bobbin	WAR	37	0.71	014	+0.00
52	116	04/96 RFO	Bobbin	WAR	42	1.11	014	+0.00
52	118	04/96 RFO	Bobbin	NQI		0.55	014	-0.85
52	119	04/96 RFO	Bobbin	WAR	30	0.61	009	+0.00
		04/96 RFO	Bobbin	WAR	46	3.27	013	+0.00
		04/96 RFO	Bobbin	WAR	79	0.80	011	+0.00
52	120	04/96 RFO	Bobbin	NQI		0.49	013	-0.66
		04/96 RFO	Bobbin	WAR	45	1.79	011	+0.00
		04/96 RFO	Bobbin	WAR	61	0.75	010	+0.00
		04/96 RFO	Bobbin	WAR	65	0.43	008	+0.00
		04/96 RFO	Bobbin	WAR	65	0.70	009	+0.00
52	121	04/96 RFO	Bobbin	ODI	28	0.44	008	+21.04
52	122	04/96 RFO	Bobbin	ODI	7	0.25	008	-0.24
52	124	04/96 RFO	Bobbin	ODI	33	0.17	007	+0.22
53	1	04/96 RFO	Bobbin	NQI		0.57	010	+2.54
53	3	04/96 RFO	Bobbin	NQI		0.51	010	+0.70
53	4	04/96 RFO	Bobbin	ODI	29	0.35	013	+13.78
53	11	04/96 RFO	Bobbin	ODI	36	2.32	010	+31.86
53	22	04/96 RFO	Bobbin	NQI		0.33	006	+29.15
53	57	04/96 RFO	Bobbin	ODI	15	0.78	006	-0.40
53	74	04/96 RFO	Bobbin	ODI	9	0.38	006	-0.37
53	90	04/96 RFO	Bobbin	ODI	9	0.22	006	-0.40
53	91	04/96 RFO	Bobbin	ODI	18	0.28	006	-0.49
53	102	04/96 RFO	Bobbin	ODI	26	0.82	008	+0.37
53	104	04/96 RFO	Bobbin	ODI	23	0.46	006	+29.34
53	115	04/96 RFO	Bobbin	WAR	70	0.61	013	+0.00
53	116	04/96 RFO	Bobbin	WAR	69	0.91	011	+0.00
		04/96 RFO	Bobbin	WAR	75	1.18	013	+0.00
53	117	04/96 RFO	Bobbin	WAR	48	2.02	013	+0.00
		04/96 RFO	Bobbin	WAR	51	1.36	011	+0.00
53	118	04/96 RFO	Bobbin	WAR	43	1.82	011	+0.00
		04/96 RFO	Bobbin	WAR	57	1.76	013	+0.00
53	121	04/96 RFO	Bobbin	NQI		0.90	007	-0.52
54	2	04/96 RFO	Bobbin	NQI		0.75	012	-0.83
		04/96 RFO	Bobbin	NQI		1.27	LTS	-0.03
		04/96 RFO	Bobbin	ODI	25	0.62	010	+0.67
54	3	04/96 RFO	Bobbin	ODI	11	0.66	008	+30.81
54	6	04/96 RFO	Bobbin	ODI	10	0.42	007	+30.11
54	12	04/96 RFO	Bobbin	ODI	18	0.35	006	+28.74
54	24	04/96 RFO	Bobbin	ODI	5	0.25	008	+0.31
54	28	04/96 RFO	Bobbin	ODI	22	0.51	006	+0.64
54	58	04/96 RFO	Bobbin	ODI	23	0.38	006	-0.56
54	67	04/96 RFO	Bobbin	ADI		1.89	013	+13.42
54	74	04/96 RFO	Bobbin	ODI	34	0.37	014	+25.45
		04/96 RFO	Bobbin	ODI	57	0.45	009	+32.86
		04/96 RFO	Bobbin	ODI	60	0.41	013	+27.38
		04/96 RFO	Bobbin	NQI		0.29	010	+25.99 to +33.79
		04/96 RFO	Bobbin	NQI		0.58	011	+30.36 to +33.99
54	78	04/96 RFO	Bobbin	ODI	38	0.53	005	+23.13
55	10	04/96 RFO	Bobbin	NQI		0.61	010	+21.82
55	11	04/96 RFO	Bobbin	NQI		1.09	009	+12.78 to +36.12
55	13	04/96 RFO	Bobbin	NQI		0.28	015	+28.26

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
55	14	04/96 RFO	Bobbin	ODI	9	0.82	015 +9.00	UTE
		04/96 RFO	Bobbin	NQI		0.41	014 +19.17 to +28.03	UTE
55	22	04/96 RFO	Bobbin	NQI		9.38	UTE -0.67	UTE
55	45	04/96 RFO	Bobbin	ODI	28	0.41	009 +2.15	UTE
55	68	04/96 RFO	Bobbin	ADI		2.16	013 +29.82	UTS
55	73	04/96 RFO	Bobbin	ODI	3	0.30	006 -0.44	UTE
55	79	04/96 RFO	Bobbin	NQI		0.42	010 +32.71	UTE
55	83	04/96 RFO	Bobbin	DWI		0.58	005 -0.90	UTE
55	89	04/96 RFO	Bobbin	NQI		0.55	006 -0.57	UTE
55	107	04/96 RFO	Bobbin	NQI		0.22	006 -0.45	UTE
55	112	04/96 RFO	Bobbin	NQI		0.51	006 +30.56	UTE
55	118	04/96 RFO	Bobbin	NQI		0.59	005 +24.93	UTE
55	120	04/96 RFO	Bobbin	WAR	9	0.56	008 +0.00	UTE
55	122	04/96 RFO	Bobbin	ODI	4	0.63	014 +9.56	UTE
		04/96 RFO	Bobbin	ODI	20	1.32	013 +4.61	UTE
		04/96 RFO	Bobbin	ODI	23	0.52	014 +29.87	UTE
55	124	04/96 RFO	Bobbin	ODI	27	0.42	009 +27.52	UTE
		04/96 RFO	Bobbin	ODI	49	0.53	009 +28.45	UTE
56	1	04/96 RFO	Bobbin	NQI		0.32	011 -0.66	UTE
		04/96 RFO	Bobbin	ODI	25	0.32	010 -0.67	UTE
		04/96 RFO	Bobbin	ODI	32	0.61	012 +0.61	UTE
56	2	04/96 RFO	Bobbin	ODI	18	0.54	008 +32.96	UTE
		04/96 RFO	Bobbin	ODI	20	0.46	008 +33.49	UTE
56	4	04/96 RFO	Bobbin	NQI		0.52	012 -0.81	UTE
56	5	04/96 RFO	Bobbin	NQI		0.51	010 +0.70	UTE
56	15	04/96 RFO	Bobbin	ODI	33	0.98	015 +43.40	UTE
56	28	04/96 RFO	Bobbin	ODI	14	0.56	008 +14.46	UTE
56	38	04/96 RFO	Bobbin	NQI		0.44	006 +9.24	UTE
56	92	04/96 RFO	Bobbin	NQI		0.35	006 -0.38	UTE
56	99	04/96 RFO	Bobbin	ODI	11	0.34	008 +0.38	UTE
56	100	04/96 RFO	Bobbin	ODI	22	0.84	008 +0.35	UTE
56	104	04/96 RFO	Bobbin	NQI		0.53	008 +0.38	UTE
56	112	04/96 RFO	Bobbin	NQI		0.45	008 +0.35	UTE
56	121	04/96 RFO	Bobbin	ODI	22	0.25	007 +0.00	UTE
56	123	04/96 RFO	Bobbin	NQI		0.49	011 +26.73	UTE
56	124	04/96 RFO	Bobbin	ODI	15	0.53	009 +25.18	UTE
56	126	04/96 RFO	Bobbin	NQI		1.22	012 +31.71	UTE
		04/96 RFO	Bobbin	NQI		2.34	015 +0.59	UTE
		04/96 RFO	Bobbin	ODI	57	0.63	015 +17.39	UTE
		04/96 RFO	Bobbin	ODI	61	0.51	015 +17.15	UTE
56	127	04/96 RFO	Bobbin	NQI		1.61	013 +1.23	UTE
57	14	04/96 RFO	Bobbin	NQI		0.45	006 +31.48	UTE
57	43	04/96 RFO	Bobbin	NQI		1.08	015 +5.37 to +42.24	UTE
		04/96 RFO	Bobbin	NQI		1.09	011 +17.67 to +20.47	UTE
		04/96 RFO	Bobbin	NQI		1.45	012 +25.82 to +30.52	UTE
57	54	04/96 RFO	Bobbin	NQI		0.74	005 -0.78	UTE
57	63	04/96 RFO	Bobbin	NQI		0.43	006 -0.28	UTS
57	86	04/96 RFO	Bobbin	NQI		0.38	006 -0.55	UTE
57	115	04/96 RFO	Bobbin	NQI		0.30	007 -0.13	UTE
57	118	04/96 RFO	Bobbin	NQI		0.25	007 +0.30	UTE
57	126	04/96 RFO	Bobbin	NQI		0.81	009 +30.38 to +38.02	UTE
57	127	04/96 RFO	Bobbin	NQI		1.24	015 -0.56	UTE
		04/96 RFO	Bobbin	ODI	64	0.47	014 +23.65	UTE
58	1	04/96 RFO	Bobbin	ODI	32	0.65	014 -0.79	UTE
58	57	04/96 RFO	Bobbin	ODI	33	0.35	003 +0.58	UTE
58	65	04/96 RFO	Bobbin	NQI		1.13	011 +25.56	UTE
58	94	04/96 RFO	Bobbin	ODI	24	0.28	006 -0.30	UTE
58	126	04/96 RFO	Bobbin	NQI		0.53	009 +31.11	UTE
		04/96 RFO	Bobbin	ODI	20	1.26	009 -0.48	UTE
		04/96 RFO	Bobbin	ODI	22	1.51	009 -0.75	UTE
58	127	04/96 RFO	Bobbin	NQI		0.46	015 +0.19	UTE
		04/96 RFO	Bobbin	NQI		0.86	015 -0.19	UTE
58	129	04/96 RFO	Bobbin	NQI		0.40	011 +10.93	UTE
		04/96 RFO	Bobbin	ODI	30	0.69	015 -0.51	UTE
		04/96 RFO	Bobbin	ODI	31	0.24	011 +9.56	UTE

FTI TUBAN II (Version 2.3) 05/14/1996 08:57:11
 Oconee Nuclear Station - Unit Two
 S/G A
 04/96 RFO
 Bobbin

Page 12 of 34

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	ODI	39	0.76	015	UTE
59	1	04/96 RFO	Bobbin	ODI	13	0.44	010	UTE
59	12	04/96 RFO	Bobbin	NQI		0.47	002	UTE
59	13	04/96 RFO	Bobbin	NQI		0.58	011	UTE
		04/96 RFO	Bobbin	NQI		0.34	010	UTE
59	19	04/96 RFO	Bobbin	NQI		0.76	012	UTE
59	23	04/96 RFO	Bobbin	NQI		0.63	013	UTE
59	89	04/96 RFO	Bobbin	ODI	30	0.23	006	UTE
59	110	04/96 RFO	Bobbin	ODI	6	0.52	005	UTE
59	120	04/96 RFO	Bobbin	NQI		0.42	009	UTE
59	121	04/96 RFO	Bobbin	NQI		0.67	009	UTE
59	124	04/96 RFO	Bobbin	ODI	5	0.54	015	UTE
		04/96 RFO	Bobbin	ODI	18	0.62	015	UTE
60	1	04/96 RFO	Bobbin	NQI		0.47	010	UTE
		04/96 RFO	Bobbin	NQI		0.51	011	UTE
60	3	04/96 RFO	Bobbin	NQI		1.08	011	UTE
60	15	04/96 RFO	Bobbin	NQI		0.53	006	UTE
60	17	04/96 RFO	Bobbin	NQI		0.36	011	UTE
60	41	04/96 RFO	Bobbin	NQI		0.33	010	UTE
60	58	04/96 RFO	Bobbin	ADI		1.36	004	UTE
60	62	04/96 RFO	Bobbin	ODI	20	0.40	006	UTE
60	124	04/96 RFO	Bobbin	NQI		0.43	009	UTE
60	125	04/96 RFO	Bobbin	ODI	14	0.56	009	UTE
60	126	04/96 RFO	Bobbin	WAR	28	1.04	009	UTE
		04/96 RFO	Bobbin	NQI		0.66	009	UTE
60	128	04/96 RFO	Bobbin	NQI		0.23	010	UTE
		04/96 RFO	Bobbin	NQI		0.44	015	UTE
		04/96 RFO	Bobbin	ODI	10	0.79	015	UTE
60	129	04/96 RFO	Bobbin	NQI		0.53	015	UTE
61	1	04/96 RFO	Bobbin	NQI		0.40	012	UTE
		04/96 RFO	Bobbin	NQI		0.89	014	UTE
61	72	04/96 RFO	Bobbin	ODI	19	0.20	014	UTE
		04/96 RFO	Bobbin	ODI	19	0.25	014	UTE
		04/96 RFO	Bobbin	ODI	19	0.30	015	UTE
		04/96 RFO	Bobbin	ODI	19	0.43	015	UTE
		04/96 RFO	Bobbin	ODI	21	0.24	014	UTE
		04/96 RFO	Bobbin	ODI	22	0.38	015	UTE
		04/96 RFO	Bobbin	ODI	27	0.46	014	UTE
		04/96 RFO	Bobbin	ODI	33	0.84	014	UTE
		04/96 RFO	Bobbin	ODI	38	0.30	015	UTE
		04/96 RFO	Bobbin	ODI	42	0.46	014	UTE
		04/96 RFO	Bobbin	ODI	43	0.43	015	UTE
		04/96 RFO	Bobbin	ODI	62	0.61	015	UTE
61	84	04/96 RFO	Bobbin	NQI		0.25	006	UTE
61	101	04/96 RFO	Bobbin	NQI		0.34	007	UTE
61	119	04/96 RFO	Bobbin	ODI	30	0.45	008	UTE
61	121	04/96 RFO	Bobbin	NQI		0.68	010	UTE
61	122	04/96 RFO	Bobbin	NQI		0.57	009	UTE
61	123	04/96 RFO	Bobbin	NQI		0.95	009	UTE
61	125	04/96 RFO	Bobbin	NQI		0.37	010	UTE
		04/96 RFO	Bobbin	ODI	4	0.47	014	UTE
62	2	04/96 RFO	Bobbin	NQI		0.59	011	UTE
62	75	04/96 RFO	Bobbin	ADI		3.66	004	UTE
62	80	04/96 RFO	Bobbin	ODI	20	0.18	006	UTE
62	88	04/96 RFO	Bobbin	ODI	13	0.67	006	UTE
62	122	04/96 RFO	Bobbin	WAR	22	0.43	008	UTE
62	124	04/96 RFO	Bobbin	NQI		0.47	009	UTE
		04/96 RFO	Bobbin	NQI		0.40	009	UTE
62	125	04/96 RFO	Bobbin	ODI	22	0.65	009	UTE
62	126	04/96 RFO	Bobbin	NQI		0.56	009	UTE
62	128	04/96 RFO	Bobbin	ODI	8	0.36	015	UTE
62	129	04/96 RFO	Bobbin	NQI		0.60	015	UTE
63	2	04/96 RFO	Bobbin	ODI	17	0.46	009	014
63	11	04/96 RFO	Bobbin	NQI		0.45	005	UTE
63	13	04/96 RFO	Bobbin	NQI		0.39	LTS	UTE

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND %TW	VOLTS	LOCATION	EXTENT1
63	27	04/96 RFO	Bobbin	NQI	0.51	015 +39.16	UTE
63	47	04/96 RFO	Bobbin	NQI	0.89	012 +1.25 to +15.30	UTE
		04/96 RFO	Bobbin	NQI	0.92	013 +1.20 to +35.05	UTE
		04/96 RFO	Bobbin	NQI	1.04	011 +10.79 to +36.78	UTE
		04/96 RFO	Bobbin	NQI	1.15	014 +0.00 to +33.83	UTE
		04/96 RFO	Bobbin	NQI	1.21	015 +3.40 to +29.60	UTE
63	59	04/96 RFO	Bobbin	ODI	12	0.53 005 +0.58	UTE
63	67	04/96 RFO	Bobbin	DWI		0.64 014 +3.71	UTE
63	105	04/96 RFO	Bobbin	ODI	52	0.72 008 +0.38	UTE
63	110	04/96 RFO	Bobbin	NQI		0.91 004 +0.90	UTE
		04/96 RFO	Bobbin	ODI	13	0.53 002 +25.57	UTE
63	121	04/96 RFO	Bobbin	NQI		0.29 008 -0.71	UTS
63	122	04/96 RFO	Bobbin	NQI		0.79 008 +0.56	UTE
63	125	04/96 RFO	Bobbin	NQI		0.50 009 +22.71 to +28.64	UTE
63	126	04/96 RFO	Bobbin	NQI		0.54 009 +19.13 to +36.31	UTE
63	127	04/96 RFO	Bobbin	NQI		0.41 012 +1.42	UTE
		04/96 RFO	Bobbin	NQI		0.65 009 +27.40 to +36.06	UTE
63	129	04/96 RFO	Bobbin	NQI		0.46 010 +20.66	UTE
		04/96 RFO	Bobbin	NQI		0.51 010 +14.61	UTE
		04/96 RFO	Bobbin	ODI	30	0.62 012 +0.54	UTE
64	119	04/96 RFO	Bobbin	NQI		0.59 008 +0.56	UTE
64	122	04/96 RFO	Bobbin	NQI		0.63 008 +0.53	UTE
64	125	04/96 RFO	Bobbin	NQI		0.34 009 +34.38	LTE
		04/96 RFO	Bobbin	ODI	13	0.84 009 -0.68	UTE
64	127	04/96 RFO	Bobbin	NQI		0.43 015 -0.14	UTE
		04/96 RFO	Bobbin	ODI	8	1.27 009 -0.67	UTE
		04/96 RFO	Bobbin	ODI	20	0.30 009 -0.38	UTE
64	128	04/96 RFO	Bobbin	ADI		1.34 015 -1.19	UTE
64	129	04/96 RFO	Bobbin	NQI		0.56 015 +0.08	LTE
65	4	04/96 RFO	Bobbin	NQI		0.42 011 +5.18	014
65	33	04/96 RFO	Bobbin	NQI		0.64 013 +14.73 to +22.92	LTE
65	39	04/96 RFO	Bobbin	NQI		0.13 008 +0.10	LTE
65	62	04/96 RFO	Bobbin	NQI		0.46 011 +25.73	UTE
65	68	04/96 RFO	Bobbin	NQI		0.24 005 +0.22	UTE
65	84	04/96 RFO	Bobbin	NQI		0.44 007 +26.75	UTE
65	96	04/96 RFO	Bobbin	ODI	33	0.59 006 -0.35	LTE
65	125	04/96 RFO	Bobbin	NQI		0.45 009 +23.29	LTE
65	126	04/96 RFO	Bobbin	NQI		0.66 009 +24.83	LTE
		04/96 RFO	Bobbin	ODI	6	0.77 009 +22.06	LTE
		04/96 RFO	Bobbin	ODI	8	0.73 009 +23.63	LTE
65	128	04/96 RFO	Bobbin	ODI	31	0.78 010 +0.73	LTE
65	129	04/96 RFO	Bobbin	ODI	8	0.33 010 +11.60	LTE
65	130	04/96 RFO	Bobbin	NQI		0.76 015 -0.33	LTE
66	4	04/96 RFO	Bobbin	NQI		0.32 012 +15.41 to +30.99	014
66	17	04/96 RFO	Bobbin	ODI	29	0.39 010 +0.47	LTE
66	19	04/96 RFO	Bobbin	NQI		0.17 010 +0.16	LTE
66	25	04/96 RFO	Bobbin	NQI		0.68 015 +14.52	LTE
		04/96 RFO	Bobbin	NQI		1.84 014 +2.41 to +30.71	LTE
66	56	04/96 RFO	Bobbin	ODI	18	0.96 006 +0.67	UTE
66	57	04/96 RFO	Bobbin	ODI	36	1.17 006 +0.65	UTE
66	75	04/96 RFO	Bobbin	NQI		0.32 004 +23.13	LTE
66	79	04/96 RFO	Bobbin	NQI		0.22 006 -0.35	UTE
66	94	04/96 RFO	Bobbin	NQI		0.28 006 -0.26	LTE
66	125	04/96 RFO	Bobbin	NQI		0.63 009 -0.70	LTE
66	126	04/96 RFO	Bobbin	NQI		0.86 009 -0.57	LTE
66	127	04/96 RFO	Bobbin	NQI		0.30 009 +29.58	LTE
		04/96 RFO	Bobbin	NQI		0.30 009 -0.74	LTE
		04/96 RFO	Bobbin	ODI	22	0.31 009 +24.11	LTE
		04/96 RFO	Bobbin	ODI	36	0.45 009 +27.53	LTE
66	128	04/96 RFO	Bobbin	NQI		0.47 009 +29.00	LTE
		04/96 RFO	Bobbin	NQI		0.49 009 +34.20	LTE
		04/96 RFO	Bobbin	NQI		0.51 009 +29.98	LTE
		04/96 RFO	Bobbin	ODI	9	1.50 009 -0.63	LTE
66	130	04/96 RFO	Bobbin	NQI		0.37 010 +18.28	LTE
		04/96 RFO	Bobbin	NQI		0.67 009 -0.67	LTE

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
67	44	04/96 RFO	Bobbin	NQI		0.83	011	+4.90
67	70	04/96 RFO	Bobbin	NQI		0.44	012	+20.03
67	75	04/96 RFO	Bobbin	ODI	20	0.30	015	+41.91
67	109	04/96 RFO	Bobbin	NQI		0.17	013	+0.08
		04/96 RFO	Bobbin	NQI		0.27	LTS	-0.48
67	111	04/96 RFO	Bobbin	ODI	25	0.85	015	-0.31
67	112	04/96 RFO	Bobbin	NQI		0.91	015	+0.16
67	113	04/96 RFO	Bobbin	ODI	18	1.17	015	-0.18
		04/96 RFO	Bobbin	ODI	57	0.45	010	+6.08
		04/96 RFO	Bobbin	ODI	61	0.47	010	+6.99
67	123	04/96 RFO	Bobbin	ODI	25	0.52	008	+0.47
67	126	04/96 RFO	Bobbin	NQI		0.71	015	+0.18
		04/96 RFO	Bobbin	ODI	26	0.40	009	+24.90
67	127	04/96 RFO	Bobbin	NQI		0.48	009	+25.55
67	128	04/96 RFO	Bobbin	NQI		0.77	009	+32.47
		04/96 RFO	Bobbin	NQI		0.94	009	+29.76
67	130	04/96 RFO	Bobbin	NQI		0.40	011	+0.08
68	7	04/96 RFO	Bobbin	ODI	7	0.28	006	+29.35
68	39	04/96 RFO	Bobbin	NQI		0.85	014	+23.44 to +31.66
68	64	04/96 RFO	Bobbin	ODI	11	0.41	007	+0.50
68	68	04/96 RFO	Bobbin	NQI		0.15	011	+0.03
68	85	04/96 RFO	Bobbin	NQI		0.13	006	-0.02
68	126	04/96 RFO	Bobbin	NQI		0.23	009	-0.32
		04/96 RFO	Bobbin	NQI		0.58	008	+0.62
68	127	04/96 RFO	Bobbin	ODI	3	0.58	009	-0.47
		04/96 RFO	Bobbin	ODI	10	0.78	012	-0.10
68	128	04/96 RFO	Bobbin	ODI	20	0.58	009	+23.23
68	129	04/96 RFO	Bobbin	NQI		0.57	009	+32.09
68	130	04/96 RFO	Bobbin	NQI		1.23	015	-0.22
69	4	04/96 RFO	Bobbin	NQI		0.28	004	-0.77
69	40	04/96 RFO	Bobbin	NQI		0.53	013	+9.82
		04/96 RFO	Bobbin	NQI		0.72	014	+15.25
		04/96 RFO	Bobbin	ODI	69	0.50	015	+34.37
		04/96 RFO	Bobbin	NQI		0.50	015	+1.68 to +5.35
69	68	04/96 RFO	Bobbin	NQI		0.33	005	+0.44
69	69	04/96 RFO	Bobbin	NQI		0.16	007	+0.02
69	70	04/96 RFO	Bobbin	NQI		0.18	012	+0.23
69	74	04/96 RFO	Bobbin	ODI	24	0.50	005	+30.80
69	79	04/96 RFO	Bobbin	NQI		0.77	015	+36.29
69	84	04/96 RFO	Bobbin	NQI		0.40	006	-0.37
69	91	04/96 RFO	Bobbin	NQI		0.96	UTS	+0.33
69	99	04/96 RFO	Bobbin	NQI		0.27	006	-0.26
69	100	04/96 RFO	Bobbin	ODI	27	0.58	006	-0.38
69	108	04/96 RFO	Bobbin	NQI		0.27	007	-0.31
69	111	04/96 RFO	Bobbin	NQI		1.31	015	+0.08
		04/96 RFO	Bobbin	ODI	7	1.38	015	-0.38
69	112	04/96 RFO	Bobbin	NQI		0.62	015	-0.18
69	117	04/96 RFO	Bobbin	NQI		0.29	007	+0.41
69	128	04/96 RFO	Bobbin	ODI	30	0.65	009	+20.43
69	129	04/96 RFO	Bobbin	NQI		0.63	009	+24.28 to +30.44
69	130	04/96 RFO	Bobbin	NQI		0.63	LTS	-0.33
69	131	04/96 RFO	Bobbin	NQI		0.25	015	+0.02
70	1	04/96 RFO	Bobbin	NQI		0.36	011	+5.52
		04/96 RFO	Bobbin	ODI	22	0.45	011	+5.20
70	43	04/96 RFO	Bobbin	NQI		0.54	002	-0.67
70	48	04/96 RFO	Bobbin	NQI		0.38	015	+38.19 to +40.86
70	55	04/96 RFO	Bobbin	ODI	20	0.45	014	+28.19
		04/96 RFO	Bobbin	ODI	29	0.41	014	+28.47
		04/96 RFO	Bobbin	ODI	45	0.78	014	+29.56
70	64	04/96 RFO	Bobbin	ODI	21	0.57	009	-0.71
70	70	04/96 RFO	Bobbin	ADI		1.21	014	+12.89
70	73	04/96 RFO	Bobbin	NQI		0.51	013	+15.30
70	82	04/96 RFO	Bobbin	ODI	11	0.57	LTS	-0.99
70	91	04/96 RFO	Bobbin	ODI	18	0.14	006	-0.28
70	93	04/96 RFO	Bobbin	NQI		0.27	006	-0.44

FTI TUBAN II (Version 2.3) 05/14/1996 08:57:11
Oconee Nuclear Station - Unit Two
S/G A
04/96 RFO
Bobbin

Page 15 of 34

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
70	99	04/96 RFO	Bobbin	NQI		0.25 004	+9.59	LTE
70	100	04/96 RFO	Bobbin	NQI		0.42 006	-0.41	LTE
70	110	04/96 RFO	Bobbin	ODI	7	0.88 015	-0.36	LTE
70	111	04/96 RFO	Bobbin	NQI		0.76 015	-0.33	LTE
70	112	04/96 RFO	Bobbin	NQI		1.01 015	+0.05	LTE
70	113	04/96 RFO	Bobbin	NQI		0.24 007	+0.05	LTE
70	114	04/96 RFO	Bobbin	ADI		2.81 015	+24.41	LTE
70	120	04/96 RFO	Bobbin	ODI	6	0.68 007	+0.61	LTE
70	121	04/96 RFO	Bobbin	NQI		0.39 006	+33.40	LTE
		04/96 RFO	Bobbin	NQI		0.40 006	+35.15	LTE
70	123	04/96 RFO	Bobbin	NQI		0.31 006	+34.78	LTE
		04/96 RFO	Bobbin	NQI		0.35 006	+35.56	LTE
70	124	04/96 RFO	Bobbin	ADI		3.42 015	+10.86	LTE
70	126	04/96 RFO	Bobbin	NQI		0.62 008	+0.80	LTE
		04/96 RFO	Bobbin	NQI		0.87 015	+0.45	LTE
70	129	04/96 RFO	Bobbin	NQI		0.51 009	+25.94	LTE
		04/96 RFO	Bobbin	NQI		0.51 009	+29.61	LTE
		04/96 RFO	Bobbin	ODI	33	0.47 009	+25.43	LTE
70	130	04/96 RFO	Bobbin	NQI		0.36 011	-0.41	LTE
70	131	04/96 RFO	Bobbin	NQI		0.41 015	-0.28	LTE
71	1	04/96 RFO	Bobbin	ODI	15	0.51 012	+4.23	014
71	53	04/96 RFO	Bobbin	NQI		0.52 008	-0.73	LTE
		04/96 RFO	Bobbin	NQI		0.58 007	+0.57	LTE
71	82	04/96 RFO	Bobbin	ADI		1.65 008	+17.18	LTE
71	96	04/96 RFO	Bobbin	ODI	17	0.18 006	-0.26	LTE
71	110	04/96 RFO	Bobbin	ODI	25	0.68 015	-0.34	LTE
71	123	04/96 RFO	Bobbin	NQI		0.47 006	+35.06	LTE
71	124	04/96 RFO	Bobbin	ADI		2.31 010	+9.83	LTE
71	128	04/96 RFO	Bobbin	NQI		0.45 014	+0.41	LTE
		04/96 RFO	Bobbin	NQI		0.58 014	+0.43	LTE
		04/96 RFO	Bobbin	NQI		0.59 009	+18.77	LTE
		04/96 RFO	Bobbin	ODI	24	0.57 009	+28.44	LTE
		04/96 RFO	Bobbin	ODI	33	0.45 010	+22.70	LTE
		04/96 RFO	Bobbin	ODI	38	0.64 014	-1.20	LTE
		04/96 RFO	Bobbin	ODI	42	0.57 010	+14.73	LTE
		04/96 RFO	Bobbin	ODI	55	0.72 015	-0.13	LTE
		04/96 RFO	Bobbin	ODI	88	1.56 015	+0.41	LTE
		04/96 RFO	Bobbin	NQI		0.48 012	+1.35 to +33.02	LTE
		04/96 RFO	Bobbin	NQI		0.50 011	+14.75 to +35.52	LTE
		04/96 RFO	Bobbin	NQI		0.52 014	+1.05 to +28.50	LTE
		04/96 RFO	Bobbin	NQI		0.64 013	+3.87 to +34.63	LTE
		04/96 RFO	Bobbin	NQI		0.75 010	+0.60	LTE
71	130	04/96 RFO	Bobbin	NQI		0.29 010	-0.55	014
72	10	04/96 RFO	Bobbin	NQI		0.58 009	-0.62	LTE
72	53	04/96 RFO	Bobbin	NQI		0.75 005	+0.72	LTE
		04/96 RFO	Bobbin	NQI		0.54 008	-0.72	LTE
72	55	04/96 RFO	Bobbin	NQI		0.28 008	+0.34	LTE
72	56	04/96 RFO	Bobbin	NQI		0.37 006	+0.70	LTE
		04/96 RFO	Bobbin	NQI		0.68 005	+0.69	LTE
72	64	04/96 RFO	Bobbin	NQI		0.65 002	+37.42	LTE
72	65	04/96 RFO	Bobbin	ODI	11	0.87 LTS	+1.78	LTE
72	66	04/96 RFO	Bobbin	ADI		2.85 LTS	+1.51	LTE
72	81	04/96 RFO	Bobbin	ADI		1.41 001	+20.47	LTE
72	99	04/96 RFO	Bobbin	NQI		0.18 006	-0.10	LTE
72	110	04/96 RFO	Bobbin	ODI	41	0.41 011	+25.19	LTE
72	125	04/96 RFO	Bobbin	NQI		0.44 006	+0.46	LTE
72	130	04/96 RFO	Bobbin	NQI		0.45 015	-0.41	LTE
73	10	04/96 RFO	Bobbin	ADI		0.95 010	+11.19	014
73	17	04/96 RFO	Bobbin	NQI		0.50 011	+0.00	UTE
		04/96 RFO	Bobbin	NQI		0.59 015	+14.92	UTE
		04/96 RFO	Bobbin	NQI		0.59 015	+44.07	UTE
73	21	04/96 RFO	Bobbin	NQI		0.79 015	+8.16 to +40.67	LTE
73	49	04/96 RFO	Bobbin	NQI		0.55 005	+0.75	LTE
73	57	04/96 RFO	Bobbin	NQI		0.56 009	-0.62	LTE
73	59	04/96 RFO	Bobbin	NQI		0.64 007	-0.67	LTE
		04/96 RFO	Bobbin					

FTI TUBAN II (Version 2.3) 05/14/1996 08:57:11
 Oconee Nuclear Station - Unit Two
 S/G A
 04/96 RFO
 Bobbin

Page 16 of 34

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
73	65	04/96 RFO	Bobbin	ODI	11	2.60	LTS	+1.90
73	66	04/96 RFO	Bobbin	ODI	11	2.26	LTS	+1.89
73	67	04/96 RFO	Bobbin	NQI		1.59	LTS	+1.85
73	77	04/96 RFO	Bobbin	NQI		0.46	015	+11.44 to +46.18
73	109	04/96 RFO	Bobbin	ODI	39	0.48	015	-0.31
73	127	04/96 RFO	Bobbin	NQI		0.95	015	+0.45
		04/96 RFO	Bobbin	ODI	36	0.74	012	+24.70
		04/96 RFO	Bobbin	NQI		0.50	011	+15.80 to +36.38
		04/96 RFO	Bobbin	NQI		0.54	010	+0.27 to +30.18
		04/96 RFO	Bobbin	NQI		0.71	013	+4.74 to +33.70
		04/96 RFO	Bobbin	NQI		1.56	014	+2.98 to +28.55
73	129	04/96 RFO	Bobbin	NQI		1.33	010	+0.68
74	1	04/96 RFO	Bobbin	ODI	17	0.27	012	+13.20
74	44	04/96 RFO	Bobbin	ODI	2	0.51	015	+15.70
74	62	04/96 RFO	Bobbin	NQI		0.68	LTS	+1.85
74	63	04/96 RFO	Bobbin	NQI		1.81	LTS	+1.83
74	80	04/96 RFO	Bobbin	ODI	13	1.03	006	-0.47
74	102	04/96 RFO	Bobbin	NQI		1.53	015	-0.42
74	103	04/96 RFO	Bobbin	NQI		1.65	015	+0.16
		04/96 RFO	Bobbin	ODI	30	1.26	015	-0.26
74	104	04/96 RFO	Bobbin	NQI		2.19	015	-0.26
74	124	04/96 RFO	Bobbin	ODI	31	0.46	013	+4.02
		04/96 RFO	Bobbin	NQI		0.42	010	+12.73 to +26.24
		04/96 RFO	Bobbin	NQI		0.58	012	+3.18 to +36.09
		04/96 RFO	Bobbin	NQI		0.66	014	+5.83 to +33.54
74	125	04/96 RFO	Bobbin	ODI	23	1.30	010	+0.62
75	1	04/96 RFO	Bobbin	ODI	17	0.40	LTS	+8.64
		04/96 RFO	Bobbin	ODI	17	0.52	LTS	+11.71
75	3	04/96 RFO	Bobbin	ODI	12	0.41	LTS	+1.99
75	13	04/96 RFO	Bobbin	ODI	34	0.47	LTS	+1.99
75	14	04/96 RFO	Bobbin	ODI	7	0.47	LTS	+1.88
75	16	04/96 RFO	Bobbin	NQI		0.38	LTS	+1.88
75	21	04/96 RFO	Bobbin	ODI	7	0.55	LTS	+1.94
75	22	04/96 RFO	Bobbin	NQI		0.73	LTS	+1.95
75	23	04/96 RFO	Bobbin	ODI	28	0.57	LTS	+2.02
75	26	04/96 RFO	Bobbin	NQI		0.38	LTS	+1.85
75	27	04/96 RFO	Bobbin	NQI		0.48	LTS	+2.02
75	36	04/96 RFO	Bobbin	NQI		0.55	LTS	+2.05
75	37	04/96 RFO	Bobbin	ODI	20	0.64	LTS	+1.97
75	41	04/96 RFO	Bobbin	ODI	26	0.50	LTS	+1.89
75	42	04/96 RFO	Bobbin	NQI		0.73	LTS	+1.81
75	50	04/96 RFO	Bobbin	NQI		1.01	LTS	+1.87
75	51	04/96 RFO	Bobbin	ODI	11	0.90	LTS	+1.93
75	52	04/96 RFO	Bobbin	ODI	33	0.88	LTS	+1.95
75	54	04/96 RFO	Bobbin	NQI		0.88	LTS	+1.95
75	56	04/96 RFO	Bobbin	NQI		0.87	LTS	+1.92
75	59	04/96 RFO	Bobbin	NQI		0.80	LTS	+1.91
75	62	04/96 RFO	Bobbin	NQI		0.85	LTS	+1.85
75	63	04/96 RFO	Bobbin	NQI		1.34	LTS	+1.85
75	80	04/96 RFO	Bobbin	NQI		0.53	015	+40.14
75	102	04/96 RFO	Bobbin	ODI	20	1.25	015	-0.43
75	111	04/96 RFO	Bobbin	NQI		0.21	012	+0.46
75	123	04/96 RFO	Bobbin	NQI		1.05	015	-0.13
		04/96 RFO	Bobbin	NQI		1.59	015	+0.48
		04/96 RFO	Bobbin	NQI		0.25	011	+3.42 to +33.72
		04/96 RFO	Bobbin	NQI		0.48	013	+5.14 to +33.23
		04/96 RFO	Bobbin	NQI		0.84	014	+4.10 to +32.51
		04/96 RFO	Bobbin	NQI		1.48	010	+6.10 to +34.50
75	124	04/96 RFO	Bobbin	NQI		0.41	011	+4.64 to +37.01
		04/96 RFO	Bobbin	NQI		0.43	010	+16.84 to +33.63
		04/96 RFO	Bobbin	NQI		0.69	012	+1.21 to +34.69
		04/96 RFO	Bobbin	NQI		0.77	013	+4.25 to +33.15
75	125	04/96 RFO	Bobbin	NQI		0.76	015	+1.77 to +19.69
76	66	04/96 RFO	Bobbin	NQI		1.09	015	+25.49
76	85	04/96 RFO	Bobbin	NQI		0.48	006	-0.23

FTI TUBAN II (Version 2.3) 05/14/1996 08:57:11
 Oconee Nuclear Station - Unit Two
 S/G A
 04/96 RFO
 Bobbin

Page 17 of 34

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
76	121	04/96 RFO	Bobbin	NQI		0.55	014	LTE
		04/96 RFO	Bobbin	NQI		0.65	014	LTE
		04/96 RFO	Bobbin	NQI		0.61	012	LTE
		04/96 RFO	Bobbin	NQI		0.88	011	LTE
76	123	04/96 RFO	Bobbin	WAR	27	0.59	011	LTE
77	5	04/96 RFO	Bobbin	ODI	15	1.42	LTS	014
77	7	04/96 RFO	Bobbin	ODI	22	1.00	LTS	014
77	9	04/96 RFO	Bobbin	NQI		0.54	LTS	014
77	13	04/96 RFO	Bobbin	ODI	32	0.43	LTS	014
77	14	04/96 RFO	Bobbin	NQI		0.70	LTS	014
77	15	04/96 RFO	Bobbin	NQI		0.88	LTS	014
77	17	04/96 RFO	Bobbin	NQI		0.35	LTS	014
		04/96 RFO	Bobbin	NQI		0.56	LTS	014
77	19	04/96 RFO	Bobbin	NQI		0.89	LTS	014
77	20	04/96 RFO	Bobbin	ODI	8	1.09	LTS	014
77	22	04/96 RFO	Bobbin	ODI	38	1.05	LTS	014
77	24	04/96 RFO	Bobbin	NQI		0.37	LTS	014
77	27	04/96 RFO	Bobbin	NQI		0.37	014	014
		04/96 RFO	Bobbin	NQI		0.64	LTS	014
77	28	04/96 RFO	Bobbin	NQI		0.51	LTS	014
77	36	04/96 RFO	Bobbin	NQI		0.57	LTS	014
77	38	04/96 RFO	Bobbin	NQI		0.44	LTS	014
77	39	04/96 RFO	Bobbin	NQI		0.70	LTS	014
77	42	04/96 RFO	Bobbin	NQI		0.56	011	UTE
		04/96 RFO	Bobbin	NQI		0.76	LTS	UTE
77	49	04/96 RFO	Bobbin	ODI	23	0.83	LTS	FL
77	50	04/96 RFO	Bobbin	ODI	6	1.05	LTS	UTE
77	51	04/96 RFO	Bobbin	NQI		1.06	LTS	FL
77	52	04/96 RFO	Bobbin	ODI	54	1.10	LTS	UTE
77	53	04/96 RFO	Bobbin	NQI		1.00	LTS	FL
77	55	04/96 RFO	Bobbin	NQI		0.86	LTS	FL
77	57	04/96 RFO	Bobbin	ODI	22	0.98	LTS	FL
77	58	04/96 RFO	Bobbin	ODI	12	0.86	LTS	UTE
77	59	04/96 RFO	Bobbin	NQI		0.96	LTS	FL
77	61	04/96 RFO	Bobbin	ODI	28	1.05	LTS	FL
77	62	04/96 RFO	Bobbin	ODI	2	0.92	LTS	LTE
77	63	04/96 RFO	Bobbin	NQI		1.29	LTS	LTE
77	67	04/96 RFO	Bobbin	NQI		0.52	008	LTE
77	86	04/96 RFO	Bobbin	ODI	13	0.56	006	LTE
77	90	04/96 RFO	Bobbin	NQI		0.31	006	LTE
77	94	04/96 RFO	Bobbin	NQI		0.56	015	LTE
77	115	04/96 RFO	Bobbin	NQI		0.55	007	LTE
77	123	04/96 RFO	Bobbin	NQI		0.56	012	LTE
77	125	04/96 RFO	Bobbin	NQI		0.41	010	LTE
		04/96 RFO	Bobbin	ODI	23	0.53	012	LTE
78	26	04/96 RFO	Bobbin	NQI		0.34	010	014
78	34	04/96 RFO	Bobbin	NQI		0.96	010	014
78	37	04/96 RFO	Bobbin	ODI	35	0.60	010	014
78	39	04/96 RFO	Bobbin	ODI	15	0.86	010	FL
78	41	04/96 RFO	Bobbin	ODI	4	0.95	010	FL
78	45	04/96 RFO	Bobbin	NQI		0.48	010	FL
78	47	04/96 RFO	Bobbin	NQI		0.73	010	FL
78	64	04/96 RFO	Bobbin	DWI		2.47	011	LTE
		04/96 RFO	Bobbin	NQI		0.57	LTS	LTE
		04/96 RFO	Bobbin	NQI		0.58	015	LTE
78	67	04/96 RFO	Bobbin	NQI		0.56	015	LTE
		04/96 RFO	Bobbin	ODI	38	0.64	015	LTE
78	91	04/96 RFO	Bobbin	NQI		0.38	006	LTE
78	105	04/96 RFO	Bobbin	ODI	25	1.66	015	LTE
78	115	04/96 RFO	Bobbin	ODI	18	0.46	007	LTE
78	123	04/96 RFO	Bobbin	NQI		0.34	010	LTE
		04/96 RFO	Bobbin	NQI		0.51	014	LTE
		04/96 RFO	Bobbin	NQI		0.64	013	LTE
78	125	04/96 RFO	Bobbin	NQI		0.36	012	LTE
		04/96 RFO	Bobbin	NQI		0.50	010	LTE

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	NQI		1.00 011	+7.59 to +35.37	LTE
79	2	04/96 RFO	Bobbin	NQI		0.46 005	-0.66	014
79	3	04/96 RFO	Bobbin	ODI	39	0.44 005	+16.61	014
79	27	04/96 RFO	Bobbin	ODI	88	0.75 014	+4.99	LTE
		04/96 RFO	Bobbin	NQI		0.77 014	+23.32 to +33.43	LTE
		04/96 RFO	Bobbin	ODI	27	0.41 015	+22.22 to +32.10	LTE
79	32	04/96 RFO	Bobbin	NQI		0.61 010	+0.52	LTE
79	48	04/96 RFO	Bobbin	ODI	29	0.45 008	+6.62	UTE
79	49	04/96 RFO	Bobbin	NQI		1.36 014	+30.14	FL
79	51	04/96 RFO	Bobbin	ODI	18	0.54 010	+0.55	FL
79	59	04/96 RFO	Bobbin	NQI		0.61 007	-0.72	FL
79	64	04/96 RFO	Bobbin	ODI	14	1.19 LTS	+1.68	LTE
79	65	04/96 RFO	Bobbin	ODI	28	1.96 LTS	+1.78	LTE
79	66	04/96 RFO	Bobbin	ODI	22	1.54 LTS	+1.98	LTE
79	67	04/96 RFO	Bobbin	ODI	12	1.01 LTS	+1.75	LTE
79	78	04/96 RFO	Bobbin	NQI		0.39 014	+20.97	LTE
		04/96 RFO	Bobbin	NQI		0.58 014	+32.60	LTE
		04/96 RFO	Bobbin	NQI		0.74 015	-0.21	LTE
		04/96 RFO	Bobbin	NQI		1.18 015	+14.65 to +38.74	LTE
79	126	04/96 RFO	Bobbin	NQI		0.51 014	+4.23 to +34.23	LTE
		04/96 RFO	Bobbin	NQI		0.60 011	+3.89 to +17.17	LTE
		04/96 RFO	Bobbin	NQI		0.66 010	+7.99 to +34.98	LTE
79	127	04/96 RFO	Bobbin	NQI		0.34 011	+9.48 to +30.63	LTE
		04/96 RFO	Bobbin	NQI		0.38 010	+4.31 to +32.69	LTE
		04/96 RFO	Bobbin	NQI		0.79 012	+17.63 to +35.01	LTE
79	128	04/96 RFO	Bobbin	DWI		9.72 010	+18.69	LTE
		04/96 RFO	Bobbin	NQI		0.49 015	+4.33 to +19.59	LTE
		04/96 RFO	Bobbin	NQI		0.76 012	+8.27 to +26.26	LTE
79	129	04/96 RFO	Bobbin	NQI		0.47 010	+11.52	LTE
80	1	04/96 RFO	Bobbin	ODI	17	0.30 013	+5.39	014
80	2	04/96 RFO	Bobbin	ODI	7	0.38 002	+7.62	014
80	5	04/96 RFO	Bobbin	NQI		0.66 011	-0.78	014
80	8	04/96 RFO	Bobbin	NQI		0.55 010	+0.55	014
80	12	04/96 RFO	Bobbin	ODI	11	0.65 010	+0.56	LTE
80	13	04/96 RFO	Bobbin	NQI		0.52 008	-0.35	LTE
		04/96 RFO	Bobbin	ODI	1	1.09 010	+0.57	LTE
80	14	04/96 RFO	Bobbin	ODI	8	0.54 010	+0.64	LTE
80	15	04/96 RFO	Bobbin	ODI	1	0.53 010	+0.64	LTE
80	20	04/96 RFO	Bobbin	ODI	1	1.28 010	+0.57	LTE
80	21	04/96 RFO	Bobbin	NQI		0.80 010	+0.54	LTE
80	23	04/96 RFO	Bobbin	NQI		0.81 010	+0.66	LTE
80	24	04/96 RFO	Bobbin	ODI	8	0.59 010	+0.59	LTE
80	35	04/96 RFO	Bobbin	NQI		0.43 010	+0.62	LTE
80	66	04/96 RFO	Bobbin	NQI		0.62 LTS	+1.71	LTE
80	68	04/96 RFO	Bobbin	NQI		0.20 015	+32.51	LTE
		04/96 RFO	Bobbin	NQI		0.40 015	+31.66	LTE
		04/96 RFO	Bobbin	NQI		0.43 015	+33.75	LTE
		04/96 RFO	Bobbin	ODI	58	1.34 014	+32.63	LTE
80	92	04/96 RFO	Bobbin	NQI		0.29 006	-0.08	LTE
80	128	04/96 RFO	Bobbin	NQI		0.73 011	+32.05	LTE
		04/96 RFO	Bobbin	NQI		0.94 011	+31.13	LTE
		04/96 RFO	Bobbin	NQI		0.94 015	+0.26	LTE
		04/96 RFO	Bobbin	ODI	18	0.63 011	+23.49	LTE
		04/96 RFO	Bobbin	ODI	34	0.60 010	+23.08	LTE
		04/96 RFO	Bobbin	ODI	38	0.83 011	+21.44	LTE
80	129	04/96 RFO	Bobbin	ODI	1	0.53 010	+0.44	LTE
		04/96 RFO	Bobbin	ODI	27	0.46 010	+9.15	LTE
80	131	04/96 RFO	Bobbin	NQI		0.51 010	+14.27	LTE
81	1	04/96 RFO	Bobbin	NQI		0.20 LTS	+2.52	014
		04/96 RFO	Bobbin	ODI	3	0.52 014	+1.36	014
		04/96 RFO	Bobbin	ODI	10	0.48 013	+4.58	014
81	3	04/96 RFO	Bobbin	ADI		1.53 001	+11.66	014
81	9	04/96 RFO	Bobbin	NQI		0.61 010	+0.55	014
81	37	04/96 RFO	Bobbin	NQI		0.42 015	+23.80	LTE
81	53	04/96 RFO	Bobbin	NQI		0.66 005	+0.75	LTE

FTI TUBAN II (Version 2.3) 05/14/1996 08:57:11
 Oconee Nuclear Station - Unit Two
 S/G A
 04/96 RFO
 Bobbin

Page 19 of 34

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
81	64	04/96 RFO	Bobbin	ADI		1.87	012	+27.99
81	69	04/96 RFO	Bobbin	NQI		0.38	015	+27.76
81	70	04/96 RFO	Bobbin	NQI		0.22	008	+0.40
81	71	04/96 RFO	Bobbin	ADI		0.31	013	+28.99
81	91	04/96 RFO	Bobbin	ODI	30	0.53	006	-0.37
81	92	04/96 RFO	Bobbin	NQI		1.17	LTS	-1.69
81	98	04/96 RFO	Bobbin	NQI		0.68	006	-0.55
81	109	04/96 RFO	Bobbin	ODI	12	1.81	015	-0.34
81	123	04/96 RFO	Bobbin	NQI		0.52	004	+2.62
81	129	04/96 RFO	Bobbin	ODI	39	0.44	001	+31.76
81	131	04/96 RFO	Bobbin	ODI	25	0.73	013	-0.84
82	3	04/96 RFO	Bobbin	ODI	14	1.14	011	-0.85
82	4	04/96 RFO	Bobbin	NQI		0.38	009	+38.46
		04/96 RFO	Bobbin	NQI		0.43	009	+23.63
82	5	04/96 RFO	Bobbin	NQI		0.52	011	-0.72
82	13	04/96 RFO	Bobbin	NQI		0.49	015	+23.52
		04/96 RFO	Bobbin	NQI		0.89	014	+19.93
		04/96 RFO	Bobbin	ODI	13	0.78	015	+2.82
		04/96 RFO	Bobbin	ODI	27	1.17	014	+16.38
		04/96 RFO	Bobbin	ODI	29	0.49	015	+12.73
		04/96 RFO	Bobbin	ODI	33	0.51	014	+17.18
		04/96 RFO	Bobbin	ODI	61	0.83	014	+22.76
82	25	04/96 RFO	Bobbin	NQI		0.44	015	+25.55
		04/96 RFO	Bobbin	NQI		0.45	001	+35.30
		04/96 RFO	Bobbin	NQI		0.48	014	+30.56
		04/96 RFO	Bobbin	ODI	29	0.40	008	+34.93
82	48	04/96 RFO	Bobbin	NQI		0.29	006	-0.36
82	77	04/96 RFO	Bobbin	NQI		1.32	007	+0.99
82	109	04/96 RFO	Bobbin	ODI	30	0.95	015	-0.21
82	110	04/96 RFO	Bobbin	NQI		1.95	015	-0.42
82	111	04/96 RFO	Bobbin	ODI	12	1.32	015	-0.34
82	126	04/96 RFO	Bobbin	NQI		0.48	013	+28.72
		04/96 RFO	Bobbin	ODI	5	0.67	011	+5.73
		04/96 RFO	Bobbin	ODI	22	0.58	012	-1.47
83	3	04/96 RFO	Bobbin	ODI	23	0.75	LTS	+14.92
83	7	04/96 RFO	Bobbin	NQI		0.21	008	+0.11
		04/96 RFO	Bobbin	ODI	20	0.19	008	-0.42
83	27	04/96 RFO	Bobbin	NQI		0.74	014	+2.29 to +25.60
		04/96 RFO	Bobbin	NQI		0.90	015	+4.07 to +44.12
83	61	04/96 RFO	Bobbin	NQI		0.63	015	+44.62
83	89	04/96 RFO	Bobbin	ODI	20	0.54	006	-0.29
83	112	04/96 RFO	Bobbin	ODI	8	1.09	015	-0.42
83	113	04/96 RFO	Bobbin	ODI	23	1.74	015	-0.40
83	126	04/96 RFO	Bobbin	NQI		0.42	011	+7.25
		04/96 RFO	Bobbin	NQI		0.48	009	+28.92
		04/96 RFO	Bobbin	NQI		0.51	010	+23.13
		04/96 RFO	Bobbin	NQI		0.57	012	+13.46
		04/96 RFO	Bobbin	ODI	16	0.50	012	+15.31
		04/96 RFO	Bobbin	ODI	26	0.73	012	+8.32
		04/96 RFO	Bobbin	ODI	40	0.60	009	+34.46
83	128	04/96 RFO	Bobbin	NQI		0.37	010	+34.13
		04/96 RFO	Bobbin	NQI		0.79	011	+34.47
		04/96 RFO	Bobbin	ODI	20	0.76	009	+36.57
		04/96 RFO	Bobbin	ODI	33	0.55	009	+34.11
		04/96 RFO	Bobbin	ODI	40	1.19	012	+20.24
84	3	04/96 RFO	Bobbin	ODI	21	0.32	009	+31.39
84	5	04/96 RFO	Bobbin	NQI		0.55	011	-0.66
84	6	04/96 RFO	Bobbin	NQI		0.49	011	-0.72
84	27	04/96 RFO	Bobbin	NQI		2.21	013	+22.73
84	73	04/96 RFO	Bobbin	NQI		0.46	012	+0.00 to +37.00
		04/96 RFO	Bobbin	NQI		0.54	014	+0.00 to +35.00
		04/96 RFO	Bobbin	NQI		0.60	013	+0.00 to +36.00
		04/96 RFO	Bobbin	NQI		0.74	015	+0.00 to +46.37
84	75	04/96 RFO	Bobbin	ODI	33	0.49	007	+18.03
84	100	04/96 RFO	Bobbin	ADI		2.41	010	+29.07

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
84	113	04/96 RFO	Bobbin	ODI	33	1.09	015	-0.21
85	2	04/96 RFO	Bobbin	ODI	29	0.50	009	+35.65
85	20	04/96 RFO	Bobbin	ODI	2	0.76	015	+25.68
		04/96 RFO	Bobbin	ODI	40	0.50	011	+17.40
		04/96 RFO	Bobbin	ODI	50	0.60	011	+17.15
85	28	04/96 RFO	Bobbin	NQI		0.39	014	+0.30
		04/96 RFO	Bobbin	NQI		0.41	015	+27.65
		04/96 RFO	Bobbin	ODI	4	0.36	015	+35.25
		04/96 RFO	Bobbin	ODI	18	0.58	015	+33.43
		04/96 RFO	Bobbin	ODI	22	0.92	014	+7.74
		04/96 RFO	Bobbin	ODI	22	1.10	013	+32.92
		04/96 RFO	Bobbin	ODI	26	0.54	015	+38.99
		04/96 RFO	Bobbin	ODI	30	0.71	014	+18.06
		04/96 RFO	Bobbin	ODI	35	0.51	015	+30.33
		04/96 RFO	Bobbin	ODI	42	0.78	015	+36.91
		04/96 RFO	Bobbin	ODI	51	0.33	015	+30.64
		04/96 RFO	Bobbin	ODI	52	0.36	015	+35.78
		04/96 RFO	Bobbin	ODI	67	0.28	014	-1.23
85	64	04/96 RFO	Bobbin	ADI		2.69	013	+8.64
85	65	04/96 RFO	Bobbin	ADI		1.07	012	+21.61
85	70	04/96 RFO	Bobbin	NQI		0.61	015	-0.51
		04/96 RFO	Bobbin	NQI		0.71	015	+38.60 to +43.11
85	88	04/96 RFO	Bobbin	NQI		0.26	006	-0.43
85	97	04/96 RFO	Bobbin	ODI	18	0.38	006	-0.22
85	99	04/96 RFO	Bobbin	ODI	16	0.35	005	+32.03
85	126	04/96 RFO	Bobbin	NQI		0.55	014	+16.63
		04/96 RFO	Bobbin	ODI	6	0.56	013	+17.27
		04/96 RFO	Bobbin	ODI	14	0.35	013	+14.35
85	130	04/96 RFO	Bobbin	ODI	12	0.57	008	+28.49
86	4	04/96 RFO	Bobbin	NQI		0.47	011	-0.72
		04/96 RFO	Bobbin	NQI		0.49	011	+0.58
86	50	04/96 RFO	Bobbin	ODI	2	1.98	007	+10.76
86	70	04/96 RFO	Bobbin	NQI		0.41	015	+39.33
86	78	04/96 RFO	Bobbin	NQI		0.44	008	+24.62
		04/96 RFO	Bobbin	NQI		0.70	003	+20.46
86	91	04/96 RFO	Bobbin	ODI	15	0.21	005	-0.29
86	118	04/96 RFO	Bobbin	ODI	14	0.46	006	+36.07
		04/96 RFO	Bobbin	ODI	33	0.31	006	+34.99
86	126	04/96 RFO	Bobbin	ODI	37	1.13	015	+0.29
86	130	04/96 RFO	Bobbin	NQI		0.38	010	+0.37
		04/96 RFO	Bobbin	ODI	34	2.28	008	+30.07
87	8	04/96 RFO	Bobbin	NQI		0.26	006	+36.70
		04/96 RFO	Bobbin	NQI		0.61	006	+35.95
87	30	04/96 RFO	Bobbin	ODI	25	0.25	010	+0.14
87	88	04/96 RFO	Bobbin	NQI		0.31	005	+30.12
87	100	04/96 RFO	Bobbin	NQI		0.41	004	+34.98
87	105	04/96 RFO	Bobbin	ODI	15	0.19	007	+0.13
87	110	04/96 RFO	Bobbin	ADI		2.60	011	+23.71
87	123	04/96 RFO	Bobbin	NQI		0.14	009	+34.04
		04/96 RFO	Bobbin	NQI		0.31	009	+35.47
		04/96 RFO	Bobbin	ODI	10	0.17	009	+33.05
87	125	04/96 RFO	Bobbin	NQI		0.27	012	+9.54
		04/96 RFO	Bobbin	ODI	39	0.43	012	+5.96
		04/96 RFO	Bobbin	NQI		0.69	011	+29.26 to +36.31
88	7	04/96 RFO	Bobbin	WAR	35	1.09	011	-0.64
88	22	04/96 RFO	Bobbin	NQI		0.41	013	+3.97
		04/96 RFO	Bobbin	NQI		0.83	013	+9.56
		04/96 RFO	Bobbin	ODI	20	0.52	013	+3.33
88	27	04/96 RFO	Bobbin	NQI		0.48	014	+15.88
		04/96 RFO	Bobbin	NQI		0.76	015	-0.22
		04/96 RFO	Bobbin	ODI	27	0.36	015	+0.17
88	28	04/96 RFO	Bobbin	ODI	20	1.22	LTS	-0.34
88	43	04/96 RFO	Bobbin	ODI	23	0.31	006	+11.92
88	68	04/96 RFO	Bobbin	ODI	16	0.57	002	+30.35
88	73	04/96 RFO	Bobbin	NQI		0.46	014	+9.78 to +20.74

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
88	93	04/96 RFO	Bobbin	ADI		0.89	014	+17.82
88	101	04/96 RFO	Bobbin	ODI	36	0.49	010	+17.38
88	117	04/96 RFO	Bobbin	NQI		0.48	007	-0.26
89	3	04/96 RFO	Bobbin	NQI		0.32	009	+22.58
89	27	04/96 RFO	Bobbin	ODI	20	1.05	015	+22.87
		04/96 RFO	Bobbin	ODI	24	0.82	015	+27.90
		04/96 RFO	Bobbin	ODI	77	0.39	015	+15.24
89	28	04/96 RFO	Bobbin	ODI	26	1.03	015	+37.24
		04/96 RFO	Bobbin	ODI	26	1.76	015	+38.78
89	57	04/96 RFO	Bobbin	NQI		1.09	005	+0.67
89	67	04/96 RFO	Bobbin	NQI		0.46	004	+6.26
89	72	04/96 RFO	Bobbin	NQI		0.90	015	+35.80
		04/96 RFO	Bobbin	ODI	16	0.72	015	+35.32
89	77	04/96 RFO	Bobbin	NQI		0.30	005	+26.83
89	79	04/96 RFO	Bobbin	NQI		0.58	003	+27.28
89	80	04/96 RFO	Bobbin	NQI		0.35	013	+21.26
89	83	04/96 RFO	Bobbin	ODI	31	1.12	LTE	+18.84
89	117	04/96 RFO	Bobbin	ODI	32	0.40	007	-0.26
90	6	04/96 RFO	Bobbin	ODI	26	1.28	011	-0.73
90	14	04/96 RFO	Bobbin	NQI		0.45	011	+15.62
90	17	04/96 RFO	Bobbin	ODI	18	0.35	015	-1.07
90	26	04/96 RFO	Bobbin	NQI		1.61	015	+6.42 to +41.98
90	28	04/96 RFO	Bobbin	ADI		2.91	012	+25.44
90	35	04/96 RFO	Bobbin	ODI	39	0.33	007	+12.75
90	56	04/96 RFO	Bobbin	ODI	36	0.54	006	-0.20
90	57	04/96 RFO	Bobbin	ODI	37	2.56	012	+23.08
90	68	04/96 RFO	Bobbin	DWI		0.77	002	+11.01
90	70	04/96 RFO	Bobbin	NQI		0.17	013	+20.64
		04/96 RFO	Bobbin	NQI		0.60	011	+6.64
		04/96 RFO	Bobbin	ODI	18	0.30	011	+6.19
90	75	04/96 RFO	Bobbin	NQI		0.83	UTS	+11.16
90	76	04/96 RFO	Bobbin	ODI	1	0.77	015	+25.67
		04/96 RFO	Bobbin	ODI	33	0.49	015	+31.83
90	87	04/96 RFO	Bobbin	ADI		3.38	013	+4.14
		04/96 RFO	Bobbin	DWI		0.59	015	+0.16
90	95	04/96 RFO	Bobbin	NQI		0.95	LTS	-0.27
91	19	04/96 RFO	Bobbin	ODI	40	1.15	015	+11.69
91	23	04/96 RFO	Bobbin	DWI		1.57	005	+14.08
91	48	04/96 RFO	Bobbin	NQI		0.60	012	+4.48
91	70	04/96 RFO	Bobbin	NQI		1.85	007	+5.33
91	120	04/96 RFO	Bobbin	ODI	31	2.24	003	+1.15
92	1	04/96 RFO	Bobbin	ODI	32	0.72	011	-0.76
92	15	04/96 RFO	Bobbin	ODI	18	0.45	010	+23.44
92	16	04/96 RFO	Bobbin	NQI		0.62	015	+36.32
		04/96 RFO	Bobbin	ODI	25	0.68	008	-0.47
92	40	04/96 RFO	Bobbin	ODI	9	0.17	015	-0.31
92	59	04/96 RFO	Bobbin	NQI		0.65	006	-0.42
92	70	04/96 RFO	Bobbin	ODI	18	1.04	010	+13.84
92	72	04/96 RFO	Bobbin	NQI		0.75	014	+15.86
93	19	04/96 RFO	Bobbin	NQI		0.28	007	+1.79
93	41	04/96 RFO	Bobbin	ODI	27	0.64	011	+14.12
		04/96 RFO	Bobbin	ODI	47	0.84	011	+16.62
93	69	04/96 RFO	Bobbin	ODI	50	0.79	011	+24.92
		04/96 RFO	Bobbin	ODI	70	0.51	011	+22.77
		04/96 RFO	Bobbin	NQI		0.72	012	+9.51 to +22.30
		04/96 RFO	Bobbin	NQI		1.20	015	+2.35 to +39.38
		04/96 RFO	Bobbin	NQI		1.23	014	+3.48 to +32.46
93	124	04/96 RFO	Bobbin	ODI	29	0.57	013	+22.38
94	15	04/96 RFO	Bobbin	NQI		0.79	014	+29.68
		04/96 RFO	Bobbin	NQI		0.57	013	+4.22 to +9.53
		04/96 RFO	Bobbin	NQI		0.61	012	+17.45 to +30.32
94	43	04/96 RFO	Bobbin	NQI		0.47	011	+24.32
		04/96 RFO	Bobbin	ODI	27	0.82	011	+11.81
		04/96 RFO	Bobbin	ODI	32	0.43	011	+15.53
		04/96 RFO	Bobbin	ODI	36	0.73	011	+8.70

FTI TUBAN II (Version 2.3) 05/14/1996 08:57:11
 Oconee Nuclear Station - Unit Two
 S/G A
 04/96 RFO
 Bobbin

Page 22 of 34

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
94	76	04/96 RFO	Bobbin	NQI		0.65	006	-0.48
95	1	04/96 RFO	Bobbin	NQI		0.48	011	-0.76
95	29	04/96 RFO	Bobbin	ODI	30	0.50	007	-0.39
95	112	04/96 RFO	Bobbin	ODI	11	0.47	006	+29.52
95	127	04/96 RFO	Bobbin	NQI		0.95	014	-0.74
96	1	04/96 RFO	Bobbin	ODI	22	0.81	011	-0.73
96	3	04/96 RFO	Bobbin	NQI		0.48	004	-0.81
96	17	04/96 RFO	Bobbin	NQI		0.24	004	+0.20
96	57	04/96 RFO	Bobbin	NQI		0.62	003	+0.68
96	66	04/96 RFO	Bobbin	NQI		0.43	006	+35.12
96	67	04/96 RFO	Bobbin	NQI		0.84	013	+26.29
96	114	04/96 RFO	Bobbin	NQI		1.00	003	+13.82
97	5	04/96 RFO	Bobbin	NQI		0.42	007	+13.83
97	37	04/96 RFO	Bobbin	ODI	28	0.36	007	-0.40
97	50	04/96 RFO	Bobbin	NQI		0.23	006	-0.08
97	124	04/96 RFO	Bobbin	ODI	27	0.62	011	+0.63
98	1	04/96 RFO	Bobbin	NQI		0.35	012	+0.03
		04/96 RFO	Bobbin	ODI	24	0.18	012	-0.22
98	8	04/96 RFO	Bobbin	ODI	10	0.55	010	+23.89
		04/96 RFO	Bobbin	NQI		0.65	015	+42.38 to +44.68
98	39	04/96 RFO	Bobbin	NQI		0.28	006	+14.13
98	125	04/96 RFO	Bobbin	NQI		0.39	007	+33.51
98	127	04/96 RFO	Bobbin	ODI	33	0.44	013	+14.72
99	1	04/96 RFO	Bobbin	ODI	19	0.39	011	-0.74
99	2	04/96 RFO	Bobbin	ODI	34	0.29	010	+0.40
99	37	04/96 RFO	Bobbin	NQI		0.36	006	+16.46
99	38	04/96 RFO	Bobbin	ODI	18	0.45	009	+7.18
99	41	04/96 RFO	Bobbin	NQI		0.46	015	+32.99
99	60	04/96 RFO	Bobbin	ADI		2.25	005	+31.69
99	124	04/96 RFO	Bobbin	WAR	52	1.14	011	+0.00
99	125	04/96 RFO	Bobbin	NQI		0.34	010	-0.11
99	126	04/96 RFO	Bobbin	NQI		0.45	011	+26.69 to +34.22
		04/96 RFO	Bobbin	NQI		0.45	012	+15.47 to +24.09
100	2	04/96 RFO	Bobbin	NQI		0.36	010	+0.28
100	5	04/96 RFO	Bobbin	NQI		0.44	007	+14.64 to +27.59
100	12	04/96 RFO	Bobbin	NQI		0.35	010	+26.06 to +28.44
100	37	04/96 RFO	Bobbin	ODI	16	0.35	006	+16.56
100	65	04/96 RFO	Bobbin	NQI		1.50	LTS	-0.35
100	66	04/96 RFO	Bobbin	NQI		0.80	014	+28.18 to +31.42
100	69	04/96 RFO	Bobbin	NQI		0.29	006	+0.00
100	71	04/96 RFO	Bobbin	NQI		0.38	006	-0.27
101	2	04/96 RFO	Bobbin	NQI		0.49	011	-0.59
101	4	04/96 RFO	Bobbin	NQI		0.32	008	+0.31
		04/96 RFO	Bobbin	ODI	22	0.56	008	+0.56
101	41	04/96 RFO	Bobbin	ODI	4	1.18	LTS	+1.49
101	49	04/96 RFO	Bobbin	ODI	21	0.69	015	+14.54
101	56	04/96 RFO	Bobbin	NQI		0.91	005	+0.58
101	72	04/96 RFO	Bobbin	NQI		0.32	010	+21.65
102	10	04/96 RFO	Bobbin	ODI	13	0.54	015	-0.61
102	13	04/96 RFO	Bobbin	ADI		2.11	003	+4.03 to +8.11
102	23	04/96 RFO	Bobbin	ODI	10	1.06	014	+4.23
		04/96 RFO	Bobbin	ODI	64	0.46	010	+21.60
		04/96 RFO	Bobbin	ODI	86	0.80	014	+6.37
102	46	04/96 RFO	Bobbin	NQI		0.45	006	+10.65
102	51	04/96 RFO	Bobbin	NQI		0.52	001	-0.97
102	55	04/96 RFO	Bobbin	NQI		0.68	005	-0.66
		04/96 RFO	Bobbin	ODI	67	0.96	004	-0.68
102	56	04/96 RFO	Bobbin	NQI		0.52	006	-0.61
102	59	04/96 RFO	Bobbin	NQI		0.36	001	-0.88
102	60	04/96 RFO	Bobbin	NQI		0.29	006	-0.28
102	67	04/96 RFO	Bobbin	NQI		0.46	010	+4.64
		04/96 RFO	Bobbin	NQI		0.60	015	+39.21
102	69	04/96 RFO	Bobbin	NQI		0.50	015	+31.17
		04/96 RFO	Bobbin	NQI		0.65	015	+15.98
102	84	04/96 RFO	Bobbin	ODI	7	0.17	006	-0.24

FTI TUBAN II (Version 2.3) 05/14/1996 08:57:11
 Oconee Nuclear Station - Unit Two
 S/G A
 04/96 RFO
 Bobbin

Page 23 of 34

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
103	11	04/96 RFO	Bobbin	NQI		0.56	014	UTE
		04/96 RFO	Bobbin	ODI	26	0.51	014	UTE
103	32	04/96 RFO	Bobbin	NQI		0.92	UTS	UTE
103	65	04/96 RFO	Bobbin	NQI		0.75	015	LTE
103	69	04/96 RFO	Bobbin	NQI		0.37	015	LTE
		04/96 RFO	Bobbin	NQI		0.63	015	LTE
103	90	04/96 RFO	Bobbin	ADI		1.38	008	LTE
103	104	04/96 RFO	Bobbin	NQI		0.55	003	LTE
104	1	04/96 RFO	Bobbin	NQI		0.48	011	UTE
104	2	04/96 RFO	Bobbin	NQI		0.49	011	UTE
104	8	04/96 RFO	Bobbin	ODI	12	0.57	011	UTE
		04/96 RFO	Bobbin	ODI	24	0.44	011	UTE
104	39	04/96 RFO	Bobbin	NQI		0.45	LTS	UTE
104	72	04/96 RFO	Bobbin	NQI		0.32	006	LTE
104	113	04/96 RFO	Bobbin	NQI		0.46	006	LTE
104	122	04/96 RFO	Bobbin	ODI	29	0.86	011	FL
105	1	04/96 RFO	Bobbin	WAR	34	0.70	011	UTE
105	2	04/96 RFO	Bobbin	NQI		0.38	011	UTE
		04/96 RFO	Bobbin	ODI	26	0.46	012	UTE
		04/96 RFO	Bobbin	ODI	29	0.81	012	UTE
105	4	04/96 RFO	Bobbin	NQI		0.43	012	UTE
105	7	04/96 RFO	Bobbin	ODI	37	0.71	LTS	UTE
105	48	04/96 RFO	Bobbin	ODI	17	2.26	009	UTE
105	68	04/96 RFO	Bobbin	ODI	38	0.49	011	FL
		04/96 RFO	Bobbin	ODI	38	0.49	011	FL
		04/96 RFO	Bobbin	ODI	39	0.48	011	FL
		04/96 RFO	Bobbin	ODI	55	0.74	011	FL
105	74	04/96 RFO	Bobbin	ODI	6	0.73	003	FL
105	89	04/96 RFO	Bobbin	ODI	10	0.37	015	FL
		04/96 RFO	Bobbin	ODI	53	1.05	015	FL
105	115	04/96 RFO	Bobbin	ODI	2	0.88	009	FL
105	119	04/96 RFO	Bobbin	WAR	15	0.86	014	FL
		04/96 RFO	Bobbin	WAR	58	0.51	008	FL
		04/96 RFO	Bobbin	WAR	97	1.07	011	FL
105	120	04/96 RFO	Bobbin	NQI		0.75	012	FL
		04/96 RFO	Bobbin	WAR	62	1.04	011	FL
105	122	04/96 RFO	Bobbin	ODI	24	0.43	010	FL
106	1	04/96 RFO	Bobbin	NQI		0.36	011	UTE
106	3	04/96 RFO	Bobbin	NQI		0.64	007	UTE
106	5	04/96 RFO	Bobbin	ODI	2	0.26	015	UTE
106	13	04/96 RFO	Bobbin	ODI	33	0.42	012	UTE
106	31	04/96 RFO	Bobbin	NQI		0.38	006	UTE
106	73	04/96 RFO	Bobbin	NQI		1.00	007	FL
106	76	04/96 RFO	Bobbin	ODI	22	0.36	006	FL
106	90	04/96 RFO	Bobbin	ADI		3.99	012	FL
106	95	04/96 RFO	Bobbin	ADI		3.28	013	FL
106	113	04/96 RFO	Bobbin	NQI		0.49	015	LTE
106	114	04/96 RFO	Bobbin	NQI		0.45	013	LTE
		04/96 RFO	Bobbin	NQI		0.51	UTS	LTE
106	115	04/96 RFO	Bobbin	NQI		0.37	007	LTE
		04/96 RFO	Bobbin	ODI	8	0.83	008	LTE
		04/96 RFO	Bobbin	WAR	55	1.10	015	LTE
107	1	04/96 RFO	Bobbin	WAR	26	0.83	011	UTE
107	3	04/96 RFO	Bobbin	ODI	28	2.48	015	UTE
107	4	04/96 RFO	Bobbin	NQI		0.46	006	UTE
107	30	04/96 RFO	Bobbin	ODI	16	0.42	006	UTE
107	67	04/96 RFO	Bobbin	NQI		2.52	007	LTE
107	68	04/96 RFO	Bobbin	NQI		0.48	015	LTE
		04/96 RFO	Bobbin	NQI		0.62	015	LTE
107	69	04/96 RFO	Bobbin	ODI	2	0.49	013	LTE
		04/96 RFO	Bobbin	ODI	20	0.23	013	LTE
		04/96 RFO	Bobbin	ODI	33	0.40	013	LTE
		04/96 RFO	Bobbin	ODI	46	0.49	013	LTE
107	70	04/96 RFO	Bobbin	ODI	23	0.15	007	LTE
107	71	04/96 RFO	Bobbin	NQI		0.17	006	LTE

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
107	78	04/96 RFO	Bobbin	ODI	2	0.34	LTS	+8.04
107	80	04/96 RFO	Bobbin	ODI	23	0.17	006	+0.24
107	103	04/96 RFO	Bobbin	NQI		0.16	007	+0.05
107	112	04/96 RFO	Bobbin	ODI	75	0.81	008	-0.63
107	113	04/96 RFO	Bobbin	NQI		0.37	008	-0.63
		04/96 RFO	Bobbin	ODI	11	0.39	014	-0.71
107	116	04/96 RFO	Bobbin	NQI		0.23	007	+31.18
		04/96 RFO	Bobbin	NQI		0.42	015	+0.66
		04/96 RFO	Bobbin	NQI		0.69	010	-0.60
		04/96 RFO	Bobbin	ODI	2	0.64	008	+0.76
		04/96 RFO	Bobbin	ODI	14	0.81	014	+0.66
		04/96 RFO	Bobbin	ODI	29	0.35	007	+33.53
		04/96 RFO	Bobbin	WAR	8	0.58	013	+0.00
108	3	04/96 RFO	Bobbin	WAR	39	2.84	015	+0.06
108	5	04/96 RFO	Bobbin	WAR	71	1.25	015	+0.65
108	19	04/96 RFO	Bobbin	ODI	3	2.40	004	+4.24
108	22	04/96 RFO	Bobbin	ODI	29	0.29	007	-0.44
108	28	04/96 RFO	Bobbin	NQI		0.86	006	+30.21
108	51	04/96 RFO	Bobbin	NQI		0.42	006	-0.54
108	52	04/96 RFO	Bobbin	ODI	26	0.47	005	+32.44
108	67	04/96 RFO	Bobbin	NQI		0.48	006	+0.03
108	73	04/96 RFO	Bobbin	ODI	16	1.14	005	+27.67
108	74	04/96 RFO	Bobbin	NQI		0.49	014	+11.21
108	109	04/96 RFO	Bobbin	NQI		0.35	013	+20.03
		04/96 RFO	Bobbin	NQI		0.42	013	+18.87
108	112	04/96 RFO	Bobbin	ODI	23	0.65	008	-0.57
108	116	04/96 RFO	Bobbin	NQI		0.39	008	+2.87
		04/96 RFO	Bobbin	NQI		0.52	008	+2.48
		04/96 RFO	Bobbin	ODI	5	0.45	013	-0.76
		04/96 RFO	Bobbin	ODI	22	0.23	008	+4.41
		04/96 RFO	Bobbin	ODI	39	0.31	003	-0.77
108	117	04/96 RFO	Bobbin	ODI	17	0.33	013	-0.47
		04/96 RFO	Bobbin	ODI	17	0.85	012	-0.76
108	119	04/96 RFO	Bobbin	NQI		0.18	015	+0.24
109	10	04/96 RFO	Bobbin	ODI	21	0.39	011	+8.09
		04/96 RFO	Bobbin	ODI	21	0.45	013	+2.63
		04/96 RFO	Bobbin	ODI	24	0.33	009	+31.23
		04/96 RFO	Bobbin	ODI	38	0.60	014	+28.44
109	20	04/96 RFO	Bobbin	NQI		0.48	006	+32.42
109	23	04/96 RFO	Bobbin	ODI	34	0.43	LTS	-0.51
109	24	04/96 RFO	Bobbin	ODI	21	0.71	LTS	-0.50
109	50	04/96 RFO	Bobbin	NQI		0.48	010	+8.89
109	54	04/96 RFO	Bobbin	ODI	26	0.56	015	+29.67
109	59	04/96 RFO	Bobbin	ODI	30	0.35	013	+11.34
109	62	04/96 RFO	Bobbin	ODI	10	0.47	009	+10.69
109	72	04/96 RFO	Bobbin	ODI	5	0.86	001	+31.63
109	73	04/96 RFO	Bobbin	ODI	8	0.24	012	+10.76
		04/96 RFO	Bobbin	ODI	23	0.58	002	-1.40
109	78	04/96 RFO	Bobbin	ODI	47	0.75	006	+0.76
109	107	04/96 RFO	Bobbin	ODI	20	0.35	006	+28.94
109	108	04/96 RFO	Bobbin	ODI	15	0.26	006	+31.70
109	109	04/96 RFO	Bobbin	NQI		0.30	006	+29.27
		04/96 RFO	Bobbin	ODI	5	0.64	LTS	-0.57
109	111	04/96 RFO	Bobbin	ODI	30	0.69	LTS	-1.28
109	114	04/96 RFO	Bobbin	NQI		0.28	007	+25.38 to +35.26
109	117	04/96 RFO	Bobbin	NQI		0.48	014	+0.71
110	6	04/96 RFO	Bobbin	ODI	9	0.40	011	+21.10
		04/96 RFO	Bobbin	ODI	38	0.47	010	+25.25
110	19	04/96 RFO	Bobbin	NQI		0.27	007	-1.52
110	33	04/96 RFO	Bobbin	NQI		0.21	004	-0.48
110	35	04/96 RFO	Bobbin	ODI	24	0.28	006	+20.68
		04/96 RFO	Bobbin	ODI	27	0.36	005	-0.91
110	39	04/96 RFO	Bobbin	NQI		0.27	006	+30.49
110	48	04/96 RFO	Bobbin	NQI		0.57	LTS	-0.47
110	51	04/96 RFO	Bobbin	ODI	26	0.29	006	+13.42

FTI TUBAN II (Version 2.3) 05/14/1996 08:57:11
Oconee Nuclear Station - Unit Two
S/G A
04/96 RFO
Bobbin

Page 25 of 34

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
110	65	04/96 RFO	Bobbin	NQI		0.66 LTS	+13.93	LTE
110	66	04/96 RFO	Bobbin	NQI		0.43 011	+30.88	LTE
		04/96 RFO	Bobbin	NQI		0.68 010	+33.03	LTE
		04/96 RFO	Bobbin	ODI	8	0.36 015	+33.18	LTE
		04/96 RFO	Bobbin	ODI	8	0.42 014	+6.90	LTE
		04/96 RFO	Bobbin	ODI	13	0.37 008	+29.77	LTE
		04/96 RFO	Bobbin	ODI	20	0.67 011	+34.52	LTE
		04/96 RFO	Bobbin	ODI	39	0.71 011	+35.01	LTE
		04/96 RFO	Bobbin	ODI	45	0.48 014	+0.42	LTE
		04/96 RFO	Bobbin	ODI	46	0.30 012	+7.91	LTE
		04/96 RFO	Bobbin	ODI	58	0.27 014	+2.89	LTE
		04/96 RFO	Bobbin	ODI	92	0.42 012	+25.59	LTE
		04/96 RFO	Bobbin	NQI		0.77 010	+6.50 to +28.81	LTE
110	68	04/96 RFO	Bobbin	ODI	17	0.34 006	+0.75	LTE
110	73	04/96 RFO	Bobbin	ODI	10	0.50 006	+24.10	LTE
		04/96 RFO	Bobbin	ODI	27	0.36 006	+20.61	LTE
110	108	04/96 RFO	Bobbin	ODI	5	0.48 006	+30.89	LTE
110	111	04/96 RFO	Bobbin	ODI	37	0.38 009	+0.47	LTE
110	113	04/96 RFO	Bobbin	WAR	17	0.66 008	+0.00	LTE
110	114	04/96 RFO	Bobbin	WAR	32	0.76 014	+0.00	LTE
111	1	04/96 RFO	Bobbin	NQI		0.46 009	+19.07	UTE
111	2	04/96 RFO	Bobbin	ODI	15	0.35 011	-0.80	UTE
		04/96 RFO	Bobbin	NQI		0.48 007	+10.93 to +15.44	UTE
111	3	04/96 RFO	Bobbin	NQI		0.34 007	+11.23	UTE
		04/96 RFO	Bobbin	ODI	46	1.17 011	+25.15	UTE
		04/96 RFO	Bobbin	ODI	66	0.86 012	+15.90	UTE
111	17	04/96 RFO	Bobbin	NQI		0.58 005	+8.09	UTE
111	32	04/96 RFO	Bobbin	ODI	25	0.37 006	+23.84	UTE
111	49	04/96 RFO	Bobbin	NQI		0.42 006	+20.71	UTE
111	66	04/96 RFO	Bobbin	NQI		0.39 006	-0.08	LTE
111	72	04/96 RFO	Bobbin	NQI		0.57 001	+8.12	LTE
		04/96 RFO	Bobbin	ODI	27	0.64 006	+26.57	LTE
111	76	04/96 RFO	Bobbin	NQI		0.47 005	+33.30	LTE
111	79	04/96 RFO	Bobbin	NQI		0.40 008	+9.61 to +29.01	LTE
111	91	04/96 RFO	Bobbin	NQI		0.26 006	+2.16 to +26.32	LTE
111	94	04/96 RFO	Bobbin	NQI		0.22 007	-0.32	LTE
111	95	04/96 RFO	Bobbin	NQI		0.39 006	+30.37	LTE
111	114	04/96 RFO	Bobbin	WAR	36	2.01 014	+0.00	LTE
111	115	04/96 RFO	Bobbin	ODI	20	0.23 009	-0.03	LTE
		04/96 RFO	Bobbin	WAR	23	2.00 014	+0.00	LTE
111	116	04/96 RFO	Bobbin	ODI	9	0.67 009	-0.03	LTE
112	1	04/96 RFO	Bobbin	NQI		0.57 011	-0.79	UTE
112	4	04/96 RFO	Bobbin	ODI	14	0.50 007	+20.28	UTE
112	5	04/96 RFO	Bobbin	NQI		0.41 007	+19.63	UTE
112	17	04/96 RFO	Bobbin	ODI	60	0.58 015	+41.21	UTE
112	43	04/96 RFO	Bobbin	NQI		0.22 006	+17.80	UTE
		04/96 RFO	Bobbin	NQI		0.42 006	+18.56	UTE
112	78	04/96 RFO	Bobbin	NQI		0.86 LTS	-0.41	LTE
112	101	04/96 RFO	Bobbin	NQI		0.51 006	+32.96	LTE
112	111	04/96 RFO	Bobbin	WAR	32	4.01 014	+0.00	LTE
112	113	04/96 RFO	Bobbin	WAR	28	1.40 014	+0.00	LTE
112	114	04/96 RFO	Bobbin	WAR	4	0.54 008	+0.00	LTE
		04/96 RFO	Bobbin	ODI	26	0.48 008	+11.82 to +23.35	LTE
113	1	04/96 RFO	Bobbin	NQI		0.40 011	-0.71	UTE
113	5	04/96 RFO	Bobbin	ODI	32	0.46 010	+5.43	UTE
113	18	04/96 RFO	Bobbin	ODI	20	0.40 LTS	+13.09	UTE
113	33	04/96 RFO	Bobbin	NQI		0.25 006	+23.45	UTE
113	46	04/96 RFO	Bobbin	ADI		2.15 012	+26.85	UTE
113	49	04/96 RFO	Bobbin	NQI		0.50 006	+12.85	UTE
113	87	04/96 RFO	Bobbin	NQI		0.49 006	+17.11 to +21.22	LTE
113	106	04/96 RFO	Bobbin	NQI		0.46 006	+30.60	LTE
113	108	04/96 RFO	Bobbin	WAR	25	0.82 009	+0.00	LTE
113	111	04/96 RFO	Bobbin	WAR	10	0.85 008	+0.00	LTE
113	112	04/96 RFO	Bobbin	WAR	4	0.50 008	+0.00	LTE
		04/96 RFO	Bobbin	WAR	18	0.60 014	+0.00	LTE

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	WAR	37	0.62	011	+0.00
113	114	04/96 RFO	Bobbin	WAR	39	2.31	014	+0.00
113	115	04/96 RFO	Bobbin	DWI		3.34	013	+0.94
		04/96 RFO	Bobbin	WAR	33	0.89	014	+0.00
114	5	04/96 RFO	Bobbin	ODI	20	0.49	007	+28.48
114	36	04/96 RFO	Bobbin	ODI	4	0.54	007	+13.93
114	56	04/96 RFO	Bobbin	ADI		1.14	015	+6.39
114	77	04/96 RFO	Bobbin	NQI		0.58	013	+22.46
		04/96 RFO	Bobbin	NQI		0.64	010	+13.33
114	88	04/96 RFO	Bobbin	NQI		0.41	006	+21.85
114	110	04/96 RFO	Bobbin	NQI		0.41	008	+7.88 to +23.78
114	111	04/96 RFO	Bobbin	ODI	55	1.21	008	-0.61
		04/96 RFO	Bobbin	WAR	37	3.43	014	+0.00
114	112	04/96 RFO	Bobbin	NQI		0.43	008	+19.05
		04/96 RFO	Bobbin	WAR	35	0.86	014	+0.00
115	3	04/96 RFO	Bobbin	NQI		0.21	015	+0.28
115	4	04/96 RFO	Bobbin	ODI	20	0.64	013	+12.73
115	5	04/96 RFO	Bobbin	ODI	53	0.57	015	+19.22
		04/96 RFO	Bobbin	NQI		0.73	010	+3.47 to +34.08
115	39	04/96 RFO	Bobbin	ADI		1.40	013	+30.06
115	47	04/96 RFO	Bobbin	ADI		2.93	008	+10.68
115	53	04/96 RFO	Bobbin	DWI		3.40	009	+28.59
115	71	04/96 RFO	Bobbin	NQI		0.45	014	+13.98
115	82	04/96 RFO	Bobbin	ODI	11	0.18	007	+0.00
115	88	04/96 RFO	Bobbin	NQI		0.51	006	+25.50
115	108	04/96 RFO	Bobbin	ODI	27	0.26	011	-0.39
		04/96 RFO	Bobbin	WAR	40	1.64	014	+0.00
115	109	04/96 RFO	Bobbin	NQI		0.53	011	-0.59
115	110	04/96 RFO	Bobbin	NQI		0.44	008	+20.87
		04/96 RFO	Bobbin	WAR	56	2.13	014	+0.00
115	111	04/96 RFO	Bobbin	WAR	23	1.96	014	+0.00
116	1	04/96 RFO	Bobbin	ODI	26	0.97	010	-0.74
116	2	04/96 RFO	Bobbin	NQI		0.39	004	-0.19
116	7	04/96 RFO	Bobbin	ODI	12	0.51	013	-0.85
116	40	04/96 RFO	Bobbin	DWI		5.30	008	+26.65
116	98	04/96 RFO	Bobbin	ODI	31	0.43	006	+32.24
116	106	04/96 RFO	Bobbin	NQI		0.18	011	-0.10
		04/96 RFO	Bobbin	NQI		0.74	014	+0.59
116	107	04/96 RFO	Bobbin	NQI		0.33	008	+0.78
		04/96 RFO	Bobbin	WAR	12	1.52	012	+0.00
		04/96 RFO	Bobbin	WAR	32	0.86	010	+0.00
116	109	04/96 RFO	Bobbin	NQI		0.64	014	+0.58
116	112	04/96 RFO	Bobbin	NQI		0.26	010	-0.17
		04/96 RFO	Bobbin	ODI	20	0.97	009	+0.00
117	9	04/96 RFO	Bobbin	NQI		0.20	003	+0.23
117	40	04/96 RFO	Bobbin	ODI	5	1.31	LTE	+19.19
117	61	04/96 RFO	Bobbin	ODI	32	0.42	015	+24.12
		04/96 RFO	Bobbin	ODI	58	0.42	015	+28.42
117	89	04/96 RFO	Bobbin	DWI		0.60	010	+32.72
		04/96 RFO	Bobbin	NQI		0.51	011	+14.24
		04/96 RFO	Bobbin	ODI	20	0.49	011	+12.94
		04/96 RFO	Bobbin	ODI	39	0.73	011	+11.43
117	102	04/96 RFO	Bobbin	WAR	20	2.01	014	+0.00
117	104	04/96 RFO	Bobbin	WAR	32	1.75	011	+0.00
		04/96 RFO	Bobbin	WAR	40	2.39	014	+0.00
117	105	04/96 RFO	Bobbin	NQI		0.50	002	+5.39
117	106	04/96 RFO	Bobbin	NQI		0.65	014	-0.74
117	108	04/96 RFO	Bobbin	NQI		0.51	010	+8.68
118	29	04/96 RFO	Bobbin	ODI	12	0.11	003	+0.00
118	39	04/96 RFO	Bobbin	NQI		0.39	008	+10.24
118	42	04/96 RFO	Bobbin	ADI		1.94	012	+31.84
118	49	04/96 RFO	Bobbin	ODI	10	0.51	007	+18.26
		04/96 RFO	Bobbin	ODI	34	0.38	011	-0.22
		04/96 RFO	Bobbin	ODI	25	2.05	011	+1.81 to +36.46
		04/96 RFO	Bobbin	ODI	44	0.91	009	+1.42 to +36.37

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	ODI	51	1.33	010	+2.69 to +34.45
		04/96 RFO	Bobbin	ODI	64	0.53	008	+6.97 to +37.26
118	50	04/96 RFO	Bobbin	NQI		0.62	011	+12.75 to +32.56
118	56	04/96 RFO	Bobbin	NQI		0.41	012	+25.24
		04/96 RFO	Bobbin	NQI		0.71	015	+41.55 to +43.58
118	70	04/96 RFO	Bobbin	ODI	35	0.64	011	+23.97
118	88	04/96 RFO	Bobbin	ODI	33	0.47	011	+34.53
118	101	04/96 RFO	Bobbin	WAR	15	0.68	014	+0.00
118	102	04/96 RFO	Bobbin	WAR	27	0.69	014	+0.00
		04/96 RFO	Bobbin	WAR	63	0.48	009	+0.00
		04/96 RFO	Bobbin	WAR	77	0.37	013	+0.00
118	103	04/96 RFO	Bobbin	WAR	15	1.03	012	+0.00
		04/96 RFO	Bobbin	WAR	27	1.37	013	+0.00
		04/96 RFO	Bobbin	WAR	38	0.46	011	+0.00
119	24	04/96 RFO	Bobbin	ODI	27	0.53	007	-0.28
119	49	04/96 RFO	Bobbin	NQI		0.94	009	+31.39
		04/96 RFO	Bobbin	ODI	19	0.82	011	+29.03
		04/96 RFO	Bobbin	ODI	47	0.76	011	+31.14
		04/96 RFO	Bobbin	ODI	55	0.61	009	+33.46
		04/96 RFO	Bobbin	ODI	62	0.33	009	+30.29
119	59	04/96 RFO	Bobbin	NQI		0.40	010	+9.47
		04/96 RFO	Bobbin	NQI		0.42	009	+19.71
		04/96 RFO	Bobbin	NQI		0.44	010	+14.50
		04/96 RFO	Bobbin	NQI		0.69	013	+12.03
		04/96 RFO	Bobbin	NQI		0.74	010	+10.29
		04/96 RFO	Bobbin	ODI	29	0.68	015	+41.63
		04/96 RFO	Bobbin	ODI	47	1.06	014	+25.67
		04/96 RFO	Bobbin	ODI	58	0.64	014	+26.20
119	77	04/96 RFO	Bobbin	ODI	20	0.34	006	+21.35
119	90	04/96 RFO	Bobbin	NQI		0.48	011	+23.49
		04/96 RFO	Bobbin	NQI		0.57	009	+24.29
		04/96 RFO	Bobbin	ODI	5	0.49	011	+26.23
		04/96 RFO	Bobbin	ODI	11	0.46	009	+25.65
		04/96 RFO	Bobbin	ODI	18	0.76	009	+18.00
		04/96 RFO	Bobbin	ODI	24	0.33	011	+28.94
		04/96 RFO	Bobbin	ODI	52	0.44	011	+29.88
119	108	04/96 RFO	Bobbin	ADI		2.67	010	+3.65
120	8	04/96 RFO	Bobbin	ODI	18	0.63	010	+9.12
120	59	04/96 RFO	Bobbin	NQI		0.94	015	+42.32
120	91	04/96 RFO	Bobbin	ODI	14	0.40	006	+31.96
120	104	04/96 RFO	Bobbin	ODI	17	0.43	008	-0.33
121	30	04/96 RFO	Bobbin	NQI		0.34	007	-0.08
121	47	04/96 RFO	Bobbin	NQI		0.45	014	+24.68
121	48	04/96 RFO	Bobbin	NQI		0.43	007	+7.63 to +37.48
		04/96 RFO	Bobbin	NQI		1.20	010	+1.16 to +33.45
		04/96 RFO	Bobbin	NQI		1.35	012	+9.04 to +34.03
		04/96 RFO	Bobbin	NQI		1.49	008	+2.79 to +33.53
		04/96 RFO	Bobbin	NQI		1.52	009	+3.31 to +38.39
		04/96 RFO	Bobbin	NQI		1.83	011	+2.27 to +35.85
121	55	04/96 RFO	Bobbin	ADI		2.49	012	+31.95
121	66	04/96 RFO	Bobbin	NQI		0.51	006	+27.67
121	74	04/96 RFO	Bobbin	ODI	6	0.51	006	+24.98
121	75	04/96 RFO	Bobbin	ODI	24	0.30	006	+30.17
121	88	04/96 RFO	Bobbin	DWI		0.32	014	+21.17
121	100	04/96 RFO	Bobbin	ODI	22	0.49	008	+9.94
122	1	04/96 RFO	Bobbin	ODI	24	0.74	014	-0.79
122	3	04/96 RFO	Bobbin	ODI	11	0.55	008	+11.57
		04/96 RFO	Bobbin	ODI	19	0.57	008	+11.80
122	4	04/96 RFO	Bobbin	ODI	25	0.44	006	+0.66
122	43	04/96 RFO	Bobbin	NQI		0.69	005	-0.03
122	63	04/96 RFO	Bobbin	NQI		0.30	006	+16.20
122	69	04/96 RFO	Bobbin	NQI		0.15	011	+35.74
122	71	04/96 RFO	Bobbin	NQI		1.14	015	+14.75
122	89	04/96 RFO	Bobbin	NQI		0.29	006	+30.87
122	95	04/96 RFO	Bobbin	ODI	6	0.29	006	+31.84

FTI TUBAN II (Version 2.3) 05/14/1996 08:57:11
 Oconee Nuclear Station - Unit Two
 S/G A
 04/96 RFO
 Bobbin

Page 28 of 34

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
122	100	04/96 RFO	Bobbin	ODI	10	0.34	UTS	+0.37
122	102	04/96 RFO	Bobbin	NQI		0.48	009	+10.59
122	103	04/96 RFO	Bobbin	ADI		2.00	013	+8.04
123	1	04/96 RFO	Bobbin	NQI		0.49	011	-0.77
123	27	04/96 RFO	Bobbin	NQI		0.57	011	+18.63
123	31	04/96 RFO	Bobbin	NQI		1.41	LTE	+21.80
123	33	04/96 RFO	Bobbin	ODI	15	1.34	LTE	+21.63
123	69	04/96 RFO	Bobbin	ODI	16	0.30	006	+30.31
123	75	04/96 RFO	Bobbin	ADI		1.20	006	+29.81
123	78	04/96 RFO	Bobbin	ODI	6	0.40	006	+35.58
123	79	04/96 RFO	Bobbin	NQI		0.28	006	+32.78
		04/96 RFO	Bobbin	ODI	10	0.19	006	+31.85
123	87	04/96 RFO	Bobbin	NQI		0.20	003	+1.19
123	100	04/96 RFO	Bobbin	ADI		3.68	009	+5.99
123	101	04/96 RFO	Bobbin	ADI		3.03	009	+12.99
		04/96 RFO	Bobbin	NQI		0.42	009	+15.50
123	102	04/96 RFO	Bobbin	NQI		0.32	010	+18.54
123	103	04/96 RFO	Bobbin	ADI		2.05	011	+4.22
123	104	04/96 RFO	Bobbin	NQI		1.27	UTS	+1.10
		04/96 RFO	Bobbin	ODI	6	0.71	011	+4.00
124	3	04/96 RFO	Bobbin	ODI	9	0.42	008	+12.40
124	59	04/96 RFO	Bobbin	NQI		0.27	008	+0.42
124	80	04/96 RFO	Bobbin	NQI		0.54	LTS	-0.56
124	98	04/96 RFO	Bobbin	NQI		0.31	003	+10.55
124	99	04/96 RFO	Bobbin	NQI		0.65	010	+0.59
		04/96 RFO	Bobbin	NQI		0.76	009	+13.64 to +17.53
124	101	04/96 RFO	Bobbin	NQI		0.40	012	+0.26
		04/96 RFO	Bobbin	NQI		0.54	011	+3.36
		04/96 RFO	Bobbin	NQI		0.64	011	+0.54
125	1	04/96 RFO	Bobbin	NQI		0.39	011	-0.82
125	28	04/96 RFO	Bobbin	ODI	16	1.04	012	+5.29
		04/96 RFO	Bobbin	ODI	37	0.60	012	+3.52
		04/96 RFO	Bobbin	ODI	47	0.65	012	+3.96
125	43	04/96 RFO	Bobbin	ADI		2.33	004	+11.58
125	45	04/96 RFO	Bobbin	ODI	63	2.21	015	+43.70
125	64	04/96 RFO	Bobbin	NQI		0.39	007	+24.32
		04/96 RFO	Bobbin	NQI		0.54	006	+29.33
125	75	04/96 RFO	Bobbin	NQI		0.38	006	+30.54
125	77	04/96 RFO	Bobbin	NQI		0.22	006	+33.35
		04/96 RFO	Bobbin	ODI	20	0.61	006	+35.04
		04/96 RFO	Bobbin	ODI	22	0.57	006	+34.46
125	78	04/96 RFO	Bobbin	ADI		2.32	014	+13.42
125	79	04/96 RFO	Bobbin	ODI	31	0.16	003	+0.10
125	85	04/96 RFO	Bobbin	NQI		0.13	014	+0.21
125	97	04/96 RFO	Bobbin	NQI		0.26	015	-0.13
125	98	04/96 RFO	Bobbin	NQI		0.40	010	+0.54
125	99	04/96 RFO	Bobbin	NQI		0.17	015	-0.26
125	100	04/96 RFO	Bobbin	ODI	12	0.81	011	+4.52
126	1	04/96 RFO	Bobbin	NQI		0.42	009	+0.42
126	4	04/96 RFO	Bobbin	NQI		0.31	008	+13.85
126	44	04/96 RFO	Bobbin	NQI		1.02	014	+28.29
126	60	04/96 RFO	Bobbin	ODI	5	1.53	LTS	+7.46
126	72	04/96 RFO	Bobbin	ODI	14	0.54	006	+32.23
126	77	04/96 RFO	Bobbin	NQI		0.37	015	+44.71
126	96	04/96 RFO	Bobbin	ODI	18	0.48	009	+0.34
126	98	04/96 RFO	Bobbin	NQI		0.48	010	+21.30
126	99	04/96 RFO	Bobbin	NQI		0.17	013	+28.55
		04/96 RFO	Bobbin	NQI		0.28	010	+14.49
		04/96 RFO	Bobbin	ODI	30	0.33	013	+25.78
127	5	04/96 RFO	Bobbin	ODI	11	0.51	008	+8.73
127	6	04/96 RFO	Bobbin	ODI	37	0.36	008	+13.79
127	13	04/96 RFO	Bobbin	ODI	21	0.44	007	-0.08
127	73	04/96 RFO	Bobbin	ODI	5	0.39	006	+36.50
127	76	04/96 RFO	Bobbin	NQI		0.22	006	+34.37
127	97	04/96 RFO	Bobbin	ODI	35	0.31	010	+31.26

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
127	98	04/96 RFO	Bobbin	NQI		0.56	014	+31.94
128	2	04/96 RFO	Bobbin	ODI	13	0.52	013	+30.73
		04/96 RFO	Bobbin	ODI	19	0.25	013	+20.36
		04/96 RFO	Bobbin	ODI	38	0.33	011	+16.98
		04/96 RFO	Bobbin	ODI	61	0.50	011	+16.62
128	6	04/96 RFO	Bobbin	ODI	14	0.48	008	+13.17
128	7	04/96 RFO	Bobbin	NQI		0.32	008	+15.11
		04/96 RFO	Bobbin	ODI	24	0.45	008	+12.67
128	50	04/96 RFO	Bobbin	NQI		0.44	014	+3.87
		04/96 RFO	Bobbin	ODI	16	0.63	006	+19.89
128	53	04/96 RFO	Bobbin	NQI		0.75	010	+30.79
128	58	04/96 RFO	Bobbin	DWI		2.92	015	+17.05
129	5	04/96 RFO	Bobbin	NQI		0.50	015	-0.03
129	7	04/96 RFO	Bobbin	ODI	24	0.50	008	+15.94
129	9	04/96 RFO	Bobbin	NQI		0.62	008	+21.20
		04/96 RFO	Bobbin	ODI	7	0.35	008	+12.82
129	10	04/96 RFO	Bobbin	ODI	24	0.34	008	+12.66
129	50	04/96 RFO	Bobbin	NQI		0.26	006	+31.43
129	81	04/96 RFO	Bobbin	ODI	28	0.77	006	+9.88
129	85	04/96 RFO	Bobbin	NQI		0.94	LTS	+3.42
129	89	04/96 RFO	Bobbin	NQI		0.32	013	+16.22
		04/96 RFO	Bobbin	NQI		0.43	011	+9.72
		04/96 RFO	Bobbin	NQI		0.44	013	+23.83
		04/96 RFO	Bobbin	ODI	9	0.39	013	+33.74
		04/96 RFO	Bobbin	ODI	9	0.41	012	+35.43
		04/96 RFO	Bobbin	ODI	48	0.34	012	+8.14
		04/96 RFO	Bobbin	ODI	51	0.33	014	-1.24
129	91	04/96 RFO	Bobbin	NQI		0.25	013	+5.42
		04/96 RFO	Bobbin	ODI	2	0.32	008	+16.84
		04/96 RFO	Bobbin	ODI	16	0.25	013	+4.77
		04/96 RFO	Bobbin	ODI	16	0.44	008	+15.57
129	93	04/96 RFO	Bobbin	ODI	15	0.41	010	+0.59
130	1	04/96 RFO	Bobbin	NQI		0.41	011	-0.85
130	7	04/96 RFO	Bobbin	ODI	31	0.59	009	+0.51
130	8	04/96 RFO	Bobbin	NQI		0.54	008	+16.12
		04/96 RFO	Bobbin	ODI	2	0.40	008	+16.87
		04/96 RFO	Bobbin	ODI	13	0.54	008	+14.80
130	13	04/96 RFO	Bobbin	NQI		0.33	012	+9.30
		04/96 RFO	Bobbin	NQI		0.89	010	+2.75
		04/96 RFO	Bobbin	ODI	41	0.85	010	+8.63
		04/96 RFO	Bobbin	ODI	43	0.51	010	+7.39
		04/96 RFO	Bobbin	ODI	52	0.60	012	+9.89
		04/96 RFO	Bobbin	ODI	65	0.52	012	+19.22
		04/96 RFO	Bobbin	ODI	81	0.44	010	+11.70
130	48	04/96 RFO	Bobbin	NQI		0.41	007	+2.00
		04/96 RFO	Bobbin	ODI	22	0.44	012	+30.78
130	67	04/96 RFO	Bobbin	NQI		0.54	006	+35.19
		04/96 RFO	Bobbin	ODI	22	0.40	006	+33.31
130	72	04/96 RFO	Bobbin	NQI		0.26	014	+12.96
130	93	04/96 RFO	Bobbin	NQI		0.32	UTS	-0.71
		04/96 RFO	Bobbin	ODI	64	0.74	LTS	+31.90
131	21	04/96 RFO	Bobbin	NQI		0.31	004	+6.89
131	46	04/96 RFO	Bobbin	NQI		0.42	001	+5.71
		04/96 RFO	Bobbin	NQI		0.44	015	+40.89
		04/96 RFO	Bobbin	NQI		0.45	013	+26.44
131	47	04/96 RFO	Bobbin	NQI		0.33	012	+13.61
131	48	04/96 RFO	Bobbin	NQI		0.45	009	+21.64
131	70	04/96 RFO	Bobbin	ODI	7	0.29	015	+24.31
131	73	04/96 RFO	Bobbin	NQI		0.51	007	+23.51
131	74	04/96 RFO	Bobbin	NQI		0.44	010	+2.78
		04/96 RFO	Bobbin	NQI		0.50	012	+26.54
131	80	04/96 RFO	Bobbin	NQI		0.41	015	+19.63
132	7	04/96 RFO	Bobbin	ODI	20	0.40	009	+0.28
132	10	04/96 RFO	Bobbin	ODI	35	0.59	008	+15.61
132	21	04/96 RFO	Bobbin	ODI	12	3.43	015	+43.06

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
132	39	04/96 RFO	Bobbin	NQI		0.26	010	+28.51
132	45	04/96 RFO	Bobbin	ODI	20	0.48	002	+10.15
132	46	04/96 RFO	Bobbin	NQI		0.45	008	+9.44
132	47	04/96 RFO	Bobbin	NQI		0.48	006	+27.98
132	49	04/96 RFO	Bobbin	NQI		0.52	003	+4.06
132	56	04/96 RFO	Bobbin	ODI	32	0.48	006	+33.13
132	60	04/96 RFO	Bobbin	ODI	32	0.48	006	+35.35
132	82	04/96 RFO	Bobbin	NQI		0.32	011	+28.43
		04/96 RFO	Bobbin	NQI		0.35	010	+25.28
		04/96 RFO	Bobbin	ODI	18	0.42	010	+32.42
		04/96 RFO	Bobbin	ODI	20	0.23	009	+35.45
		04/96 RFO	Bobbin	ODI	27	0.40	011	+28.75
133	15	04/96 RFO	Bobbin	ODI	10	0.66	011	+5.31
		04/96 RFO	Bobbin	ODI	33	0.64	010	+28.97
133	18	04/96 RFO	Bobbin	ODI	27	0.22	006	+29.36
133	54	04/96 RFO	Bobbin	NQI		0.33	014	+12.98
133	58	04/96 RFO	Bobbin	NQI		0.40	015	+36.89
133	70	04/96 RFO	Bobbin	ODI	16	0.37	006	+29.92
133	71	04/96 RFO	Bobbin	ODI	32	0.46	011	+32.28
134	1	04/96 RFO	Bobbin	ODI	2	0.58	012	-0.80
134	4	04/96 RFO	Bobbin	ODI	7	0.49	015	+42.85
		04/96 RFO	Bobbin	ODI	17	0.35	013	+30.12
		04/96 RFO	Bobbin	ODI	39	0.34	012	+26.59
		04/96 RFO	Bobbin	ODI	40	1.22	015	+44.15
		04/96 RFO	Bobbin	ODI	42	0.72	013	+31.18
		04/96 RFO	Bobbin	ODI	51	0.69	013	+29.60
		04/96 RFO	Bobbin	ODI	55	0.35	012	+28.12
		04/96 RFO	Bobbin	ODI	55	0.82	010	+29.04
134	11	04/96 RFO	Bobbin	NQI		0.29	008	+3.65
		04/96 RFO	Bobbin	ODI	12	0.27	008	+4.57
134	48	04/96 RFO	Bobbin	NQI		0.94	UTS	-0.56
		04/96 RFO	Bobbin	ODI	28	0.68	015	+40.53
		04/96 RFO	Bobbin	ODI	33	0.32	004	+0.10
		04/96 RFO	Bobbin	ODI	68	0.67	015	+39.39
134	50	04/96 RFO	Bobbin	NQI		0.61	003	+24.03
135	2	04/96 RFO	Bobbin	ODI	26	0.46	013	+3.02
		04/96 RFO	Bobbin	ODI	45	0.71	013	+2.60
		04/96 RFO	Bobbin	ODI	53	0.93	014	+12.15
		04/96 RFO	Bobbin	ODI	60	0.43	014	+15.61
135	32	04/96 RFO	Bobbin	ODI	60	0.51	011	+28.67
135	44	04/96 RFO	Bobbin	NQI		0.43	014	+30.95
		04/96 RFO	Bobbin	ODI	3	0.38	007	+37.92
		04/96 RFO	Bobbin	ODI	10	0.51	014	+27.68
		04/96 RFO	Bobbin	ODI	33	0.44	015	+12.27
135	47	04/96 RFO	Bobbin	NQI		0.72	015	+37.87
		04/96 RFO	Bobbin	NQI		1.11	015	+38.95
		04/96 RFO	Bobbin	ODI	35	0.89	015	+40.08
135	58	04/96 RFO	Bobbin	NQI		0.36	006	+28.72
135	62	04/96 RFO	Bobbin	ODI	10	0.34	006	+33.48
135	68	04/96 RFO	Bobbin	ODI	33	0.27	007	+27.00
135	76	04/96 RFO	Bobbin	DWI		0.58	004	+31.32
136	5	04/96 RFO	Bobbin	NQI		0.54	009	+18.75
136	43	04/96 RFO	Bobbin	NQI		0.47	006	+32.02
		04/96 RFO	Bobbin	NQI		0.48	006	+27.51
		04/96 RFO	Bobbin	NQI		0.50	012	+31.17
136	60	04/96 RFO	Bobbin	ODI	14	0.40	013	+17.66
136	77	04/96 RFO	Bobbin	ADI		1.68	012	+11.13
137	3	04/96 RFO	Bobbin	NQI		1.27	010	+0.66
137	44	04/96 RFO	Bobbin	ODI	22	0.52	006	+29.27
137	46	04/96 RFO	Bobbin	ODI	37	1.03	015	+37.83
		04/96 RFO	Bobbin	ODI	42	0.70	015	+9.65
137	47	04/96 RFO	Bobbin	NQI		0.43	UTS	-1.22
137	56	04/96 RFO	Bobbin	DWI		1.13	008	+18.67
137	66	04/96 RFO	Bobbin	NQI		0.34	006	+27.53
137	70	04/96 RFO	Bobbin	NQI		0.35	009	+35.96

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	NQI		0.38	009	+4.19
		04/96 RFO	Bobbin	NQI		0.38	010	-1.41
137	73	04/96 RFO	Bobbin	NQI		0.44	014	-1.34
		04/96 RFO	Bobbin	ODI	14	0.35	013	+31.66
		04/96 RFO	Bobbin	ODI	42	0.50	013	+32.24
		04/96 RFO	Bobbin	ODI	54	0.54	013	+33.67
		04/96 RFO	Bobbin	ODI	57	0.36	013	+33.96
		04/96 RFO	Bobbin	ODI	76	0.40	013	+20.48
137	74	04/96 RFO	Bobbin	NQI		0.52	009	+9.22
137	75	04/96 RFO	Bobbin	NQI		0.48	015	+41.76
138	2	04/96 RFO	Bobbin	NQI		1.08	010	+0.55
138	15	04/96 RFO	Bobbin	NQI		0.58	UTS	-0.94
138	40	04/96 RFO	Bobbin	NQI		0.53	LTS	+2.24
		04/96 RFO	Bobbin	ODI	24	0.36	007	+21.95
138	41	04/96 RFO	Bobbin	ODI	24	0.51	015	+43.02
138	44	04/96 RFO	Bobbin	ODI	42	0.96	015	+44.29
138	50	04/96 RFO	Bobbin	ODI	2	0.22	007	+22.63
138	56	04/96 RFO	Bobbin	DWI		0.38	007	+23.22
138	61	04/96 RFO	Bobbin	NQI		0.18	014	+2.38
138	63	04/96 RFO	Bobbin	ODI	20	0.17	007	-0.13
138	69	04/96 RFO	Bobbin	NQI		0.31	009	+35.02
		04/96 RFO	Bobbin	NQI		0.36	009	+34.74
		04/96 RFO	Bobbin	NQI		0.36	010	+7.46
		04/96 RFO	Bobbin	NQI		0.41	010	+10.25
		04/96 RFO	Bobbin	ODI	16	0.38	009	+32.36
		04/96 RFO	Bobbin	ODI	33	0.40	010	+9.16
138	71	04/96 RFO	Bobbin	ODI	7	0.20	010	+13.33
		04/96 RFO	Bobbin	ODI	16	0.45	010	+31.34
		04/96 RFO	Bobbin	ODI	26	0.42	012	+1.53
		04/96 RFO	Bobbin	ODI	30	0.39	010	+31.86
		04/96 RFO	Bobbin	ODI	35	0.23	010	+5.86
		04/96 RFO	Bobbin	ODI	38	0.22	010	+27.33
		04/96 RFO	Bobbin	ODI	38	0.28	010	+6.17
		04/96 RFO	Bobbin	ODI	48	0.35	010	+15.88
		04/96 RFO	Bobbin	ODI	54	0.48	010	+18.14
139	8	04/96 RFO	Bobbin	ODI	26	0.17	009	+0.11
139	15	04/96 RFO	Bobbin	NQI		1.14	012	+33.21
		04/96 RFO	Bobbin	ODI	10	0.44	012	+22.96
		04/96 RFO	Bobbin	ODI	17	0.58	012	+4.77
		04/96 RFO	Bobbin	ODI	75	0.75	012	+13.77
		04/96 RFO	Bobbin	NQI		0.73	010	+2.88 to +11.09
		04/96 RFO	Bobbin	NQI		0.74	014	+2.93 to +6.94
		04/96 RFO	Bobbin	NQI		1.16	013	+4.11 to +25.03
139	44	04/96 RFO	Bobbin	NQI		0.62	015	+39.88 to +44.91
139	68	04/96 RFO	Bobbin	ADI		0.76	015	+4.04
		04/96 RFO	Bobbin	ADI		0.89	013	+31.34
		04/96 RFO	Bobbin	NQI		0.12	014	+11.31
		04/96 RFO	Bobbin	NQI		0.16	014	+11.52
		04/96 RFO	Bobbin	NQI		0.17	008	+0.18
		04/96 RFO	Bobbin	NQI		0.36	015	+19.99
		04/96 RFO	Bobbin	ODI	20	0.21	014	+10.45
		04/96 RFO	Bobbin	ODI	20	0.73	015	+20.45
		04/96 RFO	Bobbin	ODI	35	0.54	015	+24.03
		04/96 RFO	Bobbin	ODI	37	0.25	013	+27.64
139	69	04/96 RFO	Bobbin	NQI		0.51	008	+0.15
139	72	04/96 RFO	Bobbin	NQI		0.52	009	-0.15
140	2	04/96 RFO	Bobbin	NQI		0.50	014	+0.19
		04/96 RFO	Bobbin	NQI		0.63	010	+0.58
		04/96 RFO	Bobbin	ODI	27	0.54	009	+36.72
140	4	04/96 RFO	Bobbin	NQI		0.52	014	-0.83
140	7	04/96 RFO	Bobbin	ODI	56	0.52	015	+16.81
140	8	04/96 RFO	Bobbin	NQI		0.58	015	+4.73 to +6.28
140	9	04/96 RFO	Bobbin	NQI		0.51	012	+8.95 to +25.76
140	41	04/96 RFO	Bobbin	NQI		0.54	014	+16.83
		04/96 RFO	Bobbin	NQI		0.55	003	+2.32

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	NQI		0.82	014	+15.86
140	42	04/96 RFO	Bobbin	NQI		0.21	015	+2.60
		04/96 RFO	Bobbin	NQI		0.39	015	+1.99
		04/96 RFO	Bobbin	NQI		0.93	009	+29.70
		04/96 RFO	Bobbin	ODI	20	0.60	015	+2.28
140	43	04/96 RFO	Bobbin	NQI		0.42	015	+17.63
		04/96 RFO	Bobbin	ODI	26	1.04	015	+25.96
140	47	04/96 RFO	Bobbin	ODI	12	0.26	012	+34.82
140	59	04/96 RFO	Bobbin	NQI		0.34	006	+28.29
140	71	04/96 RFO	Bobbin	NQI		0.67	014	+0.72
141	2	04/96 RFO	Bobbin	NQI		0.92	014	+0.63
141	35	04/96 RFO	Bobbin	NQI		0.44	LTS	+3.04
141	61	04/96 RFO	Bobbin	NQI		0.53	010	-1.07
		04/96 RFO	Bobbin	ODI	14	0.27	009	+37.86
		04/96 RFO	Bobbin	ODI	16	0.23	009	+31.58
		04/96 RFO	Bobbin	ODI	30	0.35	007	+14.20
		04/96 RFO	Bobbin	ODI	31	0.30	009	+36.91
141	65	04/96 RFO	Bobbin	ODI	5	0.47	011	+4.47
142	35	04/96 RFO	Bobbin	NQI		0.50	013	+8.21
142	38	04/96 RFO	Bobbin	NQI		0.72	013	+15.41
142	61	04/96 RFO	Bobbin	NQI		0.44	007	+36.19
142	64	04/96 RFO	Bobbin	NQI		0.50	012	+32.24
		04/96 RFO	Bobbin	NQI		0.53	012	+33.17
142	65	04/96 RFO	Bobbin	NQI		0.38	012	+17.43
		04/96 RFO	Bobbin	ODI	11	0.33	013	+29.51
		04/96 RFO	Bobbin	ODI	11	0.75	012	+23.17
		04/96 RFO	Bobbin	ODI	13	0.27	013	+28.54
		04/96 RFO	Bobbin	ODI	18	0.40	012	+15.46
		04/96 RFO	Bobbin	ODI	28	0.54	012	+23.86
		04/96 RFO	Bobbin	ODI	30	0.47	012	+34.64
		04/96 RFO	Bobbin	ODI	32	0.29	012	+22.12
		04/96 RFO	Bobbin	ODI	32	0.33	012	+20.65
		04/96 RFO	Bobbin	ODI	57	0.42	012	+32.03
		04/96 RFO	Bobbin	NQI		0.53	011	+6.59 to +33.54
		04/96 RFO	Bobbin	ODI	23	0.39	012	+4.44 to +7.10
		04/96 RFO	Bobbin	ODI	41	0.36	014	+24.32 to +28.47
		04/96 RFO	Bobbin	ODI	42	0.38	010	+4.40 to +30.07
		04/96 RFO	Bobbin	ODI	57	0.33	013	+11.46 to +15.98
143	5	04/96 RFO	Bobbin	NQI		0.36	008	-0.74
143	6	04/96 RFO	Bobbin	NQI		0.41	015	+42.70
		04/96 RFO	Bobbin	ODI	13	0.40	008	+8.77
143	15	04/96 RFO	Bobbin	ODI	38	0.69	008	+0.00
143	16	04/96 RFO	Bobbin	NQI		0.60	007	+12.36
143	34	04/96 RFO	Bobbin	ODI	9	0.35	015	+39.86
143	37	04/96 RFO	Bobbin	ODI	14	0.57	011	+24.80
143	43	04/96 RFO	Bobbin	NQI		0.25	008	+7.90
		04/96 RFO	Bobbin	NQI		0.31	008	+9.69
143	45	04/96 RFO	Bobbin	NQI		0.29	008	+10.59
		04/96 RFO	Bobbin	ODI	35	0.27	008	+16.00
143	48	04/96 RFO	Bobbin	NQI		0.43	008	+12.41
		04/96 RFO	Bobbin	ODI	12	0.37	008	+10.68
143	49	04/96 RFO	Bobbin	ADI		2.67	013	+6.70
143	50	04/96 RFO	Bobbin	ADI		2.98	008	+11.53
143	51	04/96 RFO	Bobbin	ADI		5.02	008	+9.34
143	53	04/96 RFO	Bobbin	NQI		0.26	015	+6.60
143	55	04/96 RFO	Bobbin	ADI		1.42	013	+3.63
143	58	04/96 RFO	Bobbin	NQI		0.43	010	+12.28
144	2	04/96 RFO	Bobbin	NQI		0.61	014	-0.88
144	7	04/96 RFO	Bobbin	ODI	36	0.65	011	+8.26
		04/96 RFO	Bobbin	NQI		0.60	010	+4.49 to +23.31
144	10	04/96 RFO	Bobbin	ODI	2	0.41	007	+9.90
144	41	04/96 RFO	Bobbin	NQI		0.35	009	+0.47
144	42	04/96 RFO	Bobbin	NQI		0.22	008	+15.41
144	43	04/96 RFO	Bobbin	NQI		0.46	008	+22.01
144	54	04/96 RFO	Bobbin	ODI	15	0.47	009	+37.80

FTI TUBAN II (Version 2.3) 05/14/1996 08:57:11
 Oconee Nuclear Station - Unit Two
 S/G A
 04/96 RFO
 Bobbin

Page 33 of 34

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	ODI	33	0.62	011	+8.97
		04/96 RFO	Bobbin	ODI	35	0.52	009	+35.74
		04/96 RFO	Bobbin	ODI	45	0.45	010	+4.78 to +28.71
144	55	04/96 RFO	Bobbin	ODI	28	1.14	005	+15.47
145	2	04/96 RFO	Bobbin	NQI		0.72	009	+14.34
145	12	04/96 RFO	Bobbin	NQI		0.82	014	-0.80
145	22	04/96 RFO	Bobbin	NQI		0.41	010	-0.55
145	34	04/96 RFO	Bobbin	NQI		0.47	015	+13.43
145	35	04/96 RFO	Bobbin	NQI		0.64	012	+24.27
145	54	04/96 RFO	Bobbin	ODI	57	0.44	010	+5.87 to +11.34
146	2	04/96 RFO	Bobbin	NQI		0.50	014	+0.69
146	28	04/96 RFO	Bobbin	NQI		0.63	008	+0.80
147	1	04/96 RFO	Bobbin	NQI		0.57	009	+0.00
147	6	04/96 RFO	Bobbin	NQI		0.36	010	+0.38
147	19	04/96 RFO	Bobbin	ODI	12	0.59	012	-0.80
147	31	04/96 RFO	Bobbin	NQI		0.31	013	+12.75
		04/96 RFO	Bobbin	NQI		0.61	013	+14.23
		04/96 RFO	Bobbin	NQI		0.70	015	+42.82
		04/96 RFO	Bobbin	NQI		0.85	015	+4.11
		04/96 RFO	Bobbin	NQI		1.22	013	+10.93
		04/96 RFO	Bobbin	ODI	36	0.34	013	+11.88
		04/96 RFO	Bobbin	ODI	46	0.61	015	+41.77
		04/96 RFO	Bobbin	ODI	49	0.44	015	+1.69
147	36	04/96 RFO	Bobbin	ODI	18	0.55	009	+10.78
147	40	04/96 RFO	Bobbin	ODI	35	0.43	010	+0.62
148	1	04/96 RFO	Bobbin	NQI		0.56	010	+17.95
148	6	04/96 RFO	Bobbin	NQI		0.55	012	+12.56
148	15	04/96 RFO	Bobbin	ODI	22	0.91	012	-0.76
148	26	04/96 RFO	Bobbin	ODI	39	0.50	013	+14.68
148	27	04/96 RFO	Bobbin	ODI	35	0.53	015	+7.14
148	28	04/96 RFO	Bobbin	NQI		0.64	008	-0.31
148	36	04/96 RFO	Bobbin	ODI	15	1.43	010	+0.33
		04/96 RFO	Bobbin	ODI	25	0.78	010	+15.10
148	37	04/96 RFO	Bobbin	ODI	3	1.04	010	+13.36
149	15	04/96 RFO	Bobbin	NQI		0.45	008	+27.82
		04/96 RFO	Bobbin	ADI		3.32	014	+18.44 to +24.25
149	20	04/96 RFO	Bobbin	NQI		0.68	010	+0.82
149	22	04/96 RFO	Bobbin	ODI	20	1.05	011	+29.39
		04/96 RFO	Bobbin	ODI	65	0.79	010	+0.73
149	23	04/96 RFO	Bobbin	NQI		0.80	010	+0.68
149	24	04/96 RFO	Bobbin	NQI		0.33	011	+23.53
		04/96 RFO	Bobbin	NQI		0.99	011	+34.91
		04/96 RFO	Bobbin	ODI	1	0.99	012	+31.99
		04/96 RFO	Bobbin	ODI	20	0.69	011	+16.36
		04/96 RFO	Bobbin	ODI	25	0.66	UTS	-1.22
		04/96 RFO	Bobbin	ODI	27	0.77	012	+34.22
		04/96 RFO	Bobbin	ODI	31	0.83	010	+0.67
		04/96 RFO	Bobbin	ODI	36	0.65	013	-1.42
		04/96 RFO	Bobbin	ODI	48	0.43	011	+20.34
		04/96 RFO	Bobbin	ODI	49	0.36	011	+32.51
		04/96 RFO	Bobbin	ODI	54	0.42	011	+1.40
		04/96 RFO	Bobbin	ODI	54	0.49	011	+18.65
		04/96 RFO	Bobbin	ODI	43	1.30	012	+12.79 to +15.43
149	27	04/96 RFO	Bobbin	ODI	3	1.26	010	+19.19
149	29	04/96 RFO	Bobbin	NQI		0.40	011	+6.67
149	30	04/96 RFO	Bobbin	ODI	16	0.45	011	+7.70
149	32	04/96 RFO	Bobbin	ODI	29	0.64	011	+4.63
150	3	04/96 RFO	Bobbin	ODI	37	0.75	009	+0.55
150	4	04/96 RFO	Bobbin	NQI		0.60	004	+24.08
150	14	04/96 RFO	Bobbin	NQI		2.46	015	+2.69
150	22	04/96 RFO	Bobbin	ADI		1.57	012	+2.68
		04/96 RFO	Bobbin	ODI	5	0.73	011	+4.15
150	23	04/96 RFO	Bobbin	ODI	5	1.21	011	+3.92
		04/96 RFO	Bobbin	ODI	11	0.75	012	+3.09
150	25	04/96 RFO	Bobbin	ODI	1	0.71	011	+4.96

FTI TUBAN II (Version 2.3) 05/14/1996 08:57:11
Oconee Nuclear Station - Unit Two
S/G A
04/96 RFO
Bobbin

Page 34 of 34

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
150	26	04/96 RFO	Bobbin	ODI	13	0.97	011 +6.20	LTE
151	14	04/96 RFO	Bobbin	NQI		1.03	015 +38.34	LTE
		04/96 RFO	Bobbin	ODI	11	0.72	012 +3.60	LTE
151	16	04/96 RFO	Bobbin	NQI		0.69	012 +26.09	LTE
		04/96 RFO	Bobbin	NQI		0.89	015 +2.22	LTE
		04/96 RFO	Bobbin	ODI	11	0.71	012 +21.40	LTE
		04/96 RFO	Bobbin	ODI	15	0.80	012 +20.10	LTE
		04/96 RFO	Bobbin	ODI	16	0.51	013 +23.54	LTE
		04/96 RFO	Bobbin	ODI	32	0.51	015 +1.69	LTE
		04/96 RFO	Bobbin	ODI	45	0.69	015 +2.94	LTE

Total Indications Found = 2155
Total Tubes Found = 1472

ATTACHMENT 2

54 Pages

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 1 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
1	1	04/96 RFO	Bobbin	ODI	56	0.43	014	+5.73 UTE
1	2	04/96 RFO	Bobbin	NQI		1.17	014	+3.61 UTE
		04/96 RFO	Bobbin	ODI	14	0.76	012	+9.25 UTE
1	3	04/96 RFO	Bobbin	ADI		1.84	012	+6.97 UTE
		04/96 RFO	Bobbin	ADI		2.70	014	+31.39 UTE
		04/96 RFO	Bobbin	ADI		3.83	014	+3.79 UTE
		04/96 RFO	Bobbin	ODI	10	0.56	013	+5.36 UTE
		04/96 RFO	Bobbin	ODI	19	0.42	011	+14.10 UTE
		04/96 RFO	Bobbin	ODI	27	0.69	013	+6.23 UTE
1	4	04/96 RFO	Bobbin	NQI		0.41	012	+6.05 UTE
1	5	04/96 RFO	Bobbin	NQI		0.64	014	+32.25 UTE
		04/96 RFO	Bobbin	NQI		0.78	012	+5.53 UTE
1	6	04/96 RFO	Bobbin	ODI	24	1.21	013	+1.55 UTE
1	8	04/96 RFO	Bobbin	NQI		0.75	010	-0.68 UTE
1	10	04/96 RFO	Bobbin	NQI		0.48	010	+20.38 UTE
1	13	04/96 RFO	Bobbin	NQI		1.17	010	-0.41 UTE
1	14	04/96 RFO	Bobbin	NQI		0.96	010	-0.92 UTE
1	15	04/96 RFO	Bobbin	NQI		0.34	013	+2.12 UTE
		04/96 RFO	Bobbin	NQI		0.43	013	+26.08 UTE
		04/96 RFO	Bobbin	ODI	12	0.78	010	-0.50 UTE
		04/96 RFO	Bobbin	ODI	13	0.62	012	+7.00 UTE
		04/96 RFO	Bobbin	ODI	18	0.33	012	+8.02 UTE
		04/96 RFO	Bobbin	ODI	46	0.40	012	+2.10 UTE
		04/96 RFO	Bobbin	NQI		0.48	012	+12.04 to +25.50 UTE
2	1	04/96 RFO	Bobbin	DWI		5.45	006	+11.76 UTE
		04/96 RFO	Bobbin	NQI		0.41	015	-0.45 UTE
		04/96 RFO	Bobbin	ODI	11	1.38	006	+6.78 UTE
2	3	04/96 RFO	Bobbin	NQI		0.42	014	+33.07 UTE
		04/96 RFO	Bobbin	NQI		0.51	010	+0.08 UTE
		04/96 RFO	Bobbin	NQI		0.64	012	+3.16 UTE
		04/96 RFO	Bobbin	ODI	17	0.83	014	+2.09 UTE
		04/96 RFO	Bobbin	ODI	19	0.37	011	+6.60 UTE
2	5	04/96 RFO	Bobbin	ODI	8	0.84	011	+6.44 UTE
		04/96 RFO	Bobbin	ODI	8	1.77	012	+4.32 UTE
		04/96 RFO	Bobbin	ODI	21	0.61	014	+1.88 UTE
2	6	04/96 RFO	Bobbin	NQI		0.86	011	+12.32 UTE
		04/96 RFO	Bobbin	NQI		0.97	014	+31.94 UTE
		04/96 RFO	Bobbin	ODI	8	0.56	011	+10.32 UTE
2	7	04/96 RFO	Bobbin	ODI	23	0.39	013	+5.59 UTE
2	8	04/96 RFO	Bobbin	NQI		0.74	010	-0.13 UTE
		04/96 RFO	Bobbin	NQI		0.65	011	+7.64 to +19.38 UTE
2	9	04/96 RFO	Bobbin	NQI		0.64	011	+6.64 UTE
2	10	04/96 RFO	Bobbin	ODI	38	0.84	009	+0.29 UTE
2	11	04/96 RFO	Bobbin	ODI	33	0.52	011	+6.99 UTE
2	12	04/96 RFO	Bobbin	ODI	19	1.13	009	+0.35 UTE
2	13	04/96 RFO	Bobbin	NQI		0.66	010	+14.48 UTE
		04/96 RFO	Bobbin	NQI		0.67	010	+25.66 UTE
2	14	04/96 RFO	Bobbin	ODI	14	0.48	010	+18.30 UTE
		04/96 RFO	Bobbin	ODI	31	0.50	009	+0.34 UTE
		04/96 RFO	Bobbin	ODI	43	0.61	010	+24.77 UTE
2	15	04/96 RFO	Bobbin	NQI		0.29	010	-0.38 UTE
		04/96 RFO	Bobbin	NQI		0.53	010	+13.30 UTE
2	17	04/96 RFO	Bobbin	ODI	36	0.61	010	-0.57 UTE
2	24	04/96 RFO	Bobbin	NQI		0.39	008	-0.52 UTE
2	25	04/96 RFO	Bobbin	ODI	37	0.43	014	+13.56 UTE
2	27	04/96 RFO	Bobbin	NQI		0.42	013	-0.74 UTE
3	2	04/96 RFO	Bobbin	NQI		0.74	015	+0.21 UTE
3	5	04/96 RFO	Bobbin	ODI	39	0.73	014	+30.39 UTE
3	6	04/96 RFO	Bobbin	ODI	28	0.45	010	-0.16 UTE
3	7	04/96 RFO	Bobbin	NQI		0.47	011	+7.52 UTE
		04/96 RFO	Bobbin	NQI		0.60	010	+0.47 UTE
		04/96 RFO	Bobbin	ODI	28	0.58	010	+0.18 UTE
		04/96 RFO	Bobbin	ODI	37	0.66	011	+6.52 UTE
3	8	04/96 RFO	Bobbin	ODI	10	0.83	011	+7.22 UTE
		04/96 RFO	Bobbin	ODI	20	0.29	010	+0.00 UTE

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
3	9	04/96 RFO	Bobbin	NQI		0.40	014	+31.84 UTE
		04/96 RFO	Bobbin	NQI		0.50	009	-0.77 UTE
		04/96 RFO	Bobbin	ODI	25	0.33	013	+3.12 UTE
		04/96 RFO	Bobbin	ODI	25	0.51	010	+10.78 UTE
		04/96 RFO	Bobbin	ODI	35	0.37	014	+1.58 UTE
3	10	04/96 RFO	Bobbin	ODI	3	0.72	011	+6.27 UTE
		04/96 RFO	Bobbin	ODI	34	0.81	015	+5.86 UTE
3	11	04/96 RFO	Bobbin	NQI		0.33	010	-0.31 UTE
3	13	04/96 RFO	Bobbin	NQI		0.66	010	+0.46 UTE
3	14	04/96 RFO	Bobbin	ODI	33	0.34	010	+0.52 UTE
3	15	04/96 RFO	Bobbin	ODI	31	0.62	010	+0.42 UTE
3	19	04/96 RFO	Bobbin	NQI		0.31	015	+0.42 LTE
3	20	04/96 RFO	Bobbin	ODI	45	0.91	009	+0.71 LTE
3	21	04/96 RFO	Bobbin	NQI		0.67	010	+0.61 LTE
3	22	04/96 RFO	Bobbin	NQI		0.46	010	-0.59 LTE
3	23	04/96 RFO	Bobbin	ODI	36	0.64	010	+0.70 LTE
3	25	04/96 RFO	Bobbin	ODI	6	0.32	009	+0.24 LTE
3	27	04/96 RFO	Bobbin	ODI	37	0.44	009	+7.52 LTE
3	29	04/96 RFO	Bobbin	NQI		0.49	008	+19.13 LTE
3	33	04/96 RFO	Bobbin	NQI		0.83	010	+0.57 LTE
4	6	04/96 RFO	Bobbin	ADI		1.59	007	+4.28 UTE
4	8	04/96 RFO	Bobbin	ADI		2.35	015	+13.48 UTE
		04/96 RFO	Bobbin	ODI	13	1.75	015	+42.39 UTE
		04/96 RFO	Bobbin	ODI	16	1.67	015	+25.02 UTE
		04/96 RFO	Bobbin	ODI	20	2.69	LTS	+33.43 UTE
4	16	04/96 RFO	Bobbin	NQI		0.51	008	+0.23 UTE
4	20	04/96 RFO	Bobbin	NQI		0.57	009	+0.67 UTE
4	22	04/96 RFO	Bobbin	ODI	2	0.26	009	+0.61 LTE
4	23	04/96 RFO	Bobbin	ODI	15	0.65	009	+0.76 LTE
4	24	04/96 RFO	Bobbin	NQI		0.46	009	+0.78 LTE
4	31	04/96 RFO	Bobbin	NQI		1.57	007	+20.82 to +24.08 LTE
4	33	04/96 RFO	Bobbin	NQI		0.43	009	+0.63 LTE
4	35	04/96 RFO	Bobbin	NQI		0.57	010	+0.63 LTE
4	41	04/96 RFO	Bobbin	NQI		0.53	010	+0.67 UTE
5	2	04/96 RFO	Bobbin	NQI		0.56	010	+1.31 UTE
5	4	04/96 RFO	Bobbin	NQI		0.52	010	+0.63 UTE
5	5	04/96 RFO	Bobbin	ODI	23	0.83	010	+0.55 UTE
5	8	04/96 RFO	Bobbin	NQI		0.67	009	+0.60 UTE
5	10	04/96 RFO	Bobbin	ODI	34	0.51	014	+12.88 UTE
5	13	04/96 RFO	Bobbin	NQI		1.02	015	-0.50 UTE
		04/96 RFO	Bobbin	NQI		1.24	015	-0.08 UTE
5	14	04/96 RFO	Bobbin	NQI		0.46	015	+0.40 UTE
5	15	04/96 RFO	Bobbin	ODI	32	0.55	009	+15.97 UTE
5	17	04/96 RFO	Bobbin	NQI		0.52	009	+19.13 UTE
5	22	04/96 RFO	Bobbin	NQI		0.32	009	+0.00 UTE
5	28	04/96 RFO	Bobbin	ODI	27	0.48	009	+0.52 LTE
5	33	04/96 RFO	Bobbin	NQI		0.46	007	+9.94 LTE
		04/96 RFO	Bobbin	ODI	18	0.45	007	+9.15 LTE
5	34	04/96 RFO	Bobbin	NQI		1.10	007	+18.42 LTE
5	36	04/96 RFO	Bobbin	NQI		0.63	008	+0.64 LTE
5	44	04/96 RFO	Bobbin	NQI		2.04	012	+28.89 LTE
5	46	04/96 RFO	Bobbin	NQI		0.45	015	+0.10 LTE
6	1	04/96 RFO	Bobbin	NQI		1.10	009	+30.03 UTE
6	5	04/96 RFO	Bobbin	NQI		0.52	015	-1.21 UTE
		04/96 RFO	Bobbin	ODI	12	0.27	011	+19.56 UTE
		04/96 RFO	Bobbin	ODI	25	0.64	011	+21.52 UTE
6	11	04/96 RFO	Bobbin	ODI	38	0.38	009	+0.42 UTE
6	12	04/96 RFO	Bobbin	ODI	20	0.27	015	-0.39 UTE
6	18	04/96 RFO	Bobbin	ODI	2	0.52	009	+14.33 UTE
6	22	04/96 RFO	Bobbin	NQI		0.32	009	+12.23 UTE
6	30	04/96 RFO	Bobbin	NQI		0.35	009	+0.52 LTE
		04/96 RFO	Bobbin	NQI		0.36	008	+0.59 LTE
6	33	04/96 RFO	Bobbin	NQI		0.45	007	+13.88 LTE
6	43	04/96 RFO	Bobbin	ODI	39	1.22	008	+9.12 LTE
6	44	04/96 RFO	Bobbin	ODI	10	0.56	008	+10.36 LTE

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
Oconee Nuclear Station - Unit Two
S/G B
04/96 RFO
Bobbin

Page 3 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
6	46	04/96 RFO	Bobbin	ODI	12	0.61	009 +0.56	LTE
6	47	04/96 RFO	Bobbin	ODI	37	0.46	008 +29.49	LTE
6	50	04/96 RFO	Bobbin	NQI		0.33	010 -0.05	LTE
7	3	04/96 RFO	Bobbin	ODI	29	0.37	008 +27.92	UTE
7	4	04/96 RFO	Bobbin	NQI		3.15	015 +41.40	UTE
7	10	04/96 RFO	Bobbin	NQI		0.52	008 +14.13	UTE
7	11	04/96 RFO	Bobbin	ODI	7	0.28	015 -0.26	UTE
7	12	04/96 RFO	Bobbin	NQI		0.49	008 +13.36 to +27.21	UTE
7	14	04/96 RFO	Bobbin	ODI	31	0.78	013 +15.93	UTE
7	15	04/96 RFO	Bobbin	ADI		3.06	LTS +11.24	UTE
7	29	04/96 RFO	Bobbin	ODI	35	0.50	007 +12.47	LTE
7	31	04/96 RFO	Bobbin	NQI		0.37	012 +15.40	LTE
7	34	04/96 RFO	Bobbin	NQI		0.49	006 +31.25	LTE
7	39	04/96 RFO	Bobbin	NQI		0.47	007 +28.32	LTE
7	45	04/96 RFO	Bobbin	NQI		0.64	008 -0.39	LTE
7	46	04/96 RFO	Bobbin	NQI		0.25	009 +0.42	LTE
7	47	04/96 RFO	Bobbin	NQI		0.40	008 +10.21	LTE
7	47	04/96 RFO	Bobbin	NQI		0.37	007 +31.25	LTE
7	50	04/96 RFO	Bobbin	NQI		0.45	008 +12.72	LTE
7	51	04/96 RFO	Bobbin	NQI		0.45	008 +9.06	LTE
7	51	04/96 RFO	Bobbin	NQI		0.39	010 +7.73	LTE
7	52	04/96 RFO	Bobbin	NQI		0.66	008 +31.76	LTE
7	52	04/96 RFO	Bobbin	NQI		0.44	010 +10.34	LTE
7	53	04/96 RFO	Bobbin	ODI	13	0.48	010 +20.46	LTE
7	53	04/96 RFO	Bobbin	NQI		0.54	014 -0.75	LTE
7	53	04/96 RFO	Bobbin	ODI	37	0.82	010 +12.62	LTE
7	53	04/96 RFO	Bobbin	ODI	48	0.81	010 +10.78	LTE
8	1	04/96 RFO	Bobbin	ADI		2.87	001 +31.21	UTE
8	6	04/96 RFO	Bobbin	ODI	27	0.53	008 +14.63	UTE
8	7	04/96 RFO	Bobbin	ODI	28	0.50	008 +11.64	UTE
8	8	04/96 RFO	Bobbin	ODI	8	1.00	008 +12.03	UTE
8	11	04/96 RFO	Bobbin	NQI		1.02	008 +10.11	UTE
8	11	04/96 RFO	Bobbin	ODI	23	0.49	008 +14.68	UTE
8	11	04/96 RFO	Bobbin	ODI	33	0.65	008 +14.11	UTE
8	12	04/96 RFO	Bobbin	ODI	36	0.38	008 +12.63	UTE
8	16	04/96 RFO	Bobbin	ODI	29	0.27	008 +22.63	UTE
8	17	04/96 RFO	Bobbin	ODI	3	0.75	008 +16.72	UTE
8	19	04/96 RFO	Bobbin	ODI	36	0.74	011 +0.34	UTE
8	20	04/96 RFO	Bobbin	ODI	20	0.47	008 +0.16	UTE
8	40	04/96 RFO	Bobbin	NQI		0.75	009 +0.74	LTE
8	49	04/96 RFO	Bobbin	NQI		0.41	007 +31.34	LTE
8	51	04/96 RFO	Bobbin	NQI		0.52	007 +31.04	LTE
8	51	04/96 RFO	Bobbin	ODI	38	0.49	007 +30.48	LTE
9	5	04/96 RFO	Bobbin	NQI		0.34	008 +12.91	UTE
9	31	04/96 RFO	Bobbin	NQI		0.40	006 +33.50	UTE
9	34	04/96 RFO	Bobbin	ADI		1.86	LTS +19.77	LTE
9	34	04/96 RFO	Bobbin	NQI		0.36	006 +34.14	LTE
9	34	04/96 RFO	Bobbin	ODI	30	0.23	009 +0.38	LTE
9	47	04/96 RFO	Bobbin	NQI		0.32	007 +11.81	LTE
9	47	04/96 RFO	Bobbin	NQI		0.43	007 +12.51	LTE
9	51	04/96 RFO	Bobbin	ODI	25	0.12	007 -0.07	LTE
9	54	04/96 RFO	Bobbin	ODI	35	0.36	007 +36.59	LTE
9	56	04/96 RFO	Bobbin	ODI	15	0.40	008 +11.45	LTE
9	58	04/96 RFO	Bobbin	ODI	15	0.45	010 -0.34	LTE
9	59	04/96 RFO	Bobbin	ODI	12	0.55	010 +0.02	LTE
9	62	04/96 RFO	Bobbin	NQI		0.70	010 +5.56	LTE
10	3	04/96 RFO	Bobbin	NQI		0.43	008 +34.60	UTE
10	4	04/96 RFO	Bobbin	ADI		3.49	001 +21.68	UTE
10	5	04/96 RFO	Bobbin	ODI	11	0.87	008 +10.81	UTE
10	9	04/96 RFO	Bobbin	ODI	11	0.55	007 +26.05	UTE
10	11	04/96 RFO	Bobbin	ODI	5	0.95	008 -0.20	UTE
10	13	04/96 RFO	Bobbin	ODI	2	1.18	LTS -1.31	UTE
10	16	04/96 RFO	Bobbin	ODI	29	0.63	015 +35.46	UTE
10	16	04/96 RFO	Bobbin	ODI	56	0.71	014 +12.44	UTE
10	23	04/96 RFO	Bobbin	ODI	23	0.66	008 +0.48	UTE

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
10	30	04/96 RFO	Bobbin	NQI		0.33 006	+35.99	UTE
10	33	04/96 RFO	Bobbin	NQI		1.56 UTS	+14.01	UTE
		04/96 RFO	Bobbin	NQI		6.69 UTS	+14.46	UTE
10	35	04/96 RFO	Bobbin	NQI		0.30 006	+33.18	UTE
10	37	04/96 RFO	Bobbin	NQI		0.52 006	+34.58	UTE
10	55	04/96 RFO	Bobbin	ODI	27	0.83 007	+23.24	UTE
10	56	04/96 RFO	Bobbin	NQI		1.09 007	+27.57	UTE
		04/96 RFO	Bobbin	ODI	14	0.30 007	+28.15	UTE
10	58	04/96 RFO	Bobbin	NQI		0.46 008	+10.98	UTE
		04/96 RFO	Bobbin	IDI	33	0.73 LTE	+12.74	UTE
10	59	04/96 RFO	Bobbin	NQI		0.45 008	+12.76	UTE
		04/96 RFO	Bobbin	ODI	2	0.32 008	+12.42	UTE
10	61	04/96 RFO	Bobbin	NQI		0.42 008	+34.60	UTE
		04/96 RFO	Bobbin	ODI	13	0.62 008	+32.92	UTE
10	63	04/96 RFO	Bobbin	NQI		0.53 010	+0.13	UTE
10	65	04/96 RFO	Bobbin	NQI		0.36 012	+3.98	UTE
11	4	04/96 RFO	Bobbin	ODI	4	1.84 013	+17.94	UTE
11	7	04/96 RFO	Bobbin	ODI	11	0.59 007	+28.06	UTE
11	13	04/96 RFO	Bobbin	NQI		0.47 015	+18.44	UTE
		04/96 RFO	Bobbin	NQI		0.65 015	+17.41	UTE
		04/96 RFO	Bobbin	ODI	30	0.44 015	+19.41	UTE
11	33	04/96 RFO	Bobbin	ODI	10	0.64 006	+33.84	UTE
11	34	04/96 RFO	Bobbin	ODI	31	0.56 006	+34.65	UTE
11	41	04/96 RFO	Bobbin	DWI		7.11 015	+13.52	UTE
11	42	04/96 RFO	Bobbin	ODI	10	0.41 006	+33.75	UTE
11	47	04/96 RFO	Bobbin	DWI		1.84 003	+19.23	UTE
11	57	04/96 RFO	Bobbin	NQI		0.52 007	+21.01	UTE
		04/96 RFO	Bobbin	NQI		0.79 007	+23.23	UTE
11	58	04/96 RFO	Bobbin	ODI	33	0.77 007	+27.70	UTE
11	60	04/96 RFO	Bobbin	NQI		0.67 008	+15.97	UTE
		04/96 RFO	Bobbin	ODI	38	0.37 008	+15.53	UTE
11	61	04/96 RFO	Bobbin	NQI		9.32 LTS	+2.95	UTE
11	62	04/96 RFO	Bobbin	ODI	27	0.54 008	+15.91	UTE
		04/96 RFO	Bobbin	ODI	31	0.42 008	+16.56	UTE
11	63	04/96 RFO	Bobbin	NQI		0.30 009	+0.42	UTE
		04/96 RFO	Bobbin	ODI	7	0.57 008	+29.30	UTE
11	64	04/96 RFO	Bobbin	NQI		0.75 009	+7.18	UTE
11	67	04/96 RFO	Bobbin	NQI		0.65 011	+0.54	UTE
11	68	04/96 RFO	Bobbin	NQI		0.80 012	+4.36	UTE
		04/96 RFO	Bobbin	ODI	8	0.94 013	+3.93	UTE
		04/96 RFO	Bobbin	ODI	22	0.70 014	+31.03	UTE
12	1	04/96 RFO	Bobbin	ODI	28	1.03 014	-0.85	UTE
12	8	04/96 RFO	Bobbin	NQI		1.53 015	+31.85	UTE
12	16	04/96 RFO	Bobbin	ODI	22	0.56 006	+31.88	UTE
12	31	04/96 RFO	Bobbin	ODI	16	0.49 007	-1.34	UTE
12	58	04/96 RFO	Bobbin	ODI	10	0.37 006	+32.00	UTE
12	61	04/96 RFO	Bobbin	NQI		0.50 007	+31.68	UTE
		04/96 RFO	Bobbin	NQI		0.54 008	+0.37	UTE
12	62	04/96 RFO	Bobbin	NQI		8.99 014	+6.72	UTE
12	69	04/96 RFO	Bobbin	ADI		1.21 012	+6.01	UTE
		04/96 RFO	Bobbin	NQI		0.28 011	+0.18	UTE
12	70	04/96 RFO	Bobbin	NQI		0.39 012	+3.89 to +6.73	UTE
		04/96 RFO	Bobbin	NQI		0.40 013	+3.73 to +6.70	UTE
		04/96 RFO	Bobbin	NQI		0.57 011	+4.19 to +8.99	UTE
12	71	04/96 RFO	Bobbin	ADI		1.03 014	+30.50	UTE
		04/96 RFO	Bobbin	NQI		0.77 015	-1.31	UTE
		04/96 RFO	Bobbin	NQI		0.98 013	+4.62	UTE
13	37	04/96 RFO	Bobbin	NQI		0.49 006	+37.19	UTE
13	41	04/96 RFO	Bobbin	NQI		0.40 006	+34.24 to +37.59	UTE
13	63	04/96 RFO	Bobbin	NQI		1.57 015	+10.81	UTE
13	66	04/96 RFO	Bobbin	NQI		0.42 008	+0.34	UTE
		04/96 RFO	Bobbin	ODI	6	0.27 008	-0.16	UTE
		04/96 RFO	Bobbin	NQI		1.00 008	+13.79 to +20.38	UTE
13	68	04/96 RFO	Bobbin	ODI	20	0.54 009	+4.43	UTE
13	69	04/96 RFO	Bobbin	ODI	29	0.72 009	+9.33	UTE

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 5 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
13	71	04/96 RFO	Bobbin	NQI		0.36	010	+13.21 to +25.80
13	72	04/96 RFO	Bobbin	NQI		0.29	011	+10.60
		04/96 RFO	Bobbin	NQI		0.42	010	+18.22
		04/96 RFO	Bobbin	NQI		0.48	012	+4.38
13	73	04/96 RFO	Bobbin	NQI		0.66	013	+5.06
		04/96 RFO	Bobbin	NQI		1.34	014	+2.81
		04/96 RFO	Bobbin	ODI	31	0.68	011	+9.60
13	74	04/96 RFO	Bobbin	NQI		0.36	011	+14.39
		04/96 RFO	Bobbin	ODI	16	0.47	014	+1.16
		04/96 RFO	Bobbin	NQI		0.32	012	+5.78 to +8.12
14	1	04/96 RFO	Bobbin	NQI		0.54	009	+0.57
		04/96 RFO	Bobbin	ODI	31	0.63	013	-0.86
14	14	04/96 RFO	Bobbin	ODI	10	3.27	015	+11.32
14	16	04/96 RFO	Bobbin	ODI	33	0.52	010	+11.05
14	25	04/96 RFO	Bobbin	NQI		1.18	001	+4.40
14	37	04/96 RFO	Bobbin	NQI		0.52	006	+37.41
14	48	04/96 RFO	Bobbin	ODI	31	0.50	006	+31.06
14	59	04/96 RFO	Bobbin	ODI	30	0.33	006	+32.79
14	67	04/96 RFO	Bobbin	ODI	24	0.37	008	+12.66
14	70	04/96 RFO	Bobbin	NQI		0.40	009	+1.93 to +23.37
14	71	04/96 RFO	Bobbin	NQI		0.82	009	+7.11 to +11.41
14	73	04/96 RFO	Bobbin	NQI		0.65	009	+0.64
		04/96 RFO	Bobbin	ODI	27	0.30	010	-0.36
14	74	04/96 RFO	Bobbin	NQI		0.41	011	+11.34 to +17.40
14	75	04/96 RFO	Bobbin	NQI		0.86	011	+7.49 to +12.27
15	3	04/96 RFO	Bobbin	ODI	4	3.23	013	+7.81
15	5	04/96 RFO	Bobbin	NQI		0.33	007	+14.96 to +18.46
15	6	04/96 RFO	Bobbin	ODI	4	0.44	007	+19.82
		04/96 RFO	Bobbin	ODI	12	0.56	007	+20.78
		04/96 RFO	Bobbin	ODI	19	0.58	007	+18.46
15	15	04/96 RFO	Bobbin	ODI	27	8.01	012	+14.36
15	25	04/96 RFO	Bobbin	ODI	31	0.50	006	+31.90
15	27	04/96 RFO	Bobbin	ODI	24	3.62	015	+7.26
15	29	04/96 RFO	Bobbin	NQI		0.45	006	+33.09
15	33	04/96 RFO	Bobbin	ODI	25	0.42	006	+35.72
15	38	04/96 RFO	Bobbin	NQI		0.44	007	+0.34
15	57	04/96 RFO	Bobbin	NQI		0.22	006	+34.62
15	64	04/96 RFO	Bobbin	NQI		0.60	006	+32.73 to +37.39
15	71	04/96 RFO	Bobbin	NQI		0.96	015	-0.92
15	75	04/96 RFO	Bobbin	NQI		0.33	009	-0.79
15	76	04/96 RFO	Bobbin	NQI		0.82	010	+17.60 to +19.26
15	77	04/96 RFO	Bobbin	ODI	4	0.41	012	+2.71
16	1	04/96 RFO	Bobbin	NQI		0.52	010	+0.35
16	5	04/96 RFO	Bobbin	NQI		0.40	007	+14.04
		04/96 RFO	Bobbin	ODI	11	0.64	007	+14.57
		04/96 RFO	Bobbin	ODI	31	0.50	007	+14.97
16	6	04/96 RFO	Bobbin	NQI		0.44	007	+14.23
16	29	04/96 RFO	Bobbin	NQI		0.29	006	+31.95
16	33	04/96 RFO	Bobbin	NQI		0.46	006	+36.06
16	34	04/96 RFO	Bobbin	NQI		0.53	007	+0.85
16	38	04/96 RFO	Bobbin	NQI		0.62	007	-0.95
16	43	04/96 RFO	Bobbin	ODI	35	0.59	007	+1.60
16	45	04/96 RFO	Bobbin	ODI	18	0.39	006	+34.82
16	52	04/96 RFO	Bobbin	ODI	54	0.52	012	+6.47
16	62	04/96 RFO	Bobbin	ODI	34	0.35	013	+1.38
16	75	04/96 RFO	Bobbin	NQI		0.72	009	-0.73
		04/96 RFO	Bobbin	ODI	28	0.47	009	+6.19
		04/96 RFO	Bobbin	ODI	29	0.88	009	+7.69
16	78	04/96 RFO	Bobbin	NQI		0.26	014	+27.88
		04/96 RFO	Bobbin	ODI	11	0.52	010	+18.50
16	81	04/96 RFO	Bobbin	NQI		1.51	014	+29.87 to +33.76
17	4	04/96 RFO	Bobbin	NQI		0.41	007	+19.21 to +22.76
17	5	04/96 RFO	Bobbin	ODI	36	0.44	007	+11.99
17	11	04/96 RFO	Bobbin	ODI	6	2.19	013	+12.30
17	28	04/96 RFO	Bobbin	NQI		0.58	006	+30.52 to +36.15

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 6 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
17	30	04/96 RFO	Bobbin	NQI		0.53 006	+32.46	UTE
17	45	04/96 RFO	Bobbin	NQI		0.42 009	+34.41	UTE
		04/96 RFO	Bobbin	NQI		0.34 010	+5.46 to +23.61	UTE
17	58	04/96 RFO	Bobbin	ODI	11	0.47 006	+34.87	UTE
17	77	04/96 RFO	Bobbin	NQI		0.38 013	+23.19	UTE
		04/96 RFO	Bobbin	ODI	29	2.17 008	+10.46	UTE
17	78	04/96 RFO	Bobbin	NQI		0.50 009	-0.70	UTE
17	79	04/96 RFO	Bobbin	NQI		0.37 010	-0.05	UTE
17	81	04/96 RFO	Bobbin	NQI		0.47 010	+17.92	UTE
		04/96 RFO	Bobbin	NQI		0.73 015	-3.91 to -1.28	UTE
17	82	04/96 RFO	Bobbin	ODI	11	0.67 015	+2.44	UTE
		04/96 RFO	Bobbin	ODI	13	1.28 014	+32.40	UTE
18	14	04/96 RFO	Bobbin	ODI	20	2.87 011	+30.65	UTE
18	37	04/96 RFO	Bobbin	NQI		0.45 012	-0.10	UTE
18	54	04/96 RFO	Bobbin	NQI		0.45 006	+33.30	UTE
		04/96 RFO	Bobbin	NQI		0.46 003	+10.75	UTE
18	55	04/96 RFO	Bobbin	NQI		0.60 006	+34.99	UTE
18	57	04/96 RFO	Bobbin	NQI		0.44 006	+35.16	UTE
		04/96 RFO	Bobbin	ODI	23	0.33 010	+29.02	UTE
18	58	04/96 RFO	Bobbin	NQI		0.53 006	+33.51	UTE
18	61	04/96 RFO	Bobbin	ODI	23	0.25 006	+35.36	UTE
18	62	04/96 RFO	Bobbin	NQI		2.98 012	+19.73	UTE
18	71	04/96 RFO	Bobbin	NQI		0.37 011	+2.45	UTE
18	75	04/96 RFO	Bobbin	ODI	11	0.82 008	+8.91	UTE
18	77	04/96 RFO	Bobbin	NQI		0.53 009	+0.52	UTE
18	79	04/96 RFO	Bobbin	ODI	6	0.69 009	+12.39	UTE
18	80	04/96 RFO	Bobbin	NQI		0.46 009	+17.79	UTE
18	81	04/96 RFO	Bobbin	ODI	24	0.55 009	+0.70	UTE
18	83	04/96 RFO	Bobbin	NQI		0.34 010	+17.61 to +20.73	UTE
18	84	04/96 RFO	Bobbin	NQI		0.38 007	+0.16	UTE
18	85	04/96 RFO	Bobbin	NQI		0.77 014	+33.14	UTE
19	34	04/96 RFO	Bobbin	ADI		5.46 003	+10.21	UTE
19	36	04/96 RFO	Bobbin	NQI		0.66 006	+35.71	UTE
19	56	04/96 RFO	Bobbin	NQI		0.33 006	+31.90	UTE
19	73	04/96 RFO	Bobbin	NQI		0.38 013	+16.94	UTE
19	78	04/96 RFO	Bobbin	ODI	22	0.61 009	+0.50	UTE
19	80	04/96 RFO	Bobbin	ODI	7	0.68 008	-0.29	UTE
		04/96 RFO	Bobbin	ODI	7	0.76 009	+0.29	UTE
19	83	04/96 RFO	Bobbin	ODI	29	0.40 010	+6.73	UTE
20	1	04/96 RFO	Bobbin	ODI	25	0.47 010	-0.23	UTE
20	51	04/96 RFO	Bobbin	ODI	15	0.58 006	+37.05	UTE
20	53	04/96 RFO	Bobbin	ODI	1	0.47 012	+32.38	UTE
		04/96 RFO	Bobbin	ODI	44	0.89 010	+14.50	UTE
		04/96 RFO	Bobbin	ODI	70	0.35 006	+22.05	UTE
20	55	04/96 RFO	Bobbin	NQI		0.52 006	+27.69	UTE
20	68	04/96 RFO	Bobbin	ODI	36	0.41 LTS	+22.72	LTE
20	78	04/96 RFO	Bobbin	NQI		0.61 014	+15.51	UTE
		04/96 RFO	Bobbin	ODI	19	0.52 014	+15.12	UTE
		04/96 RFO	Bobbin	ODI	30	0.59 014	+19.56	UTE
		04/96 RFO	Bobbin	ODI	30	0.64 014	+14.37	UTE
20	80	04/96 RFO	Bobbin	NQI		0.58 012	+12.78	UTE
20	81	04/96 RFO	Bobbin	NQI		0.98 009	+0.71	UTE
		04/96 RFO	Bobbin	ODI	20	0.47 010	+0.57	UTE
20	82	04/96 RFO	Bobbin	ODI	19	0.82 010	+0.55	UTE
21	4	04/96 RFO	Bobbin	ADI		1.72 012	+20.98	UTE
21	24	04/96 RFO	Bobbin	ADI		2.74 001	+5.81	UTE
21	27	04/96 RFO	Bobbin	ODI	16	0.50 006	+32.91	UTE
21	28	04/96 RFO	Bobbin	ODI	32	0.59 006	+30.83	UTE
21	29	04/96 RFO	Bobbin	NQI		0.29 012	+0.15	UTE
21	42	04/96 RFO	Bobbin	NQI		0.12 007	-0.10	UTE
21	52	04/96 RFO	Bobbin	NQI		0.35 002	-0.53	UTE
21	56	04/96 RFO	Bobbin	NQI		0.51 015	+1.50	UTE
21	58	04/96 RFO	Bobbin	NQI		0.65 007	-1.07	UTE
21	64	04/96 RFO	Bobbin	NQI		1.64 008	+16.31	UTE
21	80	04/96 RFO	Bobbin	ODI	21	0.66 007	+10.55	UTE

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 7 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
21	82	04/96 RFO	Bobbin	NQI		0.40 008	+6.54	UTE
21	83	04/96 RFO	Bobbin	NQI		1.31 009	+0.72	UTE
21	85	04/96 RFO	Bobbin	NQI		0.77 009	+0.71	UTE
21	87	04/96 RFO	Bobbin	ODI	90	0.61 009	+8.27 to +14.11	UTE
22	1	04/96 RFO	Bobbin	NQI		1.12 010	+2.88	UTE
22	2	04/96 RFO	Bobbin	NQI		0.43 010	+0.59	UTE
		04/96 RFO	Bobbin	NQI		0.56 010	-0.49	UTE
22	4	04/96 RFO	Bobbin	NQI		0.91 009	+0.61	UTE
22	7	04/96 RFO	Bobbin	NQI		0.88 LTS	+22.30	UTE
22	19	04/96 RFO	Bobbin	NQI		0.41 012	+0.16	UTE
22	23	04/96 RFO	Bobbin	ADI		1.98 009	+11.69	UTE
22	27	04/96 RFO	Bobbin	NQI		0.51 007	+1.30	UTE
22	28	04/96 RFO	Bobbin	NQI		0.50 006	+35.45	UTE
22	30	04/96 RFO	Bobbin	NQI		0.31 006	+33.78 to +37.66	UTS
22	32	04/96 RFO	Bobbin	NQI		0.62 006	+33.29 to +34.85	UTE
22	33	04/96 RFO	Bobbin	NQI		0.47 006	+31.26 to +36.32	UTE
22	36	04/96 RFO	Bobbin	NQI		0.90 013	+7.85 to +13.87	UTE
22	42	04/96 RFO	Bobbin	ODI	18	0.48 006	+33.94	UTE
22	46	04/96 RFO	Bobbin	NQI		0.73 012	-0.58	UTE
22	54	04/96 RFO	Bobbin	NQI		0.39 006	+36.63	UTE
22	58	04/96 RFO	Bobbin	ODI	32	2.61 LTS	+31.51	UTE
22	84	04/96 RFO	Bobbin	ODI	36	0.59 015	+20.11	UTE
22	86	04/96 RFO	Bobbin	ODI	7	0.87 009	+0.92	UTE
		04/96 RFO	Bobbin	ODI	63	1.52 009	-0.68	UTE
22	90	04/96 RFO	Bobbin	NQI		0.36 010	+0.60	UTE
23	2	04/96 RFO	Bobbin	NQI		0.61 010	+0.57	UTE
23	9	04/96 RFO	Bobbin	ADI		2.81 013	+5.90	UTE
23	12	04/96 RFO	Bobbin	ADI		5.43 UTS	+16.49	UTE
		04/96 RFO	Bobbin	NQI		1.41 UTS	+4.93	UTE
23	27	04/96 RFO	Bobbin	NQI		0.30 006	+35.76	UTE
23	28	04/96 RFO	Bobbin	ODI	2	0.43 006	+35.66	UTE
23	37	04/96 RFO	Bobbin	ODI	19	0.24 012	-0.03	UTE
23	41	04/96 RFO	Bobbin	NQI		0.44 006	+31.63	UTE
23	45	04/96 RFO	Bobbin	NQI		0.76 006	+36.07	UTS
23	87	04/96 RFO	Bobbin	ODI	34	0.36 008	+0.29	UTE
23	89	04/96 RFO	Bobbin	NQI		0.48 009	-0.44	UTE
23	92	04/96 RFO	Bobbin	NQI		0.55 010	+0.57	UTE
23	93	04/96 RFO	Bobbin	ODI	37	0.59 014	+32.14	UTE
24	2	04/96 RFO	Bobbin	NQI		0.67 009	+22.86	UTE
		04/96 RFO	Bobbin	NQI		0.81 010	+0.68	UTE
24	6	04/96 RFO	Bobbin	NQI		0.60 009	+0.22	UTE
24	7	04/96 RFO	Bobbin	NQI		0.38 009	+0.22	UTE
24	26	04/96 RFO	Bobbin	NQI		0.49 006	+34.67	UTE
		04/96 RFO	Bobbin	ODI	24	0.48 006	+36.99	UTE
24	28	04/96 RFO	Bobbin	NQI		0.36 006	+32.50 to +36.85	UTE
24	34	04/96 RFO	Bobbin	NQI		0.51 006	+34.95	UTE
24	36	04/96 RFO	Bobbin	NQI		0.43 006	+35.82	UTE
		04/96 RFO	Bobbin	NQI		0.70 012	+0.46	UTE
24	40	04/96 RFO	Bobbin	ODI	35	0.44 006	+33.49	UTE
24	41	04/96 RFO	Bobbin	ODI	8	0.79 006	+30.03	UTE
24	42	04/96 RFO	Bobbin	ODI	49	0.93 012	+0.24	UTE
		04/96 RFO	Bobbin	NQI		0.58 006	+28.01 to +34.58	UTE
24	44	04/96 RFO	Bobbin	NQI		0.43 006	+27.06 to +37.43	UTE
24	47	04/96 RFO	Bobbin	NQI		0.60 006	+25.53	UTE
		04/96 RFO	Bobbin	ODI	39	0.60 006	+25.53	UTE
24	57	04/96 RFO	Bobbin	NQI		0.53 007	-1.25	UTE
24	59	04/96 RFO	Bobbin	NQI		0.53 007	+7.13	UTE
24	88	04/96 RFO	Bobbin	NQI		0.47 007	+0.49	UTE
24	89	04/96 RFO	Bobbin	NQI		1.40 009	-0.71	UTE
24	90	04/96 RFO	Bobbin	NQI		0.16 009	-0.18	UTE
		04/96 RFO	Bobbin	NQI		0.55 009	+0.61	UTE
25	3	04/96 RFO	Bobbin	ODI	44	1.63 010	+0.63	UTE
25	6	04/96 RFO	Bobbin	ODI	50	0.76 009	-0.75	UTE
		04/96 RFO	Bobbin	ODI	71	1.63 009	+0.67	UTE
25	13	04/96 RFO	Bobbin	ADI		2.41 012	+7.97	UTE

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 8 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
25	19	04/96 RFO	Bobbin	ODI	12	1.44	014 +0.82	UTE
25	30	04/96 RFO	Bobbin	NQI		0.31	006 +33.80 to +37.23	UTE
25	32	04/96 RFO	Bobbin	NQI		0.47	006 +33.30	UTE
25	33	04/96 RFO	Bobbin	NQI		4.69	005 +7.62 to +11.92	UTE
25	41	04/96 RFO	Bobbin	NQI		1.22	015 +40.06 to +44.90	UTE
25	42	04/96 RFO	Bobbin	NQI		0.44	015 +38.49	UTE
		04/96 RFO	Bobbin	NQI		0.50	006 +25.88 to +34.29	UTE
25	43	04/96 RFO	Bobbin	NQI		0.56	006 +29.83	UTE
25	44	04/96 RFO	Bobbin	NQI		0.42	006 +30.69	UTE
		04/96 RFO	Bobbin	NQI		0.22	006 +24.78 to +34.06	UTE
25	46	04/96 RFO	Bobbin	ODI	16	0.50	006 +31.24	UTS
25	48	04/96 RFO	Bobbin	NQI		0.52	006 +22.84	UTE
25	49	04/96 RFO	Bobbin	NQI		0.30	012 +0.00	UTE
		04/96 RFO	Bobbin	NQI		0.41	006 +24.27 to +32.42	UTE
25	65	04/96 RFO	Bobbin	NQI		1.19	UTS +19.57	UTE
25	92	04/96 RFO	Bobbin	NQI		0.61	009 -0.82	UTE
25	93	04/96 RFO	Bobbin	NQI		0.86	009 -0.83	UTE
25	94	04/96 RFO	Bobbin	ODI	48	0.51	009 -0.77	UTE
25	95	04/96 RFO	Bobbin	ODI	73	1.33	009 +0.60	UTE
25	98	04/96 RFO	Bobbin	NQI		0.70	015 -1.34	UTE
		04/96 RFO	Bobbin	NQI		0.78	014 +32.25	UTE
26	17	04/96 RFO	Bobbin	ODI	5	0.65	007 +16.12	UTE
		04/96 RFO	Bobbin	ODI	30	1.32	009 +21.25	UTE
26	18	04/96 RFO	Bobbin	NQI		0.48	006 +31.96	UTE
26	26	04/96 RFO	Bobbin	NQI		0.14	006 +33.26	UTE
		04/96 RFO	Bobbin	NQI		0.50	006 +35.95	UTE
		04/96 RFO	Bobbin	ODI	31	0.81	006 +32.53	UTE
26	29	04/96 RFO	Bobbin	NQI		0.68	006 +34.25	UTE
26	30	04/96 RFO	Bobbin	NQI		0.51	007 -0.82	UTE
26	31	04/96 RFO	Bobbin	NQI		0.50	006 +33.35	UTE
26	35	04/96 RFO	Bobbin	NQI		0.37	006 +34.50	UTE
26	38	04/96 RFO	Bobbin	DWI		0.85	015 +44.32	UTE
26	40	04/96 RFO	Bobbin	NQI		0.71	012 -0.27	UTE
26	41	04/96 RFO	Bobbin	NQI		0.50	006 +33.48	UTE
26	45	04/96 RFO	Bobbin	NQI		0.56	006 +26.69	UTE
26	47	04/96 RFO	Bobbin	NQI		0.36	006 +25.84 to +36.42	UTE
26	48	04/96 RFO	Bobbin	ODI	31	0.44	006 +28.77	UTE
26	67	04/96 RFO	Bobbin	NQI		0.26	012 -0.39	UTE
26	87	04/96 RFO	Bobbin	ADI		1.30	LTS +6.46	UTE
		04/96 RFO	Bobbin	ADI		2.48	LTS +8.37	UTE
26	92	04/96 RFO	Bobbin	NQI		0.31	006 +32.27	UTE
		04/96 RFO	Bobbin	NQI		0.32	006 +36.37	UTE
		04/96 RFO	Bobbin	NQI		0.45	006 +33.37	UTE
		04/96 RFO	Bobbin	ODI	4	0.36	006 +33.06	UTE
26	93	04/96 RFO	Bobbin	ODI	23	0.20	015 +2.38	UTE
		04/96 RFO	Bobbin	ODI	28	1.25	015 +2.64	UTE
		04/96 RFO	Bobbin	ODI	31	1.21	009 -0.70	UTE
26	94	04/96 RFO	Bobbin	NQI		0.68	009 +0.61	UTE
26	96	04/96 RFO	Bobbin	NQI		0.53	008 +21.24	UTE
		04/96 RFO	Bobbin	ODI	2	0.60	008 +18.88	UTE
		04/96 RFO	Bobbin	ODI	14	0.57	008 +15.00	UTE
		04/96 RFO	Bobbin	ODI	39	0.35	008 +13.90	UTE
		04/96 RFO	Bobbin	ODI	48	1.12	009 +0.53	UTE
26	98	04/96 RFO	Bobbin	NQI		0.16	010 +0.08	UTE
26	99	04/96 RFO	Bobbin	NQI		0.24	009 -0.71	UTE
27	1	04/96 RFO	Bobbin	NQI		0.55	010 +14.36	UTE
27	5	04/96 RFO	Bobbin	NQI		0.30	009 +0.30	UTE
27	12	04/96 RFO	Bobbin	NQI		0.54	006 +28.42	UTE
27	24	04/96 RFO	Bobbin	NQI		0.64	006 +34.94	UTE
27	33	04/96 RFO	Bobbin	NQI		0.31	012 -0.16	UTE
		04/96 RFO	Bobbin	NQI		0.57	006 +31.51	UTE
		04/96 RFO	Bobbin	NQI		0.57	006 +32.19	UTE
		04/96 RFO	Bobbin	ODI	8	0.69	006 +34.86	UTE
27	34	04/96 RFO	Bobbin	NQI		0.30	006 +33.15	UTE
27	35	04/96 RFO	Bobbin	ODI	37	0.42	006 +29.88	UTE

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
27	38	04/96 RFO	Bobbin	NQI		0.69 006	+35.59	UTE
27	39	04/96 RFO	Bobbin	NQI		0.26 007	-0.05	UTE
27	43	04/96 RFO	Bobbin	ODI	14	0.60 006	+25.56	UTE
		04/96 RFO	Bobbin	ODI	31	0.71 006	+23.87	UTE
27	44	04/96 RFO	Bobbin	NQI		0.48 006	+24.57	UTE
27	45	04/96 RFO	Bobbin	NQI		0.44 006	+22.10	UTE
		04/96 RFO	Bobbin	NQI		0.49 006	+23.41	UTE
		04/96 RFO	Bobbin	NQI		0.49 006	+30.99	UTE
27	58	04/96 RFO	Bobbin	NQI		0.94 LTE	+22.36	UTE
27	92	04/96 RFO	Bobbin	ODI	3	0.45 UTS	+0.26	UTE
27	93	04/96 RFO	Bobbin	ODI	9	0.47 006	+32.97	UTE
		04/96 RFO	Bobbin	ODI	31	0.35 006	+37.04	UTE
27	94	04/96 RFO	Bobbin	NQI		0.26 006	+34.49	UTE
		04/96 RFO	Bobbin	ODI	10	0.36 006	+33.60	UTE
		04/96 RFO	Bobbin	ODI	25	0.29 006	+35.63	UTE
		04/96 RFO	Bobbin	ODI	27	0.29 006	+36.81	UTE
		04/96 RFO	Bobbin	ODI	31	0.28 006	+36.05	UTE
27	98	04/96 RFO	Bobbin	NQI		0.54 008	+9.82	UTE
		04/96 RFO	Bobbin	ODI	69	0.20 013	-0.21	UTE
		04/96 RFO	Bobbin	ODI	74	0.27 009	-0.49	UTE
		04/96 RFO	Bobbin	ODI	84	0.42 008	+11.76	UTE
27	99	04/96 RFO	Bobbin	ODI	3	0.34 009	+0.16	UTE
28	1	04/96 RFO	Bobbin	ODI	36	0.48 010	+10.98	UTE
28	5	04/96 RFO	Bobbin	NQI		0.70 009	+13.44 to +20.88	UTE
28	7	04/96 RFO	Bobbin	NQI		0.69 007	-0.73	UTE
28	16	04/96 RFO	Bobbin	NQI		1.49 LTE	+14.99	UTE
		04/96 RFO	Bobbin	ODI	37	2.10 004	+27.59	UTE
28	21	04/96 RFO	Bobbin	NQI		0.36 006	+32.88	UTE
28	32	04/96 RFO	Bobbin	NQI		0.72 006	+34.76	UTE
28	35	04/96 RFO	Bobbin	ODI	20	0.37 007	-1.59	UTE
28	37	04/96 RFO	Bobbin	NQI		0.29 006	+27.59 to +37.62	UTE
28	38	04/96 RFO	Bobbin	ODI	2	0.58 006	+33.51	UTE
28	39	04/96 RFO	Bobbin	NQI		0.36 006	+26.37	UTE
28	43	04/96 RFO	Bobbin	NQI		0.56 006	+24.98 to +31.41	UTE
28	47	04/96 RFO	Bobbin	NQI		0.46 006	+30.89	UTE
28	48	04/96 RFO	Bobbin	NQI		0.48 006	+29.60	UTE
		04/96 RFO	Bobbin	ODI	2	0.40 006	+23.33	UTE
		04/96 RFO	Bobbin	ODI	37	0.55 006	+22.89	UTE
28	49	04/96 RFO	Bobbin	NQI		0.51 006	+17.05 to +28.09	UTE
28	50	04/96 RFO	Bobbin	NQI		0.42 006	+27.18	UTE
28	56	04/96 RFO	Bobbin	ODI	15	1.02 LTS	-1.42	UTS
28	66	04/96 RFO	Bobbin	NQI		0.65 002	+0.70	UTE
28	79	04/96 RFO	Bobbin	NQI		0.23 015	+34.78	UTE
		04/96 RFO	Bobbin	ODI	36	4.17 003	+38.04	UTE
28	97	04/96 RFO	Bobbin	NQI		0.32 007	+13.10	UTE
28	101	04/96 RFO	Bobbin	NQI		0.33 009	-0.76	UTE
29	1	04/96 RFO	Bobbin	NQI		0.58 014	-0.95	UTE
29	3	04/96 RFO	Bobbin	NQI		0.76 010	+0.57	UTE
29	4	04/96 RFO	Bobbin	NQI		0.86 009	+0.62	UTE
		04/96 RFO	Bobbin	ODI	7	0.47 009	-0.73	UTE
29	7	04/96 RFO	Bobbin	NQI		0.71 009	+0.38	UTE
29	8	04/96 RFO	Bobbin	NQI		0.82 009	+0.59	UTE
		04/96 RFO	Bobbin	NQI		1.14 009	-0.78	UTE
29	10	04/96 RFO	Bobbin	NQI		0.56 006	+32.86	UTE
29	15	04/96 RFO	Bobbin	NQI		0.61 005	+32.34	UTE
29	20	04/96 RFO	Bobbin	NQI		0.46 006	+31.86	UTE
29	26	04/96 RFO	Bobbin	NQI		0.46 006	+35.27	UTE
29	27	04/96 RFO	Bobbin	NQI		0.65 006	+35.05	UTE
29	38	04/96 RFO	Bobbin	NQI		0.46 006	+28.57	UTE
		04/96 RFO	Bobbin	ODI	7	0.71 006	+27.17	UTE
29	39	04/96 RFO	Bobbin	NQI		1.18 LTS	-0.79	UTE
29	40	04/96 RFO	Bobbin	ODI	8	0.42 006	+24.99	UTE
29	41	04/96 RFO	Bobbin	NQI		0.69 012	+0.54	UTE
29	43	04/96 RFO	Bobbin	NQI		0.40 006	+25.68	UTE
29	44	04/96 RFO	Bobbin	ODI	8	0.78 006	+25.14	UTE

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
29	46	04/96 RFO	Bobbin	ODI	19	0.46	006 +20.18	UTE
		04/96 RFO	Bobbin	ODI	28	0.40	006 +26.44	UTE
		04/96 RFO	Bobbin	NQI		1.46	LTE +15.63 to +20.99	UTE
29	49	04/96 RFO	Bobbin	NQI		0.55	006 +18.55 to +26.32	UTE
29	50	04/96 RFO	Bobbin	NQI		0.48	006 +20.32	UTS
29	52	04/96 RFO	Bobbin	NQI		0.52	006 +20.58	UTS
29	76	04/96 RFO	Bobbin	ODI	21	0.42	007 +14.67	UTE
29	89	04/96 RFO	Bobbin	DWI		2.92	009 +23.62	UTE
		04/96 RFO	Bobbin	ODI	22	0.15	007 -0.03	UTE
29	98	04/96 RFO	Bobbin	ODI	5	0.47	006 +34.83	UTE
		04/96 RFO	Bobbin	ODI	12	1.22	015 +20.64	UTE
29	101	04/96 RFO	Bobbin	NQI		0.63	LTS -0.32	UTE
29	102	04/96 RFO	Bobbin	NQI		0.50	007 +32.19	UTE
30	21	04/96 RFO	Bobbin	ODI	11	0.41	006 +35.16	UTE
		04/96 RFO	Bobbin	ODI	13	0.44	006 +33.27	UTE
30	22	04/96 RFO	Bobbin	DWI		0.57	003 -0.30	UTE
30	27	04/96 RFO	Bobbin	ODI	3	0.70	006 +34.25	UTE
30	29	04/96 RFO	Bobbin	NQI		0.39	006 +33.44	UTE
		04/96 RFO	Bobbin	ODI	9	0.38	006 +32.74	UTE
30	30	04/96 RFO	Bobbin	NQI		0.45	006 +35.80	UTS
		04/96 RFO	Bobbin	NQI		0.65	006 +34.21	UTS
30	41	04/96 RFO	Bobbin	NQI		0.54	006 +31.60	UTS
		04/96 RFO	Bobbin	ODI	10	0.52	006 +30.88	UTS
30	47	04/96 RFO	Bobbin	NQI		0.31	006 +22.20	UTE
		04/96 RFO	Bobbin	NQI		0.31	006 +27.49	UTE
		04/96 RFO	Bobbin	NQI		0.36	006 +18.22	UTE
30	49	04/96 RFO	Bobbin	NQI		0.45	006 +19.50	UTE
30	50	04/96 RFO	Bobbin	NQI		0.30	006 +22.44	UTS
30	51	04/96 RFO	Bobbin	NQI		0.66	006 +20.79 to +25.64	UTE
30	52	04/96 RFO	Bobbin	NQI		0.30	006 +17.92	UTS
30	62	04/96 RFO	Bobbin	NQI		0.35	006 +30.35	UTS
30	81	04/96 RFO	Bobbin	NQI		0.30	015 +23.23	UTE
30	85	04/96 RFO	Bobbin	ODI	29	0.35	007 +7.64	UTE
30	100	04/96 RFO	Bobbin	ODI	25	0.42	007 -0.43	UTE
		04/96 RFO	Bobbin	NQI		0.38	006 +30.98 to +37.27	UTE
30	104	04/96 RFO	Bobbin	NQI		0.66	009 +0.55	UTE
		04/96 RFO	Bobbin	NQI		0.66	009 +0.55	UTE
31	1	04/96 RFO	Bobbin	ODI	13	0.47	010 +3.63	FL
		04/96 RFO	Bobbin	ODI	50	0.31	010 +5.65	FL
31	17	04/96 RFO	Bobbin	ADI		1.37	001 +15.47	FL
31	18	04/96 RFO	Bobbin	ODI	82	0.60	015 +39.94	UTE
31	21	04/96 RFO	Bobbin	ODI	25	0.39	006 +33.77	FL
31	23	04/96 RFO	Bobbin	NQI		0.39	006 +34.89	UTE
31	27	04/96 RFO	Bobbin	ODI	15	0.37	006 +33.41	UTE
31	28	04/96 RFO	Bobbin	ODI	22	0.38	006 +35.36	UTE
31	29	04/96 RFO	Bobbin	ODI	25	0.42	006 +33.56	UTE
31	39	04/96 RFO	Bobbin	ODI	28	0.47	006 +21.34	UTE
31	41	04/96 RFO	Bobbin	ODI	23	0.36	006 +18.93	UTE
31	45	04/96 RFO	Bobbin	ODI	10	0.51	007 -0.60	UTE
31	46	04/96 RFO	Bobbin	ODI	35	1.04	012 -0.58	UTE
31	49	04/96 RFO	Bobbin	NQI		0.36	012 -0.47	UTE
31	53	04/96 RFO	Bobbin	ODI	24	0.48	006 +20.22	UTE
31	64	04/96 RFO	Bobbin	NQI		0.36	012 -0.30	UTE
		04/96 RFO	Bobbin	NQI		0.41	007 +1.41	UTE
31	90	04/96 RFO	Bobbin	NQI		0.70	007 -1.07	UTE
31	99	04/96 RFO	Bobbin	NQI		0.42	006 +31.25	UTE
32	1	04/96 RFO	Bobbin	ODI	41	0.40	010 +3.10	FL
32	2	04/96 RFO	Bobbin	NQI		0.81	010 +0.63	UTE
32	3	04/96 RFO	Bobbin	NQI		0.38	009 +38.05	FL
		04/96 RFO	Bobbin	NQI		0.46	LTS +1.22	FL
32	11	04/96 RFO	Bobbin	ODI	57	0.40	007 +30.26	FL
		04/96 RFO	Bobbin	ODI	83	0.41	009 +10.78	FL
32	15	04/96 RFO	Bobbin	NQI		0.56	003 +3.06	FL
32	16	04/96 RFO	Bobbin	ADI		1.85	011 +13.25	UTE
32	17	04/96 RFO	Bobbin	ODI	32	0.39	006 +35.35	FL

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
32	22	04/96 RFO	Bobbin	NQI		0.44 006	+34.80	UTE
32	24	04/96 RFO	Bobbin	ADI		1.32 015	+20.52	UTE
		04/96 RFO	Bobbin	ADI		1.71 004	+1.58	UTE
		04/96 RFO	Bobbin	ADI		2.07 007	+30.13	UTE
		04/96 RFO	Bobbin	ADI		2.65 006	+34.42	UTE
		04/96 RFO	Bobbin	NQI		1.98 010	+24.60	UTE
32	29	04/96 RFO	Bobbin	ODI	28	0.26 006	+32.23 to +36.11	FL
32	36	04/96 RFO	Bobbin	ADI		2.34 003	+24.34	UTS
		04/96 RFO	Bobbin	ADI		3.47 003	+25.90	UTS
32	39	04/96 RFO	Bobbin	DWI		0.89 006	+21.59	UTS
32	42	04/96 RFO	Bobbin	NQI		0.37 006	+28.49	UTS
32	43	04/96 RFO	Bobbin	ODI	14	0.44 006	+30.01	UTS
32	45	04/96 RFO	Bobbin	NQI		0.98 012	-0.58	UTE
32	46	04/96 RFO	Bobbin	NQI		0.31 006	+25.51	FL
32	50	04/96 RFO	Bobbin	ADI		5.11 001	+26.98	UTE
32	59	04/96 RFO	Bobbin	ODI	23	0.30 012	+0.50	UTE
32	62	04/96 RFO	Bobbin	ODI	16	0.51 006	+29.10	UTE
32	104	04/96 RFO	Bobbin	NQI		0.53 007	+6.99	UTE
33	4	04/96 RFO	Bobbin	ODI	14	0.64 009	+24.55	UTE
33	8	04/96 RFO	Bobbin	ODI	36	0.43 008	+0.44	UTE
33	15	04/96 RFO	Bobbin	DWI		3.48 003	+36.18	FL
33	25	04/96 RFO	Bobbin	ODI	16	0.63 006	+34.24	FL
33	28	04/96 RFO	Bobbin	ODI	58	0.48 003	+19.22	FL
33	29	04/96 RFO	Bobbin	ADI		2.66 013	+30.85	UTE
		04/96 RFO	Bobbin	ADI		6.92 001	+21.80	UTE
33	33	04/96 RFO	Bobbin	ODI	38	0.81 011	+21.21	UTE
33	36	04/96 RFO	Bobbin	NQI		1.49 003	+21.94	FL
33	37	04/96 RFO	Bobbin	ODI	71	0.61 006	+26.16	UTE
33	40	04/96 RFO	Bobbin	ODI	6	0.41 006	+18.70	UTS
		04/96 RFO	Bobbin	ODI	25	0.55 006	+21.50	UTS
33	43	04/96 RFO	Bobbin	ODI	16	0.81 LTS	-0.76	FL
33	47	04/96 RFO	Bobbin	DWI		4.90 003	+25.60	UTE
33	48	04/96 RFO	Bobbin	ODI	51	1.30 012	-0.34	UTE
33	52	04/96 RFO	Bobbin	NQI		0.96 LTS	-0.79	UTE
33	54	04/96 RFO	Bobbin	NQI		0.44 005	-0.16	UTS
33	57	04/96 RFO	Bobbin	ODI	7	0.25 010	-0.03	UTE
33	58	04/96 RFO	Bobbin	ADI		1.36 008	+30.34	UTS
		04/96 RFO	Bobbin	ADI		1.55 007	+16.01	UTS
33	60	04/96 RFO	Bobbin	ODI	16	0.49 006	+23.47	UTS
33	66	04/96 RFO	Bobbin	NQI		1.51 004	+5.40	UTE
33	104	04/96 RFO	Bobbin	NQI		0.46 015	+13.10	UTE
33	107	04/96 RFO	Bobbin	NQI		0.61 LTS	-0.40	UTE
		04/96 RFO	Bobbin	NQI		4.49 007	+14.11	UTE
33	108	04/96 RFO	Bobbin	ODI	12	0.56 010	-0.83	UTE
		04/96 RFO	Bobbin	ODI	70	0.52 015	-1.42	UTE
34	4	04/96 RFO	Bobbin	NQI		0.47 009	+27.67	FL
34	5	04/96 RFO	Bobbin	ODI	35	0.63 009	+17.83	UTE
34	6	04/96 RFO	Bobbin	ODI	17	0.55 009	+0.30	FL
34	10	04/96 RFO	Bobbin	NQI		0.40 006	+29.13	FL
34	16	04/96 RFO	Bobbin	DWI		1.62 003	+21.18	FL
		04/96 RFO	Bobbin	DWI		2.92 003	+20.99	UTE
34	20	04/96 RFO	Bobbin	NQI		1.52 LTS	-0.41	FL
		04/96 RFO	Bobbin	NQI		1.49 LTS	-0.41	UTE
34	22	04/96 RFO	Bobbin	NQI		0.55 006	+33.33	FL
34	26	04/96 RFO	Bobbin	ADI		2.92 001	+6.81	UTE
		04/96 RFO	Bobbin	ADI		6.53 001	+11.65	UTE
		04/96 RFO	Bobbin	NQI		1.03 001	+10.92	UTE
34	28	04/96 RFO	Bobbin	NQI		0.95 011	+27.65	UTE
		04/96 RFO	Bobbin	ODI	1	0.64 006	+36.04	UTE
		04/96 RFO	Bobbin	ODI	45	0.80 006	+31.86	UTE
34	37	04/96 RFO	Bobbin	ODI	84	0.73 LTS	-1.11	FL
34	43	04/96 RFO	Bobbin	ODI	18	0.65 012	+0.27	UTE
34	45	04/96 RFO	Bobbin	ADI		4.60 LTS	+38.13	UTS
34	57	04/96 RFO	Bobbin	NQI		0.37 006	+10.94	UTE
34	58	04/96 RFO	Bobbin	DWI		0.79 014	+25.58	UTE

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 12 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
34	66	04/96 RFO	Bobbin	ODI	5	0.68	006	+28.86
34	87	04/96 RFO	Bobbin	ODI	18	0.45	015	+19.81
		04/96 RFO	Bobbin	ODI	27	0.56	012	+31.68
		04/96 RFO	Bobbin	ODI	52	0.27	013	+28.96
34	107	04/96 RFO	Bobbin	ODI	18	0.46	014	+31.87
		04/96 RFO	Bobbin	ODI	66	0.64	010	+0.62
35	2	04/96 RFO	Bobbin	NQI		0.59	009	+32.13
35	4	04/96 RFO	Bobbin	NQI		0.62	009	+25.07
35	5	04/96 RFO	Bobbin	NQI		0.65	009	+0.73
35	21	04/96 RFO	Bobbin	ODI	18	0.86	015	-1.00
35	25	04/96 RFO	Bobbin	NQI		0.55	012	+0.48
35	27	04/96 RFO	Bobbin	ODI	25	0.56	006	+34.30
35	28	04/96 RFO	Bobbin	ODI	18	3.78	LTS	+39.27
		04/96 RFO	Bobbin	ODI	21	4.22	LTS	+37.96
		04/96 RFO	Bobbin	ODI	27	0.80	006	+32.92
35	52	04/96 RFO	Bobbin	NQI		0.36	008	+3.66
35	68	04/96 RFO	Bobbin	NQI		0.55	006	+25.41
35	95	04/96 RFO	Bobbin	ODI	17	1.04	015	+1.03
36	1	04/96 RFO	Bobbin	ODI	22	0.65	LTS	-0.38
36	8	04/96 RFO	Bobbin	ODI	27	0.31	009	+0.35
36	10	04/96 RFO	Bobbin	DWI		0.91	004	+35.38
		04/96 RFO	Bobbin	NQI		0.45	004	+29.31
36	11	04/96 RFO	Bobbin	ODI	27	1.12	LTS	-1.01
36	24	04/96 RFO	Bobbin	ODI	21	0.62	006	+29.00
36	31	04/96 RFO	Bobbin	NQI		0.99	012	-0.49
36	39	04/96 RFO	Bobbin	NQI		2.01	014	+4.57
36	43	04/96 RFO	Bobbin	DWI		2.11	013	+31.03
		04/96 RFO	Bobbin	NQI		1.40	012	-0.14
36	55	04/96 RFO	Bobbin	NQI		0.56	012	-0.44
		04/96 RFO	Bobbin	NQI		0.78	004	-0.76
		04/96 RFO	Bobbin	NQI		1.26	LTS	-0.58
		04/96 RFO	Bobbin	NQI		1.60	LTS	-1.34
36	62	04/96 RFO	Bobbin	ODI	29	0.52	006	+15.42
36	63	04/96 RFO	Bobbin	NQI		0.20	012	-0.45
36	65	04/96 RFO	Bobbin	ODI	28	0.50	012	-0.60
36	75	04/96 RFO	Bobbin	NQI		0.42	006	+30.45
36	81	04/96 RFO	Bobbin	NQI		2.29	015	+18.11
36	113	04/96 RFO	Bobbin	ODI	25	0.57	014	+31.87
37	4	04/96 RFO	Bobbin	NQI		0.38	009	+0.27
		04/96 RFO	Bobbin	NQI		0.28	009	+20.70 to +27.14
37	5	04/96 RFO	Bobbin	ODI	10	0.59	009	+21.45
37	6	04/96 RFO	Bobbin	NQI		1.22	009	+14.60
37	7	04/96 RFO	Bobbin	ODI	18	0.43	009	+8.80
37	14	04/96 RFO	Bobbin	NQI		0.35	006	+26.41 to +34.18
37	15	04/96 RFO	Bobbin	ODI	12	0.49	007	-0.30
37	28	04/96 RFO	Bobbin	NQI		2.52	LTS	-1.15
37	30	04/96 RFO	Bobbin	ADI		3.46	015	+38.66
		04/96 RFO	Bobbin	ODI	37	0.92	LTS	+16.11
37	31	04/96 RFO	Bobbin	DWI		1.30	LTS	+6.02
37	35	04/96 RFO	Bobbin	ODI	22	1.05	014	+16.83
37	37	04/96 RFO	Bobbin	NQI		0.56	006	+20.49
37	45	04/96 RFO	Bobbin	NQI		0.85	LTS	+8.80
37	56	04/96 RFO	Bobbin	NQI		0.32	006	+12.56
		04/96 RFO	Bobbin	ODI	17	0.32	006	+12.08
		04/96 RFO	Bobbin	ODI	33	0.42	006	+11.63
37	110	04/96 RFO	Bobbin	ODI	10	0.51	015	-0.16
38	5	04/96 RFO	Bobbin	NQI		0.28	009	+0.19
38	8	04/96 RFO	Bobbin	WAR	26	0.90	008	+0.00
38	24	04/96 RFO	Bobbin	DWI		1.27	004	+20.59
38	29	04/96 RFO	Bobbin	ODI	4	0.38	006	+34.16
38	32	04/96 RFO	Bobbin	ODI	8	1.03	013	+0.00
38	51	04/96 RFO	Bobbin	ODI	31	0.52	006	+13.12
38	60	04/96 RFO	Bobbin	NQI		0.23	012	+0.08
38	79	04/96 RFO	Bobbin	NQI		0.52	006	+27.75
		04/96 RFO	Bobbin	ODI	4	0.49	006	+26.42

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 13 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
38	85	04/96 RFO	Bobbin	NQI		0.97 015	+44.82	UTE
		04/96 RFO	Bobbin	ODI	11	0.42 015	+4.23	UTE
		04/96 RFO	Bobbin	ODI	25	0.58 014	+14.67	UTE
		04/96 RFO	Bobbin	ODI	33	0.34 015	+27.00	UTE
		04/96 RFO	Bobbin	ODI	39	0.52 015	+35.73	UTE
		04/96 RFO	Bobbin	ODI	42	0.75 014	+12.56	UTE
		04/96 RFO	Bobbin	ODI	46	0.64 014	+3.86	UTE
38	86	04/96 RFO	Bobbin	ODI	20	2.61 LTS	+39.95	FL
38	111	04/96 RFO	Bobbin	ADI		2.56 015	+14.13	UTE
39	4	04/96 RFO	Bobbin	NQI		0.26 009	+18.22	FL
		04/96 RFO	Bobbin	NQI		0.38 009	+22.83	FL
		04/96 RFO	Bobbin	NQI		0.71 008	-0.33	FL
		04/96 RFO	Bobbin	ODI	24	0.79 008	-0.33	FL
39	5	04/96 RFO	Bobbin	NQI		0.39 009	+11.23	UTE
39	8	04/96 RFO	Bobbin	NQI		0.25 008	-0.11	FL
39	25	04/96 RFO	Bobbin	DWI		1.66 011	+14.01	UTE
39	32	04/96 RFO	Bobbin	ADI		1.46 006	+30.87	UTE
39	33	04/96 RFO	Bobbin	NQI		0.27 012	+0.27	UTE
39	36	04/96 RFO	Bobbin	NQI		0.56 007	-0.51	FL
39	56	04/96 RFO	Bobbin	NQI		0.33 004	+1.07	UTE
		04/96 RFO	Bobbin	NQI		0.79 006	+12.65	UTE
39	61	04/96 RFO	Bobbin	NQI		0.47 006	+11.77 to +13.30	UTE
39	115	04/96 RFO	Bobbin	NQI		0.25 LTS	+12.12	FL
		04/96 RFO	Bobbin	ODI	29	0.24 LTS	+12.68	FL
39	116	04/96 RFO	Bobbin	ODI	30	0.66 014	+32.20	UTE
40	1	04/96 RFO	Bobbin	ODI	18	1.35 010	+0.38	UTE
40	5	04/96 RFO	Bobbin	NQI		0.39 008	+0.33	UTE
40	7	04/96 RFO	Bobbin	NQI		0.56 008	+0.49	UTE
40	9	04/96 RFO	Bobbin	NQI		0.42 007	+10.97	UTE
40	12	04/96 RFO	Bobbin	NQI		0.49 006	+31.74	FL
40	18	04/96 RFO	Bobbin	NQI		0.25 007	-0.27	FL
40	29	04/96 RFO	Bobbin	ODI	10	0.70 006	+34.29	FL
40	40	04/96 RFO	Bobbin	NQI		0.87 015	+31.00 to +38.75	FL
40	68	04/96 RFO	Bobbin	ADI		2.98 012	+20.37	UTE
40	82	04/96 RFO	Bobbin	ODI	20	0.45 006	+26.38	UTE
40	87	04/96 RFO	Bobbin	NQI		0.44 010	+28.95	UTS
		04/96 RFO	Bobbin	NQI		0.82 010	+6.45	UTS
40	105	04/96 RFO	Bobbin	NQI		0.42 006	+32.61	UTE
41	15	04/96 RFO	Bobbin	NQI		0.44 014	+31.92	UTE
41	18	04/96 RFO	Bobbin	ODI	4	3.72 006	+18.80	FL
41	20	04/96 RFO	Bobbin	NQI		1.26 014	+0.93	UTE
41	31	04/96 RFO	Bobbin	ODI	5	0.36 007	-0.27	UTE
41	32	04/96 RFO	Bobbin	ODI	14	0.40 006	+32.28	FL
41	38	04/96 RFO	Bobbin	NQI		0.78 007	-0.54	UTS
41	42	04/96 RFO	Bobbin	NQI		0.40 015	+42.48	UTS
41	43	04/96 RFO	Bobbin	NQI		0.64 010	+15.76	UTE
41	56	04/96 RFO	Bobbin	NQI		0.35 015	+1.40	UTE
		04/96 RFO	Bobbin	NQI		0.19 013	+18.94 to +35.82	UTE
		04/96 RFO	Bobbin	NQI		0.27 015	+0.13 to +21.77	UTE
		04/96 RFO	Bobbin	NQI		0.55 014	+0.18 to +35.05	UTE
41	60	04/96 RFO	Bobbin	NQI		0.30 006	+12.51	UTE
41	62	04/96 RFO	Bobbin	NQI		0.35 009	+37.18	UTE
		04/96 RFO	Bobbin	NQI		0.53 009	+34.05	UTE
41	76	04/96 RFO	Bobbin	NQI		0.81 LTE	+18.27	UTE
41	80	04/96 RFO	Bobbin	NQI		0.45 006	+19.34 to +31.00	UTE
41	82	04/96 RFO	Bobbin	NQI		0.65 006	+19.85 to +30.24	UTE
41	96	04/96 RFO	Bobbin	ODI	9	1.46 015	+0.77	UTE
41	103	04/96 RFO	Bobbin	NQI		0.51 012	+5.83	LTE
42	2	04/96 RFO	Bobbin	NQI		0.40 010	+0.74	FL
42	3	04/96 RFO	Bobbin	ODI	7	0.51 009	+7.36	UTE
42	4	04/96 RFO	Bobbin	ODI	10	0.56 008	+34.03	FL
		04/96 RFO	Bobbin	ODI	12	0.59 008	+36.77	FL
		04/96 RFO	Bobbin	ODI	19	0.49 008	+35.30	FL
42	18	04/96 RFO	Bobbin	NQI		0.55 006	+26.54	UTE
42	19	04/96 RFO	Bobbin	NQI		0.27 007	+0.00	FL

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
42	33	04/96 RFO	Bobbin	ADI		1.98	001 +9.45	UTE
42	35	04/96 RFO	Bobbin	ODI	37	0.54	012 +0.00	UTE
42	59	04/96 RFO	Bobbin	ADI		1.08	LTS +5.19	UTE
42	62	04/96 RFO	Bobbin	NQI		0.26	006 +11.06	UTE
42	66	04/96 RFO	Bobbin	ODI	26	0.39	006 +15.29	UTE
42	100	04/96 RFO	Bobbin	NQI		0.43	009 +14.93	UTE
42	113	04/96 RFO	Bobbin	ODI	1	0.45	007 +7.96	UTE
42	116	04/96 RFO	Bobbin	NQI		0.56	007 +28.86 to +31.97	UTE
42	117	04/96 RFO	Bobbin	NQI		0.67	009 +0.54	UTE
43	2	04/96 RFO	Bobbin	NQI		0.52	010 +0.55	UTE
43	3	04/96 RFO	Bobbin	ODI	12	0.55	009 +13.43	UTE
43	21	04/96 RFO	Bobbin	NQI		0.52	012 +14.95	UTE
		04/96 RFO	Bobbin	ODI	12	0.41	012 +24.72	UTE
		04/96 RFO	Bobbin	ODI	19	0.38	011 +12.34	UTE
		04/96 RFO	Bobbin	NQI		0.54	013 +5.69 to +7.15	UTE
43	31	04/96 RFO	Bobbin	ODI	3	3.53	008 +12.23	UTE
43	33	04/96 RFO	Bobbin	NQI		0.45	006 +23.35	UTE
		04/96 RFO	Bobbin	ODI	24	0.39	006 +22.55	UTE
43	38	04/96 RFO	Bobbin	NQI		0.43	007 -0.47	UTE
43	63	04/96 RFO	Bobbin	ODI	7	0.32	009 +14.43	UTS
43	66	04/96 RFO	Bobbin	NQI		0.41	006 +13.16	UTE
43	69	04/96 RFO	Bobbin	NQI		0.26	006 +13.54	UTE
		04/96 RFO	Bobbin	NQI		0.32	006 +11.61	UTE
43	82	04/96 RFO	Bobbin	ODI	18	0.53	006 +28.99	UTE
43	87	04/96 RFO	Bobbin	ODI	19	0.37	015 +34.08	UTE
43	88	04/96 RFO	Bobbin	ODI	13	0.24	007 -0.40	UTE
43	95	04/96 RFO	Bobbin	NQI		0.54	015 +41.38	UTE
43	105	04/96 RFO	Bobbin	NQI		0.53	006 +32.93	UTE
43	106	04/96 RFO	Bobbin	ODI	38	0.51	003 +14.65	UTE
43	115	04/96 RFO	Bobbin	NQI		0.51	007 +19.80	UTE
		04/96 RFO	Bobbin	ODI	9	0.54	007 +15.02	UTE
43	116	04/96 RFO	Bobbin	NQI		0.35	007 +10.68 to +23.65	UTE
44	4	04/96 RFO	Bobbin	ODI	22	0.34	009 +0.05	UTE
44	34	04/96 RFO	Bobbin	NQI		0.38	006 +23.82	UTE
44	53	04/96 RFO	Bobbin	NQI		0.46	015 +41.95	UTE
		04/96 RFO	Bobbin	ODI	14	1.07	011 +21.49	UTE
		04/96 RFO	Bobbin	ODI	22	0.45	015 +37.94	UTE
		04/96 RFO	Bobbin	ODI	29	0.56	015 +6.65	UTE
		04/96 RFO	Bobbin	ODI	65	0.38	011 +20.40	UTE
44	67	04/96 RFO	Bobbin	ADI		2.54	004 +6.17	UTE
44	69	04/96 RFO	Bobbin	NQI		0.45	006 +9.63	UTS
44	78	04/96 RFO	Bobbin	NQI		0.25	006 +15.26	UTS
44	82	04/96 RFO	Bobbin	NQI		0.37	012 +0.08	UTE
		04/96 RFO	Bobbin	NQI		0.29	006 +17.94 to +30.06	UTE
44	87	04/96 RFO	Bobbin	ODI	50	0.75	013 +2.61	UTE
44	91	04/96 RFO	Bobbin	ODI	23	4.93	013 +10.31	UTE
44	96	04/96 RFO	Bobbin	NQI		0.94	015 +15.81 to +17.64	UTE
45	3	04/96 RFO	Bobbin	ODI	32	0.62	009 +9.15	UTE
		04/96 RFO	Bobbin	WAR	57	0.68	009 +0.00	UTE
45	9	04/96 RFO	Bobbin	NQI		0.48	006 +33.08	UTE
45	27	04/96 RFO	Bobbin	ADI		4.70	015 +16.50	UTE
45	33	04/96 RFO	Bobbin	NQI		0.22	012 -0.11	UTE
45	49	04/96 RFO	Bobbin	DWI		0.85	LTS +26.80	UTE
		04/96 RFO	Bobbin	NQI		1.18	006 +21.62	UTE
45	65	04/96 RFO	Bobbin	ODI	23	2.55	UTS +20.73	UTE
45	67	04/96 RFO	Bobbin	ODI	12	0.32	006 +11.46	UTE
		04/96 RFO	Bobbin	ODI	17	0.57	006 +11.19	UTE
45	85	04/96 RFO	Bobbin	NQI		0.34	012 -0.27	UTE
45	87	04/96 RFO	Bobbin	NQI		0.43	006 +18.99 to +33.33	UTE
45	105	04/96 RFO	Bobbin	ODI	26	0.33	006 +34.51	UTE
45	111	04/96 RFO	Bobbin	NQI		0.33	006 +31.07	UTE
45	117	04/96 RFO	Bobbin	NQI		0.34	006 +33.55	UTE
		04/96 RFO	Bobbin	NQI		0.71	007 +8.47	UTE
45	119	04/96 RFO	Bobbin	NQI		0.53	007 +27.67	UTE
		04/96 RFO	Bobbin	ODI	2	0.53	007 +25.92	UTE

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
45	120	04/96 RFO	Bobbin	NQI		0.51 012	+26.22	UTE
		04/96 RFO	Bobbin	NQI		0.69 014	+32.20	UTE
		04/96 RFO	Bobbin	NQI		0.85 010	+8.95	UTE
46	2	04/96 RFO	Bobbin	WAR	40	0.90 010	+0.63	UTE
46	27	04/96 RFO	Bobbin	NQI		1.23 015	+18.96	UTS
46	71	04/96 RFO	Bobbin	ODI	11	0.52 006	+10.12	UTE
46	75	04/96 RFO	Bobbin	NQI		0.57 006	+12.05	UTE
46	81	04/96 RFO	Bobbin	ODI	36	0.73 012	+0.38	UTE
46	84	04/96 RFO	Bobbin	NQI		0.24 006	+19.60	UTE
46	85	04/96 RFO	Bobbin	NQI		0.39 006	+20.57	UTE
46	88	04/96 RFO	Bobbin	NQI		0.61 007	+0.91	UTE
46	101	04/96 RFO	Bobbin	ODI	21	0.39 006	+37.14	UTE
46	115	04/96 RFO	Bobbin	NQI		0.41 006	+32.24	UTE
46	117	04/96 RFO	Bobbin	ODI	11	0.54 007	+31.12	UTE
47	3	04/96 RFO	Bobbin	NQI		0.43 004	+8.02	UTE
47	20	04/96 RFO	Bobbin	ODI	39	0.50 014	+19.84	UTE
47	41	04/96 RFO	Bobbin	ADI		3.67 007	+30.14	UTE
47	45	04/96 RFO	Bobbin	ADI		3.24 UTS	+14.52	UTE
47	48	04/96 RFO	Bobbin	NQI		0.54 006	+14.97	UTE
47	52	04/96 RFO	Bobbin	NQI		1.57 LTE	+2.32	UTE
47	55	04/96 RFO	Bobbin	NQI		1.28 013	+30.62	UTE
47	59	04/96 RFO	Bobbin	NQI		0.49 006	-0.45	UTE
47	70	04/96 RFO	Bobbin	ODI	53	1.61 012	-0.57	UTE
47	105	04/96 RFO	Bobbin	ODI	22	0.26 012	+0.27	UTE
47	106	04/96 RFO	Bobbin	NQI		0.51 006	+33.72	UTE
47	108	04/96 RFO	Bobbin	NQI		0.30 006	+34.98	UTE
47	111	04/96 RFO	Bobbin	NQI		0.37 001	+17.83	UTE
47	119	04/96 RFO	Bobbin	ODI	30	0.61 007	+29.72	UTE
47	120	04/96 RFO	Bobbin	ODI	29	0.59 007	+36.56	UTE
48	2	04/96 RFO	Bobbin	ODI	13	0.51 010	+0.69	UTE
48	4	04/96 RFO	Bobbin	NQI		0.64 010	+0.52	UTE
48	5	04/96 RFO	Bobbin	ODI	28	0.95 008	+20.39	UTE
		04/96 RFO	Bobbin	ODI	35	0.73 008	+22.60	UTE
48	16	04/96 RFO	Bobbin	NQI		0.48 006	+26.36 to +31.79	UTE
48	32	04/96 RFO	Bobbin	NQI		1.34 LTS	+40.74	UTE
48	39	04/96 RFO	Bobbin	ODI	20	1.61 004	-1.67	UTE
48	43	04/96 RFO	Bobbin	NQI		0.24 006	+12.31	UTE
		04/96 RFO	Bobbin	NQI		0.35 006	+11.69	UTE
		04/96 RFO	Bobbin	ODI	10	0.64 015	+44.48	UTE
		04/96 RFO	Bobbin	ODI	12	0.86 015	+43.36	UTE
		04/96 RFO	Bobbin	ODI	72	0.49 015	+41.19	UTE
48	44	04/96 RFO	Bobbin	NQI		0.38 006	+10.38	UTE
48	45	04/96 RFO	Bobbin	NQI		0.22 006	+11.17 to +14.07	UTE
48	48	04/96 RFO	Bobbin	NQI		0.38 006	+10.07	015
48	67	04/96 RFO	Bobbin	NQI		1.14 LTS	-1.25	UTE
48	74	04/96 RFO	Bobbin	NQI		0.42 006	+9.72	UTE
48	77	04/96 RFO	Bobbin	NQI		0.41 006	+9.12	UTE
48	78	04/96 RFO	Bobbin	NQI		0.27 006	+8.28 to +12.96	UTE
48	83	04/96 RFO	Bobbin	NQI		0.56 006	+21.29	UTE
48	90	04/96 RFO	Bobbin	NQI		0.38 006	+29.79	UTE
48	103	04/96 RFO	Bobbin	ODI	33	0.39 007	+2.64	UTE
48	106	04/96 RFO	Bobbin	NQI		6.95 015	+0.33	UTE
48	115	04/96 RFO	Bobbin	NQI		0.30 006	+31.58	UTE
		04/96 RFO	Bobbin	NQI		0.34 006	+32.60	UTE
48	119	04/96 RFO	Bobbin	NQI		0.66 006	+33.17	UTE
48	121	04/96 RFO	Bobbin	NQI		0.82 008	+5.68	UTE
49	3	04/96 RFO	Bobbin	ODI	31	0.36 009	+10.47	UTE
49	14	04/96 RFO	Bobbin	NQI		0.26 006	+28.82	UTE
		04/96 RFO	Bobbin	ODI	22	0.23 006	+27.90	UTE
49	20	04/96 RFO	Bobbin	NQI		0.33 006	+21.24	UTE
49	27	04/96 RFO	Bobbin	NQI		0.63 006	+23.30	UTE
49	31	04/96 RFO	Bobbin	ADI		1.46 015	+30.92 to +41.52	UTE
49	46	04/96 RFO	Bobbin	ODI	4	0.32 006	+10.78	UTS
49	53	04/96 RFO	Bobbin	NQI		0.38 012	+0.23	UTE
49	66	04/96 RFO	Bobbin	NQI		0.62 009	+35.35	UTE

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 16 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
49	82	04/96 RFO	Bobbin	NQI		0.38	006	+10.90
		04/96 RFO	Bobbin	ODI	14	0.76	015	-0.88
49	84	04/96 RFO	Bobbin	ODI	1	0.76	015	-0.88
49	98	04/96 RFO	Bobbin	ODI	6	0.24	015	+16.55
		04/96 RFO	Bobbin	ODI	43	0.28	015	+33.75
49	99	04/96 RFO	Bobbin	ODI	38	1.96	014	+3.96
		04/96 RFO	Bobbin	ODI	47	1.91	014	+4.71
49	103	04/96 RFO	Bobbin	ODI	17	0.50	007	+5.65
49	105	04/96 RFO	Bobbin	NQI		0.47	LTS	+38.75
49	106	04/96 RFO	Bobbin	ODI	2	0.54	007	+1.28
		04/96 RFO	Bobbin	ODI	4	0.40	006	+36.54
		04/96 RFO	Bobbin	ODI	18	0.31	006	+37.03
49	114	04/96 RFO	Bobbin	ODI	20	0.39	002	+1.21
49	120	04/96 RFO	Bobbin	NQI		0.75	007	+16.74 to +27.07
50	3	04/96 RFO	Bobbin	NQI		0.36	008	+30.27
50	4	04/96 RFO	Bobbin	NQI		0.54	008	+12.89 to +18.83
50	5	04/96 RFO	Bobbin	ODI	22	0.28	008	+2.74
		04/96 RFO	Bobbin	NQI		0.40	007	+33.92 to +37.07
50	28	04/96 RFO	Bobbin	ODI	36	0.32	006	+22.46
50	32	04/96 RFO	Bobbin	NQI		1.94	004	+0.91
50	47	04/96 RFO	Bobbin	ODI	39	0.37	006	+11.34
50	48	04/96 RFO	Bobbin	ODI	31	0.65	006	+10.82
50	55	04/96 RFO	Bobbin	ADI		6.56	011	+5.46
50	65	04/96 RFO	Bobbin	ADI		1.00	LTS	+35.90
50	77	04/96 RFO	Bobbin	DWI		0.79	014	+26.33
50	79	04/96 RFO	Bobbin	NQI		0.56	006	+0.41
50	81	04/96 RFO	Bobbin	NQI		0.80	003	+0.57
50	84	04/96 RFO	Bobbin	NQI		0.39	009	+24.22
50	90	04/96 RFO	Bobbin	NQI		0.26	006	+23.46 to +29.76
50	107	04/96 RFO	Bobbin	ODI	40	0.42	006	+36.06
50	122	04/96 RFO	Bobbin	ODI	85	1.06	009	+0.55
51	3	04/96 RFO	Bobbin	ODI	25	0.64	008	+27.44
51	4	04/96 RFO	Bobbin	NQI		0.49	008	+3.21 to +36.88
51	24	04/96 RFO	Bobbin	NQI		0.41	015	+0.14
51	27	04/96 RFO	Bobbin	ODI	8	0.86	014	+10.95
		04/96 RFO	Bobbin	ODI	18	1.38	015	+14.35
		04/96 RFO	Bobbin	ODI	32	1.38	015	+43.51
51	29	04/96 RFO	Bobbin	ODI	16	2.45	015	+9.45
51	30	04/96 RFO	Bobbin	NQI		0.52	006	+23.41
51	34	04/96 RFO	Bobbin	NQI		0.43	006	+20.50
51	40	04/96 RFO	Bobbin	NQI		0.42	011	+22.10
51	42	04/96 RFO	Bobbin	NQI		2.83	004	+7.56
		04/96 RFO	Bobbin	NQI		3.12	003	+23.18
51	51	04/96 RFO	Bobbin	NQI		0.41	006	+10.41
51	60	04/96 RFO	Bobbin	NQI		2.20	002	+33.64
		04/96 RFO	Bobbin	NQI		3.67	002	+32.66
51	76	04/96 RFO	Bobbin	ODI	14	0.29	006	+8.59
51	90	04/96 RFO	Bobbin	ODI	29	0.49	006	+22.54
51	91	04/96 RFO	Bobbin	NQI		0.80	006	+27.91
51	99	04/96 RFO	Bobbin	ODI	36	0.70	014	+11.40
51	108	04/96 RFO	Bobbin	NQI		0.37	006	+37.35
51	112	04/96 RFO	Bobbin	NQI		0.34	003	+24.09
		04/96 RFO	Bobbin	ODI	2	0.74	001	+29.88
		04/96 RFO	Bobbin	ODI	2	0.84	001	+31.27
51	117	04/96 RFO	Bobbin	ODI	46	0.57	015	+25.06
51	118	04/96 RFO	Bobbin	ODI	10	0.30	006	+32.90
51	120	04/96 RFO	Bobbin	ODI	34	0.34	007	+15.95
51	122	04/96 RFO	Bobbin	ODI	8	0.37	008	+11.44
		04/96 RFO	Bobbin	ODI	16	0.48	007	+37.66
51	123	04/96 RFO	Bobbin	ODI	1	0.81	008	+30.70
51	124	04/96 RFO	Bobbin	ODI	18	0.35	009	+0.00
		04/96 RFO	Bobbin	ODI	31	0.27	007	-0.30
52	2	04/96 RFO	Bobbin	NQI		0.73	012	+32.32
		04/96 RFO	Bobbin	NQI		0.48	011	+1.30 to +35.91
		04/96 RFO	Bobbin	NQI		1.24	010	+9.25 to +34.20

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTS

UTE

UTS

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTS

UTE

UTE

UTE

UTS

UTS

UTE

UTE

UTE

FL

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

UTE

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	NQI		1.51	015	+11.74 to +45.22
52	4	04/96 RFO	Bobbin	NQI		0.41	008	+12.60 to +21.42
52	5	04/96 RFO	Bobbin	ODI	6	0.42	008	+8.96
		04/96 RFO	Bobbin	ODI	14	0.46	008	+11.08
52	6	04/96 RFO	Bobbin	NQI		0.47	007	+21.93 to +29.73
52	24	04/96 RFO	Bobbin	NQI		0.41	006	+28.40
52	26	04/96 RFO	Bobbin	ADI		4.46	015	+8.95
52	41	04/96 RFO	Bobbin	NQI		0.91	015	+38.11
52	44	04/96 RFO	Bobbin	NQI		0.53	007	+0.49
52	49	04/96 RFO	Bobbin	ODI	29	1.21	002	+4.82
52	65	04/96 RFO	Bobbin	NQI		5.76	013	+13.60
52	70	04/96 RFO	Bobbin	NQI		0.20	006	-0.18
52	71	04/96 RFO	Bobbin	ODI	35	0.44	006	+6.83
52	74	04/96 RFO	Bobbin	ODI	2	0.49	006	+8.73
		04/96 RFO	Bobbin	ODI	34	0.67	006	+6.38
52	75	04/96 RFO	Bobbin	NQI		0.69	004	+32.22
52	83	04/96 RFO	Bobbin	NQI		0.87	015	-0.92
52	85	04/96 RFO	Bobbin	ODI	26	0.27	006	+16.53
52	89	04/96 RFO	Bobbin	ODI	3	0.46	006	+25.45
52	99	04/96 RFO	Bobbin	NQI		0.25	015	+30.08
		04/96 RFO	Bobbin	NQI		0.26	015	+30.36
52	101	04/96 RFO	Bobbin	NQI		0.22	007	-0.32
52	113	04/96 RFO	Bobbin	NQI		0.52	005	+6.84
52	122	04/96 RFO	Bobbin	ODI	19	0.30	007	+37.69
		04/96 RFO	Bobbin	ODI	56	0.51	008	+5.65
52	124	04/96 RFO	Bobbin	ODI	8	0.64	008	+27.32
52	125	04/96 RFO	Bobbin	NQI		0.33	009	-0.11
		04/96 RFO	Bobbin	ODI	5	0.44	010	+4.13
53	4	04/96 RFO	Bobbin	NQI		0.42	008	+16.29
53	6	04/96 RFO	Bobbin	DWI		2.79	LTS	+42.36
53	14	04/96 RFO	Bobbin	NQI		0.36	006	+28.64
53	16	04/96 RFO	Bobbin	NQI		0.97	007	+7.96
53	24	04/96 RFO	Bobbin	NQI		0.24	006	+25.28
53	30	04/96 RFO	Bobbin	NQI		0.43	006	+20.60
		04/96 RFO	Bobbin	ODI	16	0.55	006	+23.12
53	34	04/96 RFO	Bobbin	ADI		5.39	LTS	+33.81
53	49	04/96 RFO	Bobbin	NQI		0.49	006	+9.90
53	57	04/96 RFO	Bobbin	ADI		6.80	001	+31.72
53	75	04/96 RFO	Bobbin	NQI		0.38	006	+10.71
53	76	04/96 RFO	Bobbin	NQI		0.62	006	+10.80
53	84	04/96 RFO	Bobbin	ODI	23	1.52	015	-0.83
53	89	04/96 RFO	Bobbin	NQI		0.23	012	+0.16
53	100	04/96 RFO	Bobbin	NQI		2.00	015	+25.53
53	101	04/96 RFO	Bobbin	NQI		0.23	001	+15.44
53	103	04/96 RFO	Bobbin	NQI		0.23	012	+0.19
53	106	04/96 RFO	Bobbin	NQI		0.45	007	+3.94
53	111	04/96 RFO	Bobbin	ODI	24	0.24	001	+27.63
53	112	04/96 RFO	Bobbin	NQI		0.19	001	-0.16
		04/96 RFO	Bobbin	ODI	18	0.61	001	+11.40
53	121	04/96 RFO	Bobbin	ODI	11	0.35	006	+33.07
53	122	04/96 RFO	Bobbin	ODI	36	0.57	006	+34.33
53	124	04/96 RFO	Bobbin	NQI		0.48	008	+16.41
53	126	04/96 RFO	Bobbin	ODI	14	0.58	010	+2.44
54	5	04/96 RFO	Bobbin	NQI		0.36	010	+23.67
		04/96 RFO	Bobbin	NQI		0.44	005	+7.14
		04/96 RFO	Bobbin	ODI	38	0.27	011	+31.46
54	18	04/96 RFO	Bobbin	NQI		0.30	006	+31.91
		04/96 RFO	Bobbin	NQI		0.36	006	+28.90
54	23	04/96 RFO	Bobbin	NQI		0.49	015	+13.93
54	25	04/96 RFO	Bobbin	ODI	17	0.43	006	+26.59
		04/96 RFO	Bobbin	ODI	29	0.59	006	+26.97
54	26	04/96 RFO	Bobbin	ODI	17	0.60	012	+0.74
54	27	04/96 RFO	Bobbin	NQI		0.30	006	+27.41
		04/96 RFO	Bobbin	ODI	23	0.52	006	+26.26
54	29	04/96 RFO	Bobbin	NQI		0.38	006	+31.03

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 18 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	NQI		0.41	006	+25.58
		04/96 RFO	Bobbin	NQI		0.50	006	+24.98
54	31	04/96 RFO	Bobbin	NQI		0.47	006	+20.77 to +32.61
54	60	04/96 RFO	Bobbin	ODI	24	0.86	012	+0.48
54	77	04/96 RFO	Bobbin	DWI		1.49	015	+28.10
54	85	04/96 RFO	Bobbin	NQI		1.49	015	-0.82
54	87	04/96 RFO	Bobbin	ODI	24	0.44	015	+45.53
54	103	04/96 RFO	Bobbin	NQI		0.54	012	+0.33
54	111	04/96 RFO	Bobbin	NQI		0.35	012	-0.28
54	113	04/96 RFO	Bobbin	NQI		1.63	003	+31.37
		04/96 RFO	Bobbin	ODI	5	0.75	002	+2.91
		04/96 RFO	Bobbin	ODI	15	1.19	004	+8.91
		04/96 RFO	Bobbin	ODI	25	0.51	005	+0.08
54	114	04/96 RFO	Bobbin	DWI		1.78	014	+11.37
		04/96 RFO	Bobbin	DWI		2.42	015	+3.24
		04/96 RFO	Bobbin	DWI		3.24	015	+29.94
54	119	04/96 RFO	Bobbin	NQI		0.37	015	+34.05
		04/96 RFO	Bobbin	NQI		0.50	015	+33.29
		04/96 RFO	Bobbin	ODI	39	0.69	015	+44.29
54	122	04/96 RFO	Bobbin	NQI		0.65	006	+33.83
		04/96 RFO	Bobbin	ODI	20	0.32	006	+34.79
54	124	04/96 RFO	Bobbin	ODI	20	0.22	008	+8.75
54	125	04/96 RFO	Bobbin	NQI		0.63	009	+0.43
55	4	04/96 RFO	Bobbin	ODI	16	0.60	008	+30.55
55	5	04/96 RFO	Bobbin	ODI	27	0.47	008	+14.95
55	19	04/96 RFO	Bobbin	NQI		0.27	006	+30.39
55	23	04/96 RFO	Bobbin	NQI		0.66	006	+33.25
55	26	04/96 RFO	Bobbin	NQI		0.72	LTS	-0.33
55	27	04/96 RFO	Bobbin	NQI		0.30	006	+24.75
55	47	04/96 RFO	Bobbin	NQI		0.44	006	+8.53 to +13.63
55	50	04/96 RFO	Bobbin	ADI		2.45	015	+38.59
55	53	04/96 RFO	Bobbin	NQI		0.40	006	+9.01
55	77	04/96 RFO	Bobbin	ODI	5	1.78	001	+26.26
		04/96 RFO	Bobbin	ODI	19	0.67	006	+9.09
55	82	04/96 RFO	Bobbin	NQI		0.27	006	+8.99
55	85	04/96 RFO	Bobbin	NQI		0.25	012	+0.00
55	103	04/96 RFO	Bobbin	NQI		0.41	007	-0.35
55	119	04/96 RFO	Bobbin	ODI	19	0.38	006	+33.45
55	123	04/96 RFO	Bobbin	DWI		2.55	002	+1.85
		04/96 RFO	Bobbin	ODI	26	0.40	009	+0.41
55	124	04/96 RFO	Bobbin	NQI		0.50	009	+0.48
		04/96 RFO	Bobbin	NQI		0.60	008	+10.07
55	125	04/96 RFO	Bobbin	ODI	31	0.85	008	+36.15
55	126	04/96 RFO	Bobbin	NQI		0.30	010	+0.25
56	3	04/96 RFO	Bobbin	ODI	34	1.41	011	+11.17
56	5	04/96 RFO	Bobbin	ADI		6.74	012	+7.08
56	15	04/96 RFO	Bobbin	NQI		0.41	006	+28.91
56	25	04/96 RFO	Bobbin	NQI		0.41	006	+23.52
56	29	04/96 RFO	Bobbin	NQI		0.29	006	+24.85
56	34	04/96 RFO	Bobbin	NQI		0.44	015	+38.87
		04/96 RFO	Bobbin	ODI	7	2.04	012	+24.71
56	36	04/96 RFO	Bobbin	ADI		2.44	003	+3.12
		04/96 RFO	Bobbin	ODI	5	0.84	013	+16.66
56	61	04/96 RFO	Bobbin	ODI	52	0.60	006	+24.37
56	79	04/96 RFO	Bobbin	ODI	16	4.49	001	+7.71
56	88	04/96 RFO	Bobbin	ODI	5	2.05	015	-0.84
56	96	04/96 RFO	Bobbin	DWI		1.45	015	+35.13
		04/96 RFO	Bobbin	DWI		2.22	015	+23.66
		04/96 RFO	Bobbin	DWI		3.11	015	+41.78
56	97	04/96 RFO	Bobbin	ODI	16	0.33	006	+28.02
		04/96 RFO	Bobbin	ODI	28	0.41	006	+27.66
56	111	04/96 RFO	Bobbin	ODI	14	0.30	007	+3.60
		04/96 RFO	Bobbin	ODI	14	0.31	002	+0.41
56	112	04/96 RFO	Bobbin	NQI		1.88	003	+29.44
		04/96 RFO	Bobbin	ODI	51	0.47	009	+5.03

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
56	127	04/96 RFO	Bobbin	ODI	11	0.46	009 -0.27	FL
57	4	04/96 RFO	Bobbin	ADI		0.76	008 +14.73	UTE
57	5	04/96 RFO	Bobbin	ODI	24	0.38	008 +15.41	UTE
		04/96 RFO	Bobbin	ODI	35	0.39	008 +18.27	UTE
57	7	04/96 RFO	Bobbin	ODI	10	0.45	007 +23.40	UTE
57	10	04/96 RFO	Bobbin	ODI	14	0.52	006 +32.12	UTE
57	15	04/96 RFO	Bobbin	ODI	18	0.29	012 +0.44	UTE
57	24	04/96 RFO	Bobbin	ADI		11.27	LTS +4.40	UTE
57	30	04/96 RFO	Bobbin	ODI	4	0.42	006 +23.89	UTE
57	32	04/96 RFO	Bobbin	NQI		0.43	006 +20.55	UTE
57	35	04/96 RFO	Bobbin	ODI	12	0.72	013 +13.13	UTE
57	44	04/96 RFO	Bobbin	NQI		0.31	006 +12.70	UTS
		04/96 RFO	Bobbin	ODI	10	0.36	006 +12.41	UTS
		04/96 RFO	Bobbin	ODI	12	0.45	006 +12.60	UTE
		04/96 RFO	Bobbin	ODI	15	0.27	006 +12.06	UTS
57	51	04/96 RFO	Bobbin	DWI		6.87	LTS -0.14	UTE
57	54	04/96 RFO	Bobbin	ODI	10	0.40	006 +9.63	UTE
57	55	04/96 RFO	Bobbin	ODI	63	0.51	007 +1.55	UTE
57	68	04/96 RFO	Bobbin	ODI	32	0.53	012 -0.23	FL
57	69	04/96 RFO	Bobbin	NQI		1.10	012 -0.68	UTE
57	71	04/96 RFO	Bobbin	ODI	27	0.59	012 -0.03	UTE
57	80	04/96 RFO	Bobbin	ODI	14	0.66	006 +8.24	UTE
57	90	04/96 RFO	Bobbin	ODI	4	0.35	007 +6.33	UTE
57	94	04/96 RFO	Bobbin	ODI	20	0.50	012 -0.38	UTE
57	108	04/96 RFO	Bobbin	ODI	10	0.46	007 +4.16	UTE
57	122	04/96 RFO	Bobbin	ODI	44	0.42	006 +33.84	UTE
57	124	04/96 RFO	Bobbin	ODI	28	0.39	007 +26.65	UTE
57	127	04/96 RFO	Bobbin	NQI		0.72	010 +0.60	UTE
58	1	04/96 RFO	Bobbin	NQI		1.45	009 -0.76	UTE
58	7	04/96 RFO	Bobbin	ODI	23	0.51	007 +28.20	UTE
58	21	04/96 RFO	Bobbin	ODI	19	0.48	006 +33.83	UTE
58	24	04/96 RFO	Bobbin	NQI		0.40	012 +31.10	UTE
58	27	04/96 RFO	Bobbin	NQI		0.41	012 +0.27	UTE
		04/96 RFO	Bobbin	ODI	16	0.61	012 -0.52	UTE
58	32	04/96 RFO	Bobbin	ODI	31	0.40	006 +20.76	UTE
58	36	04/96 RFO	Bobbin	ODI	14	1.14	015 +4.95	UTE
58	37	04/96 RFO	Bobbin	NQI		0.98	LTS -0.27	UTE
		04/96 RFO	Bobbin	ODI	10	0.32	006 +20.82	UTE
		04/96 RFO	Bobbin	ODI	34	0.34	006 +19.73	UTE
58	43	04/96 RFO	Bobbin	NQI		0.45	006 +0.44	UTE
58	46	04/96 RFO	Bobbin	NQI		0.37	007 +21.89	UTE
58	49	04/96 RFO	Bobbin	ODI	28	0.44	006 +9.83	UTE
58	51	04/96 RFO	Bobbin	NQI		0.38	006 +9.23	UTE
		04/96 RFO	Bobbin	ODI	29	0.59	006 +8.22	UTE
58	53	04/96 RFO	Bobbin	ODI	20	0.47	006 +8.82	UTE
		04/96 RFO	Bobbin	ODI	26	0.26	006 +8.33	UTE
58	65	04/96 RFO	Bobbin	ADI		1.58	LTS +23.36	FL
		04/96 RFO	Bobbin	ADI		1.77	LTS +23.84	UTE
58	68	04/96 RFO	Bobbin	NQI		0.45	006 +8.07	UTE
58	71	04/96 RFO	Bobbin	NQI		0.86	010 +15.91	UTE
		04/96 RFO	Bobbin	NQI		1.28	010 +16.96	UTE
58	72	04/96 RFO	Bobbin	NQI		0.92	014 +17.18	UTE
		04/96 RFO	Bobbin	ODI	19	0.42	006 +2.37	UTE
58	74	04/96 RFO	Bobbin	NQI		0.20	006 +6.39	UTE
		04/96 RFO	Bobbin	NQI		0.24	006 +4.87	UTE
		04/96 RFO	Bobbin	NQI		0.25	006 +7.57	UTE
		04/96 RFO	Bobbin	NQI		0.32	006 +6.68	UTE
58	76	04/96 RFO	Bobbin	NQI		0.94	007 +0.19	UTE
58	77	04/96 RFO	Bobbin	ODI	22	0.42	006 +7.21	UTE
58	85	04/96 RFO	Bobbin	NQI		0.42	015 +43.42	UTE
58	90	04/96 RFO	Bobbin	NQI		1.28	004 -0.76	UTE
58	96	04/96 RFO	Bobbin	ODI	32	0.26	006 +18.80	UTE
58	98	04/96 RFO	Bobbin	NQI		0.24	001 +1.45	UTE
58	99	04/96 RFO	Bobbin	ODI	36	0.51	015 +33.47	UTE
		04/96 RFO	Bobbin	ODI	74	0.34	015 +33.82	UTE

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
58	100	04/96 RFO	Bobbin	ODI	45	0.48	015	+19.07
58	104	04/96 RFO	Bobbin	DWI		0.31	006	+35.52
58	106	04/96 RFO	Bobbin	ODI	24	0.46	007	+3.48
58	111	04/96 RFO	Bobbin	ODI	24	1.13	004	+7.40
58	114	04/96 RFO	Bobbin	ODI	45	0.77	007	+5.71
58	116	04/96 RFO	Bobbin	ODI	34	0.49	007	+1.23
58	119	04/96 RFO	Bobbin	NQI		0.25	012	-0.36
58	123	04/96 RFO	Bobbin	NQI		0.37	006	+36.01
58	126	04/96 RFO	Bobbin	ODI	27	0.41	009	-0.16
58	127	04/96 RFO	Bobbin	ODI	28	0.85	009	-0.08
58	128	04/96 RFO	Bobbin	ODI	22	1.21	010	+0.65
59	2	04/96 RFO	Bobbin	NQI		0.22	008	+11.32
		04/96 RFO	Bobbin	ODI	12	0.31	008	+11.00
59	24	04/96 RFO	Bobbin	ODI	36	0.23	006	+36.67
59	34	04/96 RFO	Bobbin	ADI		2.06	009	+26.51
59	36	04/96 RFO	Bobbin	DWI		0.54	007	+24.64
		04/96 RFO	Bobbin	NQI		0.50	015	+32.25
		04/96 RFO	Bobbin	ODI	3	0.77	008	+22.30
59	39	04/96 RFO	Bobbin	NQI		0.35	011	+0.27
59	40	04/96 RFO	Bobbin	ODI	14	0.44	006	+20.79
59	42	04/96 RFO	Bobbin	ODI	29	0.45	006	+11.02
59	52	04/96 RFO	Bobbin	ODI	10	0.35	006	+9.51
		04/96 RFO	Bobbin	ODI	31	0.28	006	+12.28
59	54	04/96 RFO	Bobbin	NQI		0.43	006	+5.23
59	83	04/96 RFO	Bobbin	ADI		8.76	006	+23.96
59	89	04/96 RFO	Bobbin	ODI	83	0.42	013	+11.99
59	91	04/96 RFO	Bobbin	ODI	46	0.33	014	+23.72
59	107	04/96 RFO	Bobbin	NQI		0.35	007	+5.76
		04/96 RFO	Bobbin	ODI	61	0.46	007	+5.02
59	108	04/96 RFO	Bobbin	NQI		0.60	001	+4.53
		04/96 RFO	Bobbin	ODI	20	0.28	006	+28.18
		04/96 RFO	Bobbin	ODI	25	0.35	006	+29.52
59	116	04/96 RFO	Bobbin	ODI	62	0.67	006	-0.14
		04/96 RFO	Bobbin	NQI		1.12	005	+27.95 to +37.00
		04/96 RFO	Bobbin	NQI		1.93	006	+0.00 to +3.92
59	119	04/96 RFO	Bobbin	ODI	12	0.76	LTS	+2.33
		04/96 RFO	Bobbin	ODI	34	0.48	006	+36.17
59	121	04/96 RFO	Bobbin	NQI		0.56	008	+16.90
		04/96 RFO	Bobbin	ODI	26	0.52	008	+13.32
60	4	04/96 RFO	Bobbin	NQI		0.93	012	+31.91
		04/96 RFO	Bobbin	ODI	33	1.13	012	+29.89
		04/96 RFO	Bobbin	ODI	38	1.19	012	+31.11
		04/96 RFO	Bobbin	ODI	47	0.71	012	+19.48
60	13	04/96 RFO	Bobbin	ODI	15	0.30	007	+1.23
60	14	04/96 RFO	Bobbin	ODI	33	3.25	007	+9.59
60	21	04/96 RFO	Bobbin	ODI	35	1.09	012	+0.76
60	23	04/96 RFO	Bobbin	ODI	34	0.37	006	+34.25
60	26	04/96 RFO	Bobbin	ODI	12	0.41	006	+32.17
60	35	04/96 RFO	Bobbin	ADI		2.57	013	+20.66
60	37	04/96 RFO	Bobbin	DWI		0.45	LTS	+26.90
		04/96 RFO	Bobbin	DWI		0.45	LTS	+38.53
		04/96 RFO	Bobbin	DWI		0.49	LTS	+43.59
		04/96 RFO	Bobbin	DWI		0.72	LTS	+4.05
		04/96 RFO	Bobbin	NQI		0.36	006	+17.97
		04/96 RFO	Bobbin	ODI	26	0.68	LTS	+44.25
60	38	04/96 RFO	Bobbin	NQI		0.45	006	+18.63 to +27.41
60	48	04/96 RFO	Bobbin	NQI		0.74	006	+11.60
60	50	04/96 RFO	Bobbin	ODI	34	0.55	012	-0.11
60	51	04/96 RFO	Bobbin	NQI		0.48	006	+10.17
60	80	04/96 RFO	Bobbin	ODI	34	0.43	006	+5.60
60	81	04/96 RFO	Bobbin	NQI		0.55	011	+20.73
60	86	04/96 RFO	Bobbin	ODI	10	0.90	005	+30.31
		04/96 RFO	Bobbin	ODI	36	0.58	005	+31.30
60	90	04/96 RFO	Bobbin	ODI	32	0.32	006	+11.87
		04/96 RFO	Bobbin	ODI	42	0.29	006	+12.72

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 21 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
60	92	04/96 RFO	Bobbin	NQI		0.35 006	+15.22	UTE
60	112	04/96 RFO	Bobbin	NQI		1.40 015	+1.02	UTE
60	120	04/96 RFO	Bobbin	ODI	9	0.86 006	+34.18	UTE
60	125	04/96 RFO	Bobbin	ODI	17	0.48 009	-0.73	UTE
60	126	04/96 RFO	Bobbin	NQI		0.38 008	+0.44	UTE
		04/96 RFO	Bobbin	ODI	6	1.31 008	+8.12	UTE
60	127	04/96 RFO	Bobbin	NQI		0.34 009	-0.73	UTE
61	3	04/96 RFO	Bobbin	ODI	5	0.34 008	+7.93	UTE
61	6	04/96 RFO	Bobbin	ODI	10	0.51 007	+37.67	FL
61	9	04/96 RFO	Bobbin	NQI		0.30 006	+32.80	UTE
61	20	04/96 RFO	Bobbin	NQI		0.33 006	+36.00	UTE
61	29	04/96 RFO	Bobbin	ODI	14	1.16 015	+14.77	FL
61	35	04/96 RFO	Bobbin	ODI	14	3.43 005	+6.17	FL
61	36	04/96 RFO	Bobbin	NQI		0.35 006	+18.67	UTE
61	40	04/96 RFO	Bobbin	NQI		0.67 012	+0.22	UTE
61	47	04/96 RFO	Bobbin	NQI		0.55 004	+0.57	FL
61	48	04/96 RFO	Bobbin	NQI		0.19 012	+0.05	UTE
61	55	04/96 RFO	Bobbin	NQI		2.23 LTS	-0.82	UTE
61	69	04/96 RFO	Bobbin	NQI		0.91 012	+0.46	UTE
61	77	04/96 RFO	Bobbin	ODI	30	0.44 012	-0.11	UTE
61	91	04/96 RFO	Bobbin	ODI	16	0.33 012	+0.16	UTE
61	92	04/96 RFO	Bobbin	ODI	38	0.52 006	+16.33	UTE
61	99	04/96 RFO	Bobbin	ODI	41	0.91 014	+6.50	UTE
61	102	04/96 RFO	Bobbin	NQI		0.46 006	+32.58	UTE
61	124	04/96 RFO	Bobbin	ODI	6	0.52 015	+21.67	UTE
		04/96 RFO	Bobbin	ODI	6	0.64 015	+4.10	UTE
		04/96 RFO	Bobbin	ODI	55	1.61 009	+0.59	UTE
61	125	04/96 RFO	Bobbin	ODI	2	0.99 010	+16.51	UTE
		04/96 RFO	Bobbin	ODI	4	0.46 010	+23.57	UTE
		04/96 RFO	Bobbin	ODI	20	0.39 010	+18.35	UTE
		04/96 RFO	Bobbin	ODI	32	0.59 011	-0.73	UTE
62	2	04/96 RFO	Bobbin	NQI		0.85 008	+8.11 to +10.91	UTE
62	13	04/96 RFO	Bobbin	NQI		0.51 001	+17.38	FL
62	21	04/96 RFO	Bobbin	NQI		0.30 006	+34.82	FL
62	24	04/96 RFO	Bobbin	NQI		0.55 012	+0.44	UTE
62	26	04/96 RFO	Bobbin	NQI		0.32 006	+31.15 to +35.59	UTE
62	38	04/96 RFO	Bobbin	ODI	14	0.36 006	+20.06	FL
		04/96 RFO	Bobbin	ODI	20	0.30 006	+17.85	FL
62	39	04/96 RFO	Bobbin	NQI		0.37 006	+13.05	UTE
62	44	04/96 RFO	Bobbin	NQI		0.52 006	+12.71 to +18.01	UTE
62	46	04/96 RFO	Bobbin	NQI		0.43 015	+27.37	UTE
		04/96 RFO	Bobbin	NQI		0.44 006	+0.08	UTE
62	49	04/96 RFO	Bobbin	NQI		2.03 UTS	+13.75	FL
62	50	04/96 RFO	Bobbin	ODI	12	0.44 006	+12.08	UTE
62	51	04/96 RFO	Bobbin	NQI		1.27 LTE	+11.96	FL
		04/96 RFO	Bobbin	ODI	38	0.25 006	+8.48	FL
62	52	04/96 RFO	Bobbin	NQI		0.40 006	+5.84 to +11.99	UTE
62	54	04/96 RFO	Bobbin	ODI	26	0.14 006	-0.29	UTE
62	71	04/96 RFO	Bobbin	ODI	53	0.45 012	+0.00	UTE
62	72	04/96 RFO	Bobbin	ODI	2	0.42 006	+1.35	UTE
62	98	04/96 RFO	Bobbin	ODI	4	0.88 013	+18.78	UTE
		04/96 RFO	Bobbin	ODI	14	0.77 014	+26.48	UTE
		04/96 RFO	Bobbin	ODI	15	0.45 012	+28.91	UTE
		04/96 RFO	Bobbin	ODI	27	0.50 014	+27.30	UTE
		04/96 RFO	Bobbin	ODI	39	0.35 014	+26.91	UTE
		04/96 RFO	Bobbin	ODI	55	0.59 012	+28.19	UTE
62	100	04/96 RFO	Bobbin	ODI	40	0.70 014	+12.78	UTE
62	104	04/96 RFO	Bobbin	ODI	32	0.44 006	+30.57	UTE
		04/96 RFO	Bobbin	ODI	34	0.47 006	+30.59	LTE
62	113	04/96 RFO	Bobbin	NQI		0.63 015	+0.44	UTE
62	122	04/96 RFO	Bobbin	ADI		10.12 LTE	+12.13	UTE
62	126	04/96 RFO	Bobbin	NQI		0.49 008	+12.48	UTE
		04/96 RFO	Bobbin	NQI		0.49 008	+16.74	UTE
		04/96 RFO	Bobbin	NQI		0.52 008	+20.62	UTE
62	127	04/96 RFO	Bobbin	NQI		0.55 009	+0.62	UTE

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 22 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
62	128	04/96 RFO	Bobbin	NQI		1.05	009	-0.51
63	24	04/96 RFO	Bobbin	NQI		0.44	015	+44.74
63	25	04/96 RFO	Bobbin	ODI	39	0.44	006	+33.17
63	28	04/96 RFO	Bobbin	NQI		0.35	006	+34.55
63	38	04/96 RFO	Bobbin	ODI	27	0.60	013	+32.09
		04/96 RFO	Bobbin	NQI		0.55	006	+12.89 to +20.45
		04/96 RFO	Bobbin	NQI		0.89	015	+0.00 to +40.52
63	40	04/96 RFO	Bobbin	NQI		0.44	006	+21.69
63	47	04/96 RFO	Bobbin	NQI		0.45	005	+24.06
63	53	04/96 RFO	Bobbin	ODI	29	0.62	012	+0.49
63	59	04/96 RFO	Bobbin	NQI		0.56	012	+0.11
63	70	04/96 RFO	Bobbin	NQI		0.20	012	+0.24
63	94	04/96 RFO	Bobbin	ODI	34	0.42	006	+14.20
		04/96 RFO	Bobbin	NQI		0.27	006	+11.26 to +14.00
63	96	04/96 RFO	Bobbin	ODI	12	0.44	006	+15.93
63	99	04/96 RFO	Bobbin	ODI	4	0.48	014	+23.35
		04/96 RFO	Bobbin	ODI	29	0.39	012	+23.21
63	100	04/96 RFO	Bobbin	NQI		0.44	009	+20.26
		04/96 RFO	Bobbin	NQI		0.44	011	+7.88
		04/96 RFO	Bobbin	NQI		0.49	010	+32.32
63	105	04/96 RFO	Bobbin	ODI	2	0.45	006	+32.66
63	106	04/96 RFO	Bobbin	NQI		0.58	006	+33.15
63	107	04/96 RFO	Bobbin	ODI	4	0.67	006	+33.63
63	108	04/96 RFO	Bobbin	NQI		0.41	015	+21.01
		04/96 RFO	Bobbin	NQI		0.56	015	+34.28
		04/96 RFO	Bobbin	ODI	33	0.51	012	-0.16
		04/96 RFO	Bobbin	ODI	33	0.53	012	+0.33
63	116	04/96 RFO	Bobbin	NQI		0.50	005	+0.11
		04/96 RFO	Bobbin	ODI	36	0.56	006	+35.31
63	122	04/96 RFO	Bobbin	ODI	6	0.58	006	+37.20
63	126	04/96 RFO	Bobbin	NQI		0.71	009	+0.51
63	128	04/96 RFO	Bobbin	ODI	30	1.33	009	+0.59
		04/96 RFO	Bobbin	ODI	64	0.98	009	-0.81
63	129	04/96 RFO	Bobbin	ODI	10	0.96	010	+10.46
		04/96 RFO	Bobbin	ODI	20	0.45	010	+12.08
64	4	04/96 RFO	Bobbin	NQI		0.39	009	+0.50
64	9	04/96 RFO	Bobbin	NQI		0.46	006	+31.17
64	17	04/96 RFO	Bobbin	NQI		0.50	006	+34.00
64	28	04/96 RFO	Bobbin	ADI		2.16	015	+40.56
		04/96 RFO	Bobbin	ADI		2.81	008	+14.34
64	32	04/96 RFO	Bobbin	ODI	33	0.41	006	+33.47
64	40	04/96 RFO	Bobbin	NQI		0.62	013	-0.19
64	49	04/96 RFO	Bobbin	NQI		0.49	006	+9.62 to +12.90
64	52	04/96 RFO	Bobbin	NQI		0.39	003	+0.08
64	59	04/96 RFO	Bobbin	NQI		0.53	006	+0.95
64	72	04/96 RFO	Bobbin	NQI		0.98	012	+0.14
64	99	04/96 RFO	Bobbin	NQI		0.46	005	+1.15
64	105	04/96 RFO	Bobbin	ODI	17	0.34	006	+24.55
		04/96 RFO	Bobbin	ODI	21	0.79	006	+25.09
64	112	04/96 RFO	Bobbin	ODI	36	0.48	015	+3.43
64	117	04/96 RFO	Bobbin	NQI		0.78	006	-0.05
64	124	04/96 RFO	Bobbin	NQI		0.67	009	-0.68
64	125	04/96 RFO	Bobbin	ODI	19	0.93	008	+16.48
		04/96 RFO	Bobbin	ODI	21	0.42	015	+27.56
		04/96 RFO	Bobbin	ODI	66	1.49	009	-0.51
64	128	04/96 RFO	Bobbin	NQI		0.60	011	-0.70
64	129	04/96 RFO	Bobbin	ODI	17	0.50	010	+19.59
65	1	04/96 RFO	Bobbin	ODI	10	0.55	012	+11.78
65	3	04/96 RFO	Bobbin	NQI		0.44	012	-0.54
65	7	04/96 RFO	Bobbin	ODI	12	0.47	006	+34.64
65	8	04/96 RFO	Bobbin	NQI		0.36	009	+0.49
65	9	04/96 RFO	Bobbin	NQI		0.42	006	+32.29
65	11	04/96 RFO	Bobbin	ODI	28	0.35	009	+0.43
65	17	04/96 RFO	Bobbin	NQI		0.33	007	-0.38
65	30	04/96 RFO	Bobbin	ADI		1.01	006	+35.96

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	ADI		6.17	015	FL
65	37	04/96 RFO	Bobbin	ADI		4.80	015	UTE
		04/96 RFO	Bobbin	NQI		0.48	015	UTE
		04/96 RFO	Bobbin	NQI		0.96	014	UTE
		04/96 RFO	Bobbin	ODI	10	1.71	015	UTE
65	76	04/96 RFO	Bobbin	NQI		0.24	009	UTE
65	93	04/96 RFO	Bobbin	ODI	24	0.64	006	UTE
65	115	04/96 RFO	Bobbin	ODI	63	0.59	015	UTE
65	118	04/96 RFO	Bobbin	ODI	36	0.30	007	UTE
65	121	04/96 RFO	Bobbin	NQI		0.75	006	UTE
65	127	04/96 RFO	Bobbin	ODI	62	0.68	009	UTE
		04/96 RFO	Bobbin	ODI	82	1.13	009	UTE
65	129	04/96 RFO	Bobbin	NQI		0.41	010	UTE
		04/96 RFO	Bobbin	ODI	10	0.42	009	UTE
65	130	04/96 RFO	Bobbin	NQI		0.27	002	UTE
		04/96 RFO	Bobbin	NQI		0.71	011	UTE
		04/96 RFO	Bobbin	ODI	37	0.51	002	UTE
66	2	04/96 RFO	Bobbin	NQI		0.50	010	014
66	8	04/96 RFO	Bobbin	ODI	19	0.25	001	UTE
66	14	04/96 RFO	Bobbin	NQI		0.39	010	UTE
66	25	04/96 RFO	Bobbin	NQI		0.40	006	FL
66	33	04/96 RFO	Bobbin	ODI	5	0.75	010	FL
		04/96 RFO	Bobbin	ODI	16	0.69	011	FL
66	78	04/96 RFO	Bobbin	DWI		1.04	012	UTE
66	101	04/96 RFO	Bobbin	ADI		1.97	012	UTE
		04/96 RFO	Bobbin	ADI		2.11	015	UTE
66	106	04/96 RFO	Bobbin	ODI	29	0.55	006	UTE
66	116	04/96 RFO	Bobbin	ODI	17	0.43	007	UTE
66	123	04/96 RFO	Bobbin	ODI	5	0.50	006	UTE
66	125	04/96 RFO	Bobbin	ODI	36	0.42	007	UTE
66	126	04/96 RFO	Bobbin	NQI		0.96	008	UTE
66	127	04/96 RFO	Bobbin	ODI	4	0.72	008	UTE
67	2	04/96 RFO	Bobbin	NQI		0.70	009	014
67	5	04/96 RFO	Bobbin	ODI	45	0.52	012	014
67	39	04/96 RFO	Bobbin	NQI		0.40	006	UTE
67	63	04/96 RFO	Bobbin	NQI		0.42	008	UTE
		04/96 RFO	Bobbin	NQI		0.66	002	UTE
67	102	04/96 RFO	Bobbin	NQI		0.42	006	UTE
67	108	04/96 RFO	Bobbin	NQI		0.60	012	UTE
67	113	04/96 RFO	Bobbin	ODI	53	2.31	015	UTE
67	121	04/96 RFO	Bobbin	ODI	2	0.64	006	UTE
67	123	04/96 RFO	Bobbin	ODI	2	0.86	006	UTE
67	125	04/96 RFO	Bobbin	ODI	17	0.26	008	UTE
67	126	04/96 RFO	Bobbin	NQI		0.91	009	UTE
67	128	04/96 RFO	Bobbin	NQI		0.51	009	UTE
67	129	04/96 RFO	Bobbin	NQI		0.43	009	UTE
68	13	04/96 RFO	Bobbin	ODI	7	0.80	003	FL
68	16	04/96 RFO	Bobbin	NQI		0.28	008	UTE
68	19	04/96 RFO	Bobbin	NQI		0.41	007	FL
68	38	04/96 RFO	Bobbin	NQI		1.07	012	UTE
68	63	04/96 RFO	Bobbin	ODI	28	0.42	007	UTE
68	67	04/96 RFO	Bobbin	NQI		0.71	006	UTE
68	75	04/96 RFO	Bobbin	NQI		0.21	006	UTE
68	77	04/96 RFO	Bobbin	NQI		0.43	015	UTE
68	98	04/96 RFO	Bobbin	ODI	25	0.51	006	UTE
68	106	04/96 RFO	Bobbin	ODI	31	0.49	006	UTE
68	108	04/96 RFO	Bobbin	NQI		0.37	006	LTE
68	112	04/96 RFO	Bobbin	ODI	7	1.30	015	UTE
68	113	04/96 RFO	Bobbin	NQI		3.32	UTS	UTE
		04/96 RFO	Bobbin	ODI	17	1.01	015	UTE
68	115	04/96 RFO	Bobbin	NQI		0.82	012	UTE
68	127	04/96 RFO	Bobbin	NQI		1.78	009	UTE
69	1	04/96 RFO	Bobbin	NQI		0.62	009	014
69	2	04/96 RFO	Bobbin	NQI		0.70	010	014
69	4	04/96 RFO	Bobbin	NQI		0.44	009	014

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 24 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
69	5	04/96 RFO	Bobbin	NQI		0.60 009	-0.69	014
69	8	04/96 RFO	Bobbin	ODI	36	0.45 008	+0.56	014
69	9	04/96 RFO	Bobbin	ODI	23	0.42 008	+0.56	014
69	24	04/96 RFO	Bobbin	ODI	4	0.56 003	+22.75	UTE
69	31	04/96 RFO	Bobbin	NQI		0.26 010	+0.38	UTS
69	36	04/96 RFO	Bobbin	ODI	27	0.43 006	+33.18	UTS
69	41	04/96 RFO	Bobbin	ODI	6	0.43 006	+27.85	UTE
69	47	04/96 RFO	Bobbin	NQI		0.30 006	+13.82	UTE
		04/96 RFO	Bobbin	ODI	32	0.78 015	+34.17	UTE
		04/96 RFO	Bobbin	ODI	44	1.20 014	+17.24	UTE
69	70	04/96 RFO	Bobbin	NQI		0.75 011	+24.59 to +27.46	UTE
69	84	04/96 RFO	Bobbin	NQI		0.63 006	-0.55	UTE
69	104	04/96 RFO	Bobbin	NQI		1.21 015	+7.62	UTE
69	107	04/96 RFO	Bobbin	NQI		0.39 006	+29.73 to +34.09	UTE
69	110	04/96 RFO	Bobbin	NQI		0.54 012	+11.46 to +30.66	UTE
69	113	04/96 RFO	Bobbin	ODI	42	1.56 015	+0.03	UTE
69	120	04/96 RFO	Bobbin	ODI	16	0.77 007	-1.02	UTE
69	129	04/96 RFO	Bobbin	NQI		1.22 009	+0.00	UTE
69	130	04/96 RFO	Bobbin	ODI	23	0.27 009	+16.03	UTE
69	131	04/96 RFO	Bobbin	ODI	22	0.99 010	+0.54	FL
69	132	04/96 RFO	Bobbin	ODI	34	0.65 004	+15.26	UTE
70	4	04/96 RFO	Bobbin	NQI		0.69 008	+0.59	014
		04/96 RFO	Bobbin	NQI		0.70 009	-0.66	014
		04/96 RFO	Bobbin	ODI	16	0.74 009	+11.80	014
70	5	04/96 RFO	Bobbin	ODI	58	0.41 011	+28.20	014
70	6	04/96 RFO	Bobbin	NQI		0.35 008	+0.48	014
70	7	04/96 RFO	Bobbin	NQI		0.71 009	+0.53	014
70	9	04/96 RFO	Bobbin	NQI		0.36 008	+0.40	014
70	17	04/96 RFO	Bobbin	ODI	15	0.28 004	-0.14	UTE
70	27	04/96 RFO	Bobbin	ODI	7	3.85 015	+18.77	UTS
		04/96 RFO	Bobbin	ODI	23	0.66 008	+21.52	UTS
70	31	04/96 RFO	Bobbin	ADI		0.83 008	+8.76	UTE
70	33	04/96 RFO	Bobbin	ODI	64	0.50 015	+2.74	UTE
70	39	04/96 RFO	Bobbin	ODI	29	0.25 007	+0.33	UTE
70	44	04/96 RFO	Bobbin	NQI		0.29 015	+18.95	UTE
		04/96 RFO	Bobbin	NQI		0.69 015	+19.94	UTE
		04/96 RFO	Bobbin	ODI	40	0.38 014	+14.67	UTE
		04/96 RFO	Bobbin	ODI	63	0.69 015	+19.94	UTE
70	51	04/96 RFO	Bobbin	ODI	14	0.54 006	+0.43	UTE
70	60	04/96 RFO	Bobbin	ODI	29	0.62 007	+16.63	LTE
70	69	04/96 RFO	Bobbin	ODI	7	0.58 008	+12.30	LTE
70	70	04/96 RFO	Bobbin	ADI		1.78 008	+7.91	LTE
70	80	04/96 RFO	Bobbin	NQI		0.54 015	-0.05	LTE
70	81	04/96 RFO	Bobbin	NQI		0.62 006	+1.16	LTE
70	97	04/96 RFO	Bobbin	NQI		0.56 011	+24.11	UTE
70	100	04/96 RFO	Bobbin	ADI		4.15 LTS	+11.81	UTE
70	106	04/96 RFO	Bobbin	NQI		0.59 006	+27.97	UTE
70	112	04/96 RFO	Bobbin	NQI		1.19 008	+3.85 to +35.75	UTE
70	127	04/96 RFO	Bobbin	NQI		0.48 007	+20.12	LTE
		04/96 RFO	Bobbin	ODI	20	0.55 007	+19.75	LTE
		04/96 RFO	Bobbin	ODI	34	0.70 009	-0.29	LTE
70	130	04/96 RFO	Bobbin	NQI		0.71 011	+15.03 to +20.15	UTE
71	1	04/96 RFO	Bobbin	NQI		0.35 013	+30.48	014
71	2	04/96 RFO	Bobbin	NQI		0.52 010	+0.56	014
71	4	04/96 RFO	Bobbin	NQI		0.47 009	-0.67	014
71	5	04/96 RFO	Bobbin	NQI		0.57 008	-0.67	014
71	12	04/96 RFO	Bobbin	NQI		0.54 010	+0.44	UTE
71	13	04/96 RFO	Bobbin	ODI	4	0.29 010	+0.41	UTE
71	17	04/96 RFO	Bobbin	NQI		0.83 010	+0.44	UTE
71	18	04/96 RFO	Bobbin	ODI	10	0.65 010	+0.44	UTE
71	19	04/96 RFO	Bobbin	ODI	10	0.23 010	+0.71	UTE
71	20	04/96 RFO	Bobbin	ODI	1	0.45 010	+0.47	UTE
71	23	04/96 RFO	Bobbin	ODI	27	0.18 010	+0.35	UTE
71	26	04/96 RFO	Bobbin	ODI	15	0.29 009	+0.27	UTE
		04/96 RFO	Bobbin	ODI	18	0.16 010	+0.19	UTE

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
71	39	04/96 RFO	Bobbin	NQI		0.22 015	-0.22	UTE
71	41	04/96 RFO	Bobbin	ODI	16	0.46 008	+10.26	UTE
71	47	04/96 RFO	Bobbin	ODI	35	0.48 005	+0.11	UTE
71	48	04/96 RFO	Bobbin	NQI		0.54 014	+8.28	UTE
		04/96 RFO	Bobbin	ODI	14	0.38 015	+26.03	UTE
71	70	04/96 RFO	Bobbin	NQI		0.63 LTS	-0.57	LTE
71	86	04/96 RFO	Bobbin	ADI		3.06 011	+13.47	LTE
		04/96 RFO	Bobbin	NQI		0.58 006	+2.03	LTE
71	99	04/96 RFO	Bobbin	NQI		2.18 015	+2.99	UTE
72	1	04/96 RFO	Bobbin	ODI	10	0.45 013	+17.51	014
72	2	04/96 RFO	Bobbin	NQI		0.57 010	+0.54	014
72	6	04/96 RFO	Bobbin	NQI		0.34 010	+2.69	014
		04/96 RFO	Bobbin	ODI	6	0.94 010	+4.79	014
72	7	04/96 RFO	Bobbin	NQI		0.65 009	-0.67	014
		04/96 RFO	Bobbin	ODI	2	0.83 010	+3.40	014
		04/96 RFO	Bobbin	ODI	32	0.43 010	-1.32	014
72	8	04/96 RFO	Bobbin	ODI	20	0.53 010	+1.97	014
72	12	04/96 RFO	Bobbin	ODI	18	0.47 009	-0.14	UTE
72	13	04/96 RFO	Bobbin	NQI		0.35 015	+44.69	UTE
72	17	04/96 RFO	Bobbin	NQI		0.32 010	+3.47	UTE
		04/96 RFO	Bobbin	ODI	14	0.53 010	+6.42	UTE
		04/96 RFO	Bobbin	ODI	21	0.63 010	+7.13	UTE
72	26	04/96 RFO	Bobbin	ODI	6	0.82 010	+0.60	UTE
72	31	04/96 RFO	Bobbin	NQI		0.38 011	+0.32	UTS
72	33	04/96 RFO	Bobbin	ODI	3	0.46 009	+0.46	UTE
72	47	04/96 RFO	Bobbin	NQI		0.35 015	+5.19	UTE
		04/96 RFO	Bobbin	ODI	24	0.53 008	+27.53	UTE
		04/96 RFO	Bobbin	ODI	49	0.70 015	+4.43	UTE
		04/96 RFO	Bobbin	NQI		0.71 015	+22.95 to +37.84	UTE
72	51	04/96 RFO	Bobbin	NQI		0.62 008	+11.39	UTE
72	54	04/96 RFO	Bobbin	NQI		0.38 004	-0.76	UTE
		04/96 RFO	Bobbin	NQI		0.76 006	+0.65	UTE
		04/96 RFO	Bobbin	NQI		1.08 003	+0.63	UTE
72	65	04/96 RFO	Bobbin	DWI		1.21 015	+35.08	LTE
72	69	04/96 RFO	Bobbin	NQI		0.65 LTE	+22.18	LTE
72	75	04/96 RFO	Bobbin	DWI		4.98 013	+2.90	LTE
72	92	04/96 RFO	Bobbin	NQI		0.50 013	+28.64	UTE
72	97	04/96 RFO	Bobbin	ODI	29	0.33 006	+14.96	UTE
72	105	04/96 RFO	Bobbin	ODI	4	0.49 006	+28.63	UTE
		04/96 RFO	Bobbin	ODI	27	0.53 006	+27.76	UTE
72	123	04/96 RFO	Bobbin	NQI		0.50 006	+36.59	UTE
72	127	04/96 RFO	Bobbin	NQI		0.93 009	+0.57	UTE
		04/96 RFO	Bobbin	ODI	14	0.78 008	+0.44	UTE
73	3	04/96 RFO	Bobbin	NQI		0.59 010	+0.62	014
73	4	04/96 RFO	Bobbin	ODI	27	0.32 010	-0.16	014
73	5	04/96 RFO	Bobbin	NQI		0.50 010	+0.54	014
73	10	04/96 RFO	Bobbin	NQI		0.53 009	-0.64	014
		04/96 RFO	Bobbin	ODI	37	0.55 010	+31.93	014
		04/96 RFO	Bobbin	ODI	39	0.58 010	+31.10	014
73	13	04/96 RFO	Bobbin	ODI	25	1.23 010	+31.74	UTE
		04/96 RFO	Bobbin	ODI	62	0.39 010	+32.78	UTE
73	15	04/96 RFO	Bobbin	NQI		0.52 004	+10.06	UTE

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
Oconee Nuclear Station - Unit Two
S/G B
04/96 RFO
Bobbin

Page 26 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
73	106	04/96 RFO	Bobbin	ODI	26	0.33	007 +0.22	UTE
73	109	04/96 RFO	Bobbin	ODI	31	0.44	015 +0.41	UTE
73	114	04/96 RFO	Bobbin	ODI	9	2.52	015 +17.07	UTE
		04/96 RFO	Bobbin	ODI	25	2.78	015 +7.34	UTE
73	120	04/96 RFO	Bobbin	NQI		0.49	007 +32.97	UTE
73	126	04/96 RFO	Bobbin	NQI		0.48	009 -0.27	UTE
		04/96 RFO	Bobbin	ODI	31	1.03	015 -0.28	UTE
73	127	04/96 RFO	Bobbin	ODI	58	2.46	009 +0.60	UTE
		04/96 RFO	Bobbin	ODI	61	0.52	009 -0.22	UTE
73	128	04/96 RFO	Bobbin	NQI		1.10	015 -0.36	UTE
		04/96 RFO	Bobbin	ODI	31	0.33	009 +0.41	UTE
73	129	04/96 RFO	Bobbin	NQI		0.57	009 +12.11	UTE
74	24	04/96 RFO	Bobbin	NQI		0.51	011 +24.32	014
74	31	04/96 RFO	Bobbin	ODI	16	0.61	011 +19.38	014
74	34	04/96 RFO	Bobbin	ODI	14	0.52	011 +20.78	014
74	39	04/96 RFO	Bobbin	NQI		0.47	015 +18.30	UTE
		04/96 RFO	Bobbin	NQI		0.51	015 +21.54	UTE
74	40	04/96 RFO	Bobbin	NQI		0.28	011 -0.03	UTE
74	46	04/96 RFO	Bobbin	NQI		0.78	010 +31.63	UTE
74	48	04/96 RFO	Bobbin	NQI		0.42	010 +27.16	UTE
74	50	04/96 RFO	Bobbin	NQI		0.96	010 +25.83	UTE
74	60	04/96 RFO	Bobbin	ODI	7	0.79	015 +43.65	LTE
74	63	04/96 RFO	Bobbin	NQI		0.70	014 +33.05	LTE
74	71	04/96 RFO	Bobbin	ODI	35	0.28	005 +30.91	LTE
74	77	04/96 RFO	Bobbin	ODI	35	0.40	015 +3.40	LTE
74	97	04/96 RFO	Bobbin	NQI		0.48	009 +34.98	LTE
74	103	04/96 RFO	Bobbin	DWI		4.53	014 +11.14	UTE
74	114	04/96 RFO	Bobbin	ODI	24	0.44	007 -1.20	UTE
74	123	04/96 RFO	Bobbin	NQI		0.30	012 +16.98	UTE
		04/96 RFO	Bobbin	ODI	71	0.54	010 +18.81	UTE
		04/96 RFO	Bobbin	NQI		0.53	014 +5.40 to +13.74	UTE
74	124	04/96 RFO	Bobbin	NQI		1.07	015 -0.46	UTE
		04/96 RFO	Bobbin	NQI		0.75	008 +12.22 to +36.68	UTE
75	3	04/96 RFO	Bobbin	NQI		0.58	011 +0.00	014
		04/96 RFO	Bobbin	NQI		0.95	014 +0.00	014
75	12	04/96 RFO	Bobbin	NQI		0.72	013 +24.95	014
75	16	04/96 RFO	Bobbin	NQI		1.09	014 -0.88	014
75	17	04/96 RFO	Bobbin	NQI		0.95	014 -0.88	014
75	18	04/96 RFO	Bobbin	NQI		0.61	014 -0.98	014
75	22	04/96 RFO	Bobbin	NQI		0.78	014 -1.05	014
75	23	04/96 RFO	Bobbin	NQI		0.90	014 -1.04	014
75	25	04/96 RFO	Bobbin	NQI		0.83	014 -0.94	014
		04/96 RFO	Bobbin	NQI		0.49	013 +31.90 to +34.36	014
75	26	04/96 RFO	Bobbin	NQI		0.47	013 +24.72 to +33.58	014
75	29	04/96 RFO	Bobbin	NQI		0.39	013 +18.84	014
75	30	04/96 RFO	Bobbin	NQI		0.84	013 +24.01	014
75	32	04/96 RFO	Bobbin	ODI	16	0.42	013 +14.03	014
75	37	04/96 RFO	Bobbin	ODI	6	2.30	003 +15.42	014
75	41	04/96 RFO	Bobbin	NQI		0.52	LTS +1.91	UTE
75	43	04/96 RFO	Bobbin	NQI		0.69	LTS +1.97	UTE
75	46	04/96 RFO	Bobbin	NQI		0.51	LTS +1.96	UTE
75	47	04/96 RFO	Bobbin	NQI		0.53	012 +31.27 to +32.63	UTE
75	55	04/96 RFO	Bobbin	NQI		0.31	LTS +1.92	UTE
75	56	04/96 RFO	Bobbin	NQI		0.52	LTS +1.92	UTE
		04/96 RFO	Bobbin	NQI		2.95	009 +32.42 to +35.04	UTE
75	61	04/96 RFO	Bobbin	ODI	22	0.43	011 +25.23	LTE
75	65	04/96 RFO	Bobbin	ADI		1.40	008 +34.53	LTE
75	124	04/96 RFO	Bobbin	NQI		0.42	010 +27.50	UTE
		04/96 RFO	Bobbin	NQI		0.40	015 / 013 +12.79	UTE
75	125	04/96 RFO	Bobbin	ODI	32	1.23	009 +1.09	UTE
		04/96 RFO	Bobbin	NQI		0.29	011 +16.45 to +28.42	UTE
75	126	04/96 RFO	Bobbin	ODI	15	0.90	010 +9.94	UTE
76	65	04/96 RFO	Bobbin	ADI		0.97	010 +21.99	LTE
		04/96 RFO	Bobbin	NQI		0.62	009 +24.75	LTS
76	66	04/96 RFO	Bobbin	NQI		0.46	008 +9.95	LTE

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
76	68	04/96 RFO	Bobbin	ADI		1.29 015	+25.33	LTE
76	75	04/96 RFO	Bobbin	ODI	10	1.59 012	+35.17	LTE
76	95	04/96 RFO	Bobbin	ODI	4	0.54 010	+3.16	LTE
		04/96 RFO	Bobbin	ODI	4	0.68 011	+5.73	LTE
		04/96 RFO	Bobbin	ODI	10	0.68 009	+28.11	LTE
		04/96 RFO	Bobbin	ODI	17	1.06 011	+22.62	LTE
		04/96 RFO	Bobbin	ODI	18	0.43 009	+27.67	LTE
		04/96 RFO	Bobbin	ODI	42	0.45 010	+2.92	LTE
		04/96 RFO	Bobbin	ODI	50	0.52 010	+1.91	LTE
		04/96 RFO	Bobbin	ODI	52	0.42 009	+26.32	LTE
76	103	04/96 RFO	Bobbin	ODI	16	0.69 015	-0.16	LTE
		04/96 RFO	Bobbin	ODI	18	2.79 015	+0.44	LTE
77	22	04/96 RFO	Bobbin	NQI		0.47 LTS	+6.07	014
77	31	04/96 RFO	Bobbin	NQI		0.52 LTS	+6.15	014
		04/96 RFO	Bobbin	NQI		0.66 014	-0.89	014
77	35	04/96 RFO	Bobbin	ODI	6	0.65 004	+19.74	014
77	38	04/96 RFO	Bobbin	NQI		0.51 013	+15.03 to +34.53	014
77	39	04/96 RFO	Bobbin	NQI		0.62 012	+3.67	014
		04/96 RFO	Bobbin	ODI	50	0.49 012	+14.38	014
77	40	04/96 RFO	Bobbin	NQI		0.48 013	+21.67	UTE
77	41	04/96 RFO	Bobbin	NQI		0.65 LTS	+5.99	UTE
77	42	04/96 RFO	Bobbin	ODI	7	0.45 012	+0.29	UTS
77	44	04/96 RFO	Bobbin	NQI		0.44 LTS	+2.07	UTE
		04/96 RFO	Bobbin	ODI	10	0.29 013	+21.91	UTE
77	46	04/96 RFO	Bobbin	ODI	23	0.57 LTS	+1.97	UTE
77	56	04/96 RFO	Bobbin	NQI		0.47 LTS	+1.99	LTE
77	61	04/96 RFO	Bobbin	NQI		0.51 LTS	+1.98	LTE
77	67	04/96 RFO	Bobbin	ADI		0.35 008	+8.69	LTE
77	71	04/96 RFO	Bobbin	NQI		0.29 005	+32.93	LTE
77	93	04/96 RFO	Bobbin	ODI	15	1.08 014	+28.93	LTE
		04/96 RFO	Bobbin	ODI	22	1.59 007	+27.36	LTE
77	103	04/96 RFO	Bobbin	DWI		1.52 005	+5.93	LTE
77	122	04/96 RFO	Bobbin	NQI		0.54 007	+21.27	LTE
77	124	04/96 RFO	Bobbin	ODI	22	0.50 008	+18.90	LTE
77	125	04/96 RFO	Bobbin	ODI	26	0.52 011	+0.19	LTE
77	126	04/96 RFO	Bobbin	ODI	20	0.68 009	+7.68	LTE
78	3	04/96 RFO	Bobbin	NQI		0.35 011	+0.38	014
78	26	04/96 RFO	Bobbin	ODI	22	0.61 011	+32.54	014
78	27	04/96 RFO	Bobbin	NQI		0.56 011	+31.25	014
78	40	04/96 RFO	Bobbin	NQI		0.58 010	+21.49	UTE
		04/96 RFO	Bobbin	NQI		0.73 010	+22.68	UTE
		04/96 RFO	Bobbin	NQI		0.62 010	+24.07	UTE
78	43	04/96 RFO	Bobbin	ODI	23	1.08 010	+22.99	UTE
		04/96 RFO	Bobbin	NQI		0.32 012	+33.31	UTE
78	46	04/96 RFO	Bobbin	NQI		0.56 UTS	+0.27	UTE
		04/96 RFO	Bobbin	NQI		1.03 LTE	+21.96	UTE
78	48	04/96 RFO	Bobbin	NQI		0.48 010	-1.23	UTE
78	50	04/96 RFO	Bobbin	NQI		0.90 LTS	-0.44	UTE
78	54	04/96 RFO	Bobbin	NQI		0.53 009	+33.33 to +37.84	UTE
78	56	04/96 RFO	Bobbin	NQI		0.52 009	+32.63	UTE
78	57	04/96 RFO	Bobbin	NQI		0.60 009	+33.69	UTE
		04/96 RFO	Bobbin	ADI		0.54 009	+31.98	UTE
78	58	04/96 RFO	Bobbin	NQI		0.78 009	+31.92	LTE
78	59	04/96 RFO	Bobbin	NQI		3.74 014	+19.69	LTE
78	67	04/96 RFO	Bobbin	ODI	10	0.84 008	+11.32	LTE
		04/96 RFO	Bobbin	ODI	25	0.41 006	+3.63	LTE
78	83	04/96 RFO	Bobbin	ODI	4	0.56 015	+33.52	LTE
78	90	04/96 RFO	Bobbin	ODI	17	0.49 015	+35.26	LTE
		04/96 RFO	Bobbin	ODI	43	0.95 014	+17.46	LTE
		04/96 RFO	Bobbin	ODI	8	0.66 006	+26.78	LTE
78	98	04/96 RFO	Bobbin	NQI		0.51 015	-0.56	LTE
78	104	04/96 RFO	Bobbin	NQI		0.47 008	+13.11	LTE
78	124	04/96 RFO	Bobbin	NQI		0.87 008	+11.64	LTE
78	125	04/96 RFO	Bobbin	ODI	5	1.01 015	-0.49	LTE
		04/96 RFO	Bobbin	ODI	34	0.64 008	+13.49	LTE

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	ODI	34	0.64	008 +13.49	LTE
79	1	04/96 RFO	Bobbin	NQI		0.75	013 +14.75 to +26.45	014
79	13	04/96 RFO	Bobbin	NQI		0.64	009 +0.68	UTE
79	14	04/96 RFO	Bobbin	NQI		0.41	011 +0.38	UTE
79	23	04/96 RFO	Bobbin	NQI		0.19	015 +35.09	UTE
79	27	04/96 RFO	Bobbin	NQI		0.55	010 +6.76	UTE
79	32	04/96 RFO	Bobbin	NQI		0.34	015 +41.68	UTS
		04/96 RFO	Bobbin	NQI		0.59	010 +11.07	UTS
		04/96 RFO	Bobbin	ODI	25	0.42	015 +40.55	UTS
		04/96 RFO	Bobbin	ODI	49	0.74	015 +17.12	UTS
79	34	04/96 RFO	Bobbin	ODI	7	0.55	015 +36.65	UTE
79	41	04/96 RFO	Bobbin	NQI		0.57	010 +0.44	UTE
		04/96 RFO	Bobbin	ODI	13	0.20	011 -0.33	UTE
79	50	04/96 RFO	Bobbin	NQI		0.67	010 +0.60	UTE
79	56	04/96 RFO	Bobbin	NQI		0.40	015 +38.44	UTE
79	58	04/96 RFO	Bobbin	ADI		3.79	008 +13.57	UTE
79	59	04/96 RFO	Bobbin	NQI		0.32	008 +24.52	LTE
		04/96 RFO	Bobbin	NQI		0.60	008 +25.33	LTE
79	65	04/96 RFO	Bobbin	ODI	16	0.57	LTS +2.12	LTE
79	80	04/96 RFO	Bobbin	ODI	1	2.14	007 +28.27	LTE
79	100	04/96 RFO	Bobbin	NQI		0.40	012 +0.11	UTS
79	102	04/96 RFO	Bobbin	NQI		0.33	006 +22.55 to +30.67	UTS
79	103	04/96 RFO	Bobbin	NQI		0.63	007 +1.10	UTS
		04/96 RFO	Bobbin	ODI	30	0.24	012 -0.03	UTS
79	104	04/96 RFO	Bobbin	ODI	13	0.63	012 +0.05	LTE
79	109	04/96 RFO	Bobbin	ODI	39	0.62	015 -0.10	LTE
79	122	04/96 RFO	Bobbin	ODI	1	1.37	LTE +20.38	LTE
79	126	04/96 RFO	Bobbin	NQI		0.88	015 -0.33	LTE
80	4	04/96 RFO	Bobbin	NQI		0.53	010 +1.70 to +7.07	014
80	7	04/96 RFO	Bobbin	NQI		0.40	LTS +26.60 to +32.86	014
80	9	04/96 RFO	Bobbin	NQI		0.45	010 +4.27	014
80	13	04/96 RFO	Bobbin	ODI	23	0.39	010 +1.61 to +10.79	UTE
80	21	04/96 RFO	Bobbin	ODI	21	1.03	010 +7.48	UTE
80	25	04/96 RFO	Bobbin	NQI		0.42	009 +0.65	UTE
80	26	04/96 RFO	Bobbin	ODI	27	0.29	010 +4.40	UTE
80	29	04/96 RFO	Bobbin	NQI		0.30	010 +6.63	UTE
80	39	04/96 RFO	Bobbin	NQI		0.42	009 +18.17	UTE
80	41	04/96 RFO	Bobbin	NQI		0.34	009 +0.46	UTE
80	45	04/96 RFO	Bobbin	ODI	7	0.49	015 +35.77	UTS
80	53	04/96 RFO	Bobbin	ODI	11	0.39	007 -0.03	UTE
80	54	04/96 RFO	Bobbin	NQI		0.27	007 +0.11	UTE
80	74	04/96 RFO	Bobbin	NQI		0.46	005 +30.92	LTE
80	75	04/96 RFO	Bobbin	NQI		1.49	014 +30.06 to +31.25	LTE
80	82	04/96 RFO	Bobbin	ODI	5	0.51	006 +1.46	LTE
80	85	04/96 RFO	Bobbin	ODI	5	0.50	005 +34.62	LTE
80	90	04/96 RFO	Bobbin	ODI	10	0.66	006 +3.12	LTE
80	107	04/96 RFO	Bobbin	ODI	6	0.42	007 +2.12	LTE
80	114	04/96 RFO	Bobbin	NQI		1.41	UTS +16.71	LTE
80	127	04/96 RFO	Bobbin	ODI	10	0.17	006 +32.97	LTE
80	130	04/96 RFO	Bobbin	ODI	13	0.63	008 +10.23	LTE
		04/96 RFO	Bobbin	ODI	17	1.31	008 +9.17	LTE
81	4	04/96 RFO	Bobbin	NQI		0.89	010 +5.87	014
81	6	04/96 RFO	Bobbin	NQI		0.54	010 +4.41	014
81	14	04/96 RFO	Bobbin	NQI		0.35	UTS +0.24	UTE
		04/96 RFO	Bobbin	ODI	7	0.35	010 -0.33	UTE
81	18	04/96 RFO	Bobbin	NQI		0.55	010 -0.60	UTE
		04/96 RFO	Bobbin	ODI	23	0.43	013 +8.90	UTE
81	22	04/96 RFO	Bobbin	ODI	19	0.35	010 -0.46	UTE
81	29	04/96 RFO	Bobbin	NQI		0.45	004 +16.88	UTE
81	32	04/96 RFO	Bobbin	NQI		0.34	015 +9.68 to +34.07	UTS
81	36	04/96 RFO	Bobbin	ODI	33	2.03	015 +38.28	UTE
81	37	04/96 RFO	Bobbin	ODI	16	0.67	003 +20.90	UTE
81	40	04/96 RFO	Bobbin	ODI	7	0.46	008 +0.41	UTE
81	42	04/96 RFO	Bobbin	NQI		0.17	006 +0.22	UTE
81	46	04/96 RFO	Bobbin	ODI	30	0.31	007 +0.38	UTE

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 29 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	ODI	34	0.27	007	-0.25
81	50	04/96 RFO	Bobbin	NQI		0.47	007	+0.11
81	51	04/96 RFO	Bobbin	NQI		0.42	007	+0.08
81	52	04/96 RFO	Bobbin	DWI		3.17	013	+4.09
81	53	04/96 RFO	Bobbin	ODI	6	1.51	014	+31.31
81	54	04/96 RFO	Bobbin	NQI		1.24	012	+0.71
81	63	04/96 RFO	Bobbin	ODI	42	0.41	015	+15.46
81	76	04/96 RFO	Bobbin	NQI		0.50	005	+28.76 to +35.44
81	82	04/96 RFO	Bobbin	NQI		0.37	012	+0.51
81	85	04/96 RFO	Bobbin	ODI	18	0.37	012	+0.10
81	106	04/96 RFO	Bobbin	NQI		0.78	001	+12.26
		04/96 RFO	Bobbin	NQI		0.78	002	+9.73
		04/96 RFO	Bobbin	NQI		1.54	011	+31.67
		04/96 RFO	Bobbin	NQI		2.69	009	+36.40
81	121	04/96 RFO	Bobbin	NQI		1.23	009	+1.46
81	126	04/96 RFO	Bobbin	NQI		0.61	008	+22.62
		04/96 RFO	Bobbin	ODI	26	1.54	007	+17.72
81	128	04/96 RFO	Bobbin	ODI	13	0.63	015	-0.51
82	1	04/96 RFO	Bobbin	NQI		0.32	013	+4.06
		04/96 RFO	Bobbin	NQI		0.38	013	+30.64
82	2	04/96 RFO	Bobbin	ODI	10	0.49	013	+0.43
82	4	04/96 RFO	Bobbin	NQI		0.56	009	+35.65
		04/96 RFO	Bobbin	NQI		0.33	010	+0.00 to +7.89
82	5	04/96 RFO	Bobbin	NQI		0.37	010	+1.24 to +6.57
82	6	04/96 RFO	Bobbin	ODI	20	0.67	009	+29.93
82	7	04/96 RFO	Bobbin	NQI		0.27	009	+11.38
		04/96 RFO	Bobbin	ODI	35	0.41	009	+0.35
82	20	04/96 RFO	Bobbin	NQI		0.16	010	-0.05
82	28	04/96 RFO	Bobbin	ODI	34	0.29	015	+12.04
82	30	04/96 RFO	Bobbin	NQI		0.27	014	+0.08
82	46	04/96 RFO	Bobbin	NQI		0.18	007	+0.22
82	50	04/96 RFO	Bobbin	ODI	16	0.25	007	+0.16
82	73	04/96 RFO	Bobbin	NQI		0.49	005	+32.60
82	76	04/96 RFO	Bobbin	NQI		0.40	005	+32.78
82	77	04/96 RFO	Bobbin	NQI		0.40	005	+32.52
82	100	04/96 RFO	Bobbin	NQI		1.88	005	+10.99
		04/96 RFO	Bobbin	ODI	30	2.02	002	+12.74
82	101	04/96 RFO	Bobbin	ODI	38	1.68	012	+0.55
82	111	04/96 RFO	Bobbin	NQI		0.43	008	+13.45 to +31.02
82	128	04/96 RFO	Bobbin	NQI		0.35	007	+30.30 to +37.95
82	129	04/96 RFO	Bobbin	NQI		0.50	008	+7.75 to +15.56
83	2	04/96 RFO	Bobbin	NQI		0.30	010	+14.50
83	3	04/96 RFO	Bobbin	ODI	4	1.10	010	+3.11
83	4	04/96 RFO	Bobbin	ODI	18	0.53	009	+37.69
83	5	04/96 RFO	Bobbin	NQI		0.56	010	-0.99
83	7	04/96 RFO	Bobbin	NQI		0.42	009	+17.27
83	8	04/96 RFO	Bobbin	ODI	8	0.25	LTS	+32.78
83	16	04/96 RFO	Bobbin	ODI	2	0.29	008	+0.49
83	33	04/96 RFO	Bobbin	NQI		0.56	015	+11.94 to +24.40
83	34	04/96 RFO	Bobbin	NQI		0.27	009	+15.76
83	40	04/96 RFO	Bobbin	NQI		0.25	007	+0.16
		04/96 RFO	Bobbin	ODI	6	0.31	006	+33.84
83	44	04/96 RFO	Bobbin	NQI		0.39	006	+31.50
83	51	04/96 RFO	Bobbin	ODI	3	0.53	007	+0.65
83	59	04/96 RFO	Bobbin	NQI		0.97	LTS	-0.51
83	83	04/96 RFO	Bobbin	ODI	33	0.39	005	+26.60
83	84	04/96 RFO	Bobbin	ODI	5	0.40	006	+2.62
		04/96 RFO	Bobbin	ODI	20	0.37	005	+35.08
83	90	04/96 RFO	Bobbin	ODI	38	0.27	006	-0.33
83	91	04/96 RFO	Bobbin	DWI		3.90	UTS	+16.61
83	95	04/96 RFO	Bobbin	NQI		0.42	006	+6.37 to +11.83
83	96	04/96 RFO	Bobbin	NQI		0.36	015	+42.47
83	102	04/96 RFO	Bobbin	NQI		0.38	006	+18.51 to +29.43
83	104	04/96 RFO	Bobbin	NQI		0.55	006	+19.61 to +28.85
83	109	04/96 RFO	Bobbin	ADI		4.23	015	+34.65

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
83	112	04/96 RFO	Bobbin	NQI		0.51 008	+12.25	LTE
83	113	04/96 RFO	Bobbin	NQI		0.47 008	+25.58 to +37.08	LTE
83	124	04/96 RFO	Bobbin	NQI		1.44 014	+16.09	LTE
83	127	04/96 RFO	Bobbin	NQI		0.82 015	+0.16	LTE
83	129	04/96 RFO	Bobbin	NQI		0.36 007	+13.30 to +29.30	LTE
83	132	04/96 RFO	Bobbin	NQI		0.48 010	+3.58	LTE
84	2	04/96 RFO	Bobbin	NQI		0.23 007	-0.11	014
84	3	04/96 RFO	Bobbin	NQI		0.30 010	+2.45	014
		04/96 RFO	Bobbin	ODI	18	0.37 009	+36.64	014
		04/96 RFO	Bobbin	ODI	25	0.30 010	+5.45	014
84	4	04/96 RFO	Bobbin	NQI		0.36 009	+35.81	014
		04/96 RFO	Bobbin	ODI	22	0.52 009	+34.43	014
84	5	04/96 RFO	Bobbin	NQI		0.48 009	+22.49	014
84	6	04/96 RFO	Bobbin	ODI	18	0.65 009	+19.75	014
84	18	04/96 RFO	Bobbin	NQI		0.57 010	+0.52	UTE
84	22	04/96 RFO	Bobbin	ADI		1.99 012	+29.83	UTE
84	28	04/96 RFO	Bobbin	NQI		0.30 001	+1.39	UTE
84	29	04/96 RFO	Bobbin	DWI		2.11 007	+37.75	UTE
84	41	04/96 RFO	Bobbin	ODI	20	0.11 011	-0.03	UTE
84	43	04/96 RFO	Bobbin	NQI		0.16 013	-0.05	UTE
84	48	04/96 RFO	Bobbin	DWI		1.81 LTS	+5.52	UTE
		04/96 RFO	Bobbin	NQI		0.90 009	+0.00	UTE
84	49	04/96 RFO	Bobbin	ODI	38	0.45 003	-0.53	UTE
84	53	04/96 RFO	Bobbin	NQI		0.38 012	+0.25	UTE
		04/96 RFO	Bobbin	NQI		0.48 006	-0.65	UTE
84	54	04/96 RFO	Bobbin	ODI	19	0.18 003	-0.11	UTE
		04/96 RFO	Bobbin	ODI	39	0.90 012	+0.46	UTE
84	58	04/96 RFO	Bobbin	NQI		0.30 006	+10.51	LTE
		04/96 RFO	Bobbin	ODI	4	0.48 006	+9.97	LTE
84	81	04/96 RFO	Bobbin	ODI	3	0.61 005	+31.90	LTE
84	83	04/96 RFO	Bobbin	ODI	27	0.33 005	+33.82	LTE
84	86	04/96 RFO	Bobbin	ODI	9	0.37 005	+35.92	LTE
84	100	04/96 RFO	Bobbin	ODI	38	0.53 012	+0.30	LTE
84	103	04/96 RFO	Bobbin	ODI	5	0.38 006	+30.84	LTE
84	111	04/96 RFO	Bobbin	ODI	10	0.56 007	+5.19	UTS
84	112	04/96 RFO	Bobbin	NQI		0.82 015	-0.20	LTE
84	125	04/96 RFO	Bobbin	ODI	34	0.50 012	-0.20	LTE
84	128	04/96 RFO	Bobbin	ADI		2.47 014	+16.74	LTE
84	130	04/96 RFO	Bobbin	ODI	22	0.57 008	+4.01	LTE
84	131	04/96 RFO	Bobbin	ODI	81	0.67 010	+2.64	LTE
		04/96 RFO	Bobbin	ODI	89	0.42 010	+3.59	LTE
85	1	04/96 RFO	Bobbin	NQI		0.47 010	-0.64	014
85	2	04/96 RFO	Bobbin	NQI		0.22 010	+3.28	014
		04/96 RFO	Bobbin	ODI	27	0.54 010	+4.37	014
85	3	04/96 RFO	Bobbin	ODI	14	0.68 009	+33.74	014
		04/96 RFO	Bobbin	ODI	27	0.36 010	+2.15	014
85	4	04/96 RFO	Bobbin	NQI		0.37 009	+24.12 to +27.49	014
85	5	04/96 RFO	Bobbin	ODI	6	0.42 009	+18.27	014
		04/96 RFO	Bobbin	NQI		0.26 009	+19.10 to +25.02	014
85	6	04/96 RFO	Bobbin	NQI		0.17 008	-0.05	014
		04/96 RFO	Bobbin	ODI	10	0.77 008	-0.45	014
85	7	04/96 RFO	Bobbin	NQI		0.70 008	+0.08	UTE
		04/96 RFO	Bobbin	ODI	16	1.63 008	+0.65	UTE
85	20	04/96 RFO	Bobbin	NQI		1.87 015	+0.14	UTE
85	24	04/96 RFO	Bobbin	ADI		3.76 012	+31.50	UTE
85	27	04/96 RFO	Bobbin	NQI		0.20 007	-0.16	UTE
85	29	04/96 RFO	Bobbin	ODI	8	2.06 015	+6.69	UTE
85	31	04/96 RFO	Bobbin	DWI		5.62 015	+35.34	UTE
		04/96 RFO	Bobbin	ODI	28	0.65 014	+28.64	UTE
		04/96 RFO	Bobbin	ODI	31	0.88 014	+28.70	UTE
85	54	04/96 RFO	Bobbin	ADI		3.89 011	+6.14	UTE
		04/96 RFO	Bobbin	ADI		4.16 011	+18.65	UTE
		04/96 RFO	Bobbin	ADI		4.61 006	+22.02	UTE
85	70	04/96 RFO	Bobbin	NQI		0.47 012	+0.14	LTE
85	84	04/96 RFO	Bobbin	NQI		0.51 005	+33.49	LTE

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 31 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
85	90	04/96 RFO	Bobbin	NQI		0.28	012	-0.21
85	100	04/96 RFO	Bobbin	NQI		0.37	006	+17.49
85	104	04/96 RFO	Bobbin	ODI	1	0.64	007	+1.17
		04/96 RFO	Bobbin	ODI	15	0.24	007	+2.34
85	107	04/96 RFO	Bobbin	ODI	36	0.50	012	-0.38
85	119	04/96 RFO	Bobbin	ODI	13	0.90	014	+14.60
		04/96 RFO	Bobbin	ODI	26	0.50	006	+35.94
85	124	04/96 RFO	Bobbin	ODI	11	0.88	014	-0.30
85	126	04/96 RFO	Bobbin	NQI		1.17	015	+0.10
		04/96 RFO	Bobbin	NQI		1.36	015	+36.28
		04/96 RFO	Bobbin	NQI		1.95	015	+35.41
		04/96 RFO	Bobbin	ODI	1	0.72	012	+0.36
85	127	04/96 RFO	Bobbin	ODI	9	0.40	007	+7.70
		04/96 RFO	Bobbin	ODI	30	0.68	007	+5.88
85	128	04/96 RFO	Bobbin	ODI	2	0.46	007	+15.43
86	1	04/96 RFO	Bobbin	NQI		0.27	002	+5.25
86	2	04/96 RFO	Bobbin	ODI	6	0.57	010	+4.69
86	3	04/96 RFO	Bobbin	NQI		0.24	010	+0.97
86	4	04/96 RFO	Bobbin	NQI		0.41	009	+26.16
		04/96 RFO	Bobbin	ODI	20	0.20	010	+0.05
86	5	04/96 RFO	Bobbin	NQI		0.51	012	+24.13
		04/96 RFO	Bobbin	NQI		0.61	009	+21.13
		04/96 RFO	Bobbin	ODI	24	0.81	012	+25.81
		04/96 RFO	Bobbin	ODI	36	0.94	012	+25.20
		04/96 RFO	Bobbin	ODI	49	0.87	012	+30.02
86	6	04/96 RFO	Bobbin	ODI	22	0.83	008	+0.05
86	7	04/96 RFO	Bobbin	ODI	13	0.31	007	-0.05
86	15	04/96 RFO	Bobbin	NQI		0.45	007	+29.87
86	28	04/96 RFO	Bobbin	ODI	24	2.17	LTS	+3.54
		04/96 RFO	Bobbin	ODI	39	0.33	006	+36.01
86	42	04/96 RFO	Bobbin	NQI		2.02	012	+0.80
86	71	04/96 RFO	Bobbin	ODI	6	0.68	012	+20.50
86	73	04/96 RFO	Bobbin	NQI		0.29	012	+0.57
		04/96 RFO	Bobbin	ODI	10	0.41	005	+26.17
86	76	04/96 RFO	Bobbin	ODI	50	2.52	013	+15.38
86	80	04/96 RFO	Bobbin	NQI		0.66	012	+27.43 to +29.30
86	126	04/96 RFO	Bobbin	ODI	33	0.48	006	+31.89
86	129	04/96 RFO	Bobbin	ODI	40	0.43	007	+18.03
87	2	04/96 RFO	Bobbin	ODI	10	0.38	010	+4.64
		04/96 RFO	Bobbin	ODI	32	0.42	010	+2.96
87	3	04/96 RFO	Bobbin	NQI		0.32	009	+32.16
		04/96 RFO	Bobbin	NQI		0.44	009	+28.78
		04/96 RFO	Bobbin	NQI		0.49	009	+32.53
87	4	04/96 RFO	Bobbin	NQI		0.51	009	+24.50 to +28.30
87	5	04/96 RFO	Bobbin	NQI		0.78	009	+17.42
		04/96 RFO	Bobbin	ODI	16	0.49	009	+22.15
		04/96 RFO	Bobbin	ODI	37	0.46	008	-0.13
87	6	04/96 RFO	Bobbin	NQI		0.66	009	+0.62
87	32	04/96 RFO	Bobbin	ODI	71	0.62	015	+18.62
87	34	04/96 RFO	Bobbin	ODI	59	0.46	012	+24.40
		04/96 RFO	Bobbin	ODI	78	0.55	012	+24.69
87	53	04/96 RFO	Bobbin	NQI		0.25	012	+0.30
87	64	04/96 RFO	Bobbin	ADI		3.23	013	+34.06
87	81	04/96 RFO	Bobbin	ODI	3	0.39	006	+1.08
87	86	04/96 RFO	Bobbin	NQI		0.46	005	+33.65
87	92	04/96 RFO	Bobbin	ODI	13	0.51	006	-0.15
87	105	04/96 RFO	Bobbin	ODI	24	0.70	012	+0.05
87	123	04/96 RFO	Bobbin	NQI		0.92	014	+29.57 to +32.10
87	124	04/96 RFO	Bobbin	NQI		2.20	UTS	+1.08
87	125	04/96 RFO	Bobbin	ODI	22	0.66	012	+34.67
		04/96 RFO	Bobbin	NQI		0.61	009	+26.01 to +36.99
		04/96 RFO	Bobbin	NQI		0.95	008	+19.58 to +35.10
88	2	04/96 RFO	Bobbin	NQI		0.30	010	+5.74
		04/96 RFO	Bobbin	ODI	29	0.52	010	+11.35
88	3	04/96 RFO	Bobbin	NQI		0.53	010	+0.50

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 32 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
88	4	04/96 RFO	Bobbin	NQI		0.42 009	+0.73	014
		04/96 RFO	Bobbin	NQI		0.71 009	+28.55	014
88	5	04/96 RFO	Bobbin	NQI		0.89 009	+19.01	UTE
88	6	04/96 RFO	Bobbin	NQI		0.23 010	-0.27	UTE
88	8	04/96 RFO	Bobbin	ODI	34	0.71 008	-0.43	UTE
88	9	04/96 RFO	Bobbin	NQI		0.29 006	+37.22	UTE
88	81	04/96 RFO	Bobbin	ODI	54	0.70 010	+30.97	LTE
88	90	04/96 RFO	Bobbin	ODI	9	0.74 012	+0.56	LTE
88	95	04/96 RFO	Bobbin	ODI	14	0.40 006	+8.04	UTS
		04/96 RFO	Bobbin	ODI	32	0.56 013	+27.83	UTS
88	96	04/96 RFO	Bobbin	ODI	26	2.02 013	+25.07	LTE
88	102	04/96 RFO	Bobbin	ODI	25	0.31 007	-0.40	UTS
88	105	04/96 RFO	Bobbin	ODI	29	0.43 012	+0.24	LTE
88	106	04/96 RFO	Bobbin	NQI		0.52 LTS	+28.43	LTE
		04/96 RFO	Bobbin	ODI	6	0.57 010	+31.28	LTE
		04/96 RFO	Bobbin	ODI	8	0.88 010	+33.74	LTE
		04/96 RFO	Bobbin	ODI	33	1.13 014	+1.81	LTE
		04/96 RFO	Bobbin	ODI	40	0.91 010	+30.25	LTE
		04/96 RFO	Bobbin	ODI	47	0.66 010	+29.48	LTE
		04/96 RFO	Bobbin	ODI	51	0.73 010	+32.31	LTE
		04/96 RFO	Bobbin	ODI	55	0.89 010	+30.62	LTE
		04/96 RFO	Bobbin	ODI	70	0.49 010	+31.73	LTE
88	117	04/96 RFO	Bobbin	ODI	18	1.13 002	+5.87	LTE
88	123	04/96 RFO	Bobbin	ODI	1	1.23 015	+0.90	LTE
88	124	04/96 RFO	Bobbin	NQI		0.73 015	+5.35	LTE
88	125	04/96 RFO	Bobbin	NQI		0.56 008	+0.68	LTE
88	127	04/96 RFO	Bobbin	ADI		0.34 007	+17.35	LTE
89	1	04/96 RFO	Bobbin	NQI		0.30 010	+10.81	014
		04/96 RFO	Bobbin	ODI	22	0.44 010	+8.42	014
		04/96 RFO	Bobbin	ODI	24	0.50 010	+7.82	014
89	4	04/96 RFO	Bobbin	NQI		0.41 009	+28.71	UTE
		04/96 RFO	Bobbin	NQI		0.43 009	+25.63	UTE
		04/96 RFO	Bobbin	NQI		0.48 009	+28.07	UTE
89	5	04/96 RFO	Bobbin	NQI		0.41 009	+16.28	UTE
		04/96 RFO	Bobbin	ODI	29	0.57 008	-0.19	UTE
89	6	04/96 RFO	Bobbin	NQI		0.31 008	+0.13	UTE
		04/96 RFO	Bobbin	NQI		0.64 008	+0.62	UTE
89	32	04/96 RFO	Bobbin	NQI		0.48 015	+38.52	UTE
		04/96 RFO	Bobbin	NQI		0.48 015	+40.41	UTE
		04/96 RFO	Bobbin	ODI	12	0.68 006	+23.43	UTE
		04/96 RFO	Bobbin	ODI	52	0.60 015	+29.93	UTE
		04/96 RFO	Bobbin	ODI	56	0.62 015	+24.24	UTE
		04/96 RFO	Bobbin	ODI	64	0.63 015	+35.49	UTE
89	33	04/96 RFO	Bobbin	NQI		0.24 012	+0.25	UTE
89	60	04/96 RFO	Bobbin	ODI	10	0.42 005	+34.72	LTE
89	87	04/96 RFO	Bobbin	ODI	31	0.22 006	-0.98	LTE
89	90	04/96 RFO	Bobbin	NQI		0.60 LTE	+20.30	LTE
89	100	04/96 RFO	Bobbin	ODI	36	0.78 012	+0.16	UTS
89	102	04/96 RFO	Bobbin	NQI		0.51 006	+31.23	LTE
89	111	04/96 RFO	Bobbin	ODI	1	1.00 015	+35.72	LTE
		04/96 RFO	Bobbin	ODI	40	1.04 015	+39.75	LTE
89	112	04/96 RFO	Bobbin	NQI		0.43 007	+5.96	UTE
89	118	04/96 RFO	Bobbin	NQI		0.71 010	-0.20	LTE
89	125	04/96 RFO	Bobbin	NQI		0.73 010	+22.07	LTE
		04/96 RFO	Bobbin	NQI		0.82 009	-0.85	LTE
89	129	04/96 RFO	Bobbin	NQI		0.32 008	+0.54	LTE
90	3	04/96 RFO	Bobbin	ODI	7	1.03 013	+16.82	UTE
		04/96 RFO	Bobbin	ODI	12	0.60 010	+6.13	UTE
		04/96 RFO	Bobbin	ODI	43	0.93 013	+18.89	UTE
		04/96 RFO	Bobbin	ODI	54	0.61 013	+21.04	UTE
		04/96 RFO	Bobbin	ODI	61	0.57 013	+17.49	UTE
90	4	04/96 RFO	Bobbin	NQI		0.51 009	+22.36	UTE
90	29	04/96 RFO	Bobbin	ODI	13	0.47 012	+0.30	UTE
90	41	04/96 RFO	Bobbin	NQI		0.33 012	+0.24	UTE
90	66	04/96 RFO	Bobbin	ADI		4.30 LTS	+4.42	LTE

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
Oconee Nuclear Station - Unit Two
S/G B
04/96 RFO
Bobbin

Page 33 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
90	80	04/96 RFO	Bobbin	ODI	12	0.51	008 +7.74	LTE
90	91	04/96 RFO	Bobbin	ODI	17	0.45	006 +6.47	LTE
90	100	04/96 RFO	Bobbin	NQI		0.30	006 +20.50 to +27.85	UTS
90	113	04/96 RFO	Bobbin	NQI		0.55	006 +35.50 to +37.14	UTE
90	116	04/96 RFO	Bobbin	ODI	3	2.05	014 +27.98	LTE
90	128	04/96 RFO	Bobbin	ODI	15	0.69	008 +0.67	LTE
91	4	04/96 RFO	Bobbin	ODI	26	0.40	009 +26.96	UTE
91	5	04/96 RFO	Bobbin	NQI		0.37	008 +0.13	UTE
		04/96 RFO	Bobbin	NQI		0.59	008 +0.64	UTE
91	6	04/96 RFO	Bobbin	ODI	1	0.49	008 +0.40	UTE
		04/96 RFO	Bobbin	ODI	1	0.49	008 +0.40	UTE
91	8	04/96 RFO	Bobbin	ODI	5	0.14	008 +0.27	UTE
91	32	04/96 RFO	Bobbin	ODI	36	0.52	013 +0.41	UTE
91	54	04/96 RFO	Bobbin	DWI		1.74	LTS +11.98	UTE
91	55	04/96 RFO	Bobbin	NQI		1.76	LTE +20.93	UTE
91	63	04/96 RFO	Bobbin	NQI		2.61	014 +2.19	LTE
91	72	04/96 RFO	Bobbin	NQI		0.55	011 +12.20	LTE
91	95	04/96 RFO	Bobbin	ODI	10	0.54	012 +0.08	LTE
91	96	04/96 RFO	Bobbin	ODI	20	0.71	012 -0.58	LTE
91	99	04/96 RFO	Bobbin	ODI	36	0.41	012 -0.29	LTE
91	111	04/96 RFO	Bobbin	NQI		1.46	015 +14.83	LTE
		04/96 RFO	Bobbin	ODI	1	1.13	015 +27.65	LTE
		04/96 RFO	Bobbin	ODI	10	1.07	015 +28.59	LTE
91	119	04/96 RFO	Bobbin	ODI	9	3.63	012 +27.73	LTE
91	122	04/96 RFO	Bobbin	ODI	36	0.53	007 +13.53	LTE
92	1	04/96 RFO	Bobbin	ODI	21	0.67	010 +9.38	UTE
92	2	04/96 RFO	Bobbin	ODI	28	0.64	009 +37.38	UTE
92	3	04/96 RFO	Bobbin	NQI		1.00	009 +27.45	UTE
92	4	04/96 RFO	Bobbin	NQI		0.72	009 +16.66	UTE
		04/96 RFO	Bobbin	ODI	36	0.44	009 +17.03	UTE
92	12	04/96 RFO	Bobbin	ODI	18	0.43	006 +32.85	UTE
92	22	04/96 RFO	Bobbin	ODI	26	0.49	006 +16.09	UTE
92	25	04/96 RFO	Bobbin	NQI		0.19	012 -0.13	UTE
		04/96 RFO	Bobbin	ODI	24	0.63	007 -0.46	UTE
92	33	04/96 RFO	Bobbin	ODI	15	3.47	013 +9.84	UTE
92	44	04/96 RFO	Bobbin	ODI	23	0.63	011 +21.18	UTE
		04/96 RFO	Bobbin	NQI		0.85	010 +16.44 to +17.82	UTE
92	54	04/96 RFO	Bobbin	NQI		0.77	012 -0.08	UTE
92	62	04/96 RFO	Bobbin	NQI		0.43	009 +12.53	LTE
92	79	04/96 RFO	Bobbin	ODI	16	0.52	005 +29.24	LTE
92	86	04/96 RFO	Bobbin	ODI	35	0.42	005 +31.06	LTE
92	94	04/96 RFO	Bobbin	NQI		0.57	006 +12.91	UTE
92	100	04/96 RFO	Bobbin	ODI	33	0.47	006 +26.02	UTE
93	1	04/96 RFO	Bobbin	NQI		1.37	009 +0.56	UTE
93	3	04/96 RFO	Bobbin	ODI	26	0.53	009 +25.24	UTE
93	5	04/96 RFO	Bobbin	WAR	60	0.86	009 +0.67	UTE
93	13	04/96 RFO	Bobbin	ADI		3.19	003 +19.78	UTE
93	37	04/96 RFO	Bobbin	ODI	20	0.32	006 +12.49	UTE
93	38	04/96 RFO	Bobbin	NQI		0.16	013 -0.19	UTE
93	45	04/96 RFO	Bobbin	ODI	22	0.18	013 +0.11	UTE
93	47	04/96 RFO	Bobbin	NQI		0.33	006 +14.31	UTE
93	48	04/96 RFO	Bobbin	DWI		0.49	001 +5.99	UTE
93	54	04/96 RFO	Bobbin	NQI		0.35	006 +0.56	LTE
93	70	04/96 RFO	Bobbin	ODI	36	0.52	005 +29.87	LTE
93	74	04/96 RFO	Bobbin	ODI	31	0.49	005 +33.22	LTE
93	75	04/96 RFO	Bobbin	ODI	22	0.55	005 +31.50	LTE
93	96	04/96 RFO	Bobbin	NQI		1.72	001 +21.72	LTE
		04/96 RFO	Bobbin	ODI	13	0.46	011 +8.27	LTE
93	122	04/96 RFO	Bobbin	ODI	18	0.40	007 +29.40	LTE
94	1	04/96 RFO	Bobbin	ODI	13	1.11	010 +4.29	UTE
94	3	04/96 RFO	Bobbin	NQI		0.64	011 +5.87	UTE
		04/96 RFO	Bobbin	NQI		1.15	009 +0.67	UTE
94	6	04/96 RFO	Bobbin	NQI		0.71	009 +0.62	UTE
		04/96 RFO	Bobbin	ODI	33	0.60	007 -0.49	UTE
94	14	04/96 RFO	Bobbin	NQI		0.54	004 +8.48	UTE

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
Oconee Nuclear Station - Unit Two
S/G B
04/96 RFO
Bobbin

Page 34 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
94	26	04/96 RFO	Bobbin	NQI		0.31 006	+36.34	UTE
		04/96 RFO	Bobbin	NQI		0.37 006	+34.40	UTE
94	28	04/96 RFO	Bobbin	NQI		0.29 006	+25.00 to +33.38	UTE
94	31	04/96 RFO	Bobbin	NQI		0.86 LTE	+14.67	UTE
94	32	04/96 RFO	Bobbin	NQI		0.45 015	+34.49	UTE
94	39	04/96 RFO	Bobbin	ODI	36	0.37 013	+0.43	UTE
94	47	04/96 RFO	Bobbin	ODI	21	3.65 015	+22.21	UTE
94	51	04/96 RFO	Bobbin	NQI		0.57 006	+6.73	UTE
95	5	04/96 RFO	Bobbin	ODI	2	0.27 009	+0.06	UTE
95	8	04/96 RFO	Bobbin	NQI		0.32 009	+0.32	UTE
95	31	04/96 RFO	Bobbin	NQI		0.62 001	+16.28	UTE
95	32	04/96 RFO	Bobbin	NQI		0.35 004	+11.18	UTE
95	37	04/96 RFO	Bobbin	NQI		0.39 013	-0.35	UTE
95	59	04/96 RFO	Bobbin	NQI		0.48 005	+32.38	LTE
95	64	04/96 RFO	Bobbin	NQI		0.84 LTE	+5.37	LTE
95	78	04/96 RFO	Bobbin	NQI		0.46 005	+32.66	LTE
95	87	04/96 RFO	Bobbin	ODI	16	0.41 006	+9.32	LTE
96	4	04/96 RFO	Bobbin	ODI	3	0.31 007	-0.08	UTE
96	5	04/96 RFO	Bobbin	NQI		0.52 008	+0.49	UTE
96	7	04/96 RFO	Bobbin	DWI		2.47 001	+10.36	UTE
		04/96 RFO	Bobbin	DWI		4.61 001	+22.00	UTE
		04/96 RFO	Bobbin	NQI		1.23 001	+28.27	UTE
96	13	04/96 RFO	Bobbin	ODI	18	0.26 006	+27.88	UTE
96	18	04/96 RFO	Bobbin	ODI	14	2.79 002	+36.50	UTE
96	23	04/96 RFO	Bobbin	NQI		0.18 006	+27.27 to +30.94	UTS
96	25	04/96 RFO	Bobbin	NQI		1.51 012	+15.78	UTE
		04/96 RFO	Bobbin	ODI	25	1.31 LTS	+13.46	UTE
		04/96 RFO	Bobbin	NQI		0.89 015	+0.05 to +38.08	UTE
		04/96 RFO	Bobbin	NQI		0.98 014	+0.05 to +34.84	UTE
96	26	04/96 RFO	Bobbin	ODI	9	2.24 001	+8.48	UTE
96	44	04/96 RFO	Bobbin	ODI	7	0.24 012	+0.00	UTE
96	45	04/96 RFO	Bobbin	NQI		0.92 014	+30.40	UTE
96	53	04/96 RFO	Bobbin	ODI	22	0.41 006	+2.10	UTE
96	59	04/96 RFO	Bobbin	NQI		0.70 006	+1.60	LTE
96	83	04/96 RFO	Bobbin	DWI		0.93 LTS	-0.50	LTE
96	90	04/96 RFO	Bobbin	NQI		0.27 012	+0.44	LTE
96	91	04/96 RFO	Bobbin	ADI		2.68 014	+6.24	LTE
96	98	04/96 RFO	Bobbin	NQI		0.85 LTS	+6.49	UTS
96	99	04/96 RFO	Bobbin	ODI	12	0.55 006	+32.41	LTE
96	103	04/96 RFO	Bobbin	NQI		1.25 004	+29.22	UTS
96	113	04/96 RFO	Bobbin	NQI		1.11 014	+18.19	UTE
		04/96 RFO	Bobbin	ODI	10	0.50 014	+29.99	UTE
		04/96 RFO	Bobbin	ODI	15	0.60 015	+6.79	UTE
		04/96 RFO	Bobbin	ODI	47	0.54 015	+30.30	UTE
96	120	04/96 RFO	Bobbin	NQI		0.30 006	+33.65	LTE
96	127	04/96 RFO	Bobbin	ODI	29	1.06 008	+0.66	LTE
97	1	04/96 RFO	Bobbin	NQI		0.62 009	+25.64	UTE
97	2	04/96 RFO	Bobbin	NQI		0.54 011	-0.33	UTE
		04/96 RFO	Bobbin	NQI		0.54 015	-0.11	UTE
97	5	04/96 RFO	Bobbin	NQI		0.43 007	+13.19	UTE
97	16	04/96 RFO	Bobbin	NQI		0.26 006	+31.78	UTE
		04/96 RFO	Bobbin	ODI	3	0.23 006	+36.56	UTE
97	17	04/96 RFO	Bobbin	ODI	3	0.54 006	+31.13	UTE
97	20	04/96 RFO	Bobbin	ODI	33	0.41 006	+30.72	UTE
97	22	04/96 RFO	Bobbin	NQI		0.28 006	+31.15	UTE
97	27	04/96 RFO	Bobbin	ODI	14	0.26 013	-0.41	UTE
97	34	04/96 RFO	Bobbin	NQI		0.45 006	+16.02	UTE
97	36	04/96 RFO	Bobbin	NQI		0.37 006	+18.16	UTE
		04/96 RFO	Bobbin	NQI		0.40 006	+13.65	UTE
97	38	04/96 RFO	Bobbin	NQI		0.17 006	-0.03	UTE
97	40	04/96 RFO	Bobbin	ODI	10	0.31 012	-0.31	UTE
97	42	04/96 RFO	Bobbin	NQI		0.18 012	-0.21	UTE
97	51	04/96 RFO	Bobbin	ODI	11	0.43 006	+7.05	UTE
97	56	04/96 RFO	Bobbin	ODI	4	0.43 012	+8.28	UTE
97	60	04/96 RFO	Bobbin	NQI		0.46 014	+1.56	LTE

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 35 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin			NQI 0.52	005 +32.83	LTE
		04/96 RFO	Bobbin			NQI 0.53	014 +15.34	LTE
97	61	04/96 RFO	Bobbin			NQI 0.37	005 +34.93	LTE
97	75	04/96 RFO	Bobbin			ODI 22 0.49	005 +32.63	LTE
97	89	04/96 RFO	Bobbin			NQI 0.28	006 -0.25	LTE
		04/96 RFO	Bobbin			ODI 12 0.40	006 +9.43	LTE
97	90	04/96 RFO	Bobbin			ODI 71 0.52	006 +10.85	UTS
97	96	04/96 RFO	Bobbin			NQI 0.52	006 +14.99 to +27.70	LTE
97	99	04/96 RFO	Bobbin			NQI 0.40	012 -0.54	LTE
		04/96 RFO	Bobbin			ODI 13 0.72	007 +0.91	LTE
97	110	04/96 RFO	Bobbin			DWI 0.61	015 +20.72	LTE
97	124	04/96 RFO	Bobbin			NQI 0.44	007 +17.30	LTE
		04/96 RFO	Bobbin			NQI 0.46	015 -0.12	LTE
98	1	04/96 RFO	Bobbin			ODI 12 2.45	010 +1.44	UTE
98	2	04/96 RFO	Bobbin			NQI 1.27	LTE +18.90	UTE
		04/96 RFO	Bobbin			ODI 13 0.47	009 +16.90	UTE
98	3	04/96 RFO	Bobbin			NQI 0.41	009 -0.41	UTE
98	4	04/96 RFO	Bobbin			NQI 0.56	010 +0.65	UTE
98	17	04/96 RFO	Bobbin			NQI 0.52	002 +13.44	UTE
98	18	04/96 RFO	Bobbin			ODI 8 2.40	LTS +3.38	UTE
98	24	04/96 RFO	Bobbin			ODI 48 0.83	011 +19.79	UTE
		04/96 RFO	Bobbin			ODI 75 0.46	011 +17.85	UTE
98	33	04/96 RFO	Bobbin			ODI 1 1.44	LTS +6.78	UTE
98	40	04/96 RFO	Bobbin			NQI 0.51	013 +0.27	UTE
98	42	04/96 RFO	Bobbin			ODI 22 4.23	007 +2.80	UTS
		04/96 RFO	Bobbin			ODI 28 0.33	006 +11.95	UTS
98	43	04/96 RFO	Bobbin			ODI 22 1.30	015 +39.28	UTE
98	47	04/96 RFO	Bobbin			ODI 7 0.73	012 +26.18	UTE
98	51	04/96 RFO	Bobbin			NQI 0.41	010 +11.55	UTE
98	54	04/96 RFO	Bobbin			ODI 22 0.69	012 +0.03	UTE
98	75	04/96 RFO	Bobbin			NQI 1.08	LTE +2.42	LTE
98	77	04/96 RFO	Bobbin			ODI 22 0.53	005 +31.58	LTE
98	79	04/96 RFO	Bobbin			ODI 2 0.61	005 +31.92	LTE
98	89	04/96 RFO	Bobbin			NQI 0.30	006 +8.34 to +12.79	LTE
98	97	04/96 RFO	Bobbin			ODI 1 5.13	004 +31.54	LTE
98	111	04/96 RFO	Bobbin			ODI 24 0.44	015 +39.41	LTE
98	126	04/96 RFO	Bobbin			NQI 1.24	UTS +17.93	LTE
99	1	04/96 RFO	Bobbin			NQI 0.56	010 +5.89	UTE
99	3	04/96 RFO	Bobbin			NQI 0.33	008 -0.03	UTE
		04/96 RFO	Bobbin			ODI 17 0.47	008 +0.38	UTE
99	4	04/96 RFO	Bobbin			NQI 0.66	009 +0.65	UTE
		04/96 RFO	Bobbin			ODI 22 0.22	009 +0.30	UTE
99	13	04/96 RFO	Bobbin			NQI 0.23	012 -0.33	UTE
99	35	04/96 RFO	Bobbin			NQI 0.36	006 +14.32	UTS
99	58	04/96 RFO	Bobbin			NQI 0.88	012 -0.71	UTE
99	65	04/96 RFO	Bobbin			ODI 36 0.60	012 +0.52	LTE
99	71	04/96 RFO	Bobbin			NQI 0.36	005 +30.72	LTE
99	99	04/96 RFO	Bobbin			ODI 10 0.34	007 -0.56	UTS
99	123	04/96 RFO	Bobbin			NQI 0.48	007 +10.37 to +14.88	LTE
99	125	04/96 RFO	Bobbin			NQI 0.67	015 -0.08	LTE
100	4	04/96 RFO	Bobbin			NQI 0.34	008 +7.49 to +13.00	UTE
100	31	04/96 RFO	Bobbin			ODI 1 0.43	012 +6.03	UTE
		04/96 RFO	Bobbin			ODI 29 0.45	012 +7.96	UTE
100	34	04/96 RFO	Bobbin			ODI 23 1.20	013 +0.74	UTE
100	39	04/96 RFO	Bobbin			ODI 23 1.18	001 +31.80	UTE
100	54	04/96 RFO	Bobbin			NQI 0.47	012 -0.27	UTE
100	64	04/96 RFO	Bobbin			ODI 16 1.80	001 +2.54	LTE
100	69	04/96 RFO	Bobbin			ODI 25 1.53	LTE +21.03	LTE
100	71	04/96 RFO	Bobbin			ODI 36 0.32	005 +34.55	LTE
100	80	04/96 RFO	Bobbin			ODI 25 0.51	006 +5.77	LTE
100	88	04/96 RFO	Bobbin			NQI 0.43	002 +26.71	LTE
		04/96 RFO	Bobbin			ODI 4 0.56	006 +18.32	LTE
100	91	04/96 RFO	Bobbin			NQI 0.58	015 +0.51	LTE
100	93	04/96 RFO	Bobbin			ODI 13 0.34	006 +23.90	LTE
		04/96 RFO	Bobbin			ODI 22 0.42	006 +26.83	LTE

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 36 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
100	99	04/96 RFO	Bobbin	NQI		0.53	015	+25.90
100	101	04/96 RFO	Bobbin	ODI	27	0.34	012	-0.36
100	110	04/96 RFO	Bobbin	ODI	13	0.25	007	+6.63
100	117	04/96 RFO	Bobbin	ODI	20	0.29	003	+0.38
100	121	04/96 RFO	Bobbin	ODI	13	0.25	007	+7.21
100	122	04/96 RFO	Bobbin	NQI		0.32	007	+12.52
100	123	04/96 RFO	Bobbin	ODI	28	0.38	007	+15.20
		04/96 RFO	Bobbin	ODI	36	1.14	014	+20.16
		04/96 RFO	Bobbin	ODI	39	0.42	014	+20.50
100	124	04/96 RFO	Bobbin	ODI	10	0.38	007	+16.65
101	2	04/96 RFO	Bobbin	ODI	27	0.48	008	+34.57
101	3	04/96 RFO	Bobbin	ODI	77	1.75	008	+0.54
101	4	04/96 RFO	Bobbin	NQI		0.65	008	+12.06
101	14	04/96 RFO	Bobbin	NQI		0.34	006	+31.31
		04/96 RFO	Bobbin	NQI		0.40	006	+33.40
101	23	04/96 RFO	Bobbin	NQI		0.29	006	+29.02
101	29	04/96 RFO	Bobbin	NQI		1.77	004	+21.30
		04/96 RFO	Bobbin	ODI	19	0.40	015	+41.37
101	30	04/96 RFO	Bobbin	NQI		0.46	006	+19.27
101	32	04/96 RFO	Bobbin	NQI		0.26	013	-0.19
101	37	04/96 RFO	Bobbin	NQI		0.94	004	+33.02
101	42	04/96 RFO	Bobbin	ODI	25	0.55	006	+11.05
101	44	04/96 RFO	Bobbin	NQI		0.36	012	-0.24
101	46	04/96 RFO	Bobbin	NQI		0.86	002	+24.26
		04/96 RFO	Bobbin	NQI		1.21	002	+23.15
		04/96 RFO	Bobbin	NQI		1.51	003	+36.98
		04/96 RFO	Bobbin	NQI		1.57	003	+37.89
101	48	04/96 RFO	Bobbin	NQI		0.50	004	-0.51
		04/96 RFO	Bobbin	NQI		0.59	001	+9.14
		04/96 RFO	Bobbin	NQI		1.40	001	+5.12
		04/96 RFO	Bobbin	NQI		1.44	002	+25.73
		04/96 RFO	Bobbin	NQI		1.50	002	+21.74
		04/96 RFO	Bobbin	NQI		1.64	003	+35.51
101	54	04/96 RFO	Bobbin	NQI		0.35	005	+33.52
		04/96 RFO	Bobbin	NQI		0.41	006	-0.11
101	68	04/96 RFO	Bobbin	ODI	12	0.33	012	+0.26
101	70	04/96 RFO	Bobbin	NQI		0.71	015	-0.65
101	82	04/96 RFO	Bobbin	NQI		0.58	012	+0.85
101	84	04/96 RFO	Bobbin	NQI		1.33	014	-0.75
101	87	04/96 RFO	Bobbin	NQI		0.29	012	+0.36
101	91	04/96 RFO	Bobbin	NQI		0.46	006	+17.09
101	94	04/96 RFO	Bobbin	ODI	5	0.38	006	+26.22
		04/96 RFO	Bobbin	ODI	29	0.50	006	+30.33
		04/96 RFO	Bobbin	ODI	47	0.29	006	+19.34
101	97	04/96 RFO	Bobbin	NQI		0.36	007	+3.14
101	106	04/96 RFO	Bobbin	ODI	46	0.30	LTS	+18.71
101	112	04/96 RFO	Bobbin	NQI		0.46	006	+35.97
101	114	04/96 RFO	Bobbin	ODI	2	0.34	006	+33.31
101	117	04/96 RFO	Bobbin	ADI		13.28	001	+9.35
		04/96 RFO	Bobbin	NQI		0.27	006	+36.50
		04/96 RFO	Bobbin	NQI		0.34	006	+34.50
101	121	04/96 RFO	Bobbin	ODI	15	0.46	007	+12.63
101	122	04/96 RFO	Bobbin	ODI	2	0.74	007	+20.13
101	123	04/96 RFO	Bobbin	ODI	11	0.50	007	+33.85
102	2	04/96 RFO	Bobbin	NQI		0.65	009	+0.57
102	5	04/96 RFO	Bobbin	DWI		1.28	004	+18.59
		04/96 RFO	Bobbin	DWI		1.34	004	+19.92
		04/96 RFO	Bobbin	NQI		0.51	007	+0.35
		04/96 RFO	Bobbin	ODI	17	0.58	007	+25.67
102	25	04/96 RFO	Bobbin	NQI		0.47	006	+27.15
		04/96 RFO	Bobbin	NQI		1.85	005	+9.31
102	31	04/96 RFO	Bobbin	NQI		0.85	014	+10.92
		04/96 RFO	Bobbin	ODI	17	1.00	014	+9.96
102	37	04/96 RFO	Bobbin	NQI		0.46	012	-0.49
102	43	04/96 RFO	Bobbin	NQI		1.27	004	+9.84

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 37 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	NQI		1.62 004	+11.76	UTE
		04/96 RFO	Bobbin	NQI		3.19 004	+13.17	UTE
102	55	04/96 RFO	Bobbin	NQI		0.84 001	+32.83	UTE
		04/96 RFO	Bobbin	NQI		1.20 001	+29.39	UTE
		04/96 RFO	Bobbin	NQI		1.63 003	+13.34	UTE
		04/96 RFO	Bobbin	NQI		2.53 LTS	+42.95	UTE
		04/96 RFO	Bobbin	ODI	26	0.47 012	-0.16	UTE
102	56	04/96 RFO	Bobbin	ODI	50	0.56 012	-0.27	UTE
102	62	04/96 RFO	Bobbin	ODI	27	0.49 006	-0.49	UTE
102	89	04/96 RFO	Bobbin	NQI		0.32 006	+21.35	LTE
		04/96 RFO	Bobbin	ODI	14	0.68 014	+18.24	LTE
102	90	04/96 RFO	Bobbin	ODI	39	0.25 012	+0.26	LTE
102	91	04/96 RFO	Bobbin	NQI		0.42 006	+20.02	LTE
102	92	04/96 RFO	Bobbin	NQI		0.82 006	+26.29	LTE
		04/96 RFO	Bobbin	ODI	37	0.76 012	-0.55	LTE
102	96	04/96 RFO	Bobbin	NQI		0.31 012	+0.35	UTS
102	97	04/96 RFO	Bobbin	NQI		0.50 007	+3.08	UTS
		04/96 RFO	Bobbin	ODI	29	0.55 007	+3.16	UTS
102	113	04/96 RFO	Bobbin	ODI	3	0.99 002	+25.43	LTE
		04/96 RFO	Bobbin	ODI	20	0.78 001	+7.34	LTE
		04/96 RFO	Bobbin	ODI	36	1.12 LTE	+15.73	LTE
102	114	04/96 RFO	Bobbin	ODI	22	1.36 002	+12.34	LTE
102	118	04/96 RFO	Bobbin	ODI	1	0.91 LTS	+39.70	LTE
		04/96 RFO	Bobbin	ODI	28	0.86 LTS	+18.25	LTE
102	120	04/96 RFO	Bobbin	NQI		0.44 007	+18.69	LTE
		04/96 RFO	Bobbin	ODI	10	0.48 003	+15.21	LTE
		04/96 RFO	Bobbin	ODI	12	0.68 001	+4.96	LTE
		04/96 RFO	Bobbin	ODI	18	0.70 LTS	+4.82	LTE
102	121	04/96 RFO	Bobbin	ODI	37	0.51 008	+0.59	LTE
103	2	04/96 RFO	Bobbin	ODI	22	0.46 009	-0.35	UTE
103	4	04/96 RFO	Bobbin	NQI		0.68 015	+0.11	UTE
103	5	04/96 RFO	Bobbin	ODI	25	0.36 005	+0.54	UTE
103	7	04/96 RFO	Bobbin	ADI		2.54 015	+42.23	UTE
		04/96 RFO	Bobbin	ODI	15	0.18 007	+13.54	UTE
		04/96 RFO	Bobbin	ODI	35	0.22 006	+33.17	UTE
103	9	04/96 RFO	Bobbin	NQI		0.27 006	+25.08 to +33.04	UTE
103	11	04/96 RFO	Bobbin	NQI		0.27 LTS	+33.21	UTE
103	13	04/96 RFO	Bobbin	ODI	13	0.41 001	+30.21	UTS
		04/96 RFO	Bobbin	ODI	14	0.44 001	+30.23	UTS
103	19	04/96 RFO	Bobbin	NQI		0.43 006	+30.68	UTE
103	23	04/96 RFO	Bobbin	NQI		0.54 006	+28.92	UTE
103	38	04/96 RFO	Bobbin	ODI	23	0.85 013	+0.00	UTE
103	39	04/96 RFO	Bobbin	ODI	46	0.80 012	+0.41	UTE
103	41	04/96 RFO	Bobbin	NQI		0.36 003	+0.00	UTE
103	42	04/96 RFO	Bobbin	NQI		0.60 006	+11.54	UTE
103	43	04/96 RFO	Bobbin	DWI		1.13 002	+16.47	UTE
103	46	04/96 RFO	Bobbin	NQI		1.30 004	+2.67	UTS
103	47	04/96 RFO	Bobbin	NQI		0.36 012	+0.41	UTE
103	48	04/96 RFO	Bobbin	NQI		1.28 003	+35.61	UTE
		04/96 RFO	Bobbin	NQI		1.82 002	+25.51	UTE
		04/96 RFO	Bobbin	NQI		1.95 002	+21.80	UTE
103	56	04/96 RFO	Bobbin	NQI		1.42 001	+10.61	UTE
		04/96 RFO	Bobbin	NQI		1.70 LTS	+25.81	UTE
		04/96 RFO	Bobbin	NQI		2.21 LTS	+29.53	UTE
103	72	04/96 RFO	Bobbin	NQI		0.36 006	-0.26	LTE
103	76	04/96 RFO	Bobbin	NQI		0.35 011	+15.00	LTE
103	79	04/96 RFO	Bobbin	ODI	2	0.62 014	+1.68	LTE
103	87	04/96 RFO	Bobbin	NQI		3.72 002	+15.58	LTE
103	96	04/96 RFO	Bobbin	NQI		0.52 007	-0.53	LTE
103	111	04/96 RFO	Bobbin	ODI	16	0.39 006	+37.28	LTE
103	114	04/96 RFO	Bobbin	ODI	10	0.69 002	+4.72	LTE
103	115	04/96 RFO	Bobbin	NQI		0.60 006	+35.44	LTE
103	117	04/96 RFO	Bobbin	ODI	7	0.72 002	+5.99	LTE
		04/96 RFO	Bobbin	ODI	12	0.37 008	+19.47	LTE
		04/96 RFO	Bobbin	ODI	18	1.26 001	+30.17	LTE

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1	
103	118	04/96 RFO	Bobbin	ODI	31	0.76	002	+26.68	LTE
		04/96 RFO	Bobbin	ODI	7	1.35	001	+8.76	LTE
		04/96 RFO	Bobbin	ODI	16	1.23	005	+22.03	LTE
		04/96 RFO	Bobbin	ODI	26	1.05	005	+13.90	LTE
		04/96 RFO	Bobbin	ODI	26	1.33	002	+2.41	LTE
103	119	04/96 RFO	Bobbin	ODI	7	0.85	001	+17.27	LTE
		04/96 RFO	Bobbin	ODI	7	0.85	001	+17.27	LTE
103	120	04/96 RFO	Bobbin	ODI	7	0.67	LTS	+39.31	LTE
		04/96 RFO	Bobbin	ODI	9	0.27	006	-0.99	LTE
103	121	04/96 RFO	Bobbin	ODI	3	0.43	001	+5.48	LTE
103	122	04/96 RFO	Bobbin	ODI	5	0.71	001	+11.12	LTE
		04/96 RFO	Bobbin	ODI	7	0.40	007	+35.85	LTE
		04/96 RFO	Bobbin	ODI	24	1.15	001	+21.92	LTE
103	123	04/96 RFO	Bobbin	NQI		0.39	002	-0.46	LTE
		04/96 RFO	Bobbin	ODI	5	0.57	001	+16.39	LTE
		04/96 RFO	Bobbin	ODI	20	0.57	002	+4.26	LTE
103	124	04/96 RFO	Bobbin	ODI	1	1.09	002	+8.48	LTE
		04/96 RFO	Bobbin	ODI	10	0.84	002	+27.88	LTE
		04/96 RFO	Bobbin	ODI	29	0.93	001	+8.94	LTE
104	2	04/96 RFO	Bobbin	NQI		0.42	015	-0.41	UTE
		04/96 RFO	Bobbin	ODI	29	0.54	015	+0.05	UTE
104	3	04/96 RFO	Bobbin	NQI		0.55	015	-0.03	UTE
104	4	04/96 RFO	Bobbin	NQI		0.95	015	+0.00	UTE
		04/96 RFO	Bobbin	NQI		0.96	015	+0.43	UTE
104	5	04/96 RFO	Bobbin	ODI	6	1.44	008	+0.46	UTE
104	6	04/96 RFO	Bobbin	NQI		0.48	007	+22.40	UTE
		04/96 RFO	Bobbin	NQI		1.03	008	+0.53	UTE
104	8	04/96 RFO	Bobbin	ODI	27	0.41	006	+26.28	UTE
104	9	04/96 RFO	Bobbin	ODI	20	0.52	006	+27.29	UTE
104	12	04/96 RFO	Bobbin	NQI		0.34	006	+26.33	UTE
		04/96 RFO	Bobbin	ODI	10	0.38	006	+29.68	UTE
104	24	04/96 RFO	Bobbin	ODI	23	0.48	006	+27.07	UTE
104	34	04/96 RFO	Bobbin	ODI	1	0.57	013	+0.46	UTE
104	37	04/96 RFO	Bobbin	NQI		0.44	006	+15.21	UTS
104	40	04/96 RFO	Bobbin	ODI	4	1.89	002	+25.95	UTS
104	42	04/96 RFO	Bobbin	DWI		0.80	LTS	+36.79	UTE
		04/96 RFO	Bobbin	ODI	7	0.71	006	+11.70	UTE
		04/96 RFO	Bobbin	ODI	22	0.27	006	+11.38	UTE
104	46	04/96 RFO	Bobbin	ODI	5	0.76	006	+10.86	UTE
104	49	04/96 RFO	Bobbin	ODI	24	2.75	UTS	+3.59	UTE
104	65	04/96 RFO	Bobbin	ODI	8	0.52	006	-0.37	LTE
104	70	04/96 RFO	Bobbin	NQI		0.30	005	+28.36	LTE
		04/96 RFO	Bobbin	ODI	14	0.29	005	+30.30	LTE
104	79	04/96 RFO	Bobbin	ODI	18	0.32	012	-0.27	LTE
104	94	04/96 RFO	Bobbin	ODI	14	0.42	013	+31.44	LTE
		04/96 RFO	Bobbin	ODI	24	0.83	013	+31.07	LTE
104	97	04/96 RFO	Bobbin	NQI		0.66	010	+27.31	LTE
		04/96 RFO	Bobbin	ODI	8	1.60	002	+33.20	LTE
104	103	04/96 RFO	Bobbin	ODI	16	0.36	015	+39.78	LTE
104	116	04/96 RFO	Bobbin	NQI		0.49	002	+30.79	LTE
		04/96 RFO	Bobbin	ODI	34	0.31	001	+5.56	LTE
104	117	04/96 RFO	Bobbin	ODI	16	0.75	002	+19.70	LTE
104	119	04/96 RFO	Bobbin	ODI	11	0.83	001	+9.47	LTE
		04/96 RFO	Bobbin	ODI	20	1.45	001	+28.37	LTE
		04/96 RFO	Bobbin	ODI	24	0.31	012	+17.71	LTE
104	121	04/96 RFO	Bobbin	ODI	9	0.80	007	+35.58	LTE
		04/96 RFO	Bobbin	ODI	18	0.35	007	+35.78	LTE
		04/96 RFO	Bobbin	ODI	20	0.34	008	+10.23	LTE
		04/96 RFO	Bobbin	ODI	53	0.43	001	+24.60	LTE
104	122	04/96 RFO	Bobbin	NQI		0.67	001	+3.64	LTE
		04/96 RFO	Bobbin	NQI		0.75	002	+7.77	LTE
		04/96 RFO	Bobbin	ODI	7	0.87	001	+7.50	LTE
		04/96 RFO	Bobbin	ODI	14	1.28	002	+9.08	LTE
104	123	04/96 RFO	Bobbin	NQI		0.27	004	+8.14	LTE
		04/96 RFO	Bobbin	ODI	16	0.41	LTS	+1.95	LTE

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
105	2	04/96 RFO	Bobbin	NQI		0.29 008	+31.44	LTE
		04/96 RFO	Bobbin	ODI	7	0.68 009	+0.67	LTE
105	6	04/96 RFO	Bobbin	NQI		0.42 008	+0.46	UTE
105	18	04/96 RFO	Bobbin	ODI	31	0.47 006	+29.51	UTE
105	19	04/96 RFO	Bobbin	ODI	24	0.35 006	+29.94	UTE
105	23	04/96 RFO	Bobbin	NQI		0.45 006	+25.85	UTE
105	24	04/96 RFO	Bobbin	NQI		0.30 006	+29.60	UTE
		04/96 RFO	Bobbin	NQI		0.37 006	+25.76	UTE
105	27	04/96 RFO	Bobbin	NQI		0.41 006	+26.05	UTE
105	28	04/96 RFO	Bobbin	ODI	10	0.34 006	+23.77	UTE
105	31	04/96 RFO	Bobbin	NQI		0.56 012	+0.49	UTE
105	33	04/96 RFO	Bobbin	ODI	10	0.31 013	-0.05	UTS
105	39	04/96 RFO	Bobbin	ODI	16	0.33 006	+15.33	UTE
105	46	04/96 RFO	Bobbin	NQI		0.43 014	+8.16	UTE
105	47	04/96 RFO	Bobbin	ODI	14	0.35 006	+11.18	UTE
105	54	04/96 RFO	Bobbin	ODI	17	0.55 005	+35.15	UTE
105	59	04/96 RFO	Bobbin	ODI	11	0.17 006	-0.19	UTE
105	62	04/96 RFO	Bobbin	DWI		0.91 014	+7.60	UTE
		04/96 RFO	Bobbin	DWI		2.58 014	+3.00	UTE
105	74	04/96 RFO	Bobbin	ODI	18	0.24 012	+0.52	LTE
105	111	04/96 RFO	Bobbin	ODI	28	0.60 015	+36.72	LTE
105	114	04/96 RFO	Bobbin	ODI	56	0.46 LTS	+24.89	LTE
105	119	04/96 RFO	Bobbin	NQI		0.24 001	+26.39	LTE
		04/96 RFO	Bobbin	NQI		0.35 001	+22.83	LTE
		04/96 RFO	Bobbin	NQI		1.24 001	+13.30	LTE
		04/96 RFO	Bobbin	ODI	11	0.85 002	+14.86	LTE
		04/96 RFO	Bobbin	ODI	20	0.99 001	+4.76	LTE
		04/96 RFO	Bobbin	ODI	24	0.94 001	+11.95	LTE
105	120	04/96 RFO	Bobbin	ODI	2	0.69 LTS	+30.93	LTE
105	121	04/96 RFO	Bobbin	ODI	18	0.41 001	+11.99	LTE
		04/96 RFO	Bobbin	ODI	34	0.41 001	+10.13	LTE
105	122	04/96 RFO	Bobbin	ODI	11	0.60 LTS	+22.99	LTE
106	5	04/96 RFO	Bobbin	ODI	34	0.42 007	+22.75	LTE
106	14	04/96 RFO	Bobbin	NQI		0.40 006	+30.71	LTE
106	24	04/96 RFO	Bobbin	NQI		0.41 006	+25.11	LTE
106	29	04/96 RFO	Bobbin	NQI		0.59 013	-0.48	UTE
106	34	04/96 RFO	Bobbin	NQI		1.06 011	+13.02	UTE
		04/96 RFO	Bobbin	NQI		1.16 006	+11.69	UTE
		04/96 RFO	Bobbin	NQI		1.32 011	+9.04	UTE
		04/96 RFO	Bobbin	NQI		1.53 012	-1.31	UTE
106	37	04/96 RFO	Bobbin	ODI	32	1.09 014	+24.92	LTE
106	47	04/96 RFO	Bobbin	ADI		3.07 014	+6.19	LTE
		04/96 RFO	Bobbin	ADI		5.81 013	+33.02	LTE
106	53	04/96 RFO	Bobbin	ODI	12	0.50 005	+34.85	LTE
106	85	04/96 RFO	Bobbin	ODI	46	0.27 006	+22.30	UTS
		04/96 RFO	Bobbin	ODI	55	0.51 006	+29.25	UTS
106	86	04/96 RFO	Bobbin	ODI	19	0.32 006	+23.11	UTS
106	88	04/96 RFO	Bobbin	NQI		0.90 015	+37.41	LTE
		04/96 RFO	Bobbin	ODI	39	0.51 015	+35.56	LTE
106	93	04/96 RFO	Bobbin	NQI		1.82 015	+33.60	LTE
106	94	04/96 RFO	Bobbin	NQI		0.61 001	+24.72	LTE
		04/96 RFO	Bobbin	NQI		0.74 009	+36.61	LTE
		04/96 RFO	Bobbin	NQI		1.56 015	+18.03	LTE
		04/96 RFO	Bobbin	ODI	10	1.20 001	+21.87	LTE
106	106	04/96 RFO	Bobbin	NQI		0.54 007	+0.98	LTE
106	108	04/96 RFO	Bobbin	ODI	9	0.55 010	+23.83	LTE
106	109	04/96 RFO	Bobbin	NQI		0.48 006	+34.22	LTE
106	110	04/96 RFO	Bobbin	ODI	2	0.62 006	+35.11	LTE
106	112	04/96 RFO	Bobbin	ODI	14	0.60 006	+32.61	LTE
106	116	04/96 RFO	Bobbin	ODI	36	0.26 008	-0.09	LTE
106	117	04/96 RFO	Bobbin	ODI	30	0.42 008	+12.85	LTE
106	118	04/96 RFO	Bobbin	ODI	9	0.42 008	+14.01	LTE
		04/96 RFO	Bobbin	ODI	39	0.41 008	+18.63	LTE
107	5	04/96 RFO	Bobbin	ODI	8	0.34 006	+31.40	LTE
107	12	04/96 RFO	Bobbin	ODI	25	0.44 006	+29.47	LTE

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 40 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
107	14	04/96 RFO	Bobbin	NQI		0.22	010	+0.15
107	23	04/96 RFO	Bobbin	ODI	16	0.48	011	+19.35
		04/96 RFO	Bobbin	ODI	31	0.61	006	+25.81
107	26	04/96 RFO	Bobbin	ODI	29	0.42	006	+25.80
107	28	04/96 RFO	Bobbin	NQI		0.32	006	+23.41
107	32	04/96 RFO	Bobbin	ODI	32	0.44	006	+20.22
107	35	04/96 RFO	Bobbin	NQI		0.16	014	-0.20
107	37	04/96 RFO	Bobbin	NQI		0.25	012	+0.40
107	42	04/96 RFO	Bobbin	ODI	11	0.96	015	+36.61
107	63	04/96 RFO	Bobbin	ODI	32	0.34	006	+5.40
107	69	04/96 RFO	Bobbin	NQI		0.45	005	+31.00
		04/96 RFO	Bobbin	ODI	8	0.45	005	+34.41
107	72	04/96 RFO	Bobbin	ODI	30	0.53	006	+8.46
107	74	04/96 RFO	Bobbin	NQI		0.31	012	+0.38
107	75	04/96 RFO	Bobbin	ODI	14	0.71	013	+25.25
		04/96 RFO	Bobbin	ODI	18	0.71	013	+26.52
		04/96 RFO	Bobbin	ODI	22	0.88	013	+20.22
		04/96 RFO	Bobbin	ODI	41	0.52	014	+18.16
		04/96 RFO	Bobbin	ODI	41	1.47	014	+17.01
107	83	04/96 RFO	Bobbin	ODI	43	0.76	012	+0.31
107	85	04/96 RFO	Bobbin	NQI		0.32	012	+0.20
107	87	04/96 RFO	Bobbin	ODI	30	0.57	006	+24.35
107	94	04/96 RFO	Bobbin	NQI		0.72	002	+9.97
107	95	04/96 RFO	Bobbin	ADI		2.74	007	+32.37
		04/96 RFO	Bobbin	ADI		2.96	008	+14.66
		04/96 RFO	Bobbin	ODI	10	1.94	003	+29.40
		04/96 RFO	Bobbin	ODI	15	2.09	008	+7.13
		04/96 RFO	Bobbin	ODI	22	0.86	008	+0.13
107	96	04/96 RFO	Bobbin	NQI		0.95	003	+31.29
107	107	04/96 RFO	Bobbin	NQI		0.56	007	+0.94
107	108	04/96 RFO	Bobbin	NQI		0.20	015	+39.34
		04/96 RFO	Bobbin	NQI		0.28	015	+43.52
		04/96 RFO	Bobbin	ODI	26	0.53	015	+41.72
		04/96 RFO	Bobbin	ODI	36	0.65	015	+41.16
		04/96 RFO	Bobbin	ODI	50	0.21	015	+39.34
		04/96 RFO	Bobbin	ODI	77	0.29	015	+43.51
107	109	04/96 RFO	Bobbin	ODI	9	0.48	006	+35.77
107	110	04/96 RFO	Bobbin	ODI	7	0.62	015	+30.33
		04/96 RFO	Bobbin	ODI	11	0.71	015	+29.43
		04/96 RFO	Bobbin	ODI	18	0.68	015	+23.96
		04/96 RFO	Bobbin	ODI	30	0.71	015	+38.97
		04/96 RFO	Bobbin	ODI	30	0.90	015	+42.86
		04/96 RFO	Bobbin	ODI	35	0.48	015	+33.52
		04/96 RFO	Bobbin	ODI	37	0.51	015	+35.99
		04/96 RFO	Bobbin	ODI	52	0.48	015	+38.66
		04/96 RFO	Bobbin	ODI	57	0.35	015	+32.61
107	113	04/96 RFO	Bobbin	ODI	39	0.31	006	+33.90
107	114	04/96 RFO	Bobbin	NQI		0.39	006	+34.37
107	117	04/96 RFO	Bobbin	ODI	24	0.33	007	+21.81
107	118	04/96 RFO	Bobbin	NQI		0.71	008	+11.08
107	119	04/96 RFO	Bobbin	NQI		0.39	008	+24.81
108	2	04/96 RFO	Bobbin	ADI		1.23	008	+33.14
108	7	04/96 RFO	Bobbin	ODI	27	0.20	006	+30.74
108	11	04/96 RFO	Bobbin	NQI		0.30	006	+27.07
		04/96 RFO	Bobbin	ODI	10	0.32	006	+31.60
108	16	04/96 RFO	Bobbin	ODI	4	1.02	006	+29.04
108	20	04/96 RFO	Bobbin	ODI	18	0.32	006	+31.52
108	21	04/96 RFO	Bobbin	NQI		0.36	006	+28.87
108	22	04/96 RFO	Bobbin	NQI		0.39	013	+0.40
		04/96 RFO	Bobbin	ODI	6	5.68	004	+25.31
		04/96 RFO	Bobbin	ODI	26	0.42	013	-0.43
108	24	04/96 RFO	Bobbin	ODI	3	0.40	006	+27.68
		04/96 RFO	Bobbin	ODI	11	0.50	006	+26.78
108	25	04/96 RFO	Bobbin	ODI	32	4.60	014	+4.15
108	34	04/96 RFO	Bobbin	NQI		1.10	011	+10.62

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
Oconee Nuclear Station - Unit Two
S/G B
04/96 RFO
Bobbin

Page 41 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
108	46	04/96 RFO	Bobbin	ODI	13	0.19	006 -0.21	UTS
		04/96 RFO	Bobbin	ODI	32	0.22	012 -0.48	UTS
108	66	04/96 RFO	Bobbin	ODI	31	0.23	011 -0.14	LTE
108	68	04/96 RFO	Bobbin	ODI	15	1.50	011 +22.47	UTS
108	71	04/96 RFO	Bobbin	ODI	11	0.65	006 +9.63	LTE
		04/96 RFO	Bobbin	ODI	26	0.51	006 +8.98	LTE
108	73	04/96 RFO	Bobbin	NQI		0.29	012 +0.44	LTE
		04/96 RFO	Bobbin	ODI	18	0.39	012 +0.21	LTE
108	74	04/96 RFO	Bobbin	ODI	22	0.88	012 -0.46	LTE
108	77	04/96 RFO	Bobbin	ODI	7	0.29	006 +10.85	LTE
108	80	04/96 RFO	Bobbin	ODI	20	0.50	006 +10.22	LTE
108	83	04/96 RFO	Bobbin	ODI	29	0.27	006 +27.57	UTS
		04/96 RFO	Bobbin	NQI		0.33	006 +14.20 to +25.28	UTS
108	94	04/96 RFO	Bobbin	NQI		1.35	014 +21.75	LTE
		04/96 RFO	Bobbin	NQI		1.98	004 +10.24	LTE
		04/96 RFO	Bobbin	NQI		2.31	009 +10.61	LTE
108	119	04/96 RFO	Bobbin	ODI	16	0.45	009 +15.17	LTE
109	10	04/96 RFO	Bobbin	NQI		0.57	006 +26.87	LTE
109	12	04/96 RFO	Bobbin	NQI		0.46	006 +28.03	LTE
109	13	04/96 RFO	Bobbin	NQI		0.42	006 +28.06	LTE
109	14	04/96 RFO	Bobbin	NQI		0.75	006 +28.38	LTE
109	16	04/96 RFO	Bobbin	NQI		0.26	006 +29.91 to +33.13	LTE
109	20	04/96 RFO	Bobbin	NQI		0.41	006 +28.28	LTE
109	28	04/96 RFO	Bobbin	NQI		0.28	015 +24.43	LTE
		04/96 RFO	Bobbin	NQI		0.41	013 +0.21	LTE
		04/96 RFO	Bobbin	ODI	1	0.35	015 +39.61	LTE
		04/96 RFO	Bobbin	ODI	34	0.30	006 +26.31	LTE
109	31	04/96 RFO	Bobbin	NQI		0.34	008 +19.71	LTE
109	32	04/96 RFO	Bobbin	NQI		1.23	011 +9.96	LTE
		04/96 RFO	Bobbin	NQI		1.40	012 +0.08	LTE
		04/96 RFO	Bobbin	NQI		1.44	011 +25.86	LTE
		04/96 RFO	Bobbin	NQI		2.06	015 +39.40	LTE
109	36	04/96 RFO	Bobbin	ODI	1	0.61	015 +43.19	LTE
109	44	04/96 RFO	Bobbin	NQI		0.58	011 +34.54	UTE
		04/96 RFO	Bobbin	ODI	9	0.63	012 -0.56	UTE
109	49	04/96 RFO	Bobbin	ODI	30	0.36	006 +8.13	LTE
109	55	04/96 RFO	Bobbin	ODI	15	0.27	005 +33.74	LTE
109	58	04/96 RFO	Bobbin	NQI		0.27	012 +7.85	LTE
109	59	04/96 RFO	Bobbin	ODI	23	1.97	006 +13.19	LTE
109	61	04/96 RFO	Bobbin	NQI		0.43	005 +35.34	UTS
109	63	04/96 RFO	Bobbin	ODI	12	0.43	012 +0.08	LTE
109	78	04/96 RFO	Bobbin	ODI	29	0.51	006 +11.70	LTE
109	83	04/96 RFO	Bobbin	ODI	10	0.44	012 +0.55	LTE
109	116	04/96 RFO	Bobbin	ODI	5	0.35	008 +13.95	LTE
110	1	04/96 RFO	Bobbin	NQI		0.99	015 +0.37	LTE
110	7	04/96 RFO	Bobbin	NQI		0.42	008 +30.90	LTE
110	16	04/96 RFO	Bobbin	NQI		0.68	006 +31.01	LTE
110	20	04/96 RFO	Bobbin	ADI		4.69	004 +29.31	LTE
		04/96 RFO	Bobbin	NQI		0.97	015 +25.74	LTE
110	26	04/96 RFO	Bobbin	NQI		0.56	006 +30.02	LTE
		04/96 RFO	Bobbin	ODI	10	0.67	013 +0.29	LTE
110	27	04/96 RFO	Bobbin	NQI		0.46	006 +29.37	LTE
110	29	04/96 RFO	Bobbin	NQI		0.37	012 +0.39	LTE
110	30	04/96 RFO	Bobbin	NQI		0.47	006 +33.26	LTE
110	35	04/96 RFO	Bobbin	NQI		0.47	006 +27.07	LTE
110	39	04/96 RFO	Bobbin	NQI		0.47	006 +17.40	LTE
110	41	04/96 RFO	Bobbin	NQI		0.73	013 +0.67	LTE
110	42	04/96 RFO	Bobbin	NQI		0.56	006 +14.69	LTE
110	43	04/96 RFO	Bobbin	NQI		0.80	012 -0.54	LTE
110	64	04/96 RFO	Bobbin	ODI	1	0.55	012 +0.53	LTE
110	67	04/96 RFO	Bobbin	ODI	20	0.41	005 +34.71	LTE
110	69	04/96 RFO	Bobbin	ODI	26	0.39	006 +7.78	LTE
110	71	04/96 RFO	Bobbin	ODI	5	0.53	006 +10.56	UTS
		04/96 RFO	Bobbin	ODI	17	0.66	006 +11.88	UTS
110	84	04/96 RFO	Bobbin	ODI	5	0.47	006 +20.83	LTE

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
110	93	04/96 RFO	Bobbin	ODI	7	2.62 009	+22.79	LTE
110	105	04/96 RFO	Bobbin	ODI	33	0.36 006	+37.23	LTE
110	106	04/96 RFO	Bobbin	ODI	22	0.29 006	+35.07	LTE
110	107	04/96 RFO	Bobbin	ODI	18	0.59 006	+36.48	LTE
110	109	04/96 RFO	Bobbin	ODI	7	0.46 006	+35.64	LTE
111	6	04/96 RFO	Bobbin	ODI	15	0.53 007	+16.68	LTE
111	22	04/96 RFO	Bobbin	ODI	12	0.16 008	+7.02	LTE
		04/96 RFO	Bobbin	ODI	12	0.25 008	+7.58	LTE
111	26	04/96 RFO	Bobbin	NQI		0.78 006	+31.87	LTE
111	30	04/96 RFO	Bobbin	NQI		0.31 006	+36.00	UTE
		04/96 RFO	Bobbin	ODI	4	0.39 002	+24.79	UTE
111	31	04/96 RFO	Bobbin	NQI		0.34 006	+25.75 to +30.37	LTE
111	42	04/96 RFO	Bobbin	ODI	16	0.33 012	+0.17	LTE
111	61	04/96 RFO	Bobbin	NQI		0.39 015	+39.71	UTS
		04/96 RFO	Bobbin	ODI	21	0.36 006	+5.46	UTS
		04/96 RFO	Bobbin	ODI	50	0.61 012	+0.13	UTS
		04/96 RFO	Bobbin	ODI	72	0.24 015	+41.76	UTS
111	63	04/96 RFO	Bobbin	ODI	87	0.96 012	-0.60	LTE
111	77	04/96 RFO	Bobbin	NQI		0.27 013	-0.13	LTE
111	78	04/96 RFO	Bobbin	NQI		0.19 015	+15.65	LTE
		04/96 RFO	Bobbin	ODI	20	0.50 012	+0.51	LTE
111	80	04/96 RFO	Bobbin	ODI	43	0.48 006	+27.27	UTE
111	86	04/96 RFO	Bobbin	ODI	12	1.94 013	+23.78	LTE
112	7	04/96 RFO	Bobbin	NQI		0.63 010	+4.30	LTE
		04/96 RFO	Bobbin	NQI		0.99 010	+1.41	LTE
		04/96 RFO	Bobbin	ODI	51	0.41 010	+6.04	LTE
112	14	04/96 RFO	Bobbin	NQI		0.37 006	+29.15	LTE
112	20	04/96 RFO	Bobbin	NQI		0.36 006	+30.39	LTE
		04/96 RFO	Bobbin	ODI	15	0.28 006	+30.76	LTE
112	22	04/96 RFO	Bobbin	NQI		1.02 LTS	+16.26	LTE
112	23	04/96 RFO	Bobbin	ODI	33	0.29 012	+0.26	LTE
112	28	04/96 RFO	Bobbin	NQI		0.23 007	+8.05	LTE
112	31	04/96 RFO	Bobbin	ODI	30	0.48 006	+30.24	LTE
112	32	04/96 RFO	Bobbin	NQI		0.35 006	+21.81	UTE
		04/96 RFO	Bobbin	ODI	32	0.60 012	+0.42	UTE
		04/96 RFO	Bobbin	ODI	47	0.85 012	+0.11	UTE
112	47	04/96 RFO	Bobbin	NQI		0.31 012	-0.08	UTE
112	50	04/96 RFO	Bobbin	NQI		0.52 001	+33.91	LTE
112	65	04/96 RFO	Bobbin	ODI	39	0.85 012	-0.21	LTE
112	66	04/96 RFO	Bobbin	ODI	12	0.39 012	+0.49	LTE
112	70	04/96 RFO	Bobbin	NQI		0.35 012	+0.41	LTE
112	74	04/96 RFO	Bobbin	NQI		0.45 004	+13.36	LTE
112	81	04/96 RFO	Bobbin	NQI		1.62 003	+15.56	LTE
112	83	04/96 RFO	Bobbin	NQI		0.18 006	+35.09	LTE
112	92	04/96 RFO	Bobbin	DWI		1.90 013	+19.39	UTS
112	98	04/96 RFO	Bobbin	ODI	7	0.94 LTS	+42.37	LTE
112	107	04/96 RFO	Bobbin	ODI	20	0.47 006	+34.65	LTE
112	111	04/96 RFO	Bobbin	ODI	26	0.34 008	+0.57	LTE
112	116	04/96 RFO	Bobbin	NQI		0.59 009	+0.00	LTE
113	6	04/96 RFO	Bobbin	ODI	24	0.77 007	+35.20	LTE
		04/96 RFO	Bobbin	ODI	26	0.43 007	+35.59	LTE
113	15	04/96 RFO	Bobbin	ODI	18	0.51 009	+18.27	LTE
113	17	04/96 RFO	Bobbin	NQI		0.30 006	+33.63	UTS
113	26	04/96 RFO	Bobbin	NQI		0.64 006	+35.56	LTE
		04/96 RFO	Bobbin	ODI	12	0.56 006	+34.88	LTE
113	29	04/96 RFO	Bobbin	ODI	5	0.52 007	+10.68	LTE
		04/96 RFO	Bobbin	ODI	55	0.63 012	+0.18	LTE
113	30	04/96 RFO	Bobbin	NQI		0.58 006	+32.49	LTE
		04/96 RFO	Bobbin	ODI	5	0.80 006	+33.11	LTE
113	32	04/96 RFO	Bobbin	NQI		2.30 008	+10.04	UTS
113	40	04/96 RFO	Bobbin	ODI	5	1.24 002	+8.56	LTE
113	46	04/96 RFO	Bobbin	NQI		0.42 015	+17.84	LTE
113	75	04/96 RFO	Bobbin	NQI		0.52 006	+15.15	LTE
113	81	04/96 RFO	Bobbin	ODI	36	0.26 013	+20.61	UTS
113	84	04/96 RFO	Bobbin	ODI	30	0.46 012	+0.05	LTE

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 43 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
113	93	04/96 RFO	Bobbin	ADI		2.61	014	+31.94
		04/96 RFO	Bobbin	NQI		1.68	001	+27.92
113	94	04/96 RFO	Bobbin	ODI	10	2.18	008	+12.92
113	109	04/96 RFO	Bobbin	NQI		0.42	006	+33.98
114	6	04/96 RFO	Bobbin	ODI	4	0.65	008	+0.57
		04/96 RFO	Bobbin	ODI	10	0.56	007	+32.10
		04/96 RFO	Bobbin	ODI	43	0.55	009	+3.95
114	16	04/96 RFO	Bobbin	ODI	29	0.39	006	+30.27
114	27	04/96 RFO	Bobbin	NQI		0.52	006	+35.03
114	30	04/96 RFO	Bobbin	ODI	10	0.46	006	+31.50
114	31	04/96 RFO	Bobbin	ODI	14	0.32	006	+22.42
		04/96 RFO	Bobbin	ODI	14	0.48	006	+24.08
114	53	04/96 RFO	Bobbin	NQI		0.48	006	+13.53
114	80	04/96 RFO	Bobbin	NQI		1.24	004	+0.13
114	83	04/96 RFO	Bobbin	NQI		0.41	001	+33.55
114	93	04/96 RFO	Bobbin	ODI	5	2.07	015	+28.75
		04/96 RFO	Bobbin	ODI	15	1.45	015	+29.42
114	107	04/96 RFO	Bobbin	NQI		0.47	LTS	+1.53
		04/96 RFO	Bobbin	NQI		0.67	006	+33.14
		04/96 RFO	Bobbin	NQI		1.34	015	+39.78
114	111	04/96 RFO	Bobbin	ODI	7	0.54	009	+0.21
114	112	04/96 RFO	Bobbin	ODI	27	0.26	009	-0.10
115	2	04/96 RFO	Bobbin	NQI		0.81	015	+0.42
115	15	04/96 RFO	Bobbin	NQI		0.53	006	+29.81
115	17	04/96 RFO	Bobbin	NQI		0.36	006	+30.41
115	18	04/96 RFO	Bobbin	NQI		0.40	006	+30.87
115	21	04/96 RFO	Bobbin	NQI		0.56	006	+28.37
115	23	04/96 RFO	Bobbin	NQI		0.43	006	+28.86
115	25	04/96 RFO	Bobbin	NQI		0.62	014	+18.32
115	30	04/96 RFO	Bobbin	NQI		0.36	012	+18.63
115	31	04/96 RFO	Bobbin	NQI		0.33	006	+24.68
115	34	04/96 RFO	Bobbin	NQI		0.80	011	+35.15
		04/96 RFO	Bobbin	ODI	23	1.03	011	+33.96
		04/96 RFO	Bobbin	ODI	57	0.31	011	+33.05
115	38	04/96 RFO	Bobbin	NQI		0.62	007	+0.60
115	44	04/96 RFO	Bobbin	NQI		0.18	012	-0.15
115	48	04/96 RFO	Bobbin	NQI		0.34	012	-0.05
115	63	04/96 RFO	Bobbin	NQI		0.41	003	+20.08
115	69	04/96 RFO	Bobbin	ODI	46	0.40	012	+0.32
		04/96 RFO	Bobbin	ODI	75	1.06	012	-0.63
115	75	04/96 RFO	Bobbin	NQI		0.25	012	+0.21
115	76	04/96 RFO	Bobbin	ODI	15	0.51	006	+23.97
		04/96 RFO	Bobbin	ODI	29	0.52	006	+19.04
115	77	04/96 RFO	Bobbin	ODI	5	0.68	006	+31.12
115	79	04/96 RFO	Bobbin	NQI		0.86	015	+39.41
115	82	04/96 RFO	Bobbin	ODI	30	0.36	012	+0.50
115	94	04/96 RFO	Bobbin	ODI	2	2.75	005	+2.24
		04/96 RFO	Bobbin	ODI	6	2.86	005	+4.43
		04/96 RFO	Bobbin	ODI	18	0.20	005	+3.40
115	100	04/96 RFO	Bobbin	ODI	7	0.60	014	+7.65
115	106	04/96 RFO	Bobbin	ODI	14	0.70	013	+2.67
		04/96 RFO	Bobbin	ODI	44	0.29	013	+3.17
115	111	04/96 RFO	Bobbin	ODI	12	0.66	008	+29.24
115	112	04/96 RFO	Bobbin	NQI		0.53	009	+14.96
		04/96 RFO	Bobbin	ODI	13	0.56	009	+0.26
116	3	04/96 RFO	Bobbin	NQI		0.54	008	+16.13 to +36.78
116	18	04/96 RFO	Bobbin	NQI		0.53	006	+29.70 to +31.87
116	19	04/96 RFO	Bobbin	NQI		0.44	006	+30.04
116	44	04/96 RFO	Bobbin	ODI	22	0.32	006	+14.75
116	56	04/96 RFO	Bobbin	ODI	31	1.10	012	-0.59
116	62	04/96 RFO	Bobbin	ADI		2.51	014	+25.51
116	64	04/96 RFO	Bobbin	ODI	7	0.21	012	+0.24
		04/96 RFO	Bobbin	ODI	16	0.49	006	+15.91
116	70	04/96 RFO	Bobbin	ODI	18	0.40	006	+29.83
116	75	04/96 RFO	Bobbin	ODI	11	0.53	006	+32.05

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
116	76	04/96 RFO	Bobbin	ODI	14	0.51	006 +27.91	LTE
116	91	04/96 RFO	Bobbin	ODI	30	1.55	014 +22.99	LTE
		04/96 RFO	Bobbin	ADI		2.77	015 +21.08 to +25.58	LTE
116	100	04/96 RFO	Bobbin	ODI	4	3.27	015 +26.77	LTE
116	107	04/96 RFO	Bobbin	ODI	24	0.55	006 +34.45	LTE
116	111	04/96 RFO	Bobbin	NQI		0.43	009 +12.07	LTE
117	2	04/96 RFO	Bobbin	ODI	34	0.47	008 +32.49	LTE
117	10	04/96 RFO	Bobbin	NQI		0.42	006 +28.39	LTE
117	16	04/96 RFO	Bobbin	ODI	24	0.61	015 +29.29	LTE
		04/96 RFO	Bobbin	ODI	51	0.73	015 +28.21	LTE
117	17	04/96 RFO	Bobbin	ODI	6	0.66	006 +30.10	LTE
		04/96 RFO	Bobbin	ODI	6	1.66	014 +6.33	LTE
117	19	04/96 RFO	Bobbin	NQI		1.46	015 +2.12	LTE
		04/96 RFO	Bobbin	ODI	15	1.23	013 +12.58	LTE
117	27	04/96 RFO	Bobbin	NQI		0.55	015 +36.75	LTE
117	30	04/96 RFO	Bobbin	ODI	3	1.06	012 +0.84	LTE
117	40	04/96 RFO	Bobbin	NQI		0.45	006 +20.29	LTE
117	41	04/96 RFO	Bobbin	ODI	27	0.32	001 +34.24	UTE
117	46	04/96 RFO	Bobbin	NQI		0.34	006 +10.21	UTE
117	51	04/96 RFO	Bobbin	ODI	64	0.88	012 +0.64	LTE
117	60	04/96 RFO	Bobbin	NQI		0.19	013 +0.05	LTE
117	64	04/96 RFO	Bobbin	NQI		0.56	013 -0.37	LTE
117	67	04/96 RFO	Bobbin	ODI	2	0.33	015 +31.41	LTE
117	77	04/96 RFO	Bobbin	ADI		7.85	015 +42.94	LTE
117	94	04/96 RFO	Bobbin	ODI	24	0.94	015 +37.38	LTE
		04/96 RFO	Bobbin	ODI	37	0.41	015 +32.08	LTE
118	1	04/96 RFO	Bobbin	NQI		0.61	008 +0.77	LTE
118	2	04/96 RFO	Bobbin	ODI	61	0.59	011 +31.82	LTE
		04/96 RFO	Bobbin	ODI	65	0.34	011 +30.97	LTE
118	3	04/96 RFO	Bobbin	NQI		0.58	007 +32.28	LTE
118	17	04/96 RFO	Bobbin	NQI		0.53	014 +18.65	LTE
		04/96 RFO	Bobbin	ODI	27	0.46	006 +33.84	LTE
118	18	04/96 RFO	Bobbin	ODI	11	0.87	015 +31.01	LTE
118	19	04/96 RFO	Bobbin	ODI	63	0.44	012 +5.34	LTE
118	24	04/96 RFO	Bobbin	NQI		1.01	013 +0.60	LTE
118	38	04/96 RFO	Bobbin	NQI		0.41	006 +26.81	UTE
		04/96 RFO	Bobbin	ODI	25	0.23	012 +0.31	UTE
118	44	04/96 RFO	Bobbin	NQI		0.17	012 -0.28	LTE
118	56	04/96 RFO	Bobbin	NQI		0.56	006 +13.10	UTS
		04/96 RFO	Bobbin	ODI	17	0.39	006 +14.86	UTS
118	65	04/96 RFO	Bobbin	ODI	28	0.33	006 +24.20	LTE
118	68	04/96 RFO	Bobbin	ODI	5	0.62	006 +30.47	UTS
		04/96 RFO	Bobbin	ODI	21	0.31	006 +24.06	UTS
118	70	04/96 RFO	Bobbin	ODI	4	0.54	014 -1.50	LTE
118	73	04/96 RFO	Bobbin	ADI		1.23	015 +21.79	LTE
118	74	04/96 RFO	Bobbin	ODI	18	0.40	007 +1.42	LTE
118	88	04/96 RFO	Bobbin	ADI		1.79	007 +28.45	LTE
118	95	04/96 RFO	Bobbin	ODI	29	0.42	006 +34.18	LTE
118	103	04/96 RFO	Bobbin	NQI		0.33	008 +10.97	LTE
118	104	04/96 RFO	Bobbin	ODI	12	0.58	008 +21.47	LTE
118	105	04/96 RFO	Bobbin	ODI	22	0.53	009 +6.43	LTE
119	2	04/96 RFO	Bobbin	NQI		0.53	010 +0.60	LTE
		04/96 RFO	Bobbin	ODI	31	0.27	010 +28.56	LTE
119	3	04/96 RFO	Bobbin	NQI		0.38	015 -0.03	LTE
		04/96 RFO	Bobbin	NQI		0.65	015 -1.35	LTE
119	4	04/96 RFO	Bobbin	NQI		0.52	015 +0.29	LTE
		04/96 RFO	Bobbin	NQI		0.53	015 +0.59	LTE
119	16	04/96 RFO	Bobbin	ODI	25	0.36	006 +30.75	LTE
119	17	04/96 RFO	Bobbin	ODI	22	0.35	006 +32.51	LTE
119	28	04/96 RFO	Bobbin	ODI	12	0.33	012 -0.18	LTE
		04/96 RFO	Bobbin	ODI	41	1.13	012 +0.62	LTE
119	34	04/96 RFO	Bobbin	NQI		1.52	014 +22.18	LTE
		04/96 RFO	Bobbin	ODI	4	0.49	006 +25.39	LTE
		04/96 RFO	Bobbin	ODI	34	0.43	006 +28.63	LTE
		04/96 RFO	Bobbin	ODI	37	0.49	006 +30.33	LTE

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
119	36	04/96 RFO	Bobbin	NQI		0.35	006	+25.31
		04/96 RFO	Bobbin	ODI	31	0.11	013	-0.25
119	37	04/96 RFO	Bobbin	ODI	12	0.29	006	+27.99
119	38	04/96 RFO	Bobbin	NQI		0.67	013	+0.53
119	39	04/96 RFO	Bobbin	NQI		0.31	006	+25.21
119	44	04/96 RFO	Bobbin	NQI		0.25	006	+27.94
119	45	04/96 RFO	Bobbin	NQI		0.41	012	+0.36
119	46	04/96 RFO	Bobbin	NQI		0.41	006	+16.27
119	50	04/96 RFO	Bobbin	ODI	4	1.16	002	+7.63
119	52	04/96 RFO	Bobbin	ODI	25	0.39	006	+17.67
119	53	04/96 RFO	Bobbin	ODI	19	1.23	015	+33.73
119	57	04/96 RFO	Bobbin	ODI	3	0.49	006	+13.00
119	59	04/96 RFO	Bobbin	ODI	10	0.32	012	+0.41
		04/96 RFO	Bobbin	ODI	27	0.34	012	-0.13
119	61	04/96 RFO	Bobbin	ODI	33	0.29	012	+0.31
119	63	04/96 RFO	Bobbin	ODI	28	0.46	006	+13.31
119	65	04/96 RFO	Bobbin	ODI	29	0.58	012	+0.23
119	68	04/96 RFO	Bobbin	ODI	36	0.42	006	+25.56
		04/96 RFO	Bobbin	ODI	60	0.35	006	+27.11
119	69	04/96 RFO	Bobbin	ODI	36	0.91	015	+11.01
		04/96 RFO	Bobbin	ODI	59	0.31	006	+29.54
119	70	04/96 RFO	Bobbin	ODI	21	0.37	006	+29.00
119	71	04/96 RFO	Bobbin	ODI	5	0.71	006	+35.02
119	88	04/96 RFO	Bobbin	NQI		0.53	006	+33.57
119	99	04/96 RFO	Bobbin	ADI		3.43	013	+17.93
119	101	04/96 RFO	Bobbin	ODI	18	0.62	LTS	-0.36
119	104	04/96 RFO	Bobbin	ODI	7	0.61	008	+18.14
119	106	04/96 RFO	Bobbin	ODI	14	0.64	009	+10.08
119	108	04/96 RFO	Bobbin	ODI	18	1.00	010	+6.52
120	2	04/96 RFO	Bobbin	ODI	12	0.71	010	+0.56
120	3	04/96 RFO	Bobbin	NQI		0.53	009	+0.55
		04/96 RFO	Bobbin	NQI		0.63	012	+0.56
		04/96 RFO	Bobbin	ODI	37	0.38	007	+29.84
120	10	04/96 RFO	Bobbin	NQI		0.28	006	+28.05
120	17	04/96 RFO	Bobbin	ODI	11	3.10	LTS	+14.53
120	28	04/96 RFO	Bobbin	NQI		0.15	013	-0.03
		04/96 RFO	Bobbin	ODI	36	0.25	012	+0.10
120	89	04/96 RFO	Bobbin	NQI		1.03	LTS	+27.70
120	91	04/96 RFO	Bobbin	ODI	24	0.33	007	-1.39
120	103	04/96 RFO	Bobbin	NQI		0.89	012	+9.80
		04/96 RFO	Bobbin	ODI	5	0.27	008	+16.22
120	105	04/96 RFO	Bobbin	ADI		1.82	009	+4.44 to +14.05
120	107	04/96 RFO	Bobbin	ODI	18	0.58	010	+5.66
121	1	04/96 RFO	Bobbin	NQI		0.38	015	+0.33
121	7	04/96 RFO	Bobbin	ODI	2	0.11	008	-0.39
121	13	04/96 RFO	Bobbin	ODI	10	0.57	006	+30.35
121	18	04/96 RFO	Bobbin	ODI	22	0.39	006	+0.70
121	25	04/96 RFO	Bobbin	ODI	22	0.73	013	+0.28
121	32	04/96 RFO	Bobbin	ODI	20	0.66	006	+27.59
121	38	04/96 RFO	Bobbin	ODI	10	0.33	012	+28.72
121	40	04/96 RFO	Bobbin	ODI	6	0.35	006	+19.33
121	44	04/96 RFO	Bobbin	NQI		0.40	012	+0.17
		04/96 RFO	Bobbin	NQI		0.79	012	+0.64
121	59	04/96 RFO	Bobbin	ADI		1.19	006	+18.73
121	70	04/96 RFO	Bobbin	NQI		0.44	005	+20.22
121	86	04/96 RFO	Bobbin	ODI	12	1.12	003	+27.58
121	87	04/96 RFO	Bobbin	ODI	8	0.83	006	+37.25
121	89	04/96 RFO	Bobbin	NQI		0.42	007	+5.81
121	91	04/96 RFO	Bobbin	ODI	5	0.43	006	+35.20
121	92	04/96 RFO	Bobbin	NQI		0.47	007	+1.44
121	93	04/96 RFO	Bobbin	NQI		0.47	007	+1.40
121	100	04/96 RFO	Bobbin	ODI	47	0.50	009	+27.92
121	104	04/96 RFO	Bobbin	ADI		2.13	009	+9.14
121	106	04/96 RFO	Bobbin	NQI		0.44	010	+6.85
122	1	04/96 RFO	Bobbin	NQI		0.44	LTS	-0.22

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	NQI		0.52	014	+12.30
		04/96 RFO	Bobbin	ODI	70	0.23	014	+11.56
122	2	04/96 RFO	Bobbin	ODI	12	0.23	008	+24.61
122	3	04/96 RFO	Bobbin	NQI		0.36	015	+0.13
122	9	04/96 RFO	Bobbin	NQI		0.52	006	+31.27
122	14	04/96 RFO	Bobbin	NQI		0.26	006	+37.02
122	20	04/96 RFO	Bobbin	ODI	13	0.45	012	+0.50
122	21	04/96 RFO	Bobbin	NQI		0.44	006	+26.21
122	23	04/96 RFO	Bobbin	NQI		0.40	006	+27.81
122	25	04/96 RFO	Bobbin	NQI		0.10	007	-0.15
122	32	04/96 RFO	Bobbin	NQI		0.24	007	-1.27
122	34	04/96 RFO	Bobbin	ODI	57	1.32	012	+0.61
122	36	04/96 RFO	Bobbin	ODI	4	0.43	012	-0.49
122	37	04/96 RFO	Bobbin	ODI	12	0.46	006	+29.43
122	50	04/96 RFO	Bobbin	ODI	32	0.58	012	+0.10
122	63	04/96 RFO	Bobbin	ODI	32	0.61	012	+0.40
122	76	04/96 RFO	Bobbin	NQI		0.47	007	+12.17
		04/96 RFO	Bobbin	ODI	42	0.48	012	+0.47
122	78	04/96 RFO	Bobbin	NQI		0.50	006	+0.05
122	81	04/96 RFO	Bobbin	ODI	28	0.44	007	+7.98
122	83	04/96 RFO	Bobbin	ADI		0.34	007	+7.59
122	84	04/96 RFO	Bobbin	NQI		0.17	013	+0.26
		04/96 RFO	Bobbin	ODI	25	0.26	007	-0.23
122	85	04/96 RFO	Bobbin	NQI		0.22	007	+6.90
122	86	04/96 RFO	Bobbin	NQI		0.41	006	+36.48
		04/96 RFO	Bobbin	NQI		0.60	013	+21.10
		04/96 RFO	Bobbin	ODI	7	0.33	006	+35.53
		04/96 RFO	Bobbin	ODI	20	0.38	007	+4.21
122	87	04/96 RFO	Bobbin	NQI		0.38	007	-1.49
		04/96 RFO	Bobbin	ODI	36	0.44	006	+36.85
122	88	04/96 RFO	Bobbin	NQI		0.26	006	+36.02
		04/96 RFO	Bobbin	NQI		0.66	014	+18.55
122	103	04/96 RFO	Bobbin	NQI		0.46	009	+13.55
		04/96 RFO	Bobbin	NQI		0.62	009	+16.76
123	1	04/96 RFO	Bobbin	NQI		0.41	009	+14.98
123	2	04/96 RFO	Bobbin	ODI	24	0.52	013	+12.04
123	14	04/96 RFO	Bobbin	NQI		0.34	002	+25.91
		04/96 RFO	Bobbin	ODI	4	3.63	006	+29.49
123	15	04/96 RFO	Bobbin	ODI	10	5.18	015	+42.97
123	19	04/96 RFO	Bobbin	DWI		0.80	001	+28.44
		04/96 RFO	Bobbin	DWI		4.05	001	+17.58
123	24	04/96 RFO	Bobbin	NQI		0.46	006	+28.75
123	26	04/96 RFO	Bobbin	NQI		0.27	011	+30.24
		04/96 RFO	Bobbin	NQI		0.62	015	+1.53
		04/96 RFO	Bobbin	ODI	41	0.32	011	+30.80
123	36	04/96 RFO	Bobbin	ODI	7	0.45	006	+34.62
123	42	04/96 RFO	Bobbin	NQI		0.52	006	+26.62
123	44	04/96 RFO	Bobbin	NQI		0.29	012	-0.25
123	52	04/96 RFO	Bobbin	DWI		1.60	012	+23.82
123	58	04/96 RFO	Bobbin	NQI		0.25	006	+25.44
123	63	04/96 RFO	Bobbin	ADI		1.69	007	+20.10
		04/96 RFO	Bobbin	ODI	10	0.22	006	+24.59
		04/96 RFO	Bobbin	ODI	12	0.22	006	+23.98
		04/96 RFO	Bobbin	ODI	18	0.16	006	+26.23
		04/96 RFO	Bobbin	ODI	35	0.29	006	+22.17
123	67	04/96 RFO	Bobbin	ODI	40	0.73	011	+4.97
123	69	04/96 RFO	Bobbin	ADI		1.94	013	+12.43
123	70	04/96 RFO	Bobbin	NQI		0.22	012	+0.68
		04/96 RFO	Bobbin	ODI	29	0.39	012	+0.28
123	93	04/96 RFO	Bobbin	ODI	15	0.16	012	-0.10
123	94	04/96 RFO	Bobbin	ADI		2.69	015	+9.00
123	97	04/96 RFO	Bobbin	NQI		0.21	008	+0.40
123	102	04/96 RFO	Bobbin	ODI	50	0.32	010	+15.59
		04/96 RFO	Bobbin	ODI	57	0.48	010	+15.99
123	103	04/96 RFO	Bobbin	NQI		0.65	011	+3.61

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
123	104	04/96 RFO	Bobbin	ADI		2.38	011	+3.85
		04/96 RFO	Bobbin	NQI		0.37	010	+4.39
124	11	04/96 RFO	Bobbin	ODI	18	1.98	015	+15.43
124	13	04/96 RFO	Bobbin	ODI	3	1.75	011	+16.30
124	14	04/96 RFO	Bobbin	ODI	10	0.46	006	+30.09
124	41	04/96 RFO	Bobbin	ODI	28	0.69	012	-0.19
124	43	04/96 RFO	Bobbin	ODI	7	2.44	009	+28.30
		04/96 RFO	Bobbin	ODI	23	0.47	012	+0.14
124	50	04/96 RFO	Bobbin	NQI		0.49	012	+0.27
124	54	04/96 RFO	Bobbin	NQI		0.18	006	+30.17
		04/96 RFO	Bobbin	ODI	5	0.15	006	+28.85
		04/96 RFO	Bobbin	ODI	33	0.19	006	+30.53
124	56	04/96 RFO	Bobbin	NQI		0.55	012	-0.56
124	60	04/96 RFO	Bobbin	ODI	10	0.57	006	+26.87
		04/96 RFO	Bobbin	ODI	12	0.36	006	+21.18
		04/96 RFO	Bobbin	ODI	19	0.33	006	+20.60
124	61	04/96 RFO	Bobbin	NQI		0.20	006	+24.82
		04/96 RFO	Bobbin	NQI		0.26	006	+27.85
		04/96 RFO	Bobbin	NQI		0.27	006	+36.70
		04/96 RFO	Bobbin	ODI	3	0.27	LTE	+21.79
		04/96 RFO	Bobbin	ODI	3	0.34	006	+30.61
		04/96 RFO	Bobbin	ODI	12	0.25	006	+29.90
		04/96 RFO	Bobbin	ODI	16	0.25	006	+26.18
		04/96 RFO	Bobbin	ODI	35	0.20	006	+22.91
124	63	04/96 RFO	Bobbin	NQI		0.65	LTE	+20.41
		04/96 RFO	Bobbin	NQI		0.65	LTE	+20.41
124	66	04/96 RFO	Bobbin	ODI	10	0.27	007	+5.29
124	67	04/96 RFO	Bobbin	NQI		0.31	007	+6.14
124	68	04/96 RFO	Bobbin	NQI		1.00	012	+0.72
		04/96 RFO	Bobbin	ODI	16	0.36	007	+6.61
124	92	04/96 RFO	Bobbin	NQI		0.59	UTS	+0.42
124	97	04/96 RFO	Bobbin	DWI		3.17	011	+34.42
124	100	04/96 RFO	Bobbin	NQI		0.33	009	+0.20
		04/96 RFO	Bobbin	NQI		0.60	015	-0.33
124	101	04/96 RFO	Bobbin	NQI		0.53	015	-0.33
		04/96 RFO	Bobbin	NQI		0.66	011	+0.58
125	5	04/96 RFO	Bobbin	NQI		0.57	008	-0.63
125	12	04/96 RFO	Bobbin	ADI		2.56	015	+13.65
		04/96 RFO	Bobbin	ODI	14	0.52	006	+30.89
125	15	04/96 RFO	Bobbin	NQI		0.41	006	+27.71
125	19	04/96 RFO	Bobbin	NQI		0.73	006	+29.20 to +32.53
125	20	04/96 RFO	Bobbin	NQI		0.38	006	+25.65 to +30.63
125	21	04/96 RFO	Bobbin	NQI		0.47	006	+29.36
125	24	04/96 RFO	Bobbin	NQI		0.50	006	+27.66 to +36.02
125	25	04/96 RFO	Bobbin	NQI		0.52	006	+26.77 to +35.13
125	26	04/96 RFO	Bobbin	NQI		0.34	006	+31.20
125	30	04/96 RFO	Bobbin	ODI	17	0.34	006	+32.13
125	31	04/96 RFO	Bobbin	NQI		0.61	006	+28.36 to +30.19
125	32	04/96 RFO	Bobbin	NQI		0.55	006	+28.79 to +38.43
125	36	04/96 RFO	Bobbin	NQI		0.46	006	+33.54
125	37	04/96 RFO	Bobbin	NQI		0.42	006	+29.37
125	42	04/96 RFO	Bobbin	NQI		0.53	007	+1.97
125	43	04/96 RFO	Bobbin	NQI		0.46	006	+24.15
125	56	04/96 RFO	Bobbin	NQI		1.06	012	+0.68
		04/96 RFO	Bobbin	ODI	6	0.51	012	+0.49
125	57	04/96 RFO	Bobbin	ODI	84	1.06	012	+0.68
125	66	04/96 RFO	Bobbin	ODI	13	0.54	007	+5.79
125	68	04/96 RFO	Bobbin	ODI	15	0.40	007	+3.36
125	82	04/96 RFO	Bobbin	ODI	17	0.21	007	-0.27
125	87	04/96 RFO	Bobbin	NQI		0.38	014	+20.39
		04/96 RFO	Bobbin	NQI		0.38	015	+33.92
		04/96 RFO	Bobbin	NQI		0.41	013	+33.34
		04/96 RFO	Bobbin	ODI	1	0.63	013	+28.92
		04/96 RFO	Bobbin	ODI	17	0.41	014	-0.33
		04/96 RFO	Bobbin	ODI	39	0.72	014	+21.67

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 48 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
125	95	04/96 RFO	Bobbin	NQI		0.52	008	+0.96
125	97	04/96 RFO	Bobbin	ODI	10	0.43	008	+20.16
125	98	04/96 RFO	Bobbin	NQI		2.43	015	+25.02
		04/96 RFO	Bobbin	ODI	7	0.84	015	+23.57
		04/96 RFO	Bobbin	ODI	10	1.67	UTS	-1.35
125	100	04/96 RFO	Bobbin	NQI		0.44	010	+14.03
126	22	04/96 RFO	Bobbin	NQI		0.43	006	+34.43
126	57	04/96 RFO	Bobbin	ODI	23	0.22	012	+0.20
126	58	04/96 RFO	Bobbin	ODI	36	0.39	007	-0.27
126	59	04/96 RFO	Bobbin	ODI	32	0.87	015	+40.08
126	75	04/96 RFO	Bobbin	ODI	7	0.48	007	+6.75
126	96	04/96 RFO	Bobbin	NQI		0.85	008	+24.18
127	5	04/96 RFO	Bobbin	NQI		0.56	008	-0.62
127	20	04/96 RFO	Bobbin	NQI		0.81	006	+25.36 to +29.02
127	25	04/96 RFO	Bobbin	ODI	34	0.63	010	+9.02
127	28	04/96 RFO	Bobbin	ODI	22	0.35	012	+0.00
127	33	04/96 RFO	Bobbin	NQI		0.43	006	+30.18 to +35.16
127	71	04/96 RFO	Bobbin	NQI		0.47	007	+11.83
127	72	04/96 RFO	Bobbin	NQI		0.42	007	+9.20
127	74	04/96 RFO	Bobbin	NQI		0.55	007	+6.86
127	84	04/96 RFO	Bobbin	ODI	74	0.42	001	+25.82
127	94	04/96 RFO	Bobbin	NQI		0.70	010	+4.78
127	98	04/96 RFO	Bobbin	ODI	14	0.87	011	-0.91
128	9	04/96 RFO	Bobbin	ODI	4	0.54	007	+0.48
128	15	04/96 RFO	Bobbin	ODI	8	0.78	013	+8.34
128	16	04/96 RFO	Bobbin	NQI		0.62	006	+28.35
128	24	04/96 RFO	Bobbin	ODI	16	0.32	006	+29.82
128	27	04/96 RFO	Bobbin	NQI		0.48	006	+34.87
128	28	04/96 RFO	Bobbin	NQI		0.38	012	+0.45
		04/96 RFO	Bobbin	NQI		0.42	006	+29.89
		04/96 RFO	Bobbin	ODI	4	0.44	006	+30.40
128	29	04/96 RFO	Bobbin	ODI	12	0.41	006	+33.83
128	32	04/96 RFO	Bobbin	ODI	14	0.34	006	+32.18
128	35	04/96 RFO	Bobbin	ODI	20	0.43	006	+29.91
128	41	04/96 RFO	Bobbin	ODI	29	0.59	006	+22.65
128	44	04/96 RFO	Bobbin	ODI	16	0.44	006	+25.83
128	45	04/96 RFO	Bobbin	ODI	34	0.36	006	+24.03
128	55	04/96 RFO	Bobbin	NQI		1.24	012	+0.78
128	69	04/96 RFO	Bobbin	ODI	4	0.57	007	+8.51
128	92	04/96 RFO	Bobbin	ODI	16	1.62	LTS	+0.84
129	4	04/96 RFO	Bobbin	ODI	17	0.67	008	-0.67
129	8	04/96 RFO	Bobbin	NQI		2.43	015	+27.07
129	18	04/96 RFO	Bobbin	NQI		0.77	013	-0.77
129	29	04/96 RFO	Bobbin	ODI	16	0.49	006	+31.44
129	33	04/96 RFO	Bobbin	ODI	8	0.43	006	+33.47
129	34	04/96 RFO	Bobbin	ODI	25	0.41	006	+34.57
129	39	04/96 RFO	Bobbin	NQI		0.30	012	+0.15
129	41	04/96 RFO	Bobbin	ODI	25	0.43	006	+22.87
		04/96 RFO	Bobbin	ODI	37	0.47	006	+25.75
129	47	04/96 RFO	Bobbin	NQI		0.26	006	+23.18
		04/96 RFO	Bobbin	ODI	39	0.24	006	+25.98
129	56	04/96 RFO	Bobbin	ODI	16	0.45	006	+34.85
129	64	04/96 RFO	Bobbin	ODI	34	0.94	007	+0.90
130	4	04/96 RFO	Bobbin	ODI	6	0.58	009	+0.75
130	5	04/96 RFO	Bobbin	NQI		0.57	009	+0.71
130	6	04/96 RFO	Bobbin	NQI		0.34	009	+10.37
		04/96 RFO	Bobbin	ODI	2	0.65	009	+0.75
130	8	04/96 RFO	Bobbin	ODI	10	1.29	009	+8.26
130	9	04/96 RFO	Bobbin	NQI		1.08	009	+0.60
130	11	04/96 RFO	Bobbin	ODI	9	0.45	007	-0.15
130	12	04/96 RFO	Bobbin	ADI		1.99	007	+22.09
130	15	04/96 RFO	Bobbin	ODI	15	0.58	008	+0.57
130	20	04/96 RFO	Bobbin	ADI		3.30	LTS	+7.57
		04/96 RFO	Bobbin	NQI		0.23	006	+28.58
130	22	04/96 RFO	Bobbin	ODI	32	0.38	006	+30.37

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 49 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
130	23	04/96 RFO	Bobbin	NQI		0.98	012	-0.77
130	30	04/96 RFO	Bobbin	ODI	6	0.47	006	+30.51
130	35	04/96 RFO	Bobbin	NQI		0.78	013	-0.83
130	39	04/96 RFO	Bobbin	ODI	24	0.29	006	+23.48
		04/96 RFO	Bobbin	ODI	29	0.32	006	+29.07
130	40	04/96 RFO	Bobbin	ODI	16	0.44	006	+26.24
130	41	04/96 RFO	Bobbin	ODI	31	0.45	006	+26.74
130	54	04/96 RFO	Bobbin	ODI	25	0.50	007	-0.38
130	60	04/96 RFO	Bobbin	NQI		0.34	012	-0.36
130	71	04/96 RFO	Bobbin	NQI		0.16	007	+8.30
130	87	04/96 RFO	Bobbin	ODI	17	0.45	015	+2.44
		04/96 RFO	Bobbin	ODI	20	0.41	015	+2.65
130	91	04/96 RFO	Bobbin	ODI	23	0.61	008	+34.80
131	2	04/96 RFO	Bobbin	NQI		0.57	009	+21.75
131	3	04/96 RFO	Bobbin	ODI	16	0.69	009	+23.26
		04/96 RFO	Bobbin	ODI	22	0.52	009	+18.31
131	4	04/96 RFO	Bobbin	ODI	37	0.97	009	+0.75
131	6	04/96 RFO	Bobbin	NQI		0.63	009	+15.01
131	16	04/96 RFO	Bobbin	ODI	16	0.29	006	+26.79
131	21	04/96 RFO	Bobbin	ODI	16	0.46	006	+28.88
131	54	04/96 RFO	Bobbin	NQI		0.73	006	+29.89
131	56	04/96 RFO	Bobbin	ODI	3	0.58	006	+29.28
131	63	04/96 RFO	Bobbin	NQI		0.43	012	+0.49
131	66	04/96 RFO	Bobbin	ODI	20	0.55	007	+7.49
131	74	04/96 RFO	Bobbin	NQI		0.30	006	+33.71
131	77	04/96 RFO	Bobbin	NQI		0.32	015	+41.46
		04/96 RFO	Bobbin	ODI	16	0.76	015	+39.62
131	87	04/96 RFO	Bobbin	NQI		0.43	008	+10.67
		04/96 RFO	Bobbin	ODI	29	0.33	008	+12.17
		04/96 RFO	Bobbin	ODI	36	0.51	008	+8.40
131	88	04/96 RFO	Bobbin	NQI		0.49	008	+26.69
132	4	04/96 RFO	Bobbin	ODI	25	0.53	009	+23.30
		04/96 RFO	Bobbin	ODI	31	0.34	009	+21.17
132	5	04/96 RFO	Bobbin	ODI	2	0.67	009	+20.35
		04/96 RFO	Bobbin	ODI	10	0.46	009	+20.88
132	9	04/96 RFO	Bobbin	ODI	5	0.58	009	+3.30
132	24	04/96 RFO	Bobbin	NQI		0.35	006	+29.16
132	27	04/96 RFO	Bobbin	ODI	25	0.76	006	+29.21
132	29	04/96 RFO	Bobbin	NQI		0.39	006	+30.54
132	34	04/96 RFO	Bobbin	ODI	16	0.35	006	+25.46
132	35	04/96 RFO	Bobbin	ODI	3	0.44	006	+25.16
		04/96 RFO	Bobbin	ODI	18	0.53	006	+25.70
132	36	04/96 RFO	Bobbin	ODI	5	0.40	006	+29.75
		04/96 RFO	Bobbin	ODI	18	0.85	LTS	-0.25
132	39	04/96 RFO	Bobbin	ODI	15	0.50	006	+26.92
132	40	04/96 RFO	Bobbin	NQI		0.26	006	+30.87
132	42	04/96 RFO	Bobbin	ODI	20	0.39	006	+29.87
		04/96 RFO	Bobbin	ODI	31	0.31	007	-0.08
132	51	04/96 RFO	Bobbin	NQI		0.51	006	+32.01
132	58	04/96 RFO	Bobbin	NQI		0.88	007	-0.94
132	75	04/96 RFO	Bobbin	ADI		2.23	LTS	+25.22
132	76	04/96 RFO	Bobbin	NQI		0.53	015	+38.81
		04/96 RFO	Bobbin	ODI	12	0.45	015	+28.21
		04/96 RFO	Bobbin	ODI	72	0.32	015	+3.25
132	77	04/96 RFO	Bobbin	NQI		0.28	014	+26.79
		04/96 RFO	Bobbin	NQI		0.37	014	+27.86
		04/96 RFO	Bobbin	NQI		1.05	014	+28.33
		04/96 RFO	Bobbin	ODI	63	0.32	014	+29.61
132	82	04/96 RFO	Bobbin	NQI		0.31	015	+0.05
		04/96 RFO	Bobbin	ODI	3	0.41	008	+9.94
		04/96 RFO	Bobbin	ODI	7	0.46	008	+10.26
132	83	04/96 RFO	Bobbin	NQI		0.50	015	+33.34
		04/96 RFO	Bobbin	NQI		0.57	015	+32.86
		04/96 RFO	Bobbin	ODI	16	0.70	008	+27.66
		04/96 RFO	Bobbin	ODI	29	0.46	008	+18.03

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
133	1	04/96 RFO	Bobbin	ODI	13	0.61	010	+5.68
133	5	04/96 RFO	Bobbin	ODI	13	6.74	006	+16.34
133	6	04/96 RFO	Bobbin	ODI	20	0.70	009	+20.22
133	8	04/96 RFO	Bobbin	WAR	34	1.13	009	-0.64
133	12	04/96 RFO	Bobbin	NQI		0.63	008	+0.49
133	21	04/96 RFO	Bobbin	ODI	5	0.49	006	+30.16
133	26	04/96 RFO	Bobbin	ADI		1.61	006	+29.06
		04/96 RFO	Bobbin	NQI		0.20	007	-0.23
133	36	04/96 RFO	Bobbin	NQI		0.36	006	+31.70
		04/96 RFO	Bobbin	ODI	9	0.50	006	+25.70
		04/96 RFO	Bobbin	ODI	11	0.47	006	+27.03
133	37	04/96 RFO	Bobbin	ODI	23	0.47	006	+26.18
133	50	04/96 RFO	Bobbin	NQI		0.22	007	-0.24
133	52	04/96 RFO	Bobbin	NQI		0.59	006	+32.13
133	55	04/96 RFO	Bobbin	NQI		0.29	006	+25.78
133	59	04/96 RFO	Bobbin	NQI		0.29	006	+34.53
133	60	04/96 RFO	Bobbin	ODI	18	0.57	006	+34.96
		04/96 RFO	Bobbin	ODI	24	0.27	006	+36.91
133	61	04/96 RFO	Bobbin	ODI	18	0.51	006	+34.45
133	62	04/96 RFO	Bobbin	ODI	18	0.63	006	+33.17
133	63	04/96 RFO	Bobbin	NQI		0.34	006	+34.84
133	71	04/96 RFO	Bobbin	ADI		2.43	004	+27.59
		04/96 RFO	Bobbin	ODI	26	1.37	LTS	+16.54
134	3	04/96 RFO	Bobbin	NQI		0.80	010	+0.65
		04/96 RFO	Bobbin	ODI	15	0.41	008	+0.39
134	4	04/96 RFO	Bobbin	ODI	13	0.82	009	+25.38
		04/96 RFO	Bobbin	ODI	20	0.63	009	+24.64
134	5	04/96 RFO	Bobbin	ODI	2	1.16	009	+20.67
134	6	04/96 RFO	Bobbin	NQI		0.74	009	+17.45 to +27.35
134	8	04/96 RFO	Bobbin	ODI	7	0.69	009	+0.60
134	9	04/96 RFO	Bobbin	NQI		0.51	008	+0.28
134	10	04/96 RFO	Bobbin	ODI	35	0.54	009	+0.67
134	13	04/96 RFO	Bobbin	ODI	31	0.32	008	+0.49
134	27	04/96 RFO	Bobbin	NQI		0.35	006	+27.63
		04/96 RFO	Bobbin	ODI	25	0.54	006	+28.00
134	33	04/96 RFO	Bobbin	ODI	4	0.67	006	+26.54
		04/96 RFO	Bobbin	ODI	25	0.59	006	+24.94
134	36	04/96 RFO	Bobbin	ODI	11	0.75	006	+27.06
134	46	04/96 RFO	Bobbin	NQI		2.23	LTS	+26.03
134	50	04/96 RFO	Bobbin	NQI		0.63	006	+34.09
134	54	04/96 RFO	Bobbin	NQI		0.92	006	+33.94
134	57	04/96 RFO	Bobbin	ODI	7	0.49	006	+33.36
134	67	04/96 RFO	Bobbin	ODI	7	0.50	006	+32.92
134	79	04/96 RFO	Bobbin	ODI	27	0.76	015	+0.32
134	85	04/96 RFO	Bobbin	ODI	5	0.56	009	+18.07
135	2	04/96 RFO	Bobbin	NQI		0.72	010	+0.39
135	4	04/96 RFO	Bobbin	NQI		0.85	009	+21.66 to +30.25
135	10	04/96 RFO	Bobbin	NQI		1.11	009	-0.78
135	51	04/96 RFO	Bobbin	NQI		0.44	007	-0.19
135	52	04/96 RFO	Bobbin	ODI	18	0.76	006	+33.24
135	54	04/96 RFO	Bobbin	NQI		0.41	006	+34.90
135	70	04/96 RFO	Bobbin	NQI		0.39	006	+30.39
135	78	04/96 RFO	Bobbin	ODI	22	0.83	UTS	-0.52
135	79	04/96 RFO	Bobbin	DWI		1.20	LTE	+16.34
		04/96 RFO	Bobbin	ODI	29	0.90	008	+0.70
135	80	04/96 RFO	Bobbin	ODI	24	0.55	015	+0.17
135	81	04/96 RFO	Bobbin	ODI	10	0.57	012	+18.98
		04/96 RFO	Bobbin	ODI	51	0.82	012	+19.86
		04/96 RFO	Bobbin	ODI	54	0.39	012	+18.48
		04/96 RFO	Bobbin	ODI	80	0.43	012	+17.97
		04/96 RFO	Bobbin	WAR	68	1.67	010	+0.00
136	3	04/96 RFO	Bobbin	NQI		0.92	010	+14.40
		04/96 RFO	Bobbin	ODI	25	0.66	010	+0.58
136	5	04/96 RFO	Bobbin	NQI		0.45	009	+21.42
136	6	04/96 RFO	Bobbin	NQI		0.41	009	+21.03

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	ODI	37	0.64	009	+15.88
136	7	04/96 RFO	Bobbin	NQI		0.41	009	+12.74 to +19.46
136	11	04/96 RFO	Bobbin	NQI		0.97	008	+0.60
136	31	04/96 RFO	Bobbin	NQI		0.31	006	+26.84
136	47	04/96 RFO	Bobbin	NQI		0.56	006	+30.72
		04/96 RFO	Bobbin	ODI	5	0.58	012	+0.22
136	71	04/96 RFO	Bobbin	DWI		0.37	014	+18.44
136	77	04/96 RFO	Bobbin	NQI		0.82	008	+0.67
136	78	04/96 RFO	Bobbin	NQI		0.59	007	+33.72
137	1	04/96 RFO	Bobbin	NQI		0.41	014	-0.05
137	4	04/96 RFO	Bobbin	ODI	10	0.58	010	+0.63
		04/96 RFO	Bobbin	NQI		0.55	009	+21.91 to +23.94
137	5	04/96 RFO	Bobbin	NQI		0.76	009	+15.75 to +23.43
137	6	04/96 RFO	Bobbin	ODI	16	0.47	009	+14.89
137	9	04/96 RFO	Bobbin	NQI		0.65	009	+0.65
137	28	04/96 RFO	Bobbin	NQI		0.52	006	+24.31
137	40	04/96 RFO	Bobbin	NQI		1.06	012	+19.26
		04/96 RFO	Bobbin	ODI	4	0.27	008	+15.39
		04/96 RFO	Bobbin	ODI	4	0.89	005	+15.85
137	43	04/96 RFO	Bobbin	NQI		0.49	006	+30.34
137	44	04/96 RFO	Bobbin	ADI		1.59	006	+30.31
137	49	04/96 RFO	Bobbin	ODI	35	0.71	006	+28.82
137	63	04/96 RFO	Bobbin	ODI	15	4.94	LTS	+4.38
137	68	04/96 RFO	Bobbin	ODI	20	0.64	007	+13.54
137	74	04/96 RFO	Bobbin	NQI		0.42	007	+32.21
137	77	04/96 RFO	Bobbin	NQI		0.40	009	+0.10
137	78	04/96 RFO	Bobbin	NQI		0.21	010	+0.44
138	3	04/96 RFO	Bobbin	ODI	6	0.53	009	+22.84
138	4	04/96 RFO	Bobbin	NQI		0.63	009	+21.69
138	10	04/96 RFO	Bobbin	ODI	18	0.41	006	+30.03
138	51	04/96 RFO	Bobbin	NQI		0.58	006	+30.35
138	65	04/96 RFO	Bobbin	ODI	18	1.78	001	+2.01
138	74	04/96 RFO	Bobbin	ODI	13	0.65	014	+23.92
139	1	04/96 RFO	Bobbin	ADI		2.11	014	+12.74
139	4	04/96 RFO	Bobbin	NQI		0.73	009	+18.53 to +25.07
139	23	04/96 RFO	Bobbin	ODI	25	0.62	006	+26.41
139	43	04/96 RFO	Bobbin	ODI	37	0.31	006	+26.70
139	44	04/96 RFO	Bobbin	NQI		0.36	006	+28.01
		04/96 RFO	Bobbin	ODI	34	0.31	007	+0.05
139	70	04/96 RFO	Bobbin	NQI		0.27	007	+29.75
		04/96 RFO	Bobbin	NQI		0.60	013	+29.84
		04/96 RFO	Bobbin	ODI	34	0.33	013	+30.20
		04/96 RFO	Bobbin	ODI	53	0.72	011	+33.19
139	71	04/96 RFO	Bobbin	ODI	10	0.71	007	+36.11
140	2	04/96 RFO	Bobbin	NQI		1.00	013	-0.78
		04/96 RFO	Bobbin	ODI	9	3.68	013	+16.63
		04/96 RFO	Bobbin	ODI	13	2.04	012	+11.30
		04/96 RFO	Bobbin	ADI		0.71	009	+13.10 to +27.25
140	4	04/96 RFO	Bobbin	ODI	2	0.44	009	+8.77
140	5	04/96 RFO	Bobbin	ODI	36	0.51	009	+5.73
140	6	04/96 RFO	Bobbin	ODI	48	0.47	009	+7.19
140	10	04/96 RFO	Bobbin	ODI	18	0.54	007	+15.47
140	12	04/96 RFO	Bobbin	NQI		0.42	006	+29.36
140	20	04/96 RFO	Bobbin	NQI		0.26	006	+30.06
140	37	04/96 RFO	Bobbin	ODI	13	0.57	006	+30.35
140	47	04/96 RFO	Bobbin	ODI	10	0.27	007	+28.67
140	65	04/96 RFO	Bobbin	ODI	16	0.38	007	+14.54
		04/96 RFO	Bobbin	ODI	32	0.59	007	+32.66
140	66	04/96 RFO	Bobbin	ODI	7	0.55	008	+24.23
140	70	04/96 RFO	Bobbin	ODI	10	0.96	009	+0.47
141	6	04/96 RFO	Bobbin	ODI	12	0.39	009	+0.39
141	10	04/96 RFO	Bobbin	NQI		0.23	006	-0.26
141	17	04/96 RFO	Bobbin	ADI		0.90	006	+24.53
141	26	04/96 RFO	Bobbin	ODI	31	0.34	006	+27.25
141	40	04/96 RFO	Bobbin	DWI		6.49	010	+25.93
141	41	04/96 RFO	Bobbin					

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
Oconee Nuclear Station - Unit Two
S/G B
04/96 RFO
Bobbin

Page 52 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	ODI	31	0.26	015	+20.46
141	50	04/96 RFO	Bobbin	NQI		0.46	015	+1.40
141	54	04/96 RFO	Bobbin	ODI	36	0.30	006	+29.07
141	62	04/96 RFO	Bobbin	NQI		0.36	007	+11.42
		04/96 RFO	Bobbin	ODI	8	0.35	007	+15.49
141	64	04/96 RFO	Bobbin	NQI		0.42	007	+29.99
142	12	04/96 RFO	Bobbin	ODI	14	0.63	007	+12.99 to +17.56
142	30	04/96 RFO	Bobbin	ODI	18	0.69	UTS	+0.53
142	35	04/96 RFO	Bobbin	ODI	29	0.28	006	+33.98
142	38	04/96 RFO	Bobbin	NQI		0.54	LTE	+21.92
142	52	04/96 RFO	Bobbin	NQI		1.46	LTE	+20.49
142	53	04/96 RFO	Bobbin	NQI		0.96	LTE	+20.49
142	55	04/96 RFO	Bobbin	ODI	6	0.24	007	+33.33
142	56	04/96 RFO	Bobbin	ADI		1.76	012	+22.22
		04/96 RFO	Bobbin	ODI	2	0.23	008	-1.17
142	59	04/96 RFO	Bobbin	ADI		0.97	007	+31.71
142	60	04/96 RFO	Bobbin	ODI	10	0.49	007	+33.14
142	62	04/96 RFO	Bobbin	NQI		0.21	009	-0.32
		04/96 RFO	Bobbin	NQI		0.64	015	-0.41
		04/96 RFO	Bobbin	ODI	16	0.57	008	+8.76
142	64	04/96 RFO	Bobbin	NQI		0.26	008	+0.49
		04/96 RFO	Bobbin	NQI		0.63	015	+0.00
143	3	04/96 RFO	Bobbin	NQI		0.46	015	-0.18
143	11	04/96 RFO	Bobbin	NQI		0.54	007	+20.18 to +25.56
143	34	04/96 RFO	Bobbin	NQI		0.36	006	+31.70
143	35	04/96 RFO	Bobbin	ODI	16	0.58	006	+28.88
143	44	04/96 RFO	Bobbin	ODI	18	0.47	007	+17.44
143	55	04/96 RFO	Bobbin	NQI		0.48	008	+6.99
143	58	04/96 RFO	Bobbin	NQI		0.29	008	+6.40
		04/96 RFO	Bobbin	ODI	3	0.52	008	+12.82
		04/96 RFO	Bobbin	ODI	9	0.35	008	+5.65
143	61	04/96 RFO	Bobbin	NQI		0.54	015	+0.33
143	62	04/96 RFO	Bobbin	ODI	42	0.70	009	+0.59
144	3	04/96 RFO	Bobbin	NQI		0.70	009	+11.37
		04/96 RFO	Bobbin	ODI	20	0.19	012	-0.15
144	7	04/96 RFO	Bobbin	NQI		0.42	015	+0.02
144	9	04/96 RFO	Bobbin	ODI	14	1.26	007	+21.19
		04/96 RFO	Bobbin	ODI	16	0.50	007	+22.06
144	11	04/96 RFO	Bobbin	ODI	9	0.47	007	+12.00
144	16	04/96 RFO	Bobbin	ODI	12	0.66	014	+27.30
144	17	04/96 RFO	Bobbin	ODI	20	0.46	006	+28.54
144	20	04/96 RFO	Bobbin	ODI	22	0.44	006	+24.16
144	34	04/96 RFO	Bobbin	NQI		0.23	007	+21.24
		04/96 RFO	Bobbin	NQI		0.31	008	+0.70
		04/96 RFO	Bobbin	ODI	12	0.29	007	+20.94
144	41	04/96 RFO	Bobbin	ODI	44	0.55	008	+3.38
		04/96 RFO	Bobbin	ODI	44	0.65	008	+5.50
144	45	04/96 RFO	Bobbin	NQI		0.39	008	+16.99
		04/96 RFO	Bobbin	NQI		0.55	008	+22.07
144	49	04/96 RFO	Bobbin	ODI	7	0.56	008	+20.64
144	51	04/96 RFO	Bobbin	NQI		0.55	008	+0.68
		04/96 RFO	Bobbin	ODI	28	0.76	008	+32.79
144	53	04/96 RFO	Bobbin	ODI	13	0.80	008	+0.51
144	57	04/96 RFO	Bobbin	NQI		0.77	015	+0.52
145	5	04/96 RFO	Bobbin	ODI	25	0.53	009	-0.39
145	7	04/96 RFO	Bobbin	ODI	11	0.68	007	+30.32
		04/96 RFO	Bobbin	ODI	25	0.43	007	+30.06
		04/96 RFO	Bobbin	ODI	30	0.37	007	+33.77
145	12	04/96 RFO	Bobbin	ODI	29	0.54	007	+15.45
145	19	04/96 RFO	Bobbin	ODI	38	0.74	009	+34.41
145	27	04/96 RFO	Bobbin	ODI	5	0.37	LTS	+3.01
145	28	04/96 RFO	Bobbin	ODI	4	0.58	007	+0.53
145	33	04/96 RFO	Bobbin	NQI		0.61	008	-0.91
145	35	04/96 RFO	Bobbin	NQI		0.37	008	+3.09
145	38	04/96 RFO	Bobbin	NQI		0.53	008	+16.56

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
 Oconee Nuclear Station - Unit Two
 S/G B
 04/96 RFO
 Bobbin

Page 53 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	Bobbin	ODI	9	0.76	008	+17.44
145	39	04/96 RFO	Bobbin	NQI		0.70	008	+23.93
		04/96 RFO	Bobbin	ODI	34	0.50	008	+27.78
145	41	04/96 RFO	Bobbin	ODI	9	0.55	008	+33.18
145	44	04/96 RFO	Bobbin	NQI		0.41	008	+34.46
145	48	04/96 RFO	Bobbin	NQI		0.18	009	+0.00
145	54	04/96 RFO	Bobbin	NQI		0.35	009	+0.10
		04/96 RFO	Bobbin	NQI		0.61	LTS	-0.28
146	2	04/96 RFO	Bobbin	NQI		0.75	014	-0.76
146	7	04/96 RFO	Bobbin	ODI	16	0.53	007	+20.34
146	10	04/96 RFO	Bobbin	NQI		0.65	007	+24.73
146	16	04/96 RFO	Bobbin	NQI		0.50	007	+9.70
146	17	04/96 RFO	Bobbin	ODI	3	1.73	LTS	+37.95
146	18	04/96 RFO	Bobbin	ODI	18	0.30	007	-0.16
		04/96 RFO	Bobbin	ODI	18	0.57	006	+30.72
		04/96 RFO	Bobbin	ODI	30	0.58	006	+30.15
146	27	04/96 RFO	Bobbin	NQI		0.27	007	+29.50
146	29	04/96 RFO	Bobbin	NQI		0.28	008	-0.35
146	30	04/96 RFO	Bobbin	NQI		0.99	008	+1.19
146	35	04/96 RFO	Bobbin	NQI		0.52	008	+31.93
146	36	04/96 RFO	Bobbin	NQI		0.71	008	+27.91
		04/96 RFO	Bobbin	ODI	22	0.48	008	+28.62
146	37	04/96 RFO	Bobbin	ADI		1.69	008	+34.75
		04/96 RFO	Bobbin	NQI		0.63	009	+1.03
146	44	04/96 RFO	Bobbin	ODI	9	0.85	009	+9.22
146	45	04/96 RFO	Bobbin	NQI		0.33	009	-0.03
		04/96 RFO	Bobbin	NQI		0.45	009	+11.56
147	3	04/96 RFO	Bobbin	NQI		0.44	008	+35.67
		04/96 RFO	Bobbin	NQI		3.38	014	+27.73
147	5	04/96 RFO	Bobbin	ODI	20	0.41	008	+9.09
147	13	04/96 RFO	Bobbin	ODI	33	0.36	007	+23.69
147	16	04/96 RFO	Bobbin	ODI	7	0.62	007	+20.21
		04/96 RFO	Bobbin	ODI	11	0.83	007	+22.39
147	25	04/96 RFO	Bobbin	ODI	22	0.42	008	+3.53
147	26	04/96 RFO	Bobbin	ODI	29	0.16	008	-0.29
147	29	04/96 RFO	Bobbin	NQI		0.33	008	-0.39
		04/96 RFO	Bobbin	NQI		0.35	008	+21.53
		04/96 RFO	Bobbin	NQI		0.43	008	+18.25
147	31	04/96 RFO	Bobbin	NQI		0.51	008	+22.82
147	34	04/96 RFO	Bobbin	NQI		0.25	009	-0.20
147	38	04/96 RFO	Bobbin	ODI	23	0.40	009	+8.82
147	39	04/96 RFO	Bobbin	ODI	5	0.60	009	+12.58
		04/96 RFO	Bobbin	ODI	35	0.54	009	+10.29
147	41	04/96 RFO	Bobbin	NQI		0.49	009	+15.38
148	29	04/96 RFO	Bobbin	NQI		0.96	009	-0.77
148	37	04/96 RFO	Bobbin	NQI		0.43	009	+17.57
148	40	04/96 RFO	Bobbin	NQI		0.68	010	+2.44
148	41	04/96 RFO	Bobbin	NQI		0.66	011	+0.13
149	3	04/96 RFO	Bobbin	NQI		0.47	001	+22.86
149	5	04/96 RFO	Bobbin	NQI		0.87	014	-0.77
149	8	04/96 RFO	Bobbin	ODI	23	0.32	009	+5.81
149	9	04/96 RFO	Bobbin	NQI		0.39	008	+33.59
149	13	04/96 RFO	Bobbin	ODI	10	0.48	008	+0.64
149	22	04/96 RFO	Bobbin	NQI		0.32	007	+0.83
149	24	04/96 RFO	Bobbin	NQI		0.48	008	+34.26
		04/96 RFO	Bobbin	NQI		0.49	009	+6.39
149	26	04/96 RFO	Bobbin	ODI	22	0.35	009	+13.41
149	32	04/96 RFO	Bobbin	NQI		0.51	010	+4.99
149	33	04/96 RFO	Bobbin	ODI	23	0.48	010	+6.38
150	11	04/96 RFO	Bobbin	ODI	3	0.36	008	+33.87
150	12	04/96 RFO	Bobbin	ODI	9	0.33	008	+32.58
150	13	04/96 RFO	Bobbin	NQI		0.25	004	+33.77
		04/96 RFO	Bobbin	NQI		0.34	009	+7.83
		04/96 RFO	Bobbin	NQI		0.45	009	+10.06
		04/96 RFO	Bobbin	NQI		2.26	004	+29.32

FTI TUBAN II (Version 2.3) 05/14/1996 09:12:10
Oconee Nuclear Station - Unit Two
S/G B
04/96 RFO
Bobbin

Page 54 of 54

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN
OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND %TW	VOLTS	LOCATION	EXTENT1
150	14	04/96 RFO	Bobbin	NQI	0.48	009 +8.01	LTE
150	23	04/96 RFO	Bobbin	NQI	0.26	010 +6.00	LTE
150	26	04/96 RFO	Bobbin	NQI	0.64	015 +0.36	LTE
150	27	04/96 RFO	Bobbin	ODI	23	0.36 010 +4.93	LTE
		04/96 RFO	Bobbin	ODI	39	0.31 010 +4.68	LTE
151	1	04/96 RFO	Bobbin	ODI	5	0.65 008 +32.30	LTE
		04/96 RFO	Bobbin	ODI	37	0.48 009 +10.95	LTE
151	7	04/96 RFO	Bobbin	NQI	0.86	010 +0.69	LTE
151	8	04/96 RFO	Bobbin	ADI	3.09	010 +17.13	LTE
151	9	04/96 RFO	Bobbin	ADI	2.24	015 +7.12	LTE
151	10	04/96 RFO	Bobbin	ADI	3.07	015 +7.21	LTE
151	13	04/96 RFO	Bobbin	ODI	28	0.28 006 +33.73	LTE
151	16	04/96 RFO	Bobbin	NQI	0.60	009 -0.69	LTE

Total Indications Found = 3458
Total Tubes Found = 2563

ATTACHMENT 3

13 Pages

FTI TUBAN II (Version 2.3) 05/14/1996 09:32:23

Oconee Nuclear Station - Unit Two

S/G A

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 1 of 13

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
1	15	04/96 RFO	SPECIAL INTEREST	WAR	9	0.43	011	+0.00
2	1	04/96 RFO	SPECIAL INTEREST	VOL		0.17	011	-0.35
		04/96 RFO	SPECIAL INTEREST	VOL		0.43	011	+0.33
2	11	04/96 RFO	SPECIAL INTEREST	SAI		0.11	012	+10.65
		04/96 RFO	SPECIAL INTEREST	VOL		0.56	010	+0.64
		04/96 RFO	SPECIAL INTEREST	MAI		0.15	014	+9.56 to +21.44
		04/96 RFO	SPECIAL INTEREST	SAI		0.24	013	+12.65 to +25.17
3	2	04/96 RFO	SPECIAL INTEREST	VOL		0.18	011	-0.09
		04/96 RFO	SPECIAL INTEREST	VOL		0.18	014	-0.79
3	23	04/96 RFO	SPECIAL INTEREST	WAR	12	0.34	010	+0.82
4	5	04/96 RFO	SPECIAL INTEREST	VOL		0.38	010	+0.67
4	8	04/96 RFO	SPECIAL INTEREST	VOL		0.65	010	+0.70
4	10	04/96 RFO	SPECIAL INTEREST	VOL		0.40	009	+0.77
4	19	04/96 RFO	SPECIAL INTEREST	SAI		0.04	015	-1.86
4	27	04/96 RFO	SPECIAL INTEREST	SAI		0.27	012	+14.78
4	31	04/96 RFO	SPECIAL INTEREST	WAR	16	0.73	008	+0.69
4	35	04/96 RFO	SPECIAL INTEREST	VOL		1.23	009	-7.35
6	3	04/96 RFO	SPECIAL INTEREST	SAI		0.35	015	+11.03
		04/96 RFO	SPECIAL INTEREST	WAR	6	0.56	011	+0.00
		04/96 RFO	SPECIAL INTEREST	WAR	10	0.54	010	+0.00
		04/96 RFO	SPECIAL INTEREST	SAI		0.07	014	+9.21 to +9.53
		04/96 RFO	SPECIAL INTEREST	SAI		0.10	014	-20.67 to -15.75
		04/96 RFO	SPECIAL INTEREST	SAI		0.12	014	+16.97 to +17.37
		04/96 RFO	SPECIAL INTEREST	SAI		0.12	014	-24.70 to -23.43
		04/96 RFO	SPECIAL INTEREST	SAI		0.16	011	+23.00 to +28.80
		04/96 RFO	SPECIAL INTEREST	SAI		0.39	011	+14.90 to +15.27
6	4	04/96 RFO	SPECIAL INTEREST	WAR	9	0.51	010	+0.00
6	5	04/96 RFO	SPECIAL INTEREST	VOL		0.50	009	-3.68
		04/96 RFO	SPECIAL INTEREST	WAR	9	0.51	010	+0.00
		04/96 RFO	SPECIAL INTEREST	VOL		0.78	009	-6.08 to -4.08
6	11	04/96 RFO	SPECIAL INTEREST	WAR	12	0.68	009	+0.00
6	32	04/96 RFO	SPECIAL INTEREST	SAI		0.45	011	+4.65
7	1	04/96 RFO	SPECIAL INTEREST	VOL		0.61	012	-0.78
9	1	04/96 RFO	SPECIAL INTEREST	WAR	8	0.40	008	+0.00
		04/96 RFO	SPECIAL INTEREST	WAR	13	0.65	010	+0.00
9	5	04/96 RFO	SPECIAL INTEREST	SAI		0.59	015	-0.22
		04/96 RFO	SPECIAL INTEREST	SAI		0.82	011	+30.18
		04/96 RFO	SPECIAL INTEREST	MAI		0.15	012	+12.95 to +15.54
		04/96 RFO	SPECIAL INTEREST	MAI		0.28	013	+19.01 to +23.10
		04/96 RFO	SPECIAL INTEREST	MAI		0.32	014	+9.03 to +15.01
		04/96 RFO	SPECIAL INTEREST	MAI		0.38	015	+0.43 to +21.50
		04/96 RFO	SPECIAL INTEREST	MAI		0.42	011	+33.44 to +33.70
		04/96 RFO	SPECIAL INTEREST	MAI		0.69	012	+17.25 to +25.74
9	53	04/96 RFO	SPECIAL INTEREST	VOL		1.11	007	-7.08 to -3.87
9	54	04/96 RFO	SPECIAL INTEREST	SAI		0.26	UTS	-21.88
10	3	04/96 RFO	SPECIAL INTEREST	ODI	16	0.69	009	+0.00
13	11	04/96 RFO	SPECIAL INTEREST	SAI		0.25	014	+8.12
		04/96 RFO	SPECIAL INTEREST	SAI		0.26	015	+38.08
		04/96 RFO	SPECIAL INTEREST	SAI		0.28	015	+35.61
		04/96 RFO	SPECIAL INTEREST	SAI		0.29	013	+8.01
		04/96 RFO	SPECIAL INTEREST	SAI		0.29	013	+22.77
		04/96 RFO	SPECIAL INTEREST	SAI		0.31	013	+6.96
		04/96 RFO	SPECIAL INTEREST	SAI		0.42	015	+9.83
		04/96 RFO	SPECIAL INTEREST	MAI		0.74	015	+18.13 to +26.64
13	13	04/96 RFO	SPECIAL INTEREST	SAI		0.37	012	+1.63
		04/96 RFO	SPECIAL INTEREST	SAI		0.53	012	+8.86
		04/96 RFO	SPECIAL INTEREST	SAI		0.68	011	+35.16
		04/96 RFO	SPECIAL INTEREST	MAI		0.85	012	+12.11 to +16.48
		04/96 RFO	SPECIAL INTEREST	SAI		0.27	010	+14.01 to +17.68
		04/96 RFO	SPECIAL INTEREST	SAI		0.27	011	+1.00 to +4.02
		04/96 RFO	SPECIAL INTEREST	SAI		0.62	011	+21.68 to +28.93
13	39	04/96 RFO	SPECIAL INTEREST	VOL		1.45	001	-15.88
13	52	04/96 RFO	SPECIAL INTEREST	VOL		0.19	002	+3.78
		04/96 RFO	SPECIAL INTEREST	VOL		0.48	002	+6.08
13	56	04/96 RFO	SPECIAL INTEREST	VOL		0.71	010	-2.94

FTI TUBAN II (Version 2.3) 05/14/1996 09:32:23

Oconee Nuclear Station - Unit Two

S/G A

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 2 of 13

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
14	70	04/96 RFO	SPECIAL INTEREST	VOL		1.28 009	+21.94	009
		04/96 RFO	SPECIAL INTEREST	WAR	15	0.88 009	+0.00	009
14	71	04/96 RFO	SPECIAL INTEREST	WAR	15	0.51 009	+0.00	009
16	23	04/96 RFO	SPECIAL INTEREST	SAI		0.16 015	+24.23	015
16	45	04/96 RFO	SPECIAL INTEREST	VOL		0.92 014	+23.78	014
16	70	04/96 RFO	SPECIAL INTEREST	VOL		0.91 014	+13.46	014
16	71	04/96 RFO	SPECIAL INTEREST	VOL		0.51 011	-5.16	011
		04/96 RFO	SPECIAL INTEREST	VOL		1.66 008	+14.66	008
17	72	04/96 RFO	SPECIAL INTEREST	VOL		1.44 005	-0.81 to +7.02	005
		04/96 RFO	SPECIAL INTEREST	VOL		2.06 005	-8.61 to -0.82	005
19	19	04/96 RFO	SPECIAL INTEREST	NQI		0.65 013	+15.80	013
19	85	04/96 RFO	SPECIAL INTEREST	VOL		0.28 010	+0.61	010
20	70	04/96 RFO	SPECIAL INTEREST	VOL		0.33 003	+0.11	003
21	28	04/96 RFO	SPECIAL INTEREST	SAI		0.07 UTS	-17.63	UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.39 014	+23.06	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.48 014	+3.81	014
22	6	04/96 RFO	SPECIAL INTEREST	WAR	9	0.45 006	+0.00	006
		04/96 RFO	SPECIAL INTEREST	WAR	11	0.52 009	+0.00	009
22	7	04/96 RFO	SPECIAL INTEREST	WAR	21	1.02 009	+0.00	009
23	31	04/96 RFO	SPECIAL INTEREST	SAI		0.87 UTS	-1.39	UTS
		04/96 RFO	SPECIAL INTEREST	MAI		0.13 014	+5.50 to +6.50	014
23	37	04/96 RFO	SPECIAL INTEREST	VOL		0.20 007	-0.28	007
23	62	04/96 RFO	SPECIAL INTEREST	VOL		0.04 002	+14.65	002
		04/96 RFO	SPECIAL INTEREST	VOL		0.39 004	-1.81	004
24	25	04/96 RFO	SPECIAL INTEREST	SAI		0.39 014	+10.65	014
24	55	04/96 RFO	SPECIAL INTEREST	VOL		0.06 012	+20.86	012
25	64	04/96 RFO	SPECIAL INTEREST	VOL		0.05 002	+26.89	002
		04/96 RFO	SPECIAL INTEREST	VOL		0.08 002	+12.86	002
		04/96 RFO	SPECIAL INTEREST	VOL		0.09 002	+9.94	002
		04/96 RFO	SPECIAL INTEREST	VOL		0.10 002	+10.95	002
		04/96 RFO	SPECIAL INTEREST	VOL		0.10 002	+37.53	002
		04/96 RFO	SPECIAL INTEREST	VOL		0.22 002	+6.90	002
		04/96 RFO	SPECIAL INTEREST	VOL		0.23 002	+20.08	002
26	69	04/96 RFO	SPECIAL INTEREST	VOL		0.28 007	-11.04	007
27	61	04/96 RFO	SPECIAL INTEREST	VOL		0.16 007	-10.89	007
		04/96 RFO	SPECIAL INTEREST	VOL		0.25 007	+0.38	007
27	62	04/96 RFO	SPECIAL INTEREST	SAI		0.49 014	+18.12	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.57 014	+15.59	014
27	64	04/96 RFO	SPECIAL INTEREST	SAI		0.06 014	+27.74	014
27	65	04/96 RFO	SPECIAL INTEREST	VOL		0.55 003	-17.83	003
31	2	04/96 RFO	SPECIAL INTEREST	WAR	13	0.57 010	+0.00	010
31	36	04/96 RFO	SPECIAL INTEREST	VOL		0.28 007	-15.18	007
31	67	04/96 RFO	SPECIAL INTEREST	SAI		0.66 013	-0.79	013
34	2	04/96 RFO	SPECIAL INTEREST	WAR	10	0.44 010	+0.00	010
35	108	04/96 RFO	SPECIAL INTEREST	VOL		0.92 011	-0.63	011
36	110	04/96 RFO	SPECIAL INTEREST	VOL		0.27 009	-0.13	009
37	42	04/96 RFO	SPECIAL INTEREST	SAI		0.67 013	-18.20	013
		04/96 RFO	SPECIAL INTEREST	SAI		0.72 013	-17.32	013
37	95	04/96 RFO	SPECIAL INTEREST	VOL		0.48 007	-5.10	007
38	1	04/96 RFO	SPECIAL INTEREST	WAR	13	0.57 010	+0.00	010
38	79	04/96 RFO	SPECIAL INTEREST	NQI		0.54 006	-0.51	006
38	89	04/96 RFO	SPECIAL INTEREST	WAR	6	0.26 009	+0.00	009
42	71	04/96 RFO	SPECIAL INTEREST	VOL		0.28 001	+32.82	002
42	91	04/96 RFO	SPECIAL INTEREST	NQI		0.74 UTS	-13.04	UTS
42	112	04/96 RFO	SPECIAL INTEREST	NQI		0.37 014	-0.70	014
42	114	04/96 RFO	SPECIAL INTEREST	WAR	21	0.99 014	+0.00	014
42	115	04/96 RFO	SPECIAL INTEREST	WAR	12	0.51 014	+0.00	014
43	5	04/96 RFO	SPECIAL INTEREST	WAR	13	0.58 012	+0.00	012
		04/96 RFO	SPECIAL INTEREST	WAR	20	0.97 014	+0.00	014
43	15	04/96 RFO	SPECIAL INTEREST	SAI		0.56 UTS	-4.35	UTS
43	93	04/96 RFO	SPECIAL INTEREST	SAI		0.16 015	+11.42	015
43	115	04/96 RFO	SPECIAL INTEREST	WAR	10	0.42 014	+0.00	014
44	2	04/96 RFO	SPECIAL INTEREST	MAI		1.35 013	+3.08 to +13.66	013
44	105	04/96 RFO	SPECIAL INTEREST	WAR	11	0.51 007	-0.42	007
44	115	04/96 RFO	SPECIAL INTEREST	WAR	12	0.53 014	+0.00	014

FTI TUBAN II (Version 2.3) 05/14/1996 09:32:23

Oconee Nuclear Station - Unit Two

S/G A

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 3 of 13

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
44	119	04/96 RFO	SPECIAL INTEREST	WAR	16	0.75	011	011
45	34	04/96 RFO	SPECIAL INTEREST	MAI		0.48	015	015
		04/96 RFO	SPECIAL INTEREST	MAI		0.08	014	014
		04/96 RFO	SPECIAL INTEREST	MAI		0.13	015	015
		04/96 RFO	SPECIAL INTEREST	MAI		0.24	011	011
		04/96 RFO	SPECIAL INTEREST	MAI		0.72	013	013
		04/96 RFO	SPECIAL INTEREST	MAI		0.83	012	012
		04/96 RFO	SPECIAL INTEREST	SAI		0.39	014	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.44	010	010
		04/96 RFO	SPECIAL INTEREST	SAI		0.58	014	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.91	014	014
45	39	04/96 RFO	SPECIAL INTEREST	MAI		0.41	015	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.17	015	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.20	010	010
		04/96 RFO	SPECIAL INTEREST	SAI		0.21	010	010
		04/96 RFO	SPECIAL INTEREST	SAI		0.27	010	010
		04/96 RFO	SPECIAL INTEREST	SAI		0.63	009	009
		04/96 RFO	SPECIAL INTEREST	SAI		0.79	008	008
		04/96 RFO	SPECIAL INTEREST	MAI		0.28	015	015
		04/96 RFO	SPECIAL INTEREST	MAI		0.35	010	010
46	1	04/96 RFO	SPECIAL INTEREST	WAR	6	0.38	014	014
46	3	04/96 RFO	SPECIAL INTEREST	WAR	13	0.74	010	010
		04/96 RFO	SPECIAL INTEREST	WAR	14	0.77	013	013
		04/96 RFO	SPECIAL INTEREST	WAR	16	0.92	014	014
		04/96 RFO	SPECIAL INTEREST	WAR	21	1.28	012	012
46	71	04/96 RFO	SPECIAL INTEREST	VOL		1.05	LTS	001
47	6	04/96 RFO	SPECIAL INTEREST	WAR	15	0.89	014	014
47	58	04/96 RFO	SPECIAL INTEREST	MAI		0.25	011	011
		04/96 RFO	SPECIAL INTEREST	SAI		0.28	014	014
		04/96 RFO	SPECIAL INTEREST	MAI		0.50	015	015
47	79	04/96 RFO	SPECIAL INTEREST	NQI		0.51	008	008
47	87	04/96 RFO	SPECIAL INTEREST	VOL		0.34	013	013
47	108	04/96 RFO	SPECIAL INTEREST	VOL		0.43	007	007
47	121	04/96 RFO	SPECIAL INTEREST	SAI		0.11	UTS	UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.14	UTS	UTS
48	6	04/96 RFO	SPECIAL INTEREST	WAR	21	1.35	009	009
48	45	04/96 RFO	SPECIAL INTEREST	SAI		0.62	010	010
48	76	04/96 RFO	SPECIAL INTEREST	VOL		0.22	003	003
48	117	04/96 RFO	SPECIAL INTEREST	WAR	19	0.91	014	014
49	2	04/96 RFO	SPECIAL INTEREST	WAR	6	0.50	013	013
49	33	04/96 RFO	SPECIAL INTEREST	MAI		0.08	013	013
49	61	04/96 RFO	SPECIAL INTEREST	VOL		0.51	006	006
49	80	04/96 RFO	SPECIAL INTEREST	VOL		0.15	006	006
49	114	04/96 RFO	SPECIAL INTEREST	WAR	8	0.33	013	013
49	116	04/96 RFO	SPECIAL INTEREST	WAR	21	0.99	011	011
		04/96 RFO	SPECIAL INTEREST	WAR	30	1.60	013	013
49	117	04/96 RFO	SPECIAL INTEREST	WAR	12	0.54	011	011
		04/96 RFO	SPECIAL INTEREST	WAR	21	0.98	011	011
		04/96 RFO	SPECIAL INTEREST	WAR	26	1.33	013	013
49	119	04/96 RFO	SPECIAL INTEREST	WAR	13	0.56	008	008
		04/96 RFO	SPECIAL INTEREST	WAR	22	1.05	011	011
50	2	04/96 RFO	SPECIAL INTEREST	WAR	10	0.45	010	010
		04/96 RFO	SPECIAL INTEREST	WAR	12	0.56	011	011
50	115	04/96 RFO	SPECIAL INTEREST	WAR	12	0.51	015	015
		04/96 RFO	SPECIAL INTEREST	WAR	13	0.56	015	015
		04/96 RFO	SPECIAL INTEREST	WAR	23	1.13	014	014
50	117	04/96 RFO	SPECIAL INTEREST	WAR	14	0.60	014	014
		04/96 RFO	SPECIAL INTEREST	WAR	14	0.61	014	014
50	120	04/96 RFO	SPECIAL INTEREST	WAR	13	0.55	011	011
51	18	04/96 RFO	SPECIAL INTEREST	MAI		0.97	UTS	UTS
51	37	04/96 RFO	SPECIAL INTEREST	SAI		0.53	UTS	UTS
51	41	04/96 RFO	SPECIAL INTEREST	VOL		0.26	015	015
51	49	04/96 RFO	SPECIAL INTEREST	VOL		0.13	006	006
51	76	04/96 RFO	SPECIAL INTEREST	VOL		0.33	006	006
		04/96 RFO	SPECIAL INTEREST	VOL		0.52	005	005

Oconee Nuclear Station - Unit Two

S/G A

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
51	115	04/96 RFO	SPECIAL INTEREST	WAR	10	0.43	013	+0.00 013
51	119	04/96 RFO	SPECIAL INTEREST	WAR	11	0.54	012	+0.00 012
		04/96 RFO	SPECIAL INTEREST	WAR	14	0.70	013	+0.00 013
		04/96 RFO	SPECIAL INTEREST	WAR	17	0.75	013	+0.00 013
		04/96 RFO	SPECIAL INTEREST	WAR	18	0.82	013	+0.00 013
52	1	04/96 RFO	SPECIAL INTEREST	VOL		1.37	003	+2.72 003
52	114	04/96 RFO	SPECIAL INTEREST	WAR	15	0.66	007	+0.00 007
		04/96 RFO	SPECIAL INTEREST	WAR	22	1.07	014	+0.00 014
52	115	04/96 RFO	SPECIAL INTEREST	WAR	14	0.60	014	+0.00 014
52	116	04/96 RFO	SPECIAL INTEREST	WAR	17	0.78	014	+0.00 014
		04/96 RFO	SPECIAL INTEREST	WAR	18	0.83	014	+0.00 014
52	118	04/96 RFO	SPECIAL INTEREST	WAR	19	0.92	014	+0.00 014
52	119	04/96 RFO	SPECIAL INTEREST	WAR	12	0.51	009	+0.00 009
		04/96 RFO	SPECIAL INTEREST	WAR	22	1.06	011	+0.00 011
		04/96 RFO	SPECIAL INTEREST	WAR	41	2.51	013	+0.00 013
52	120	04/96 RFO	SPECIAL INTEREST	WAR	10	0.46	013	+0.00 013
		04/96 RFO	SPECIAL INTEREST	WAR	16	0.77	008	+0.00 008
		04/96 RFO	SPECIAL INTEREST	WAR	17	0.82	009	+0.00 009
		04/96 RFO	SPECIAL INTEREST	WAR	24	1.26	011	+0.00 011
		04/96 RFO	SPECIAL INTEREST	WAR	26	1.41	010	+0.00 010
52	121	04/96 RFO	SPECIAL INTEREST	WAR	14	0.81	009	+0.00 009
53	1	04/96 RFO	SPECIAL INTEREST	VOL		0.77	010	+2.66 010
53	3	04/96 RFO	SPECIAL INTEREST	WAR	17	1.00	010	+0.00 010
53	11	04/96 RFO	SPECIAL INTEREST	SAI		1.13	011	-4.29 011
53	102	04/96 RFO	SPECIAL INTEREST	WAR	5	0.24	008	+0.00 008
53	115	04/96 RFO	SPECIAL INTEREST	WAR	15	0.81	013	+0.00 013
53	116	04/96 RFO	SPECIAL INTEREST	WAR	21	1.16	011	+0.00 011
		04/96 RFO	SPECIAL INTEREST	WAR	24	1.41	013	+0.00 013
53	117	04/96 RFO	SPECIAL INTEREST	WAR	20	1.14	011	+0.00 011
		04/96 RFO	SPECIAL INTEREST	WAR	30	1.95	013	+0.00 013
53	118	04/96 RFO	SPECIAL INTEREST	WAR	25	1.45	011	+0.00 011
		04/96 RFO	SPECIAL INTEREST	WAR	29	1.79	013	+0.00 013
53	121	04/96 RFO	SPECIAL INTEREST	WAR	16	0.93	007	+0.00 007
54	2	04/96 RFO	SPECIAL INTEREST	WAR	11	0.90	010	+0.00 010
		04/96 RFO	SPECIAL INTEREST	WAR	11	0.90	012	+0.00 012
54	3	04/96 RFO	SPECIAL INTEREST	VOL		0.17	009	-8.08 009
55	10	04/96 RFO	SPECIAL INTEREST	SAI		0.42	011	-14.40 011
55	11	04/96 RFO	SPECIAL INTEREST	SAI		0.10	010	-1.75 010
		04/96 RFO	SPECIAL INTEREST	SAI		0.52	010	-3.70 010
		04/96 RFO	SPECIAL INTEREST	SAI		0.71	010	-0.10 010
		04/96 RFO	SPECIAL INTEREST	SAI		1.09	010	-7.61 to -6.81 010
		04/96 RFO	SPECIAL INTEREST	SAI		1.22	010	-25.30 to -22.58 010
55	14	04/96 RFO	SPECIAL INTEREST	SAI		0.41	014	+27.39 014
55	83	04/96 RFO	SPECIAL INTEREST	SAI		0.93	005	-0.90 005
55	89	04/96 RFO	SPECIAL INTEREST	VOL		0.13	006	-0.55 006
55	122	04/96 RFO	SPECIAL INTEREST	SAI		0.36	013	+4.68 013
55	124	04/96 RFO	SPECIAL INTEREST	VOL		0.98	010	-11.89 010
56	1	04/96 RFO	SPECIAL INTEREST	WAR	7	0.60	012	+0.00 012
		04/96 RFO	SPECIAL INTEREST	WAR	11	0.89	011	+0.00 011
56	2	04/96 RFO	SPECIAL INTEREST	VOL		1.64	009	-6.56 to -5.51 009
56	5	04/96 RFO	SPECIAL INTEREST	WAR	17	1.02	010	+0.00 010
56	15	04/96 RFO	SPECIAL INTEREST	SAI		0.65	UTS	-2.38 UTS
56	100	04/96 RFO	SPECIAL INTEREST	WAR	10	0.33	008	+0.00 008
56	104	04/96 RFO	SPECIAL INTEREST	NQI		0.10	008	+0.50 008
56	126	04/96 RFO	SPECIAL INTEREST	SAI		0.14	013	-5.17 013
		04/96 RFO	SPECIAL INTEREST	WAR	18	0.92	013	+0.00 013
		04/96 RFO	SPECIAL INTEREST	SAI		0.14	015	+17.24 to +17.77 015
57	43	04/96 RFO	SPECIAL INTEREST	MAI		0.34	013	-8.99 013
		04/96 RFO	SPECIAL INTEREST	MAI		0.43	013	-11.30 to -6.00 013
		04/96 RFO	SPECIAL INTEREST	MAI		0.47	011	+17.45 to +20.00 011
		04/96 RFO	SPECIAL INTEREST	MAI		0.65	015	+5.37 to +42.24 015
57	54	04/96 RFO	SPECIAL INTEREST	VOL		0.60	005	-0.71 005
57	63	04/96 RFO	SPECIAL INTEREST	VOL		0.50	006	-0.20 006
57	126	04/96 RFO	SPECIAL INTEREST	VOL		0.79	010	-7.20 010
58	1	04/96 RFO	SPECIAL INTEREST	VOL		0.37	014	-0.78 014

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
58	57	04/96 RFO	SPECIAL INTEREST	VOL		0.65	003	003
58	126	04/96 RFO	SPECIAL INTEREST	WAR	24	1.17	009	010
59	13	04/96 RFO	SPECIAL INTEREST	SAI		0.30	012	012
59	19	04/96 RFO	SPECIAL INTEREST	SAI		0.18	012	012
59	23	04/96 RFO	SPECIAL INTEREST	MAI		0.26	013	013
60	1	04/96 RFO	SPECIAL INTEREST	VOL		0.55	011	011
		04/96 RFO	SPECIAL INTEREST	VOL		0.56	010	010
60	3	04/96 RFO	SPECIAL INTEREST	WAR	17	0.98	011	011
60	41	04/96 RFO	SPECIAL INTEREST	SAI		0.16	010	010
60	126	04/96 RFO	SPECIAL INTEREST	WAR	25	1.23	009	009
61	1	04/96 RFO	SPECIAL INTEREST	MAI		0.21	013	013
		04/96 RFO	SPECIAL INTEREST	MAI		0.26	014	014
61	72	04/96 RFO	SPECIAL INTEREST	SAI		0.34	014	014
61	119	04/96 RFO	SPECIAL INTEREST	VOL		0.99	008	008
62	2	04/96 RFO	SPECIAL INTEREST	VOL		0.33	011	011
62	75	04/96 RFO	SPECIAL INTEREST	VOL		0.65	004	004
63	27	04/96 RFO	SPECIAL INTEREST	SAI		0.09	UTS	UTS
63	47	04/96 RFO	SPECIAL INTEREST	SAI		0.32	015	015
		04/96 RFO	SPECIAL INTEREST	MAI		0.40	013	014
		04/96 RFO	SPECIAL INTEREST	MAI		0.40	013	014
		04/96 RFO	SPECIAL INTEREST	MAI		0.69	013	014
		04/96 RFO	SPECIAL INTEREST	MAI		0.71	011	012
		04/96 RFO	SPECIAL INTEREST	MAI		0.72	011	012
		04/96 RFO	SPECIAL INTEREST	MAI		0.85	014	014
		04/96 RFO	SPECIAL INTEREST	MAI		0.96	012	012
		04/96 RFO	SPECIAL INTEREST	SAI		0.54	015	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.56	015	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.64	012	012
		04/96 RFO	SPECIAL INTEREST	SAI		0.73	015	015
63	105	04/96 RFO	SPECIAL INTEREST	VOL		0.30	008	008
63	110	04/96 RFO	SPECIAL INTEREST	VOL		0.55	004	004
63	122	04/96 RFO	SPECIAL INTEREST	VOL		0.71	008	008
64	122	04/96 RFO	SPECIAL INTEREST	VOL		0.26	008	008
64	125	04/96 RFO	SPECIAL INTEREST	VOL		0.49	009	009
65	33	04/96 RFO	SPECIAL INTEREST	MAI		0.15	013	013
65	96	04/96 RFO	SPECIAL INTEREST	VOL		0.27	006	006
65	128	04/96 RFO	SPECIAL INTEREST	VOL		0.58	010	010
66	4	04/96 RFO	SPECIAL INTEREST	SAI		1.00	012	012
66	25	04/96 RFO	SPECIAL INTEREST	MAI		0.53	014	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.62	014	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.64	015	015
		04/96 RFO	SPECIAL INTEREST	SAI		1.38	014	014
66	57	04/96 RFO	SPECIAL INTEREST	WAR	12	0.50	006	006
		04/96 RFO	SPECIAL INTEREST	WAR	21	1.04	006	006
66	75	04/96 RFO	SPECIAL INTEREST	VOL		1.48	005	005
		04/96 RFO	SPECIAL INTEREST	VOL		1.07	005	005
66	126	04/96 RFO	SPECIAL INTEREST	VOL		0.78	009	009
66	128	04/96 RFO	SPECIAL INTEREST	VOL		0.79	009	009
66	130	04/96 RFO	SPECIAL INTEREST	VOL		0.30	009	009
67	111	04/96 RFO	SPECIAL INTEREST	VOL		0.57	015	015
67	113	04/96 RFO	SPECIAL INTEREST	VOL		0.70	015	015
67	130	04/96 RFO	SPECIAL INTEREST	VOL		0.62	011	011
68	39	04/96 RFO	SPECIAL INTEREST	MAI		0.90	015	015
69	40	04/96 RFO	SPECIAL INTEREST	SAI		0.18	015	015
		04/96 RFO	SPECIAL INTEREST	MAI		0.26	015	015
69	68	04/96 RFO	SPECIAL INTEREST	VOL		0.10	005	005
		04/96 RFO	SPECIAL INTEREST	VOL		0.22	005	005
69	100	04/96 RFO	SPECIAL INTEREST	VOL		0.63	006	006
69	111	04/96 RFO	SPECIAL INTEREST	VOL		1.34	015	015
70	43	04/96 RFO	SPECIAL INTEREST	VOL		0.23	002	002
70	48	04/96 RFO	SPECIAL INTEREST	SAI		0.20	UTS	UTS
70	55	04/96 RFO	SPECIAL INTEREST	SAI		0.21	014	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.40	014	015
70	70	04/96 RFO	SPECIAL INTEREST	VOL		0.79	014	014
70	82	04/96 RFO	SPECIAL INTEREST	SAI		1.00	LTS	LTS

FTI TUBAN II (Version 2.3) 05/14/1996 09:32:23

Oconee Nuclear Station - Unit Two

S/G A

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 6 of 13

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
70	121	04/96 RFO	SPECIAL INTEREST	VOL		0.06	007	007
70	126	04/96 RFO	SPECIAL INTEREST	WAR	7	0.33	015	015
71	128	04/96 RFO	SPECIAL INTEREST	MAI		0.23	012	012
		04/96 RFO	SPECIAL INTEREST	MAI		0.74	013	013
		04/96 RFO	SPECIAL INTEREST	MAI		0.75	014	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.83	012	012
72	53	04/96 RFO	SPECIAL INTEREST	VOL		0.58	005	005
		04/96 RFO	SPECIAL INTEREST	WAR	18	0.87	009	009
72	56	04/96 RFO	SPECIAL INTEREST	VOL		0.43	005	005
72	81	04/96 RFO	SPECIAL INTEREST	VOL		1.55	002	002
72	110	04/96 RFO	SPECIAL INTEREST	SAI		0.15	011	011
		04/96 RFO	SPECIAL INTEREST	SAI		0.16	012	012
73	32	04/96 RFO	MRPC Lane & Wedge	VOL		0.16	015	015
73	49	04/96 RFO	SPECIAL INTEREST	MAI		0.31	015	015
73	57	04/96 RFO	SPECIAL INTEREST	WAR	15	0.67	005	005
73	59	04/96 RFO	SPECIAL INTEREST	WAR	9	0.38	007	007
73	66	04/96 RFO	SPECIAL INTEREST	VOL		0.52	LTS	LTS
73	127	04/96 RFO	SPECIAL INTEREST	WAR	17	0.83	015	015
		04/96 RFO	SPECIAL INTEREST	MAI		0.40	012	012
		04/96 RFO	SPECIAL INTEREST	MAI		0.61	013	013
		04/96 RFO	SPECIAL INTEREST	SAI		0.32	014	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.41	013	013
		04/96 RFO	SPECIAL INTEREST	SAI		0.59	010	010
		04/96 RFO	SPECIAL INTEREST	SAI		0.63	014	014
73	129	04/96 RFO	SPECIAL INTEREST	VOL		0.47	010	010
74	63	04/96 RFO	SPECIAL INTEREST	VOL		0.48	LTS	LTS
74	80	04/96 RFO	SPECIAL INTEREST	VOL		0.47	006	006
74	102	04/96 RFO	SPECIAL INTEREST	WAR	10	0.66	015	015
74	103	04/96 RFO	SPECIAL INTEREST	WAR	12	0.78	015	015
74	104	04/96 RFO	SPECIAL INTEREST	VOL		1.29	015	015
74	124	04/96 RFO	SPECIAL INTEREST	SAI		0.22	014	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.31	012	012
74	125	04/96 RFO	SPECIAL INTEREST	VOL		0.51	010	010
75	43	04/96 RFO	SPECIAL INTEREST	VOL		0.17	UTS	UTS
		04/96 RFO	MRPC Lane & Wedge	VOL		0.27	UTS	UTS
75	102	04/96 RFO	SPECIAL INTEREST	VOL		0.84	015	015
75	123	04/96 RFO	SPECIAL INTEREST	MAI		0.32	013	013
		04/96 RFO	SPECIAL INTEREST	MAI		0.49	011	011
		04/96 RFO	SPECIAL INTEREST	MAI		1.01	010	010
75	124	04/96 RFO	SPECIAL INTEREST	SAI		0.24	011	011
		04/96 RFO	SPECIAL INTEREST	SAI		0.54	013	013
		04/96 RFO	SPECIAL INTEREST	SAI		0.67	012	012
75	125	04/96 RFO	SPECIAL INTEREST	SAI		0.39	015	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.46	015	015
76	66	04/96 RFO	SPECIAL INTEREST	SAI		0.57	UTS	UTS
76	85	04/96 RFO	SPECIAL INTEREST	WAR	11	0.39	006	006
76	121	04/96 RFO	SPECIAL INTEREST	SAI		0.18	015	015
		04/96 RFO	SPECIAL INTEREST	MAI		0.09	013	013
		04/96 RFO	SPECIAL INTEREST	MAI		0.26	011	011
		04/96 RFO	SPECIAL INTEREST	SAI		0.18	013	013
78	67	04/96 RFO	SPECIAL INTEREST	SAI		0.06	UTS	UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.12	UTS	UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.13	UTS	UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.18	UTS	UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.22	UTS	UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.42	UTS	UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.42	UTS	UTS
78	105	04/96 RFO	SPECIAL INTEREST	VOL		1.34	015	015
78	123	04/96 RFO	SPECIAL INTEREST	SAI		0.11	011	011
		04/96 RFO	SPECIAL INTEREST	SAI		0.17	011	011
		04/96 RFO	SPECIAL INTEREST	VOL		0.27	011	011
		04/96 RFO	SPECIAL INTEREST	MAI		0.08	014	014
		04/96 RFO	SPECIAL INTEREST	MAI		0.12	014	014
		04/96 RFO	SPECIAL INTEREST	MAI		0.13	013	013
		04/96 RFO	SPECIAL INTEREST	SAI		0.11	013	013

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
78	125	04/96 RFO	SPECIAL INTEREST	SAI		0.73	012	-30.53 to -2.65
		04/96 RFO	SPECIAL INTEREST	SAI		1.17	013	-5.86 to -3.20
79	2	04/96 RFO	SPECIAL INTEREST	VOL		3.88	005	-0.48
79	23	04/96 RFO	MRPC Lane & Wedge	VOL		0.25	UTS	+1.08
79	27	04/96 RFO	SPECIAL INTEREST	SAI		0.23	014	+5.06
		04/96 RFO	SPECIAL INTEREST	SAI		0.51	UTS	-21.93
79	49	04/96 RFO	SPECIAL INTEREST	SAI		0.21	014	+30.51
79	59	04/96 RFO	SPECIAL INTEREST	WAR	7	0.28	007	+0.00
79	66	04/96 RFO	SPECIAL INTEREST	VOL		0.25	LTS	+1.99
79	78	04/96 RFO	SPECIAL INTEREST	SAI		0.52	015	-0.42
		04/96 RFO	SPECIAL INTEREST	SAI		0.14	UTS	-16.19 to -15.65
		04/96 RFO	SPECIAL INTEREST	SAI		0.17	UTS	-31.24 to -30.27
		04/96 RFO	SPECIAL INTEREST	SAI		1.04	UTS	-7.44 to -6.52
		04/96 RFO	SPECIAL INTEREST	SAI		1.27	UTS	-11.85 to -7.65
79	126	04/96 RFO	SPECIAL INTEREST	SAI		0.15	011	+4.99
		04/96 RFO	SPECIAL INTEREST	SAI		0.37	014	+31.71
		04/96 RFO	SPECIAL INTEREST	SAI		0.54	014	+2.17
		04/96 RFO	SPECIAL INTEREST	MAI		0.40	011	+3.82 to +16.41
79	127	04/96 RFO	SPECIAL INTEREST	SAI		0.66	013	-8.85
79	128	04/96 RFO	SPECIAL INTEREST	SAI		0.19	015	+4.18 to +9.66
80	5	04/96 RFO	SPECIAL INTEREST	WAR	10	0.64	011	+0.00
80	8	04/96 RFO	SPECIAL INTEREST	WAR	27	4.50	010	+0.00
80	68	04/96 RFO	SPECIAL INTEREST	SAI		0.42	015	-2.17
80	128	04/96 RFO	SPECIAL INTEREST	SAI		0.30	011	+23.54
		04/96 RFO	SPECIAL INTEREST	SAI		0.31	011	+32.08
		04/96 RFO	SPECIAL INTEREST	SAI		0.53	011	+31.13
81	3	04/96 RFO	SPECIAL INTEREST	VOL		0.47	001	+11.91
81	91	04/96 RFO	SPECIAL INTEREST	WAR	13	0.47	006	+0.00
81	98	04/96 RFO	SPECIAL INTEREST	WAR	14	0.52	006	+0.00
81	109	04/96 RFO	SPECIAL INTEREST	WAR	13	0.83	015	+0.00
82	3	04/96 RFO	SPECIAL INTEREST	WAR	18	1.24	011	+0.00
82	5	04/96 RFO	SPECIAL INTEREST	WAR	10	0.67	011	+0.00
82	13	04/96 RFO	SPECIAL INTEREST	SAI		0.26	015	+12.63
		04/96 RFO	SPECIAL INTEREST	SAI		0.39	015	-18.99
		04/96 RFO	SPECIAL INTEREST	SAI		0.42	015	+2.92
		04/96 RFO	SPECIAL INTEREST	SAI		0.48	015	+23.54
		04/96 RFO	SPECIAL INTEREST	MAI		0.51	015	-15.86 to -9.39
82	110	04/96 RFO	SPECIAL INTEREST	WAR	10	0.66	015	+0.00
82	111	04/96 RFO	SPECIAL INTEREST	WAR	22	1.54	015	+0.00
82	126	04/96 RFO	SPECIAL INTEREST	SAI		0.30	012	-1.49
		04/96 RFO	SPECIAL INTEREST	SAI		0.89	011	+5.73
83	27	04/96 RFO	SPECIAL INTEREST	MAI		0.44	014	+1.88 to +7.29
		04/96 RFO	SPECIAL INTEREST	SAI		0.56	015	+17.15 to +20.36
		04/96 RFO	SPECIAL INTEREST	SAI		0.78	015	+2.21 to +5.35
83	126	04/96 RFO	SPECIAL INTEREST	SAI		0.17	012	+8.88
		04/96 RFO	SPECIAL INTEREST	SAI		0.20	010	-13.75 to -8.80
		04/96 RFO	SPECIAL INTEREST	SAI		0.28	010	+19.71 to +22.32
		04/96 RFO	SPECIAL INTEREST	SAI		0.40	012	+12.69 to +14.83
83	128	04/96 RFO	SPECIAL INTEREST	SAI		0.19	012	+8.08
		04/96 RFO	SPECIAL INTEREST	SAI		0.24	012	+19.41
		04/96 RFO	SPECIAL INTEREST	SAI		0.30	012	+1.58
		04/96 RFO	SPECIAL INTEREST	SAI		0.17	012	-4.42 to -0.24
		04/96 RFO	SPECIAL INTEREST	SAI		0.45	009	+26.64 to +36.57
84	5	04/96 RFO	SPECIAL INTEREST	WAR	12	0.81	011	+0.00
84	6	04/96 RFO	SPECIAL INTEREST	WAR	9	0.60	011	+0.00
84	27	04/96 RFO	SPECIAL INTEREST	SAI		0.72	014	-13.37
84	73	04/96 RFO	SPECIAL INTEREST	SAI		0.24	015	+21.04 to +43.07
		04/96 RFO	SPECIAL INTEREST	SAI		0.57	013	+7.41 to +20.00
84	113	04/96 RFO	SPECIAL INTEREST	WAR	13	0.87	015	+0.00
85	20	04/96 RFO	SPECIAL INTEREST	SAI		0.28	015	+25.80
		04/96 RFO	SPECIAL INTEREST	SAI		0.86	011	+16.27 to +17.65
85	28	04/96 RFO	SPECIAL INTEREST	SAI		0.04	014	+18.10
		04/96 RFO	SPECIAL INTEREST	SAI		0.10	015	+33.97
		04/96 RFO	SPECIAL INTEREST	SAI		0.17	015	+27.71
		04/96 RFO	SPECIAL INTEREST	SAI		0.22	014	+7.49

FTI TUBAN II (Version 2.3) 05/14/1996 09:32:23

Oconee Nuclear Station - Unit Two

S/G A

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 8 of 13

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	SPECIAL INTEREST	SAI		0.25	015 +30.87	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.29	014 -1.17	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.36	013 +33.09	013
		04/96 RFO	SPECIAL INTEREST	SAI		0.36	015 +38.82	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.45	015 +37.40	015
85	70	04/96 RFO	SPECIAL INTEREST	SAI		0.42	015 +38.73	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.43	015 +37.39	015
85	126	04/96 RFO	SPECIAL INTEREST	SAI		0.76	013 +1.48 to +4.43	013
86	4	04/96 RFO	SPECIAL INTEREST	WAR	13	0.89	011 +0.00	011
86	50	04/96 RFO	SPECIAL INTEREST	VOL		1.35	007 +10.76	007
86	126	04/96 RFO	SPECIAL INTEREST	WAR	9	0.96	015 +0.00	015
86	130	04/96 RFO	SPECIAL INTEREST	WAR	18	0.92	010 +0.00	010
88	22	04/96 RFO	SPECIAL INTEREST	SAI		0.34	013 +9.73	013
		04/96 RFO	SPECIAL INTEREST	SAI		0.71	013 +4.13	013
88	27	04/96 RFO	SPECIAL INTEREST	VOL		1.05	015 -0.20	015
88	73	04/96 RFO	SPECIAL INTEREST	MAI		0.51	014 +10.17	014
88	101	04/96 RFO	SPECIAL INTEREST	SAI		0.16	010 +16.85	010
89	27	04/96 RFO	SPECIAL INTEREST	SAI		0.45	015 +22.91	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.61	015 +27.74	015
89	28	04/96 RFO	SPECIAL INTEREST	SAI		0.58	015 +39.06	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.63	015 +37.55	015
89	57	04/96 RFO	SPECIAL INTEREST	VOL		0.24	005 +0.74	005
89	72	04/96 RFO	SPECIAL INTEREST	MAI		0.23	UTS -10.40	UTS
90	6	04/96 RFO	SPECIAL INTEREST	VOL		0.70	011 -0.71	011
90	56	04/96 RFO	SPECIAL INTEREST	VOL		0.33	006 -0.17	006
90	57	04/96 RFO	SPECIAL INTEREST	SAI		0.80	013 -13.77	013
90	68	04/96 RFO	SPECIAL INTEREST	VOL		1.13	002 +11.52	002
90	70	04/96 RFO	SPECIAL INTEREST	SAI		0.15	011 +6.69	011
		04/96 RFO	SPECIAL INTEREST	SAI		0.28	013 +19.20 to +21.43	013
90	75	04/96 RFO	SPECIAL INTEREST	VOL		1.11	UTS +11.24	UTS
91	19	04/96 RFO	SPECIAL INTEREST	SAI		0.43	015 +11.69	015
91	23	04/96 RFO	SPECIAL INTEREST	VOL		1.64	005 +14.19	005
92	1	04/96 RFO	SPECIAL INTEREST	VOL		0.35	011 -0.76	011
92	15	04/96 RFO	SPECIAL INTEREST	SAI		0.16	010 +23.44	010
92	16	04/96 RFO	SPECIAL INTEREST	SAI		0.30	UTS -10.64	UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.31	UTS -10.05	UTS
		04/96 RFO	SPECIAL INTEREST	VOL		0.25	008 -0.44	008
92	59	04/96 RFO	SPECIAL INTEREST	VOL		0.16	006 -0.35	006
92	70	04/96 RFO	SPECIAL INTEREST	SAI		0.41	010 +13.97	010
92	72	04/96 RFO	SPECIAL INTEREST	SAI		0.33	014 +15.55	014
93	69	04/96 RFO	SPECIAL INTEREST	SAI		0.03	012 -15.92	012
		04/96 RFO	SPECIAL INTEREST	SAI		0.06	012 -13.76	012
		04/96 RFO	SPECIAL INTEREST	SAI		0.11	015 +38.57	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.27	014 +4.76	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.30	014 +18.77	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.42	014 +18.01	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.73	012 +21.00	012
		04/96 RFO	SPECIAL INTEREST	SAI		0.05	014 +28.47 to +32.21	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.24	013 +19.94 to +22.59	013
94	15	04/96 RFO	SPECIAL INTEREST	SAI		0.27	013 +15.05	013
		04/96 RFO	SPECIAL INTEREST	SAI		0.34	015 -5.32	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.32	012 +17.12 to +20.22	012
		04/96 RFO	SPECIAL INTEREST	SAI		0.44	013 +4.93 to +8.39	013
94	43	04/96 RFO	SPECIAL INTEREST	VOL		0.34	012 -26.36	012
		04/96 RFO	SPECIAL INTEREST	VOL		0.52	012 -29.34	012
95	1	04/96 RFO	SPECIAL INTEREST	VOL		0.46	011 -0.75	011
95	29	04/96 RFO	SPECIAL INTEREST	VOL		0.16	007 -0.43	007
95	127	04/96 RFO	SPECIAL INTEREST	WAR	19	0.99	014 +0.00	014
96	1	04/96 RFO	SPECIAL INTEREST	VOL		0.26	011 -0.74	011
96	67	04/96 RFO	SPECIAL INTEREST	SAI		0.14	014 -9.67	014
96	114	04/96 RFO	SPECIAL INTEREST	NQI		5.28	003 +13.23	003
98	125	04/96 RFO	SPECIAL INTEREST	VOL		0.41	008 -5.14	008
99	124	04/96 RFO	SPECIAL INTEREST	WAR	25	1.42	011 +0.00	011
101	56	04/96 RFO	SPECIAL INTEREST	VOL		0.15	005 +0.68	005
		04/96 RFO	SPECIAL INTEREST	VOL		0.19	005 -0.66	005

FTI TUBAN II (Version 2.3) 05/14/1996 09:32:23

Oconee Nuclear Station - Unit Two

S/G A

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 9 of 13

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
102	23	04/96 RFO	SPECIAL INTEREST	SAI		0.39	014	+4.23
102	55	04/96 RFO	SPECIAL INTEREST	VOL		0.16	005	-0.71
		04/96 RFO	SPECIAL INTEREST	WAR	16	0.74	004	+0.00
102	67	04/96 RFO	SPECIAL INTEREST	SAI		0.40	UTS	-7.27
102	69	04/96 RFO	SPECIAL INTEREST	SAI		0.17	015	+15.96
		04/96 RFO	SPECIAL INTEREST	SAI		0.23	015	+16.80
		04/96 RFO	SPECIAL INTEREST	SAI		0.28	015	+30.96
103	11	04/96 RFO	SPECIAL INTEREST	SAI		0.30	014	+14.23
103	65	04/96 RFO	SPECIAL INTEREST	SAI		0.55	015	+1.24 to +43.76
103	69	04/96 RFO	SPECIAL INTEREST	SAI		0.20	015	+2.07
104	8	04/96 RFO	SPECIAL INTEREST	SAI		0.22	012	-10.63
104	122	04/96 RFO	SPECIAL INTEREST	WAR	10	0.73	011	+0.00
105	1	04/96 RFO	SPECIAL INTEREST	WAR	16	0.98	011	+0.00
105	2	04/96 RFO	SPECIAL INTEREST	SAI		0.20	013	-14.74
105	48	04/96 RFO	SPECIAL INTEREST	VOL		0.81	009	+8.94
105	68	04/96 RFO	SPECIAL INTEREST	SAI		0.28	011	+31.69
		04/96 RFO	SPECIAL INTEREST	SAI		0.08	011	+10.00 to +18.36
		04/96 RFO	SPECIAL INTEREST	SAI		0.27	012	-8.34 to -5.91
105	89	04/96 RFO	SPECIAL INTEREST	SAI		0.22	UTS	-2.75
		04/96 RFO	SPECIAL INTEREST	SAI		0.77	UTS	-3.82 to -1.83
105	115	04/96 RFO	SPECIAL INTEREST	WAR	17	0.89	009	+0.00
105	119	04/96 RFO	SPECIAL INTEREST	WAR	10	0.68	014	+0.00
		04/96 RFO	SPECIAL INTEREST	WAR	13	0.90	008	+0.00
		04/96 RFO	SPECIAL INTEREST	WAR	17	1.21	011	+0.00
105	120	04/96 RFO	SPECIAL INTEREST	WAR	12	0.86	012	+0.00
		04/96 RFO	SPECIAL INTEREST	WAR	21	1.60	011	+0.00
06	1	04/96 RFO	SPECIAL INTEREST	WAR	11	0.66	011	+0.00
106	3	04/96 RFO	SPECIAL INTEREST	VOL		0.19	007	+14.06
106	73	04/96 RFO	SPECIAL INTEREST	VOL		1.54	007	+10.29
106	113	04/96 RFO	SPECIAL INTEREST	WAR	8	0.54	015	+0.00
106	115	04/96 RFO	SPECIAL INTEREST	WAR	17	0.91	015	+0.00
107	1	04/96 RFO	SPECIAL INTEREST	WAR	15	0.87	011	+0.00
107	3	04/96 RFO	SPECIAL INTEREST	WAR	19	1.21	015	+0.00
107	4	04/96 RFO	SPECIAL INTEREST	VOL		0.23	006	+13.64
107	68	04/96 RFO	SPECIAL INTEREST	SAI		0.05	UTS	-19.65
		04/96 RFO	SPECIAL INTEREST	SAI		0.42	UTS	-14.03
107	112	04/96 RFO	SPECIAL INTEREST	WAR	10	0.49	008	+0.00
107	113	04/96 RFO	SPECIAL INTEREST	WAR	12	0.62	014	+0.00
		04/96 RFO	SPECIAL INTEREST	WAR	21	1.15	008	+0.00
107	116	04/96 RFO	SPECIAL INTEREST	WAR	7	0.32	015	+0.00
		04/96 RFO	SPECIAL INTEREST	WAR	8	0.52	008	+0.00
		04/96 RFO	SPECIAL INTEREST	WAR	9	0.45	014	+0.00
		04/96 RFO	SPECIAL INTEREST	WAR	16	0.84	010	+0.00
		04/96 RFO	SPECIAL INTEREST	WAR	16	1.14	008	+0.00
		04/96 RFO	SPECIAL INTEREST	WAR	20	1.06	013	+0.00
108	3	04/96 RFO	SPECIAL INTEREST	WAR	21	1.31	015	+0.00
108	5	04/96 RFO	SPECIAL INTEREST	WAR	19	1.18	015	+0.00
108	51	04/96 RFO	SPECIAL INTEREST	VOL		0.12	006	-0.62
108	117	04/96 RFO	SPECIAL INTEREST	WAR	20	1.10	013	+0.00
		04/96 RFO	SPECIAL INTEREST	WAR	21	1.61	012	+0.00
109	10	04/96 RFO	SPECIAL INTEREST	NQI		0.43	015	-7.34
109	72	04/96 RFO	SPECIAL INTEREST	VOL		0.39	002	-6.23
109	73	04/96 RFO	SPECIAL INTEREST	VOL		0.02	012	+10.79
109	78	04/96 RFO	SPECIAL INTEREST	VOL		0.13	006	+0.70
109	117	04/96 RFO	SPECIAL INTEREST	WAR	12	0.62	014	+0.00
110	6	04/96 RFO	SPECIAL INTEREST	SAI		0.19	012	-21.95
		04/96 RFO	SPECIAL INTEREST	SAI		0.24	012	-17.52 to -15.70
110	66	04/96 RFO	SPECIAL INTEREST	SAI		0.02	012	+8.07
		04/96 RFO	SPECIAL INTEREST	SAI		0.04	014	+7.15
		04/96 RFO	SPECIAL INTEREST	SAI		0.12	009	-9.08
		04/96 RFO	SPECIAL INTEREST	SAI		0.41	014	+0.44
		04/96 RFO	SPECIAL INTEREST	SAI		0.47	010	+33.12
		04/96 RFO	SPECIAL INTEREST	SAI		0.24	012	-7.06 to -2.10
		04/96 RFO	SPECIAL INTEREST	SAI		0.28	014	+1.38 to +5.04
		04/96 RFO	SPECIAL INTEREST	SAI		0.29	014	+0.47 to +6.97

FTI TUBAN II (Version 2.3)

05/14/1996 09:32:23

Oconee Nuclear Station - Unit Two

S/G A

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 10 of 13

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	SPECIAL INTEREST	SAI		0.59 010	+6.50 to +28.81	010
111	3	04/96 RFO	SPECIAL INTEREST	SAI		0.54 012	-12.64	012
111	17	04/96 RFO	SPECIAL INTEREST	VOL		0.06 005	+8.52	005
111	72	04/96 RFO	SPECIAL INTEREST	VOL		0.53 001	+8.02	001
111	114	04/96 RFO	SPECIAL INTEREST	WAR	11	0.75 014	+0.00	014
		04/96 RFO	SPECIAL INTEREST	WAR	26	2.08 014	+0.00	014
111	115	04/96 RFO	SPECIAL INTEREST	WAR	24	1.85 014	+0.00	014
		04/96 RFO	SPECIAL INTEREST	WAR	24	1.91 014	+0.00	014
112	1	04/96 RFO	SPECIAL INTEREST	WAR	9	0.28 011	+0.00	011
112	111	04/96 RFO	SPECIAL INTEREST	WAR	5	0.37 014	+0.00	014
		04/96 RFO	SPECIAL INTEREST	WAR	35	3.07 014	+0.00	014
112	113	04/96 RFO	SPECIAL INTEREST	WAR	16	1.20 014	+0.00	014
112	114	04/96 RFO	SPECIAL INTEREST	WAR	11	0.57 008	+0.00	008
113	1	04/96 RFO	SPECIAL INTEREST	WAR	11	0.62 011	+0.00	011
113	5	04/96 RFO	SPECIAL INTEREST	SAI		0.07 010	+5.36	010
113	112	04/96 RFO	SPECIAL INTEREST	WAR	5	0.45 014	+0.00	014
		04/96 RFO	SPECIAL INTEREST	WAR	17	0.78 011	+0.00	011
		04/96 RFO	SPECIAL INTEREST	WAR	17	0.82 008	+0.00	008
113	114	04/96 RFO	SPECIAL INTEREST	WAR	30	1.70 014	+0.00	014
113	115	04/96 RFO	SPECIAL INTEREST	WAR	29	1.57 014	+0.00	014
114	110	04/96 RFO	SPECIAL INTEREST	VOL		1.02 008	+7.88 to +8.52	008
114	111	04/96 RFO	SPECIAL INTEREST	WAR	16	0.77 008	+0.00	008
		04/96 RFO	SPECIAL INTEREST	WAR	28	2.53 014	+0.00	014
114	112	04/96 RFO	SPECIAL INTEREST	WAR	12	0.52 014	+0.00	014
115	4	04/96 RFO	SPECIAL INTEREST	SAI		0.05 013	+13.14	013
115	5	04/96 RFO	SPECIAL INTEREST	SAI		0.10 015	+19.79	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.12 010	+4.39 to +35.18	010
115	71	04/96 RFO	SPECIAL INTEREST	VOL		0.14 014	+13.90	014
115	108	04/96 RFO	SPECIAL INTEREST	WAR	16	0.72 011	+0.00	011
		04/96 RFO	SPECIAL INTEREST	WAR	24	2.15 014	-0.33	014
115	109	04/96 RFO	SPECIAL INTEREST	WAR	19	1.65 011	-0.59	011
115	110	04/96 RFO	SPECIAL INTEREST	WAR	33	3.04 014	+0.00	014
115	111	04/96 RFO	SPECIAL INTEREST	WAR	14	1.07 014	+0.00	014
		04/96 RFO	SPECIAL INTEREST	WAR	24	2.09 014	+0.00	014
116	1	04/96 RFO	SPECIAL INTEREST	WAR	13	0.57 010	+0.00	010
		04/96 RFO	SPECIAL INTEREST	WAR	13	0.74 010	+0.00	010
116	7	04/96 RFO	SPECIAL INTEREST	WAR	5	0.37 013	+0.00	013
116	40	04/96 RFO	SPECIAL INTEREST	VOL		1.37 009	-12.68	009
116	106	04/96 RFO	SPECIAL INTEREST	WAR	6	0.24 014	+0.00	014
		04/96 RFO	SPECIAL INTEREST	WAR	8	0.33 011	+0.00	011
116	107	04/96 RFO	SPECIAL INTEREST	WAR	20	1.59 010	+0.00	010
		04/96 RFO	SPECIAL INTEREST	WAR	21	1.78 012	+0.00	012
117	61	04/96 RFO	SPECIAL INTEREST	SAI		0.07 015	+29.44	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.11 015	+25.67 to +28.67	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.22 UTS	-3.95 to -2.65	UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.38 UTS	-21.00 to -18.61	UTS
117	89	04/96 RFO	SPECIAL INTEREST	VOL		0.03 011	+13.59	011
		04/96 RFO	SPECIAL INTEREST	VOL		0.04 011	+14.94	011
		04/96 RFO	SPECIAL INTEREST	VOL		0.66 011	-2.59	011
117	102	04/96 RFO	SPECIAL INTEREST	WAR	26	2.26 014	+0.00	014
117	104	04/96 RFO	SPECIAL INTEREST	WAR	27	2.31 011	+0.00	011
		04/96 RFO	SPECIAL INTEREST	WAR	34	3.22 014	+0.00	014
118	49	04/96 RFO	SPECIAL INTEREST	SAI		0.47 011	+0.01	011
		04/96 RFO	SPECIAL INTEREST	MAI		0.37 011	+1.07 to +37.80	011
		04/96 RFO	SPECIAL INTEREST	MAI		0.92 010	+3.11 to +34.64	010
		04/96 RFO	SPECIAL INTEREST	SAI		0.38 008	+33.27 to +37.95	008
		04/96 RFO	SPECIAL INTEREST	SAI		0.41 009	+15.17 to +37.88	009
118	50	04/96 RFO	SPECIAL INTEREST	MAI		0.22 012	-23.20 to -5.86	012
118	56	04/96 RFO	SPECIAL INTEREST	SAI		0.22 UTS	-3.44	UTS
118	102	04/96 RFO	SPECIAL INTEREST	WAR	6	0.47 013	+0.00	013
		04/96 RFO	SPECIAL INTEREST	WAR	9	0.67 014	+0.00	014
		04/96 RFO	SPECIAL INTEREST	WAR	12	0.53 009	+0.00	009
		04/96 RFO	SPECIAL INTEREST	WAR	12	0.94 013	+0.00	013
118	103	04/96 RFO	SPECIAL INTEREST	WAR	8	0.33 011	+0.00	011
		04/96 RFO	SPECIAL INTEREST	WAR	16	1.23 012	+0.00	012

FTI TUBAN II (Version 2.3)

05/14/1996 09:32:23

Oconee Nuclear Station - Unit Two

S/G A

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 11 of 13

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	SPECIAL INTEREST	WAR	27	2.34	013	+0.00
119	49	04/96 RFO	SPECIAL INTEREST	SAI		0.14	010	-6.48
		04/96 RFO	SPECIAL INTEREST	SAI		0.21	012	-9.97
		04/96 RFO	SPECIAL INTEREST	SAI		0.27	010	-8.65
		04/96 RFO	SPECIAL INTEREST	SAI		0.62	012	-6.09
119	59	04/96 RFO	SPECIAL INTEREST	SAI		0.03	015	-5.61
		04/96 RFO	SPECIAL INTEREST	SAI		0.04	015	-3.61
		04/96 RFO	SPECIAL INTEREST	SAI		0.04	015	-4.18
		04/96 RFO	SPECIAL INTEREST	SAI		0.04	015	-9.17
		04/96 RFO	SPECIAL INTEREST	SAI		0.06	015	-9.12
		04/96 RFO	SPECIAL INTEREST	SAI		0.07	015	-8.59
		04/96 RFO	SPECIAL INTEREST	SAI		0.09	015	-9.66
		04/96 RFO	SPECIAL INTEREST	SAI		0.46	010	+9.58
		04/96 RFO	SPECIAL INTEREST	SAI		0.47	010	+10.68
		04/96 RFO	SPECIAL INTEREST	SAI		0.51	010	+15.09
		04/96 RFO	SPECIAL INTEREST	SAI		0.47	013	+12.22 to +15.15
		04/96 RFO	SPECIAL INTEREST	SAI		1.12	UTS	-10.38 to -4.92
119	90	04/96 RFO	SPECIAL INTEREST	SAI		0.42	010	-22.21 to -13.99
119	108	04/96 RFO	SPECIAL INTEREST	VOL		0.61	010	+4.73
120	59	04/96 RFO	SPECIAL INTEREST	SAI		0.69	UTS	-4.04
121	47	04/96 RFO	SPECIAL INTEREST	SAI		0.81	015	-10.52
		04/96 RFO	SPECIAL INTEREST	MAI		0.23	010	+0.00 to +10.50
		04/96 RFO	SPECIAL INTEREST	MAI		0.32	010	-1.14 to +1.11
		04/96 RFO	SPECIAL INTEREST	MAI		0.38	009	+5.97 to +38.80
121	48	04/96 RFO	SPECIAL INTEREST	MAI		0.20	010	+6.23 to +34.98
		04/96 RFO	SPECIAL INTEREST	MAI		0.39	011	+1.35 to +35.07
		04/96 RFO	SPECIAL INTEREST	MAI		0.67	008	+16.72 to +33.53
		04/96 RFO	SPECIAL INTEREST	MAI		0.96	009	+6.00 to +37.95
		04/96 RFO	SPECIAL INTEREST	SAI		0.51	013	-27.72 to -25.15
		04/96 RFO	SPECIAL INTEREST	SAI		0.81	013	-8.04 to -2.42
121	88	04/96 RFO	SPECIAL INTEREST	VOL		1.13	015	-13.95
122	1	04/96 RFO	SPECIAL INTEREST	WAR	8	0.34	014	+0.00
122	3	04/96 RFO	SPECIAL INTEREST	VOL		0.48	008	+11.76
122	71	04/96 RFO	SPECIAL INTEREST	VOL		0.72	015	+15.39
123	27	04/96 RFO	SPECIAL INTEREST	VOL		0.07	011	+18.23
124	3	04/96 RFO	SPECIAL INTEREST	VOL		0.49	008	+12.27
124	98	04/96 RFO	SPECIAL INTEREST	VOL		0.06	003	+10.05
124	99	04/96 RFO	SPECIAL INTEREST	NQI		1.26	009	+11.47 to +20.96
124	101	04/96 RFO	SPECIAL INTEREST	VOL		0.08	011	+4.36
		04/96 RFO	SPECIAL INTEREST	WAR	8	0.43	012	+0.00
125	28	04/96 RFO	SPECIAL INTEREST	SAI		0.84	012	+3.49 to +5.31
125	43	04/96 RFO	SPECIAL INTEREST	VOL		1.19	004	+11.49
125	45	04/96 RFO	SPECIAL INTEREST	SAI		0.64	UTS	-3.05
125	64	04/96 RFO	SPECIAL INTEREST	NQI		0.10	007	-10.15
126	77	04/96 RFO	SPECIAL INTEREST	VOL		0.06	UTS	-1.63
128	2	04/96 RFO	SPECIAL INTEREST	SAI		0.26	014	-4.97
		04/96 RFO	SPECIAL INTEREST	SAI		0.30	011	+16.61
128	53	04/96 RFO	SPECIAL INTEREST	VOL		0.09	011	-5.64
128	58	04/96 RFO	SPECIAL INTEREST	VOL		1.31	015	+17.39
129	81	04/96 RFO	SPECIAL INTEREST	VOL		1.30	006	+9.91
129	89	04/96 RFO	SPECIAL INTEREST	SAI		0.09	011	+6.93
		04/96 RFO	SPECIAL INTEREST	SAI		0.17	011	+9.15
		04/96 RFO	SPECIAL INTEREST	MAI		0.05	013	+1.62 to +17.00
		04/96 RFO	SPECIAL INTEREST	MAI		0.11	012	+1.00 to +14.23
130	7	04/96 RFO	SPECIAL INTEREST	WAR	7	0.29	009	+0.65
130	13	04/96 RFO	SPECIAL INTEREST	SAI		0.06	010	+11.78
		04/96 RFO	SPECIAL INTEREST	SAI		0.10	012	+19.33
		04/96 RFO	SPECIAL INTEREST	SAI		0.26	010	+2.77
		04/96 RFO	SPECIAL INTEREST	SAI		0.13	012	+15.58 to +16.43
		04/96 RFO	SPECIAL INTEREST	SAI		0.19	012	+9.83 to +11.89
		04/96 RFO	SPECIAL INTEREST	SAI		0.35	010	+6.07 to +8.96
130	93	04/96 RFO	SPECIAL INTEREST	VOL		0.10	001	-13.84
131	73	04/96 RFO	SPECIAL INTEREST	VOL		0.57	008	-16.88
132	82	04/96 RFO	SPECIAL INTEREST	SAI		0.20	009	+36.56
		04/96 RFO	SPECIAL INTEREST	SAI		0.34	011	-4.70

FTI TUBAN II (Version 2.3)

05/14/1996 09:32:23

Oconee Nuclear Station - Unit Two

S/G A

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 12 of 13

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	SPECIAL INTEREST	SAI		0.22	011 +10.66 to +15.66	011
		04/96 RFO	SPECIAL INTEREST	SAI		0.32	010 +23.99 to +35.31	010
		04/96 RFO	SPECIAL INTEREST	SAI		0.33	011 +0.83 to +7.00	011
133	15	04/96 RFO	SPECIAL INTEREST	VOL		0.15	011 +5.30	011
		04/96 RFO	SPECIAL INTEREST	VOL		0.40	011 -7.02	011
133	54	04/96 RFO	SPECIAL INTEREST	VOL		0.22	014 +13.26	014
133	70	04/96 RFO	SPECIAL INTEREST	VOL		0.24	006 +2.19	006
134	4	04/96 RFO	SPECIAL INTEREST	SAI		0.05	011 -7.07	011
		04/96 RFO	SPECIAL INTEREST	SAI		0.09	013 -13.69	013
		04/96 RFO	SPECIAL INTEREST	SAI		0.43	UTS -2.05	UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.07	013 -9.59 to -8.01	013
		04/96 RFO	SPECIAL INTEREST	SAI		0.18	014 -6.45 to -2.47	014
134	48	04/96 RFO	SPECIAL INTEREST	SAI		0.25	UTS -0.50	UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.28	UTS -0.69	UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.29	UTS -0.55	UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.32	UTS -5.18 to -2.62	UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.36	UTS -5.05 to -2.55	UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.38	UTS -5.31 to -2.57	UTS
135	2	04/96 RFO	SPECIAL INTEREST	SAI		0.26	014 +15.48	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.42	014 +12.35	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.11	013 +2.63 to +4.49	013
135	32	04/96 RFO	SPECIAL INTEREST	SAI		0.26	012 -9.47	012
135	47	04/96 RFO	SPECIAL INTEREST	SAI		0.42	UTS -8.54	UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.65	UTS -6.49	UTS
137	3	04/96 RFO	SPECIAL INTEREST	WAR	7	0.31	010 +0.00	010
137	46	04/96 RFO	SPECIAL INTEREST	SAI		0.29	015 +9.50	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.36	UTS -8.83	UTS
137	73	04/96 RFO	SPECIAL INTEREST	SAI		0.23	014 -1.45	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.49	014 -15.41	014
138	2	04/96 RFO	SPECIAL INTEREST	WAR	7	0.27	010 +0.00	010
138	15	04/96 RFO	SPECIAL INTEREST	SAI		0.29	UTS -1.21 to +0.10	UTS
138	44	04/96 RFO	SPECIAL INTEREST	SAI		0.25	UTS -1.44	UTS
139	15	04/96 RFO	SPECIAL INTEREST	MAI		0.12	012 +4.69 to +33.15	012
		04/96 RFO	SPECIAL INTEREST	MAI		0.15	014 +2.77 to +6.21	014
		04/96 RFO	SPECIAL INTEREST	MAI		0.31	010 +2.65 to +14.51	010
		04/96 RFO	SPECIAL INTEREST	MAI		0.59	013 +4.06 to +24.96	013
139	44	04/96 RFO	SPECIAL INTEREST	MAI		0.49	015 +39.09 to +44.91	015
139	68	04/96 RFO	SPECIAL INTEREST	SAI		0.20	015 +24.08	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.48	015 +4.40	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.28	013 +26.76 to +28.28	013
		04/96 RFO	SPECIAL INTEREST	SAI		0.43	013 +28.28 to +32.13	013
		04/96 RFO	SPECIAL INTEREST	SAI		0.49	014 +9.05 to +12.21	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.61	015 +19.79 to +20.84	015
140	2	04/96 RFO	SPECIAL INTEREST	VOL		0.83	010 -3.50	010
		04/96 RFO	SPECIAL INTEREST	WAR	4	0.17	010 +0.00	010
140	7	04/96 RFO	SPECIAL INTEREST	SAI		0.04	015 +16.95 to +17.26	015
140	8	04/96 RFO	SPECIAL INTEREST	SAI		0.95	015 +4.84 to +7.02	015
140	41	04/96 RFO	SPECIAL INTEREST	SAI		0.26	014 +16.18 to +17.78	014
140	42	04/96 RFO	SPECIAL INTEREST	SAI		0.24	009 +30.05	009
140	43	04/96 RFO	SPECIAL INTEREST	SAI		0.23	015 +24.73	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.38	015 +26.32	015
140	71	04/96 RFO	SPECIAL INTEREST	VOL		0.22	014 +0.74	014
141	2	04/96 RFO	SPECIAL INTEREST	WAR	7	0.51	014 +0.00	014
141	65	04/96 RFO	SPECIAL INTEREST	SAI		0.29	011 +2.35 to +4.59	011
142	65	04/96 RFO	SPECIAL INTEREST	MAI		0.11	010 +29.78	010
		04/96 RFO	SPECIAL INTEREST	SAI		0.24	010 +30.73 to +34.78	010
		04/96 RFO	SPECIAL INTEREST	SAI		0.42	010 +18.13 to +20.31	010
143	15	04/96 RFO	SPECIAL INTEREST	VOL		0.18	008 +0.06	008
143	58	04/96 RFO	SPECIAL INTEREST	SAI		0.24	010 +12.24 to +19.21	010
144	7	04/96 RFO	SPECIAL INTEREST	SAI		0.21	011 +8.30	010
		04/96 RFO	SPECIAL INTEREST	MAI		0.32	010 +4.49 to +23.31	010
145	12	04/96 RFO	SPECIAL INTEREST	VOL		0.68	014 -0.80	014
146	2	04/96 RFO	SPECIAL INTEREST	VOL		0.39	014 +0.66	014
147	31	04/96 RFO	SPECIAL INTEREST	SAI		0.38	013 +10.70	013
		04/96 RFO	SPECIAL INTEREST	SAI		0.38	013 +12.87	013

FTI TUBAN II (Version 2.3) 05/14/1996 09:32:23

Oconee Nuclear Station - Unit Two

S/G A

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 13 of 13

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	SPECIAL INTEREST	SAI		0.41	015	+2.96
		04/96 RFO	SPECIAL INTEREST	SAI		1.07	015	+41.45 to +43.19
148	15	04/96 RFO	SPECIAL INTEREST	VOL		0.50	012	-0.74
148	28	04/96 RFO	SPECIAL INTEREST	VOL		0.40	008	-0.40
148	36	04/96 RFO	SPECIAL INTEREST	VOL		0.40	010	+0.35
149	22	04/96 RFO	SPECIAL INTEREST	SAI		0.44	012	-8.57
		04/96 RFO	SPECIAL INTEREST	WAR	13	0.78	010	+0.66
149	24	04/96 RFO	SPECIAL INTEREST	MAI		0.72	012	+35.41
		04/96 RFO	SPECIAL INTEREST	SAI		0.15	011	+33.58
		04/96 RFO	SPECIAL INTEREST	SAI		0.27	UTS	-1.24
		04/96 RFO	SPECIAL INTEREST	SAI		0.34	012	+30.09
		04/96 RFO	SPECIAL INTEREST	SAI		0.73	011	+34.70
		04/96 RFO	SPECIAL INTEREST	SAI		0.28	012	+12.79 to +15.43
149	29	04/96 RFO	SPECIAL INTEREST	VOL		0.69	011	+5.32
150	3	04/96 RFO	SPECIAL INTEREST	VOL		0.61	009	+0.52
150	22	04/96 RFO	SPECIAL INTEREST	VOL		0.49	011	+3.99
151	14	04/96 RFO	SPECIAL INTEREST	SAI		0.25	UTS	-8.37
151	16	04/96 RFO	SPECIAL INTEREST	SAI		0.26	015	+1.73
		04/96 RFO	SPECIAL INTEREST	SAI		0.31	015	+2.95
		04/96 RFO	SPECIAL INTEREST	SAI		0.41	013	-10.16

Total Indications Found = 800

Total Tubes Found = 452

ATTACHMENT 4

12 Pages

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
1	1	04/96 RFO	SPECIAL INTEREST			1.92	014	+4.49
1	2	04/96 RFO	SPECIAL INTEREST			0.48	013	+7.37
1	6	04/96 RFO	SPECIAL INTEREST			0.73	013	+1.61
1	8	04/96 RFO	SPECIAL INTEREST			0.40	010	-0.41
1	14	04/96 RFO	SPECIAL INTEREST			0.41	010	-0.48
1	15	04/96 RFO	SPECIAL INTEREST	WAR	10	0.50	010	+0.00
		04/96 RFO	SPECIAL INTEREST	MAI		0.07	012	+2.10 to +25.50
2	1	04/96 RFO	SPECIAL INTEREST	VOL		1.65	006	+11.53 to +12.73
2	3	04/96 RFO	SPECIAL INTEREST	WAR	11	0.53	010	+0.14
2	5	04/96 RFO	SPECIAL INTEREST	VOL		0.19	012	+4.27
2	10	04/96 RFO	SPECIAL INTEREST	VOL		0.39	009	+0.43
2	14	04/96 RFO	SPECIAL INTEREST	SAI		0.17	010	+25.27
2	17	04/96 RFO	SPECIAL INTEREST	VOL		0.22	010	-0.64
3	5	04/96 RFO	SPECIAL INTEREST	SAI		0.26	015	-5.51
3	7	04/96 RFO	SPECIAL INTEREST	VOL		0.47	011	+6.70
3	8	04/96 RFO	SPECIAL INTEREST	VOL		0.31	011	+7.17
3	9	04/96 RFO	SPECIAL INTEREST	VOL		0.31	010	+12.91
3	10	04/96 RFO	SPECIAL INTEREST	SAI		0.19	015	+5.98
		04/96 RFO	SPECIAL INTEREST	VOL		0.64	011	+6.38
3	20	04/96 RFO	SPECIAL INTEREST	VOL		0.28	009	+0.80
		04/96 RFO	SPECIAL INTEREST	VOL		0.48	009	+0.73
		04/96 RFO	SPECIAL INTEREST	VOL		0.62	009	-0.38
		04/96 RFO	SPECIAL INTEREST	VOL		1.01	009	-0.21
3	33	04/96 RFO	SPECIAL INTEREST	VOL		0.25	010	+0.58
4	8	04/96 RFO	SPECIAL INTEREST	VOL		1.40	001	-13.05
4	16	04/96 RFO	SPECIAL INTEREST	VOL		0.09	008	+0.28
		04/96 RFO	SPECIAL INTEREST	VOL		0.21	008	-0.30
4	20	04/96 RFO	SPECIAL INTEREST	VOL		0.21	009	+0.69
4	41	04/96 RFO	SPECIAL INTEREST	VOL		0.19	010	+0.68
5	4	04/96 RFO	SPECIAL INTEREST	VOL		0.26	010	+0.70
5	13	04/96 RFO	SPECIAL INTEREST	VOL		0.80	015	-0.74 to +0.57
5	36	04/96 RFO	SPECIAL INTEREST	VOL		0.17	008	+0.81
6	5	04/96 RFO	SPECIAL INTEREST	SAI		0.22	012	-16.23
		04/96 RFO	SPECIAL INTEREST	SAI		0.24	015	-1.23
		04/96 RFO	SPECIAL INTEREST	SAI		0.29	012	-15.43
7	4	04/96 RFO	SPECIAL INTEREST	VOL		1.71	UTS	-4.59
7	15	04/96 RFO	SPECIAL INTEREST	VOL		1.29	LTS	+10.35
7	45	04/96 RFO	SPECIAL INTEREST	VOL		0.27	008	-0.48
8	15	04/96 RFO	SPECIAL INTEREST	VOL		1.15	UTS	-30.00 to -13.94
8	40	04/96 RFO	SPECIAL INTEREST	VOL		0.51	009	+0.63
9	47	04/96 RFO	SPECIAL INTEREST	VOL		1.37	007	+12.30
10	3	04/96 RFO	SPECIAL INTEREST	VOL		1.21	009	-4.17
10	4	04/96 RFO	SPECIAL INTEREST	VOL		1.82	001	+20.53
10	63	04/96 RFO	SPECIAL INTEREST	VOL		0.23	010	+0.14
		04/96 RFO	SPECIAL INTEREST	VOL		0.37	010	+0.55
11	67	04/96 RFO	SPECIAL INTEREST	VOL		0.48	011	+0.77
11	68	04/96 RFO	SPECIAL INTEREST	VOL		0.41	015	-3.97
12	1	04/96 RFO	SPECIAL INTEREST	WAR	16	0.72	014	+0.00
13	69	04/96 RFO	SPECIAL INTEREST	VOL		0.63	009	+9.74
14	1	04/96 RFO	SPECIAL INTEREST	VOL		0.20	013	-0.58
		04/96 RFO	SPECIAL INTEREST	VOL		0.24	009	+0.60
14	14	04/96 RFO	SPECIAL INTEREST	VOL		0.70	015	+10.73
14	25	04/96 RFO	SPECIAL INTEREST	VOL		0.42	001	+4.37
15	3	04/96 RFO	SPECIAL INTEREST	VOL		1.16	013	+8.75
15	15	04/96 RFO	SPECIAL INTEREST	VOL		0.98	012	+13.29
15	27	04/96 RFO	SPECIAL INTEREST	VOL		0.95	015	+6.99
16	1	04/96 RFO	SPECIAL INTEREST	VOL		0.24	010	+0.41
16	52	04/96 RFO	SPECIAL INTEREST	MAI		0.37	012	+6.00 to +7.50
16	78	04/96 RFO	SPECIAL INTEREST	VOL		0.56	010	+18.95
		04/96 RFO	SPECIAL INTEREST	MAI		0.10	015	-7.86 to -6.71
16	81	04/96 RFO	SPECIAL INTEREST	VOL		0.99	015	-3.65 to -1.55
17	11	04/96 RFO	SPECIAL INTEREST	VOL		0.51	013	+11.36
17	77	04/96 RFO	SPECIAL INTEREST	SAI		0.23	014	-13.46
		04/96 RFO	SPECIAL INTEREST	VOL		0.76	008	+9.86
17	79	04/96 RFO	SPECIAL INTEREST	VOL		0.17	010	+0.00

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
17	81	04/96 RFO	SPECIAL INTEREST	VOL		0.63 015	-3.90 to -1.20	015
17	82	04/96 RFO	SPECIAL INTEREST	VOL		0.68 015	-2.62	015
		04/96 RFO	SPECIAL INTEREST	VOL		0.69 015	-1.85	015
18	14	04/96 RFO	SPECIAL INTEREST	VOL		1.17 012	-1.88	012
		04/96 RFO	SPECIAL INTEREST	VOL		1.47 012	-7.76	012
18	55	04/96 RFO	SPECIAL INTEREST	VOL		1.05 007	-3.35	007
18	57	04/96 RFO	SPECIAL INTEREST	VOL		0.40 007	-4.86 to -1.78	007
18	62	04/96 RFO	SPECIAL INTEREST	NQI		1.24 015	-5.78	015
		04/96 RFO	SPECIAL INTEREST	NQI		1.40 013	-17.15	013
19	34	04/96 RFO	SPECIAL INTEREST	VOL		1.60 003	+9.61	003
20	53	04/96 RFO	SPECIAL INTEREST	SAI		0.09 010	+14.50	010
20	78	04/96 RFO	SPECIAL INTEREST	MAI		0.18 015	-20.99 to -19.21	015
21	24	04/96 RFO	SPECIAL INTEREST	VOL		0.71 001	+4.16 to +6.40	001
21	80	04/96 RFO	SPECIAL INTEREST	VOL		0.54 007	+10.55	007
21	87	04/96 RFO	SPECIAL INTEREST	VOL		1.07 009	+8.27 to +14.11	009
22	1	04/96 RFO	SPECIAL INTEREST	VOL		1.18 010	+2.77	010
22	46	04/96 RFO	SPECIAL INTEREST	VOL		0.35 012	-0.49	012
22	58	04/96 RFO	SPECIAL INTEREST	VOL		1.10 001	-14.49	001
22	86	04/96 RFO	SPECIAL INTEREST	WAR	26	2.26 009	+0.00	009
22	90	04/96 RFO	SPECIAL INTEREST	VOL		0.18 010	+0.61	010
23	12	04/96 RFO	SPECIAL INTEREST	VOL		1.21 UTS	+5.49	UTS
23	41	04/96 RFO	SPECIAL INTEREST	VOL		1.46 007	+0.14	007
23	92	04/96 RFO	SPECIAL INTEREST	VOL		0.28 010	+0.59	010
24	36	04/96 RFO	SPECIAL INTEREST	WAR	6	0.30 012	+0.65	012
24	47	04/96 RFO	SPECIAL INTEREST	WAR	6	0.29 007	+0.00	007
25	3	04/96 RFO	SPECIAL INTEREST	VOL		0.28 010	+0.63	010
25	6	04/96 RFO	SPECIAL INTEREST	VOL		0.23 009	-0.59	009
		04/96 RFO	SPECIAL INTEREST	WAR	25	1.29 009	+0.00	009
25	40	04/96 RFO	SPECIAL INTEREST	VOL		1.01 015	+7.72	015
25	65	04/96 RFO	SPECIAL INTEREST	VOL		1.14 UTS	+19.18	UTE
25	94	04/96 RFO	SPECIAL INTEREST	VOL		0.36 009	-0.64	009
25	95	04/96 RFO	SPECIAL INTEREST	WAR	9	0.16 009	+0.00	009
25	98	04/96 RFO	SPECIAL INTEREST	SAI		0.43 015	-3.12 to -1.18	015
26	17	04/96 RFO	SPECIAL INTEREST	VOL		0.25 009	+20.36	009
26	30	04/96 RFO	SPECIAL INTEREST	VOL		0.15 007	-0.17	007
		04/96 RFO	SPECIAL INTEREST	VOL		0.18 007	+0.42	007
26	93	04/96 RFO	SPECIAL INTEREST	VOL		0.22 015	+2.69	015
26	94	04/96 RFO	SPECIAL INTEREST	VOL		0.44 009	+0.63	009
		04/96 RFO	SPECIAL INTEREST	VOL		0.45 009	-0.66	009
26	96	04/96 RFO	SPECIAL INTEREST	WAR	11	0.54 009	+0.00	009
		04/96 RFO	SPECIAL INTEREST	VOL		0.78 008	+11.58 to +28.23	008
27	93	04/96 RFO	SPECIAL INTEREST	VOL		0.32 007	-8.02 to -1.66	007
27	94	04/96 RFO	SPECIAL INTEREST	VOL		0.44 007	-7.90 to -1.04	007
27	98	04/96 RFO	SPECIAL INTEREST	WAR	10	0.46 009	+0.00	009
		04/96 RFO	SPECIAL INTEREST	VOL		0.42 008	+9.58 to +13.84	008
28	7	04/96 RFO	SPECIAL INTEREST	VOL		0.20 007	-0.44	007
28	16	04/96 RFO	SPECIAL INTEREST	VOL		1.78 LTS	-8.94	LTS
28	66	04/96 RFO	SPECIAL INTEREST	VOL		0.14 002	+0.74	002
28	79	04/96 RFO	SPECIAL INTEREST	VOL		1.33 004	-2.71	004
28	98	04/96 RFO	SPECIAL INTEREST	WAR	19	0.80 009	+0.00	009
29	8	04/96 RFO	SPECIAL INTEREST	VOL		0.32 009	-0.52	009
		04/96 RFO	SPECIAL INTEREST	VOL		0.42 009	+0.63	009
29	89	04/96 RFO	SPECIAL INTEREST	VOL		0.36 009	+23.51	009
29	98	04/96 RFO	SPECIAL INTEREST	VOL		0.39 015	+20.52	015
30	100	04/96 RFO	SPECIAL INTEREST	WAR	9	0.33 007	+0.00	007
		04/96 RFO	SPECIAL INTEREST	VOL		0.85 007	-8.02 to -0.89	007
31	45	04/96 RFO	SPECIAL INTEREST	VOL		0.35 007	-0.50	007
31	46	04/96 RFO	SPECIAL INTEREST	WAR	11	0.56 012	+0.00	012
32	24	04/96 RFO	SPECIAL INTEREST	VOL		0.19 008	-10.03	008
		04/96 RFO	SPECIAL INTEREST	VOL		0.23 015	+19.70	015
		04/96 RFO	SPECIAL INTEREST	VOL		0.40 011	-11.38	011
		04/96 RFO	SPECIAL INTEREST	VOL		0.64 007	-4.58	007
32	36	04/96 RFO	SPECIAL INTEREST	VOL		0.49 004	-16.11	004
		04/96 RFO	SPECIAL INTEREST	VOL		0.86 004	-14.68	004
32	39	04/96 RFO	SPECIAL INTEREST	VOL		2.86 007	-17.39	007

FTI TUBAN II (Version 2.3) 05/14/1996 09:43:16

Oconee Nuclear Station - Unit Two

S/G B

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 3 of 12

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
32	45	04/96 RFO	SPECIAL INTEREST	VOL		0.26	012 -0.48	012
32	50	04/96 RFO	SPECIAL INTEREST	VOL		1.28	002 -11.02	002
33	15	04/96 RFO	SPECIAL INTEREST	VOL		1.48	004 -3.55	004
33	28	04/96 RFO	SPECIAL INTEREST	VOL		0.25	003 +18.64	003
33	29	04/96 RFO	SPECIAL INTEREST	VOL		0.46	014 -5.56	014
		04/96 RFO	SPECIAL INTEREST	VOL		1.23	002 -16.83	002
33	33	04/96 RFO	SPECIAL INTEREST	SAI		0.05	012 -17.42	012
33	36	04/96 RFO	SPECIAL INTEREST	NQI		0.42	003 +22.50	003
33	37	04/96 RFO	SPECIAL INTEREST	WAR	14	0.70	007 +0.00	007
33	47	04/96 RFO	SPECIAL INTEREST	VOL		1.29	004 -14.40	004
33	48	04/96 RFO	SPECIAL INTEREST	VOL		0.28	012 -0.28	012
33	104	04/96 RFO	SPECIAL INTEREST	SAI		0.26	015 +12.47	015
33	107	04/96 RFO	SPECIAL INTEREST	VOL		2.29	007 +13.98	007
33	108	04/96 RFO	SPECIAL INTEREST	SAI		0.15	015 -2.01 to -1.28	015
34	16	04/96 RFO	SPECIAL INTEREST	VOL		2.08	003 +23.12	003
34	42	04/96 RFO	SPECIAL INTEREST	VOL		0.60	UTS -2.85 to -0.29	UTS
34	58	04/96 RFO	SPECIAL INTEREST	VOL		0.19	015 -11.33	015
34	107	04/96 RFO	SPECIAL INTEREST	SAI		0.27	015 -1.95	015
		04/96 RFO	SPECIAL INTEREST	VOL		0.49	010 -0.74	010
35	2	04/96 RFO	SPECIAL INTEREST	WAR	9	0.45	010 +0.00	010
35	28	04/96 RFO	SPECIAL INTEREST	VOL		0.62	001 -9.03	001
		04/96 RFO	SPECIAL INTEREST	VOL		0.76	001 -9.97	001
		04/96 RFO	SPECIAL INTEREST	VOL		0.92	001 -7.66	001
35	95	04/96 RFO	SPECIAL INTEREST	VOL		0.17	015 +0.82	015
36	10	04/96 RFO	SPECIAL INTEREST	VOL		0.79	005 -4.17	005
36	31	04/96 RFO	SPECIAL INTEREST	VOL		0.21	012 -0.43	012
		04/96 RFO	SPECIAL INTEREST	WAR	10	0.51	012 +0.00	012
36	39	04/96 RFO	SPECIAL INTEREST	WAR	6	0.30	014 +0.00	014
36	43	04/96 RFO	SPECIAL INTEREST	WAR	10	0.43	012 +0.00	012
36	81	04/96 RFO	SPECIAL INTEREST	VOL		0.45	015 +18.48	015
36	113	04/96 RFO	SPECIAL INTEREST	SAI		0.11	015 -2.97	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.26	015 -1.23	015
37	4	04/96 RFO	SPECIAL INTEREST	WAR	10	0.51	009 +0.00	009
37	6	04/96 RFO	SPECIAL INTEREST	VOL		0.61	009 +14.47	009
37	30	04/96 RFO	SPECIAL INTEREST	VOL		0.22	UTS -8.18	UTS
37	31	04/96 RFO	SPECIAL INTEREST	VOL		0.25	LTS +5.91	LTS
37	35	04/96 RFO	SPECIAL INTEREST	SAI		0.25	014 +16.85	014
38	51	04/96 RFO	SPECIAL INTEREST	WAR	8	0.43	006 +0.00	006
38	85	04/96 RFO	SPECIAL INTEREST	SAI		0.13	014 +3.82	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.60	014 +14.25	014
38	86	04/96 RFO	SPECIAL INTEREST	VOL		0.61	001 -6.66	001
38	111	04/96 RFO	SPECIAL INTEREST	VOL		0.36	015 +13.57	015
39	25	04/96 RFO	SPECIAL INTEREST	VOL		0.33	011 +14.47	011
39	32	04/96 RFO	SPECIAL INTEREST	WAR	9	0.48	007 +0.00	007
39	33	04/96 RFO	SPECIAL INTEREST	VOL		0.24	012 +0.30	012
39	116	04/96 RFO	SPECIAL INTEREST	SAI		0.16	015 -2.41	015
40	25	04/96 RFO	SPECIAL INTEREST	VOL		0.12	UTS -9.76	UTS
		04/96 RFO	SPECIAL INTEREST	VOL		0.91	UTS -11.11	UTS
		04/96 RFO	SPECIAL INTEREST	VOL		2.59	004 -13.96	004
40	68	04/96 RFO	SPECIAL INTEREST	VOL		0.64	013 -15.03	013
40	87	04/96 RFO	SPECIAL INTEREST	SAI		0.45	010 +6.34	010
		04/96 RFO	SPECIAL INTEREST	SAI		0.50	011 -8.42	011
41	18	04/96 RFO	SPECIAL INTEREST	VOL		0.59	006 +18.72	006
41	38	04/96 RFO	SPECIAL INTEREST	VOL		0.28	007 -0.48	007
41	76	04/96 RFO	SPECIAL INTEREST	VOL		0.52	LTS -6.03	LTS
42	33	04/96 RFO	SPECIAL INTEREST	VOL		0.48	001 +10.22	001
42	35	04/96 RFO	SPECIAL INTEREST	VOL		0.21	012 +0.04	012
		04/96 RFO	SPECIAL INTEREST	VOL		0.26	012 +0.05	012
43	31	04/96 RFO	SPECIAL INTEREST	VOL		0.75	008 +11.81	008
43	87	04/96 RFO	SPECIAL INTEREST	SAI		0.24	UTS -11.96	UTS
44	38	04/96 RFO	SPECIAL INTEREST	VOL		0.50	015 -3.57	015
44	53	04/96 RFO	SPECIAL INTEREST	SAI		0.18	015 +5.85	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.24	011 +20.87	011
44	82	04/96 RFO	SPECIAL INTEREST	VOL		0.16	012 +0.13	012
44	87	04/96 RFO	SPECIAL INTEREST	SAI		0.15	013 +2.61	013

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
44	96	04/96 RFO	SPECIAL INTEREST	SAI		0.41 015	+15.79 to +17.55	015
45	3	04/96 RFO	SPECIAL INTEREST	WAR	9	0.49 009	+0.00	009
45	9	04/96 RFO	SPECIAL INTEREST	VOL		0.45 007	-5.77	007
45	27	04/96 RFO	SPECIAL INTEREST	VOL		0.78 015	+16.52	015
45	32	04/96 RFO	SPECIAL INTEREST	VOL		0.35 014	-0.16	014
45	49	04/96 RFO	SPECIAL INTEREST	VOL		0.32 001	-21.25	001
		04/96 RFO	SPECIAL INTEREST	VOL		0.38 007	-18.34	007
		04/96 RFO	SPECIAL INTEREST	VOL		0.58 001	-19.09	001
45	65	04/96 RFO	SPECIAL INTEREST	VOL		2.26 UTS	+19.32	UTS
45	120	04/96 RFO	SPECIAL INTEREST	SAI		0.33 010	+9.04	010
		04/96 RFO	SPECIAL INTEREST	SAI		0.14 015	-3.09 to -0.98	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.24 013	-12.46 to -8.72	013
46	2	04/96 RFO	SPECIAL INTEREST	WAR	7	0.29 010	+0.00	010
		04/96 RFO	SPECIAL INTEREST	WAR	8	0.33 010	+0.00	010
46	27	04/96 RFO	SPECIAL INTEREST	VOL		1.50 015	+19.20	015
46	81	04/96 RFO	SPECIAL INTEREST	WAR	6	0.26 012	+0.00	012
47	41	04/96 RFO	SPECIAL INTEREST	VOL		0.79 008	-10.46	008
47	55	04/96 RFO	SPECIAL INTEREST	VOL		0.72 014	-5.84	014
47	59	04/96 RFO	SPECIAL INTEREST	VOL		0.95 006	-0.63	006
47	70	04/96 RFO	SPECIAL INTEREST	WAR	14	0.53 012	+0.00	012
47	106	04/96 RFO	SPECIAL INTEREST	WAR	5	0.22 007	+0.00	007
48	39	04/96 RFO	SPECIAL INTEREST	VOL		1.66 004	-1.68	004
48	43	04/96 RFO	SPECIAL INTEREST	VOL		0.44 UTS	-1.93	UTS
48	121	04/96 RFO	SPECIAL INTEREST	VOL		0.45 008	+6.12	008
49	53	04/96 RFO	SPECIAL INTEREST	VOL		0.29 012	+0.32	012
49	99	04/96 RFO	SPECIAL INTEREST	SAI		0.64 014	+3.91	014
		04/96 RFO	SPECIAL INTEREST	SAI		0.70 014	+4.76	014
50	32	04/96 RFO	SPECIAL INTEREST	VOL		7.70 004	+1.05	004
50	55	04/96 RFO	SPECIAL INTEREST	VOL		1.52 011	+5.18	011
50	122	04/96 RFO	SPECIAL INTEREST	WAR	15	0.79 009	+0.00	009
51	27	04/96 RFO	SPECIAL INTEREST	SAI		0.06 014	+10.69	014
		04/96 RFO	SPECIAL INTEREST	VOL		0.26 UTS	-2.96	UTS
		04/96 RFO	SPECIAL INTEREST	VOL		0.41 014	+17.19	014
		04/96 RFO	SPECIAL INTEREST	VOL		0.45 015	+13.88	015
		04/96 RFO	SPECIAL INTEREST	VOL		1.19 UTS	-5.66	UTS
51	29	04/96 RFO	SPECIAL INTEREST	VOL		1.03 015	+9.43	015
51	42	04/96 RFO	SPECIAL INTEREST	VOL		0.27 004	+7.58	004
		04/96 RFO	SPECIAL INTEREST	VOL		0.58 004	-17.08	004
51	60	04/96 RFO	SPECIAL INTEREST	NQI		0.54 003	-6.30	003
		04/96 RFO	SPECIAL INTEREST	NQI		0.90 003	-5.16	003
51	108	04/96 RFO	SPECIAL INTEREST	WAR	6	0.25 007	+0.00	007
51	112	04/96 RFO	SPECIAL INTEREST	VOL		0.30 002	-6.87	002
		04/96 RFO	SPECIAL INTEREST	VOL		0.46 002	-7.98	002
		04/96 RFO	SPECIAL INTEREST	VOL		1.89 004	-6.53	004
51	118	04/96 RFO	SPECIAL INTEREST	VOL		0.38 007	-6.80	007
52	2	04/96 RFO	SPECIAL INTEREST	SAI		0.16 013	-4.67	013
		04/96 RFO	SPECIAL INTEREST	SAI		0.37 013	-0.87	013
		04/96 RFO	SPECIAL INTEREST	MAI		0.26 011	+1.30 to +35.91	011
		04/96 RFO	SPECIAL INTEREST	MAI		0.30 010	+9.25 to +34.49	010
		04/96 RFO	SPECIAL INTEREST	MAI		1.18 015	+12.13 to +45.22	015
52	26	04/96 RFO	SPECIAL INTEREST	VOL		1.30 015	+8.20	015
52	36	04/96 RFO	SPECIAL INTEREST	VOL		1.27 002	+8.08	002
52	41	04/96 RFO	SPECIAL INTEREST	SAI		0.12 UTS	-8.12	UTS
52	44	04/96 RFO	SPECIAL INTEREST	VOL		0.20 007	+0.51	007
52	49	04/96 RFO	SPECIAL INTEREST	VOL		0.86 002	+4.91	002
52	65	04/96 RFO	SPECIAL INTEREST	NQI		0.38 013	+8.34	013
		04/96 RFO	SPECIAL INTEREST	NQI		0.71 013	+6.74	013
		04/96 RFO	SPECIAL INTEREST	NQI		1.12 013	+13.19	013
52	113	04/96 RFO	SPECIAL INTEREST	VOL		0.60 005	+7.07	005
53	6	04/96 RFO	SPECIAL INTEREST	VOL		0.86 001	-3.85	001
53	34	04/96 RFO	SPECIAL INTEREST	VOL		2.18 001	-12.75	001
53	35	04/96 RFO	SPECIAL INTEREST	VOL		0.36 015	+14.16 to +15.18	015
53	57	04/96 RFO	SPECIAL INTEREST	VOL		1.04 002	-7.79	002
53	100	04/96 RFO	SPECIAL INTEREST	VOL		1.35 UTS	-20.40	UTS
53	112	04/96 RFO	SPECIAL INTEREST	NQI		0.44 001	+14.88	001

FTI TUBAN II (Version 2.3) 05/14/1996 09:43:16

Oconee Nuclear Station - Unit Two

S/G B

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 5 of 12

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	SPECIAL INTEREST	NQI		0.54	001	+11.24 001
54	77	04/96 RFO	SPECIAL INTEREST	VOL		1.73	UTS	-17.76 UTS
54	103	04/96 RFO	SPECIAL INTEREST	VOL		0.38	012	+0.25 012
54	113	04/96 RFO	SPECIAL INTEREST	NQI		0.13	002	+2.90 002
		04/96 RFO	SPECIAL INTEREST	NQI		0.26	004	+9.03 004
		04/96 RFO	SPECIAL INTEREST	NQI		0.76	004	-8.91 004
54	114	04/96 RFO	SPECIAL INTEREST	VOL		0.34	014	+10.87 014
		04/96 RFO	SPECIAL INTEREST	VOL		0.72	015	+3.29 015
		04/96 RFO	SPECIAL INTEREST	VOL		1.46	015	+29.38 015
54	125	04/96 RFO	SPECIAL INTEREST	VOL		0.24	009	+0.48 009
55	103	04/96 RFO	SPECIAL INTEREST	VOL		0.23	007	-0.36 007
		04/96 RFO	SPECIAL INTEREST	VOL		0.30	007	-0.31 007
55	123	04/96 RFO	SPECIAL INTEREST	VOL		1.24	002	+1.42 002
56	3	04/96 RFO	SPECIAL INTEREST	SAI		0.57	011	+10.69 011
56	5	04/96 RFO	SPECIAL INTEREST	VOL		1.22	012	+6.32 012
56	34	04/96 RFO	SPECIAL INTEREST	VOL		0.31	013	-13.22 013
56	61	04/96 RFO	SPECIAL INTEREST	VOL		0.22	007	-15.28 007
56	79	04/96 RFO	SPECIAL INTEREST	VOL		1.22	001	+10.40 001
		04/96 RFO	SPECIAL INTEREST	VOL		1.92	001	+7.17 001
56	96	04/96 RFO	SPECIAL INTEREST	VOL		1.24	UTS	-22.71 UTS
		04/96 RFO	SPECIAL INTEREST	VOL		1.28	UTS	-11.24 UTS
		04/96 RFO	SPECIAL INTEREST	VOL		1.28	UTS	+0.31 to +1.53 UTS
		04/96 RFO	SPECIAL INTEREST	VOL		2.01	UTS	-5.20 to -0.84 UTS
56	112	04/96 RFO	SPECIAL INTEREST	VOL		0.91	004	-10.90 004
57	44	04/96 RFO	SPECIAL INTEREST	VOL		0.43	006	+6.42 006
57	55	04/96 RFO	SPECIAL INTEREST	VOL		0.25	007	+1.99 007
57	69	04/96 RFO	SPECIAL INTEREST	VOL		0.97	012	-0.66 012
57	122	04/96 RFO	SPECIAL INTEREST	VOL		0.64	005	+10.38 005
58	1	04/96 RFO	SPECIAL INTEREST	VOL		0.26	009	-0.78 009
58	104	04/96 RFO	SPECIAL INTEREST	VOL		0.88	007	-3.71 007
58	111	04/96 RFO	SPECIAL INTEREST	VOL		1.12	004	+7.31 004
59	108	04/96 RFO	SPECIAL INTEREST	VOL		0.19	001	+4.69 001
60	4	04/96 RFO	SPECIAL INTEREST	SAI		0.56	013	-7.72 to -4.86 013
60	35	04/96 RFO	SPECIAL INTEREST	VOL		0.84	014	-13.33 014
60	112	04/96 RFO	SPECIAL INTEREST	VOL		0.28	015	+0.89 015
60	126	04/96 RFO	SPECIAL INTEREST	VOL		1.86	008	+8.12 008
61	29	04/96 RFO	SPECIAL INTEREST	VOL		0.78	015	+5.90 015
		04/96 RFO	SPECIAL INTEREST	VOL		0.98	015	+8.55 015
		04/96 RFO	SPECIAL INTEREST	VOL		1.24	015	+11.94 015
61	35	04/96 RFO	SPECIAL INTEREST	VOL		2.94	005	+6.17 005
61	36	04/96 RFO	SPECIAL INTEREST	VOL		0.30	007	-0.45 007
61	47	04/96 RFO	SPECIAL INTEREST	WAR	15	0.76	004	+0.00 004
61	69	04/96 RFO	SPECIAL INTEREST	VOL		0.20	012	+0.60 012
61	99	04/96 RFO	SPECIAL INTEREST	SAI		0.51	014	+6.50 014
61	124	04/96 RFO	SPECIAL INTEREST	SAI		0.64	015	+21.68 UTS
		04/96 RFO	SPECIAL INTEREST	VOL		0.46	009	+0.70 009
		04/96 RFO	SPECIAL INTEREST	SAI		0.71	015	+3.41 to +5.72 015
62	2	04/96 RFO	SPECIAL INTEREST	VOL		0.34	008	+8.08 008
62	24	04/96 RFO	SPECIAL INTEREST	VOL		0.33	012	+0.51 012
62	49	04/96 RFO	SPECIAL INTEREST	VOL		2.31	UTS	+14.56 UTS
62	71	04/96 RFO	SPECIAL INTEREST	VOL		0.24	012	+0.00 012
62	98	04/96 RFO	SPECIAL INTEREST	SAI		0.33	013	+18.52 013
		04/96 RFO	SPECIAL INTEREST	MAI		0.11	013	-8.88 to -7.80 013
		04/96 RFO	SPECIAL INTEREST	SAI		0.50	015	-8.77 to -7.77 015
62	100	04/96 RFO	SPECIAL INTEREST	SAI		0.58	014	+12.71 014
62	113	04/96 RFO	SPECIAL INTEREST	VOL		0.30	015	+0.59 015
62	122	04/96 RFO	SPECIAL INTEREST	VOL		1.75	LTE	+11.73 LTS
62	127	04/96 RFO	SPECIAL INTEREST	VOL		0.33	009	+0.76 009
63	38	04/96 RFO	SPECIAL INTEREST	SAI		0.07	014	-4.24 014
		04/96 RFO	SPECIAL INTEREST	MAI		0.22	015	+0.53 to +37.97 015
63	59	04/96 RFO	SPECIAL INTEREST	VOL		0.21	012	+0.23 012
63	116	04/96 RFO	SPECIAL INTEREST	VOL		0.61	005	-0.32 005
63	128	04/96 RFO	SPECIAL INTEREST	WAR	15	1.27	009	+0.00 009
64	99	04/96 RFO	SPECIAL INTEREST	VOL		0.09	005	+1.21 005
64	124	04/96 RFO	SPECIAL INTEREST	VOL		1.42	009	-0.96 009

FTI TUBAN II (Version 2.3)

05/14/1996 09:43:16

Oconee Nuclear Station - Unit Two

S/G B

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 6 of 12

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
64	125	04/96 RFO	SPECIAL INTEREST	VOL		0.23 009	+0.53	009
		04/96 RFO	SPECIAL INTEREST	VOL		0.84 009	-0.88	009
65	1	04/96 RFO	SPECIAL INTEREST	VOL		0.43 012	+12.27	012
65	30	04/96 RFO	SPECIAL INTEREST	VOL		0.90 UTS	-4.91	UTS
65	37	04/96 RFO	SPECIAL INTEREST	SAI		0.30 015	+20.57	UTS
		04/96 RFO	SPECIAL INTEREST	VOL		0.45 015	+3.74	UTS
		04/96 RFO	SPECIAL INTEREST	VOL		0.60 014	+1.13	014
65	93	04/96 RFO	SPECIAL INTEREST	VOL		0.36 006	+10.88	006
65	115	04/96 RFO	SPECIAL INTEREST	SAI		0.10 UTS	-5.61	UTS
65	127	04/96 RFO	SPECIAL INTEREST	WAR	16	1.10 009	+0.00	009
		04/96 RFO	SPECIAL INTEREST	WAR	17	1.21 009	+0.00	009
65	129	04/96 RFO	SPECIAL INTEREST	VOL		0.10 010	+0.43	010
65	130	04/96 RFO	SPECIAL INTEREST	VOL		0.04 003	-19.63	003
		04/96 RFO	SPECIAL INTEREST	VOL		0.30 003	-18.14	003
		04/96 RFO	SPECIAL INTEREST	VOL		0.32 011	-0.71	011
66	33	04/96 RFO	SPECIAL INTEREST	SAI		0.14 011	+18.00	011
		04/96 RFO	SPECIAL INTEREST	SAI		0.15 010	+6.73	010
66	78	04/96 RFO	SPECIAL INTEREST	VOL		1.96 013	-9.75	013
67	5	04/96 RFO	SPECIAL INTEREST	MAI		0.11 012	+19.49 to +21.69	013
67	113	04/96 RFO	SPECIAL INTEREST	WAR	15	1.03 015	+0.00	015
67	126	04/96 RFO	SPECIAL INTEREST	WAR	16	1.08 009	+0.00	009
68	112	04/96 RFO	SPECIAL INTEREST	WAR	7	0.36 015	+0.00	015
68	113	04/96 RFO	SPECIAL INTEREST	VOL		0.42 015	-0.02	015
69	4	04/96 RFO	SPECIAL INTEREST	WAR	13	0.60 009	+0.00	009
69	8	04/96 RFO	SPECIAL INTEREST	WAR	17	0.96 008	+0.00	008
69	24	04/96 RFO	SPECIAL INTEREST	VOL		0.22 003	+22.10	003
69	47	04/96 RFO	SPECIAL INTEREST	SAI		0.20 014	+18.03	014
69	70	04/96 RFO	SPECIAL INTEREST	MAI		0.50 012	-14.08 to -11.04	012
69	104	04/96 RFO	SPECIAL INTEREST	SAI		0.22 015	+7.56	015
69	110	04/96 RFO	SPECIAL INTEREST	MAI		0.11 013	-25.54 to -6.34	013
69	113	04/96 RFO	SPECIAL INTEREST	WAR	8	0.42 015	+0.00	015
69	120	04/96 RFO	SPECIAL INTEREST	WAR	7	0.25 007	+0.00	007
69	132	04/96 RFO	SPECIAL INTEREST	VOL		0.19 004	+14.55	004
70	4	04/96 RFO	SPECIAL INTEREST	WAR	8	0.33 009	+0.00	009
70	5	04/96 RFO	SPECIAL INTEREST	SAI		0.04 012	-9.69	012
70	27	04/96 RFO	SPECIAL INTEREST	VOL		0.98 015	+18.64	015
70	33	04/96 RFO	SPECIAL INTEREST	MAI		0.08 012	+17.05 to +20.07	012
70	44	04/96 RFO	SPECIAL INTEREST	SAI		0.14 015	+19.94	015
70	112	04/96 RFO	SPECIAL INTEREST	MAI		0.26 008	+3.85 to +35.75	008
70	130	04/96 RFO	SPECIAL INTEREST	MAI		0.28 011	+14.56 to +19.66	011
71	86	04/96 RFO	SPECIAL INTEREST	VOL		0.22 011	+13.60	011
71	99	04/96 RFO	SPECIAL INTEREST	VOL		0.78 015	+2.80	015
72	6	04/96 RFO	SPECIAL INTEREST	VOL		0.85 010	+1.95	010
72	7	04/96 RFO	SPECIAL INTEREST	WAR	8	0.35 009	+0.00	009
72	47	04/96 RFO	SPECIAL INTEREST	MAI		0.26 015	+23.70 to +36.05	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.46 015	+4.13 to +6.65	015
72	65	04/96 RFO	SPECIAL INTEREST	VOL		2.32 UTS	-12.19 to -10.25	UTS
73	3	04/96 RFO	SPECIAL INTEREST	VOL		0.36 010	+0.69	010
73	114	04/96 RFO	SPECIAL INTEREST	VOL		0.22 015	+6.73	015
		04/96 RFO	SPECIAL INTEREST	VOL		0.30 015	+16.34	015
73	127	04/96 RFO	SPECIAL INTEREST	WAR	29	1.94 009	+0.00	009
73	128	04/96 RFO	SPECIAL INTEREST	WAR	4	0.29 009	+0.00	009
74	63	04/96 RFO	SPECIAL INTEREST	VOL		0.38 014	+32.55	014
74	77	04/96 RFO	SPECIAL INTEREST	VOL		0.07 015	+3.49	015
74	123	04/96 RFO	SPECIAL INTEREST	VOL		0.10 010	+18.36	010
		04/96 RFO	SPECIAL INTEREST	MAI		0.06 012	+16.68 to +18.18	012
		04/96 RFO	SPECIAL INTEREST	MAI		0.10 014	+4.18 to +13.73	014
74	124	04/96 RFO	SPECIAL INTEREST	SAI		0.50 015	-0.43	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.58 015	-0.66	015
		04/96 RFO	SPECIAL INTEREST	VOL		0.73 008	+11.69 to +16.56	008
75	124	04/96 RFO	SPECIAL INTEREST	MAI		0.16 013	+14.42 to +16.20	013
		04/96 RFO	SPECIAL INTEREST	MAI		0.16 013	+20.16 to +23.41	013
		04/96 RFO	SPECIAL INTEREST	MAI		0.39 014	+10.10 to +28.28	014
		04/96 RFO	SPECIAL INTEREST	MAI		0.46 014	+1.42 to +8.39	014
75	125	04/96 RFO	SPECIAL INTEREST	VOL		0.36 009	+1.05	009

FTI TUBAN II (Version 2.3) 05/14/1996 09:43:16

Oconee Nuclear Station - Unit Two

S/G B

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 7 of 12

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	SPECIAL INTEREST	SAI		0.13	012	-14.54 to -13.03
76	75	04/96 RFO	SPECIAL INTEREST	SAI		0.43	013	-1.82
76	95	04/96 RFO	SPECIAL INTEREST	SAI		0.24	011	+6.01
		04/96 RFO	SPECIAL INTEREST	SAI		0.44	011	+22.68
		04/96 RFO	SPECIAL INTEREST	MAI		0.18	010	+1.72 to +3.52
78	67	04/96 RFO	SPECIAL INTEREST	NQI		1.97	014	+24.16
78	90	04/96 RFO	SPECIAL INTEREST	SAI		0.11	014	+18.50
79	34	04/96 RFO	SPECIAL INTEREST	SAI		0.27	UTS	-8.63
79	80	04/96 RFO	SPECIAL INTEREST	VOL		1.13	008	-11.61
80	41	04/96 RFO	SPECIAL INTEREST	WAR	5	0.21	009	+0.00
80	114	04/96 RFO	SPECIAL INTEREST	VOL		0.45	UTE	-8.85
81	4	04/96 RFO	SPECIAL INTEREST	VOL		1.05	010	+6.04
81	6	04/96 RFO	SPECIAL INTEREST	VOL		0.38	010	+4.51
81	37	04/96 RFO	SPECIAL INTEREST	VOL		0.36	003	+20.07
81	53	04/96 RFO	SPECIAL INTEREST	VOL		11.90	015	-3.76
81	54	04/96 RFO	SPECIAL INTEREST	VOL		0.62	012	+0.68
81	126	04/96 RFO	SPECIAL INTEREST	VOL		1.70	007	+17.99
82	4	04/96 RFO	SPECIAL INTEREST	VOL		0.38	010	+2.71 to +7.89
82	5	04/96 RFO	SPECIAL INTEREST	VOL		0.46	010	+3.08
		04/96 RFO	SPECIAL INTEREST	VOL		0.32	010	+2.76 to +3.35
82	6	04/96 RFO	SPECIAL INTEREST	VOL		0.57	010	-12.05
		04/96 RFO	SPECIAL INTEREST	VOL		0.67	010	-10.98
82	100	04/96 RFO	SPECIAL INTEREST	VOL		0.39	002	+13.12
82	101	04/96 RFO	SPECIAL INTEREST	VOL		0.50	012	+0.48
83	33	04/96 RFO	SPECIAL INTEREST	SAI		0.15	015	+10.70
83	91	04/96 RFO	SPECIAL INTEREST	VOL		3.28	UTS	+6.70
		04/96 RFO	SPECIAL INTEREST	VOL		5.06	UTS	+16.61
83	112	04/96 RFO	SPECIAL INTEREST	SAI		0.10	008	+12.16
83	124	04/96 RFO	SPECIAL INTEREST	SAI		0.23	014	+16.40
83	127	04/96 RFO	SPECIAL INTEREST	NQI		0.20	015	-0.30
		04/96 RFO	SPECIAL INTEREST	NQI		0.35	015	-0.02
83	132	04/96 RFO	SPECIAL INTEREST	VOL		0.37	010	+4.12
84	100	04/96 RFO	SPECIAL INTEREST	VOL		0.23	012	+0.16
85	5	04/96 RFO	SPECIAL INTEREST	VOL		1.31	009	+19.10 to +25.02
85	29	04/96 RFO	SPECIAL INTEREST	VOL		0.35	015	+6.04
85	70	04/96 RFO	SPECIAL INTEREST	VOL		0.28	012	+0.08
85	107	04/96 RFO	SPECIAL INTEREST	VOL		0.16	012	-0.43
85	119	04/96 RFO	SPECIAL INTEREST	VOL		0.40	007	-0.15
86	5	04/96 RFO	SPECIAL INTEREST	VOL		0.64	013	-12.87 to -7.28
86	28	04/96 RFO	SPECIAL INTEREST	VOL		0.10	007	-3.24
86	42	04/96 RFO	SPECIAL INTEREST	VOL		0.66	012	+0.75
86	71	04/96 RFO	SPECIAL INTEREST	VOL		0.43	013	-15.86
86	80	04/96 RFO	SPECIAL INTEREST	MAI		0.19	013	-9.52 to -7.49
86	126	04/96 RFO	SPECIAL INTEREST	VOL		0.59	007	-7.40
87	123	04/96 RFO	SPECIAL INTEREST	NQI		0.89	015	-6.82
		04/96 RFO	SPECIAL INTEREST	VOL		1.16	015	-7.80 to -6.01
87	124	04/96 RFO	SPECIAL INTEREST	VOL		1.23	UTS	-0.82
87	125	04/96 RFO	SPECIAL INTEREST	SAI		0.18	013	-1.97
		04/96 RFO	SPECIAL INTEREST	MAI		0.30	009	-19.30 to -13.50
88	4	04/96 RFO	SPECIAL INTEREST	VOL		0.18	010	-11.94
88	95	04/96 RFO	SPECIAL INTEREST	SAI		0.25	014	-8.57
88	96	04/96 RFO	SPECIAL INTEREST	SAI		0.58	014	-10.90
88	106	04/96 RFO	SPECIAL INTEREST	SAI		0.50	014	+1.82
		04/96 RFO	SPECIAL INTEREST	MAI		0.41	010	+29.46 to +34.15
88	117	04/96 RFO	SPECIAL INTEREST	VOL		0.48	002	+5.91
88	123	04/96 RFO	SPECIAL INTEREST	NQI		0.23	015	+0.81
88	125	04/96 RFO	SPECIAL INTEREST	VOL		0.31	008	+0.63
89	100	04/96 RFO	SPECIAL INTEREST	VOL		0.13	012	+0.14
89	118	04/96 RFO	SPECIAL INTEREST	VOL		0.25	010	-0.16
90	3	04/96 RFO	SPECIAL INTEREST	SAI		0.39	010	+6.26
		04/96 RFO	SPECIAL INTEREST	MAI		0.44	013	+14.82 to +19.41
90	116	04/96 RFO	SPECIAL INTEREST	VOL		0.72	015	-6.99
91	63	04/96 RFO	SPECIAL INTEREST	VOL		2.02	014	+2.52
91	111	04/96 RFO	SPECIAL INTEREST	VOL		0.38	015	+28.11
		04/96 RFO	SPECIAL INTEREST	VOL		0.62	015	+26.90

FTI TUBAN II (Version 2.3) 05/14/1996 09:43:16

Oconee Nuclear Station - Unit Two

S/G B

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 8 of 12

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	SPECIAL INTEREST	VOL		0.96	015	015
91	119	04/96 RFO	SPECIAL INTEREST	VOL		0.72	013	013
92	33	04/96 RFO	SPECIAL INTEREST	VOL		1.08	013	013
92	44	04/96 RFO	SPECIAL INTEREST	SAI		0.12	010	010
92	94	04/96 RFO	SPECIAL INTEREST	WAR	6	0.35	006	006
93	5	04/96 RFO	SPECIAL INTEREST	WAR	11	0.53	009	009
93	96	04/96 RFO	SPECIAL INTEREST	VOL		1.37	001	001
93	122	04/96 RFO	SPECIAL INTEREST	VOL		0.67	008	008
94	3	04/96 RFO	SPECIAL INTEREST	SAI		0.24	011	011
		04/96 RFO	SPECIAL INTEREST	SAI		0.31	011	011
94	6	04/96 RFO	SPECIAL INTEREST	VOL		0.23	009	009
94	47	04/96 RFO	SPECIAL INTEREST	VOL		0.43	015	015
		04/96 RFO	SPECIAL INTEREST	VOL		1.37	015	015
95	87	04/96 RFO	SPECIAL INTEREST	VOL		0.26	006	006
96	18	04/96 RFO	SPECIAL INTEREST	VOL		0.65	003	003
96	25	04/96 RFO	SPECIAL INTEREST	VOL		0.32	012	012
		04/96 RFO	SPECIAL INTEREST	VOL		0.39	012	012
		04/96 RFO	SPECIAL INTEREST	MAI		0.23	014	014
		04/96 RFO	SPECIAL INTEREST	MAI		0.33	015	015
96	26	04/96 RFO	SPECIAL INTEREST	VOL		1.18	001	001
96	78	04/96 RFO	SPECIAL INTEREST	VOL		0.69	LTE	LTS
96	90	04/96 RFO	SPECIAL INTEREST	VOL		0.13	012	012
96	103	04/96 RFO	SPECIAL INTEREST	VOL		1.23	005	005
		04/96 RFO	SPECIAL INTEREST	WAR	10	0.62	004	004
		04/96 RFO	SPECIAL INTEREST	WAR	12	0.71	004	004
96	113	04/96 RFO	SPECIAL INTEREST	SAI		0.08	015	015
		04/96 RFO	SPECIAL INTEREST	SAI		0.15	015	015
97	60	04/96 RFO	SPECIAL INTEREST	SAI		0.29	014	014
97	110	04/96 RFO	SPECIAL INTEREST	VOL		0.41	015	015
98	3	04/96 RFO	SPECIAL INTEREST	VOL		0.38	009	009
98	24	04/96 RFO	SPECIAL INTEREST	SAI		0.33	011	011
98	42	04/96 RFO	SPECIAL INTEREST	VOL		1.56	007	007
98	43	04/96 RFO	SPECIAL INTEREST	VOL		0.53	UTS	UTS
98	47	04/96 RFO	SPECIAL INTEREST	SAI		0.11	013	013
98	97	04/96 RFO	SPECIAL INTEREST	VOL		2.11	005	005
98	126	04/96 RFO	SPECIAL INTEREST	VOL		0.56	UTS	UTS
99	58	04/96 RFO	SPECIAL INTEREST	WAR	7	0.29	012	012
100	34	04/96 RFO	SPECIAL INTEREST	VOL		0.35	013	013
100	39	04/96 RFO	SPECIAL INTEREST	VOL		2.05	002	002
100	64	04/96 RFO	SPECIAL INTEREST	VOL		0.76	001	001
100	99	04/96 RFO	SPECIAL INTEREST	VOL		0.42	015	015
100	123	04/96 RFO	SPECIAL INTEREST	VOL		1.80	014	014
101	3	04/96 RFO	SPECIAL INTEREST	WAR	10	0.48	008	008
101	70	04/96 RFO	SPECIAL INTEREST	WAR	8	0.40	015	015
101	84	04/96 RFO	SPECIAL INTEREST	VOL		0.29	014	014
101	117	04/96 RFO	SPECIAL INTEREST	VOL		0.57	001	001
102	5	04/96 RFO	SPECIAL INTEREST	VOL		0.19	007	007
		04/96 RFO	SPECIAL INTEREST	VOL		0.44	004	004
102	25	04/96 RFO	SPECIAL INTEREST	VOL		1.08	005	005
102	31	04/96 RFO	SPECIAL INTEREST	VOL		1.09	014	014
102	89	04/96 RFO	SPECIAL INTEREST	VOL		0.74	014	014
102	97	04/96 RFO	SPECIAL INTEREST	WAR	12	0.72	007	007
		04/96 RFO	SPECIAL INTEREST	WAR	15	0.92	007	007
102	113	04/96 RFO	SPECIAL INTEREST	VOL		0.31	003	003
		04/96 RFO	SPECIAL INTEREST	VOL		0.38	LTE	LTS
		04/96 RFO	SPECIAL INTEREST	VOL		0.50	001	001
102	114	04/96 RFO	SPECIAL INTEREST	VOL		0.19	002	002
102	118	04/96 RFO	SPECIAL INTEREST	VOL		0.28	LTS	LTS
102	121	04/96 RFO	SPECIAL INTEREST	VOL		0.09	008	008
		04/96 RFO	SPECIAL INTEREST	VOL		0.30	008	008
103	7	04/96 RFO	SPECIAL INTEREST	VOL		0.32	UTS	UTS
103	117	04/96 RFO	SPECIAL INTEREST	VOL		0.12	002	002
103	118	04/96 RFO	SPECIAL INTEREST	VOL		0.22	001	001
		04/96 RFO	SPECIAL INTEREST	VOL		0.44	005	005
		04/96 RFO	SPECIAL INTEREST	VOL		0.45	005	005

FTI TUBAN II (Version 2.3) 05/14/1996 09:43:16

Oconee Nuclear Station - Unit Two

S/G B

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 9 of 12

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		04/96 RFO	SPECIAL INTEREST	VOL		0.60	002	+2.58 002
103	122	04/96 RFO	SPECIAL INTEREST	VOL		0.25	001	+22.56 001
103	124	04/96 RFO	SPECIAL INTEREST	VOL		0.20	001	+9.47 001
		04/96 RFO	SPECIAL INTEREST	VOL		0.30	002	+8.93 002
		04/96 RFO	SPECIAL INTEREST	VOL		0.40	003	-11.80 003
104	37	04/96 RFO	SPECIAL INTEREST	VOL		0.38	006	+10.04 006
104	40	04/96 RFO	SPECIAL INTEREST	VOL		1.52	003	-13.32 003
104	49	04/96 RFO	SPECIAL INTEREST	VOL		0.86	UTS	+3.63 UTS
104	94	04/96 RFO	SPECIAL INTEREST	SAI		0.62	014	-5.74 to -4.74 014
104	97	04/96 RFO	SPECIAL INTEREST	VOL		0.29	011	-9.03 011
		04/96 RFO	SPECIAL INTEREST	VOL		0.36	003	-5.33 003
104	116	04/96 RFO	SPECIAL INTEREST	VOL		0.69	003	-7.84 003
104	119	04/96 RFO	SPECIAL INTEREST	VOL		0.22	001	+28.15 001
104	121	04/96 RFO	SPECIAL INTEREST	VOL		0.52	008	-3.75 008
104	122	04/96 RFO	SPECIAL INTEREST	VOL		0.11	001	+3.70 001
		04/96 RFO	SPECIAL INTEREST	VOL		0.12	001	+7.58 001
		04/96 RFO	SPECIAL INTEREST	VOL		0.17	002	+9.61 002
		04/96 RFO	SPECIAL INTEREST	VOL		0.18	002	+1.48 002
		04/96 RFO	SPECIAL INTEREST	VOL		0.20	001	+11.70 001
		04/96 RFO	SPECIAL INTEREST	VOL		0.22	002	+8.15 002
		04/96 RFO	SPECIAL INTEREST	VOL		0.48	002	+4.94 002
105	62	04/96 RFO	SPECIAL INTEREST	VOL		0.63	014	+7.66 014
		04/96 RFO	SPECIAL INTEREST	VOL		1.13	014	+11.78 014
		04/96 RFO	SPECIAL INTEREST	VOL		1.21	014	+3.11 014
105	120	04/96 RFO	SPECIAL INTEREST	VOL		0.93	001	-15.28 001
106	34	04/96 RFO	SPECIAL INTEREST	VOL		0.26	011	+8.87 011
		04/96 RFO	SPECIAL INTEREST	VOL		0.28	011	+12.90 011
		04/96 RFO	SPECIAL INTEREST	VOL		0.43	012	-1.26 012
106	37	04/96 RFO	SPECIAL INTEREST	VOL		0.91	015	-9.88 015
106	47	04/96 RFO	SPECIAL INTEREST	VOL		0.85	014	-2.71 014
106	88	04/96 RFO	SPECIAL INTEREST	SAI		0.20	UTS	-7.29 UTS
106	93	04/96 RFO	SPECIAL INTEREST	VOL		0.71	UTS	-12.12 UTS
106	94	04/96 RFO	SPECIAL INTEREST	VOL		0.37	015	+19.20 015
106	117	04/96 RFO	SPECIAL INTEREST	VOL		1.25	008	+8.37 to +12.28 008
107	32	04/96 RFO	SPECIAL INTEREST	VOL		0.39	007	+0.37 007
107	75	04/96 RFO	SPECIAL INTEREST	SAI		0.27	014	-10.75 014
		04/96 RFO	SPECIAL INTEREST	SAI		0.39	014	+17.01 014
		04/96 RFO	SPECIAL INTEREST	SAI		0.50	014	-15.78 014
107	83	04/96 RFO	SPECIAL INTEREST	VOL		0.13	012	+0.24 012
107	95	04/96 RFO	SPECIAL INTEREST	VOL		0.26	008	-8.01 008
		04/96 RFO	SPECIAL INTEREST	VOL		0.41	008	+15.32 008
		04/96 RFO	SPECIAL INTEREST	VOL		0.44	004	-10.60 004
		04/96 RFO	SPECIAL INTEREST	VOL		0.53	008	+11.40 008
		04/96 RFO	SPECIAL INTEREST	VOL		0.57	008	+7.00 008
107	96	04/96 RFO	SPECIAL INTEREST	VOL		1.60	004	-8.71 004
107	108	04/96 RFO	SPECIAL INTEREST	SAI		0.15	UTS	-4.98 UTS
107	109	04/96 RFO	SPECIAL INTEREST	VOL		0.39	007	-4.76 to -1.53 007
107	110	04/96 RFO	SPECIAL INTEREST	MAI		0.21	UTS	-24.55 to -9.30 UTS
107	117	04/96 RFO	SPECIAL INTEREST	VOL		0.25	008	-23.98 to -17.24 008
108	22	04/96 RFO	SPECIAL INTEREST	VOL		2.89	005	-13.11 005
108	25	04/96 RFO	SPECIAL INTEREST	VOL		1.09	014	+4.83 014
108	68	04/96 RFO	SPECIAL INTEREST	VOL		0.78	011	+23.03 011
108	81	04/96 RFO	SPECIAL INTEREST	VOL		0.68	003	-19.65 003
		04/96 RFO	SPECIAL INTEREST	VOL		1.50	003	-14.23 003
		04/96 RFO	SPECIAL INTEREST	VOL		2.12	003	+11.45 003
		04/96 RFO	SPECIAL INTEREST	VOL		2.71	004	+12.06 004
108	94	04/96 RFO	SPECIAL INTEREST	VOL		1.29	004	+10.26 004
109	28	04/96 RFO	SPECIAL INTEREST	SAI		0.12	UTS	-21.38 UTS
		04/96 RFO	SPECIAL INTEREST	SAI		0.22	UTS	-6.33 UTS
109	44	04/96 RFO	SPECIAL INTEREST	SAI		0.28	012	-3.55 012
		04/96 RFO	SPECIAL INTEREST	VOL		0.30	012	-0.53 012
110	20	04/96 RFO	SPECIAL INTEREST	SAI		0.33	015	+25.11 015
110	93	04/96 RFO	SPECIAL INTEREST	VOL		0.34	009	+22.44 009
110	107	04/96 RFO	SPECIAL INTEREST	VOL		0.50	007	-4.33 to -1.01 007
111	61	04/96 RFO	SPECIAL INTEREST	VOL		0.32	012	+0.29 012

FTI TUBAN II (Version 2.3) 05/14/1996 09:43:16

Oconee Nuclear Station - Unit Two

S/G B

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 10 of 12

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
111	63	04/96 RFO	SPECIAL INTEREST	VOL		0.95	012	-0.54
111	86	04/96 RFO	SPECIAL INTEREST	VOL		0.20	014	-11.46
112	7	04/96 RFO	SPECIAL INTEREST	SAI		0.36	010	+1.34
		04/96 RFO	SPECIAL INTEREST	SAI		0.28	010	+4.10 to +6.20
112	32	04/96 RFO	SPECIAL INTEREST	VOL		0.30	012	+0.08
112	65	04/96 RFO	SPECIAL INTEREST	VOL		0.29	012	-0.23
112	92	04/96 RFO	SPECIAL INTEREST	VOL		1.51	013	+19.37
113	29	04/96 RFO	SPECIAL INTEREST	VOL		0.60	012	+0.23
113	40	04/96 RFO	SPECIAL INTEREST	VOL		0.33	002	+8.87
		04/96 RFO	SPECIAL INTEREST	VOL		1.39	002	+7.11
113	93	04/96 RFO	SPECIAL INTEREST	VOL		0.43	002	-13.09
		04/96 RFO	SPECIAL INTEREST	VOL		0.50	015	-2.42
		04/96 RFO	SPECIAL INTEREST	VOL		0.59	002	-10.08
113	94	04/96 RFO	SPECIAL INTEREST	VOL		1.30	008	+13.77
114	6	04/96 RFO	SPECIAL INTEREST	VOL		0.30	008	+0.47
		04/96 RFO	SPECIAL INTEREST	VOL		0.46	008	-0.63
114	80	04/96 RFO	SPECIAL INTEREST	VOL		0.76	004	+0.05
114	93	04/96 RFO	SPECIAL INTEREST	VOL		0.69	015	+29.13
114	107	04/96 RFO	SPECIAL INTEREST	VOL		1.69	015	+38.83
115	25	04/96 RFO	SPECIAL INTEREST	VOL		0.56	014	+30.08
115	30	04/96 RFO	SPECIAL INTEREST	SAI		0.28	012	+18.28
		04/96 RFO	SPECIAL INTEREST	SAI		0.44	012	+2.21
115	34	04/96 RFO	SPECIAL INTEREST	SAI		0.30	012	-4.07
		04/96 RFO	SPECIAL INTEREST	SAI		0.41	012	-2.75
115	69	04/96 RFO	SPECIAL INTEREST	VOL		0.52	012	-0.67
115	106	04/96 RFO	SPECIAL INTEREST	SAI		0.36	013	+2.63
116	62	04/96 RFO	SPECIAL INTEREST	VOL		0.72	015	-9.62
116	91	04/96 RFO	SPECIAL INTEREST	VOL		0.45	015	-12.44
		04/96 RFO	SPECIAL INTEREST	VOL		0.48	015	+29.10
		04/96 RFO	SPECIAL INTEREST	VOL		0.35	015	+20.69 to +25.58
116	100	04/96 RFO	SPECIAL INTEREST	VOL		0.53	015	+26.56
116	107	04/96 RFO	SPECIAL INTEREST	SAI		0.18	007	-1.98
117	16	04/96 RFO	SPECIAL INTEREST	SAI		0.13	UTS	-16.98
		04/96 RFO	SPECIAL INTEREST	SAI		0.14	UTS	-16.06
117	17	04/96 RFO	SPECIAL INTEREST	VOL		0.50	014	+6.35
117	19	04/96 RFO	SPECIAL INTEREST	VOL		0.18	015	+2.36
117	27	04/96 RFO	SPECIAL INTEREST	SAI		0.19	UTS	-9.40
117	51	04/96 RFO	SPECIAL INTEREST	VOL		0.91	012	+0.59
117	77	04/96 RFO	SPECIAL INTEREST	VOL		1.94	UTS	-3.54
118	24	04/96 RFO	SPECIAL INTEREST	VOL		0.30	013	+0.64
118	70	04/96 RFO	SPECIAL INTEREST	SAI		0.18	014	-1.71 to -0.59
119	3	04/96 RFO	SPECIAL INTEREST	SAI		0.30	015	-1.29
		04/96 RFO	SPECIAL INTEREST	SAI		0.63	015	-0.20
119	28	04/96 RFO	SPECIAL INTEREST	VOL		0.19	012	+0.61
119	34	04/96 RFO	SPECIAL INTEREST	SAI		0.94	014	+22.32
119	69	04/96 RFO	SPECIAL INTEREST	VOL		0.92	015	+11.05
119	99	04/96 RFO	SPECIAL INTEREST	VOL		0.32	013	+18.27
120	17	04/96 RFO	SPECIAL INTEREST	VOL		1.04	LTS	+14.52
120	103	04/96 RFO	SPECIAL INTEREST	VOL		0.64	012	+10.12
121	44	04/96 RFO	SPECIAL INTEREST	VOL		0.41	012	+0.66
		04/96 RFO	SPECIAL INTEREST	VOL		0.43	012	+0.17
121	100	04/96 RFO	SPECIAL INTEREST	VOL		0.11	010	-12.20
121	104	04/96 RFO	SPECIAL INTEREST	VOL		1.13	009	+9.79
122	1	04/96 RFO	SPECIAL INTEREST	SAI		0.25	014	+12.01
122	34	04/96 RFO	SPECIAL INTEREST	VOL		0.68	012	+0.68
122	76	04/96 RFO	SPECIAL INTEREST	WAR	6	0.35	012	+0.00
122	78	04/96 RFO	SPECIAL INTEREST	VOL		0.31	006	+0.55
122	88	04/96 RFO	SPECIAL INTEREST	VOL		0.29	014	+18.50
123	2	04/96 RFO	SPECIAL INTEREST	MAI		0.31	013	+10.31 to +12.43
123	14	04/96 RFO	SPECIAL INTEREST	VOL		0.90	007	-8.27
123	15	04/96 RFO	SPECIAL INTEREST	VOL		0.80	UTS	-2.71
123	19	04/96 RFO	SPECIAL INTEREST	VOL		0.95	001	+15.39
123	26	04/96 RFO	SPECIAL INTEREST	SAI		0.34	015	+1.30
123	67	04/96 RFO	SPECIAL INTEREST	SAI		0.05	011	+5.10
123	104	04/96 RFO	SPECIAL INTEREST	VOL		1.14	011	+3.99

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT
 OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
124	11	04/96 RFO	SPECIAL INTEREST	VOL		0.51	015 +15.43	015
		04/96 RFO	SPECIAL INTEREST	VOL		1.31	015 +1.67	015
124	13	04/96 RFO	SPECIAL INTEREST	VOL		0.29	011 +16.44	011
124	43	04/96 RFO	SPECIAL INTEREST	VOL		0.88	010 -11.62	010
124	61	04/96 RFO	SPECIAL INTEREST	VOL		0.59	007 -21.17	007
124	68	04/96 RFO	SPECIAL INTEREST	VOL		1.00	012 +0.52	012
124	97	04/96 RFO	SPECIAL INTEREST	VOL		2.19	012 -3.89	012
125	12	04/96 RFO	SPECIAL INTEREST	VOL		0.44	015 +13.73	015
125	56	04/96 RFO	SPECIAL INTEREST	WAR	17	1.06	012 +0.00	012
125	57	04/96 RFO	SPECIAL INTEREST	VOL		0.17	012 +0.70	012
125	87	04/96 RFO	SPECIAL INTEREST	MAI		0.60	014 -5.56 to -2.05	014
125	95	04/96 RFO	SPECIAL INTEREST	WAR	10	0.70	008 +0.00	008
125	98	04/96 RFO	SPECIAL INTEREST	VOL		1.27	015 +25.70	015
128	67	04/96 RFO	SPECIAL INTEREST	VOL		1.03	007 -16.55	007
129	64	04/96 RFO	SPECIAL INTEREST	VOL		0.35	007 +0.63	007
130	8	04/96 RFO	SPECIAL INTEREST	VOL		0.44	009 +8.28 to +9.04	009
130	12	04/96 RFO	SPECIAL INTEREST	VOL		0.95	007 +21.97	007
131	3	04/96 RFO	SPECIAL INTEREST	VOL		0.49	009 +19.29 to +25.04	009
132	4	04/96 RFO	SPECIAL INTEREST	VOL		0.42	009 +22.79	009
		04/96 RFO	SPECIAL INTEREST	WAR	4	0.24	009 +0.00	009
132	5	04/96 RFO	SPECIAL INTEREST	VOL		0.06	009 +25.45	009
132	9	04/96 RFO	SPECIAL INTEREST	WAR	9	0.55	009 +0.00	009
132	75	04/96 RFO	SPECIAL INTEREST	VOL		1.13	001 -19.55	001
132	77	04/96 RFO	SPECIAL INTEREST	SAI		0.20	015 -6.40	015
132	83	04/96 RFO	SPECIAL INTEREST	VOL		0.73	UTS -17.93	UTS
		04/96 RFO	SPECIAL INTEREST	VOL		1.62	UTS -12.63	UTS
133	5	04/96 RFO	SPECIAL INTEREST	VOL		2.74	006 +17.14	006
133	36	04/96 RFO	SPECIAL INTEREST	WAR	12	0.75	007 -0.56	007
133	52	04/96 RFO	SPECIAL INTEREST	VOL		0.55	006 +31.03 to +35.24	006
133	71	04/96 RFO	SPECIAL INTEREST	VOL		0.19	LTS +16.64	LTS
134	5	04/96 RFO	SPECIAL INTEREST	VOL		0.79	009 +21.60	009
134	46	04/96 RFO	SPECIAL INTEREST	VOL		0.67	LTS +22.91	LTS
		04/96 RFO	SPECIAL INTEREST	VOL		0.80	LTS +20.15	LTS
		04/96 RFO	SPECIAL INTEREST	VOL		0.81	LTS +19.19	LTS
		04/96 RFO	SPECIAL INTEREST	VOL		1.08	LTS +24.99	LTS
134	50	04/96 RFO	SPECIAL INTEREST	WAR	23	1.55	007 +0.00	007
134	54	04/96 RFO	SPECIAL INTEREST	VOL		0.65	007 -7.89 to -1.01	007
135	4	04/96 RFO	SPECIAL INTEREST	VOL		0.73	010 -18.99 to -16.97	010
135	52	04/96 RFO	SPECIAL INTEREST	VOL		1.04	007 -7.65	007
135	78	04/96 RFO	SPECIAL INTEREST	SAI		0.44	UTS -0.48	UTS
135	81	04/96 RFO	SPECIAL INTEREST	WAR	24	1.72	010 +0.00	010
		04/96 RFO	SPECIAL INTEREST	MAI		0.24	012 +17.97 to +20.04	012
136	6	04/96 RFO	SPECIAL INTEREST	VOL		0.28	009 +15.63 to +16.97	009
136	71	04/96 RFO	SPECIAL INTEREST	VOL		2.04	014 +18.69	014
137	9	04/96 RFO	SPECIAL INTEREST	WAR	13	0.88	009 +0.00	009
137	68	04/96 RFO	SPECIAL INTEREST	VOL		1.01	007 +13.82	007
138	74	04/96 RFO	SPECIAL INTEREST	SAI		0.24	015 -11.20	015
139	44	04/96 RFO	SPECIAL INTEREST	WAR	12	0.71	007 +0.00	007
139	70	04/96 RFO	SPECIAL INTEREST	SAI		0.25	014 -5.99	014
140	2	04/96 RFO	SPECIAL INTEREST	VOL		0.17	013 +16.75	013
		04/96 RFO	SPECIAL INTEREST	VOL		0.33	012 +10.41	012
		04/96 RFO	SPECIAL INTEREST	WAR	8	0.97	013 +0.00	013
141	50	04/96 RFO	SPECIAL INTEREST	VOL		0.38	015 +1.30	015
143	58	04/96 RFO	SPECIAL INTEREST	VOL		0.70	008 +6.39	008
143	62	04/96 RFO	SPECIAL INTEREST	VOL		0.55	009 +0.52	009
144	3	04/96 RFO	SPECIAL INTEREST	VOL		0.31	009 +10.89	009
144	16	04/96 RFO	SPECIAL INTEREST	SAI		0.38	015 -8.71 to -7.24	015
145	19	04/96 RFO	SPECIAL INTEREST	SAI		0.20	010 -5.63	010
145	39	04/96 RFO	SPECIAL INTEREST	VOL		0.71	009 -14.28	009
		04/96 RFO	SPECIAL INTEREST	WAR	6	0.23	009 +0.00	009
145	54	04/96 RFO	SPECIAL INTEREST	WAR	8	0.35	009 +0.00	009
146	30	04/96 RFO	SPECIAL INTEREST	VOL		0.62	008 +3.59	008
147	29	04/96 RFO	SPECIAL INTEREST	WAR	12	0.70	008 +0.00	008
147	41	04/96 RFO	SPECIAL INTEREST	SAI		1.26	009 +14.68	009
149	5	04/96 RFO	SPECIAL INTEREST	VOL		0.75	014 -0.70	014

FTI TUBAN II (Version 2.3) 05/14/1996 09:43:16

Oconee Nuclear Station - Unit Two

S/G B

04/96 RFO

MRPC Lane & Wedge, Re-expanded MRPC, SLEEVE ROLL +POINT, SPECIAL INTEREST

Page 12 of 12

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC AND PLUS POINT

OCONEE 90 DAY NRC REPORT

ROW	COL	OUTAGE	TEST TYPE	IND %TW	VOLTS	LOCATION	EXTENT1
149	24	04/96 RFO	SPECIAL INTEREST	VOL	0.26	009 -1.98	009
150	13	04/96 RFO	SPECIAL INTEREST	VOL	1.33	004 +29.35	004

Total Indications Found = 717

Total Tubes Found = 551

ATTACHMENT 5

3 Pages

FTI TUBAN II (Version 2.3) 05/14/1996 08:35:26
 Oconee Nuclear Station - Unit Two
 S/G A
 04/96 RFO

Page 1

PLUGGED TUBES - ATTACHMENT #5

COUNT	ROW	COL	COUNT	ROW	COL
1.	2	11	47.	55	83
2.	2	22	48.	55	122
3.	4	19	49.	55	124
4.	4	27	50.	56	15
5.	6	3	51.	56	104
6.	6	32	52.	56	126
7.	9	5	53.	57	43
8.	9	54	54.	57	127
9.	13	11	55.	59	13
10.	13	13	56.	59	19
11.	16	23	57.	59	23
12.	17	72	58.	60	41
13.	18	19	59.	61	1
14.	21	28	60.	61	72
15.	23	31	61.	63	27
16.	23	62	62.	63	47
17.	24	25	63.	63	105
18.	24	55	64.	65	33
19.	25	64	65.	66	4
20.	27	62	66.	66	25
21.	27	64	67.	67	113
22.	27	65	68.	68	39
23.	31	67	69.	69	40
24.	37	42	70.	70	48
25.	42	91	71.	70	55
26.	43	15	72.	70	82
27.	43	93	73.	71	128
28.	44	2	74.	72	110
29.	45	34	75.	73	32
30.	45	39	76.	73	49
31.	47	58	77.	73	127
32.	47	79	78.	74	124
33.	47	108	79.	75	43
34.	47	121	80.	75	123
35.	48	45	81.	75	124
36.	48	76	82.	75	125
37.	49	33	83.	76	66
38.	51	18	84.	76	121
39.	51	37	85.	77	52
40.	51	41	86.	78	67
41.	52	119	87.	78	123
42.	53	11	88.	78	125
43.	54	74	89.	79	27
44.	55	10	90.	79	49
45.	55	11	91.	79	78
46.	55	14	92.	79	126

FTI TUBAN II (Version 2.3)

05/14/1996 08:35:26

Oconee Nuclear Station - Unit Two

S/G A

04/96 RFO

Page 2

PLUGGED TUBES - ATTACHMENT #5

COUNT ROW COL

COUNT ROW COL

93. 79 127
94. 79 128
95. 80 68
96. 80 128
97. 82 13
98. 82 126
99. 83 27
100. 83 126
101. 83 128
102. 84 27
103. 84 73
104. 85 20
105. 85 28
106. 85 70
107. 85 126
108. 88 7
109. 88 22
110. 88 73
111. 88 101
112. 89 27
113. 89 28
114. 89 72
115. 90 57
116. 90 70
117. 91 19
118. 91 23
119. 92 15
120. 92 16
121. 92 70
122. 92 72
123. 93 41
124. 93 69
125. 94 15
126. 94 43
127. 96 67
128. 102 23
129. 102 67
130. 102 69
131. 103 11
132. 103 65
133. 103 69
134. 104 8
135. 105 2
136. 105 68
137. 105 89
138. 107 68

139. 107 69
140. 109 10
141. 109 24
142. 109 78
143. 110 6
144. 110 66
145. 111 3
146. 111 17
147. 112 17
148. 113 5
149. 115 4
150. 115 5
151. 116 40
152. 117 61
153. 118 49
154. 118 50
155. 118 56
156. 119 49
157. 119 59
158. 119 90
159. 120 59
160. 121 47
161. 121 48
162. 123 27
163. 125 28
164. 125 45
165. 128 2
166. 128 7
167. 129 89
168. 130 13
169. 130 93
170. 132 82
171. 134 4
172. 134 48
173. 135 2
174. 135 32
175. 135 47
176. 137 46
177. 137 73
178. 138 15
179. 138 44
180. 138 71
181. 139 15
182. 139 44
183. 139 68
184. 140 7

FTI TUBAN II (Version 2.3)

05/14/1996 08:35:26

Oconee Nuclear Station - Unit Two

S/G A

04/96 RFO

Page 3

PLUGGED TUBES - ATTACHMENT #5

COUNT ROW COL

COUNT ROW COL

185.	140	8
186.	140	41
187.	140	42
188.	140	43
189.	141	65
190.	142	65
191.	143	58
192.	144	7
193.	144	54
194.	145	54
195.	147	31
196.	149	22
197.	149	24
198.	151	14
199.	151	16

Total Data Items Found = 199

Total Tubes Found = 199

ATTACHMENT 6

3 Pages

FTI TUBAN II (Version 2.3)

05/14/1996 07:49:23

Oconee Nuclear Station - Unit Two

S/G B

04/96 RFO

Page 1

PLUGGED TUBES - ATTACHMENT #6

COUNT	ROW	COL	COUNT	ROW	COL
1.	1	1	47.	39	116
2.	1	15	48.	40	87
3.	2	14	49.	41	76
4.	3	5	50.	43	87
5.	3	7	51.	44	53
6.	3	10	52.	44	87
7.	3	20	53.	44	96
8.	5	36	54.	45	120
9.	6	5	55.	47	70
10.	7	4	56.	48	43
11.	7	53	57.	49	99
12.	10	16	58.	51	27
13.	11	68	59.	51	112
14.	13	69	60.	51	117
15.	16	52	61.	52	2
16.	16	78	62.	52	41
17.	17	77	63.	52	65
18.	17	81	64.	53	112
19.	18	55	65.	54	103
20.	18	57	66.	54	113
21.	18	62	67.	56	3
22.	20	53	68.	56	61
23.	20	78	69.	56	79
24.	21	80	70.	56	112
25.	21	87	71.	57	55
26.	22	58	72.	58	111
27.	23	12	73.	60	4
28.	24	42	74.	61	99
29.	25	3	75.	61	124
30.	25	6	76.	62	71
31.	25	94	77.	62	98
32.	25	98	78.	62	100
33.	26	17	79.	63	38
34.	26	93	80.	64	99
35.	27	98	81.	64	125
36.	31	18	82.	65	37
37.	33	33	83.	65	93
38.	33	48	84.	65	115
39.	33	104	85.	65	130
40.	33	108	86.	66	33
41.	34	58	87.	67	5
42.	34	87	88.	69	24
43.	34	107	89.	69	47
44.	36	113	90.	69	70
45.	37	35	91.	69	104
46.	38	85	92.	69	110

FTI TUBAN II (Version 2.3)

05/14/1996 07:49:23

Oconee Nuclear Station - Unit Two

S/G B

04/96 RFO

Page 2

PLUGGED TUBES - ATTACHMENT #6

COUNT ROW COL

COUNT ROW COL

93. 69 132
94. 70 5
95. 70 33
96. 70 44
97. 70 112
98. 70 130
99. 72 47
100. 72 65
101. 73 13
102. 74 77
103. 74 123
104. 74 124
105. 75 124
106. 75 125
107. 76 75
108. 76 95
109. 77 39
110. 78 67
111. 78 90
112. 79 32
113. 79 34
114. 81 54
115. 81 63
116. 82 101
117. 83 33
118. 83 91
119. 83 112
120. 83 124
121. 83 127
122. 84 100
123. 85 5
124. 86 5
125. 86 42
126. 86 76
127. 86 80
128. 87 32
129. 87 34
130. 87 125
131. 88 4
132. 88 81
133. 88 95
134. 88 96
135. 88 106
136. 89 32
137. 89 111
138. 90 3

139. 92 44
140. 94 3
141. 96 25
142. 96 113
143. 97 60
144. 98 24
145. 98 47
146. 101 84
147. 102 56
148. 102 113
149. 102 114
150. 103 39
151. 103 124
152. 104 49
153. 104 94
154. 104 121
155. 104 122
156. 105 114
157. 106 88
158. 107 75
159. 107 83
160. 107 108
161. 107 110
162. 107 117
163. 108 81
164. 109 28
165. 109 44
166. 110 20
167. 111 61
168. 111 63
169. 112 7
170. 112 32
171. 113 29
172. 114 6
173. 114 80
174. 115 30
175. 115 34
176. 115 69
177. 115 106
178. 116 107
179. 117 16
180. 117 27
181. 117 51
182. 118 2
183. 118 19
184. 118 24

FTI TUBAN II (Version 2.3)

05/14/1996 07:49:23

Ocone Nuclear Station - Unit Two

S/G B

04/96 RFO

Page 3

PLUGGED TUBES - ATTACHMENT #6

COUNT ROW COL

COUNT ROW COL

185.	118	70
186.	119	3
187.	119	28
188.	119	34
189.	121	100
190.	122	1
191.	122	34
192.	123	2
193.	123	26
194.	123	67
195.	123	102
196.	125	57
197.	125	87
198.	127	84
199.	132	5
200.	132	76
201.	132	77
202.	134	5
203.	134	46
204.	135	78
205.	135	81
206.	138	74
207.	139	70
208.	140	10
209.	143	62
210.	144	16
211.	144	41
212.	145	19
213.	147	41

Total Data Items Found = 213

Total Tubes Found = 213