

August 28, 2015

Mr. Bruce S. Montgomery  
Senior Project Manager, Licensing  
Nuclear Energy Institute  
1201 F Street, NW, Suite 1100  
Washington, DC 20004

SUBJECT: NEI COMMENTS ON THE USE OF DOORS ON SAFETY-RELATED ELECTRICAL  
CABINETS

Dear Mr. Montgomery:

By letter dated July 28, 2015 (Agencywide Documents Access and Management System Accession No. ML15211A296; Package ML15211A295), the Nuclear Energy Institute (NEI) submitted a position paper to the U.S. Nuclear Regulatory Commission (NRC) staff documenting the industry's view on the use of doors on safety-related electrical cabinets and the seismic qualification of safety-related electrical cabinets. The purpose of this letter is to inform you that the NRC staff considered the information delineated in NEI's position paper and determined that clarification or revision to Regulatory Oversight Process (ROP) governance documentation, e.g., Inspection Manual Chapter 0326, "Operability Determinations and Functionality Assessments for Conditions Adverse to Quality or Safety," is not necessary at this time.

NRC staff will be prepared to discuss NEI's position paper at the September 16, 2015, ROP public meeting. If you have any further questions regarding this issue, please contact Gabriel Levasseur at (301) 415-1487 or Stephen Campbell at (301) 415-3353.

Sincerely,

**/RA/**

Christopher M. Regan, Branch Chief  
Division of Inspection and Regional Support  
Office of Nuclear Reactor Regulation

August 28, 2015

Mr. Bruce S. Montgomery  
Senior Project Manager, Licensing  
Nuclear Energy Institute  
1201 F Street, NW, Suite 1100  
Washington, DC 20004

SUBJECT: NEI COMMENTS ON THE USE OF DOORS ON SAFETY-RELATED ELECTRICAL  
CABINETS

Dear Mr. Montgomery:

By letter dated July 28, 2015 (Agencywide Documents Access and Management System Accession No. ML15211A296; Package ML15211A295), the Nuclear Energy Institute (NEI) submitted a position paper to the U.S. Nuclear Regulatory Commission (NRC) staff documenting the industry's view on the use of doors on safety-related electrical cabinets and the seismic qualification of safety-related electrical cabinets. The purpose of this letter is to inform you that the NRC staff considered the information delineated in NEI's position paper and determined that clarification or revision to Regulatory Oversight Process (ROP) governance documentation, e.g., Inspection Manual Chapter 0326, "Operability Determinations and Functionality Assessments for Conditions Adverse to Quality or Safety," is not necessary at this time.

NRC staff will be prepared to discuss NEI's position paper at the September 16, 2015, ROP public meeting. If you have any further questions regarding this issue, please contact Gabriel Levasseur at (301) 415-1487 or Stephen Campbell at (301) 415-3353.

Sincerely,

/RA/

Christopher M. Regan, Branch Chief  
Division of Inspection and Regional Support  
Office of Nuclear Reactor Regulation

**DISTRIBUTION:**

RidsRgn1MailCenter  
RidsRgn2MailCenter

RidsRgn3MailCenter  
RidsRgn4MailCenter

RPowell  
AStone

AMasters  
ERuesch

**ADAMS Accession No.: ML15219A145; Pkg: ML15211A295**

OFFICE	NRR/DIRS/IRIB	NRR/DIRS/IRIB	NRR/DSS/STSB	NRR/DIRS	NRR/DIRS/IRIB
NAME	GLevasseur	CRegan	RElliott	SMorris	CRegan
DATE	08/19/2015	08/19/2015	08/27/2015	08/27/2015	08/28/2015

**OFFICIAL RECORD COPY**