

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:7905040352 DOC.DATE: 79/04/30 NOTARIZED: NO  
 FACIL:50-269 OCONEE NUCLEAR STATION, UNIT 1, DUKE POWER CO.  
 50-270 OCONEE NUCLEAR STATION, UNIT 2, DUKE POWER CO.  
 50-287 OCONEE NUCLEAR STATION, UNIT 3, DUKE POWER CO.

DOCKET #  
 05000269  
 05000270  
 05000287

AUTH.NAME AUTHOR AFFILIATION  
 PARKER,W.O. DUKE POWER CO.  
 RECIP.NAME RECIPIENT AFFILIATION  
 DENTON,H.R. OFFICE OF NUCLEAR REACTOR REGULATION  
 REID,R.W. OPERATING REACTORS BRANCH 4

SUBJECT: FORWARDS RESPONSE TO 780329 REQUEST FOR ADDL INFO RE  
 PROPOSED CHANGES TO HYDRAULIC SHOCK SUPPRESSOR TECH SPEC.

DISTRIBUTION CODE: A001S COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2  
 TITLE: GENERAL DISTRIBUTION FOR AFTER ISSUANCE OF OPERATING LIC

NOTES: M CUNNINGHAM - All AMOTS TO ESAR + CHANCES TO TECH SPECS.

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
ACTION:	05 BC <u>ORR 4</u>	7 7		
INTERNAL:	01 <u>REG FILE</u>	1 1	02 NRC PDR	1 1
	12 I&E	2 2	14 TA/EDO	1 1
	15 CORE PERF BR	1 1	16 AD SYS/PROJ	1 1
	17 ENGR BR	1 1	18 REAC SFTY BR	1 1
	19 PLANT SYS BR	1 1	20 EEB	1 1
	21 EFLT TRT SYS	1 1	22 BRINKMAN	1 1
EXTERNAL:	03 LPDR	1 1	04 NSIC	1 1
	23 ACRS	16 16		

MAY 7 1979

# DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.  
VICE PRESIDENT  
STEAM PRODUCTION

April 30, 1979

TELEPHONE: AREA 704  
373-4083

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Mr. R. W. Reid, Chief  
Operating Reactors Branch #4

Re: Oconee Nuclear Station  
Docket Nos. 50-269, -270, -287

Dear Sir:

With regard to your letter of March 29, 1978, please find attached a response to the request for additional information concerning proposed changes to the hydraulic shock suppressor Technical Specification.

Very truly yours,

*William O. Parker Jr.*  
William O. Parker, Jr.

*by WAH*

RLG:scs  
Attachment

REGULATORY DOCKET FILE COPY

7905040352



*Acc'd  
5/11*

OCONEE NUCLEAR STATION  
RESPONSE TO NRC REQUEST FOR INFORMATION ON  
HYDRAULIC SHOCK SUPPRESSORS

1. Provide sufficient information to justify your request to change the designation of Snubber 2-130 to, "especially difficult to remove."

Response

Snubber 2-130 is located on the pier supporting the main steam line from the 'B' steam generator outside containment. This suppressor is approximately 29 feet from the ground. Special equipment is required to lift personnel to the installed snubber in order to perform the required surveillance.

This same snubber is already listed as "especially difficult to remove" in the tables for Units 1, 3 and is considered an administrative error that it was omitted from the Unit 2 listing.

2. In replacing hydraulic snubbers with mechanical snubbers, verify that Duke Power Company has used replacement snubbers that do not negate the results of the original pipe stress or equipment dynamic analyses, i.e., the displacements, velocities, accelerations and damping factors are controlled by the new snubbers in a no less conservative manner than by the old snubbers.

Response

The use of mechanical snubbers to replace hydraulic snubbers does not negate the original piping analysis.