

3.1.12

Reactor Coolant System Subcooling Margin Monitor

Specification

3.1.12.1

- a. The Reactor Coolant System subcooling monitors shall be operable when the average RCS coolant temperature is above 300°F.
- b. If one monitor is inoperable, the monitor shall be restored to operable status within seven days or the unit shall be in hot shutdown within the next 12 hours.
- c. If both of the subcooling monitors are inoperable because of an outage of the operational computer, and the computer is out of service for less than four hours, and the backup method for determining subcooling margin is available, then a capability to determine subcooling margin is available and a report pursuant to Specification 6.6.2 is not required.
- d. If both of the subcooling monitors are inoperable, then restore at least one monitor to operable status within 48 hours or be in at least hot shutdown within the next 12 hours.