

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION: NBR: 8107130266 DOC. DATE: 81/07/06 NOTARIZED: YES  
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.  
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.  
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.

DOCKET #  
 05000269  
 05000270  
 05000287

AUTH. NAME: PARKER, W.O. AUTHOR AFFILIATION: Duke Power Co.  
 RECIP. NAME: DENTON, H.R. RECIPIENT AFFILIATION: Office of Nuclear Reactor Regulation, Director  
 STOLZ, J.F. Operating Reactors Branch 4

SUBJECT: Application to amend OLs, changing degraded mode to make mode sufficient when testing for dc grounds. Changes consist of one Class III & two Class I license amends. Fee encl.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+5  
 TITLE: General Distribution for after Issuance of Operating License

NOTES: AEOD, Ornstein: 1cc.  
 AEOD, Ornstein: 1cc.  
 AEOD, Ornstein: 1cc.

05000269  
 05000270  
 05000287

ACTION:	RECIPIENT		COPIES		RECIPIENT	COPIES		
	ID	CODE/NAME	LTR	ENCL		ID	CODE/NAME	LTR
ACTION:	ORB	#4 BC 04	13	13				
INTERNAL:	D/DIR, HUM	FAC08	1	1	DIR, DIV OF LIC		1	1
	I&E	06	2	2	NRC PDR	02	1	1
	OELD	11	1	0	OR ASSESS BR	10	1	0
	RAD ASMT BR		1	1	REG FILE	01	1	1
EXTERNAL:	ACRS	09	16	16	LPDR	03	1	1
	NSIC	05	1	1	NTIS		1	1

W/CHECK  
 \$4,800

JUL 16 1981

TOTAL NUMBER OF COPIES REQUIRED: LTR 42 ENCL 40

RG

# DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.  
VICE PRESIDENT  
STEAM PRODUCTION


July 6, 1981

TELEPHONE: AREA 704  
373-4083

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: J. F. Stolz, Chief  
Operating Reactors Branch No. 4

Re: Oconee Nuclear Station  
Docket Nos. 50-269, -270, -287



Dear Sir:

A careful examination of Oconee Nuclear Station Technical Specification 3.7 has revealed that the current degraded mode of the Technical Specification is not sufficient when testing for DC grounds. Please review the attached proposed revision to Technical Specification 3.7 in an expeditious manner. This proposed revision has been reviewed and approved by both an on-site safety committee and an off-site safety review board.

Pursuant to 10 CFR 170 § 170.22 this proposed amendment consists of one Class III and two Class I license amendments. Therefore please find a check in the amount of \$4,800.

Very truly yours,

A large, stylized handwritten signature of William O. Parker, Jr. in dark ink.

William O. Parker, Jr.


JLJ:pw  
Attachment

*Handwritten:* w/check \$4,800  
A001  
5/11


8107130266	810706
PDR	ADOCK 05000269
P	PDR

Mr. Harold R. Denton, Director  
Page Two  
July 6, 1981

WILLIAM O. PARKER, JR., being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Technical Specifications, Appendix A to Facility Operating Licenses DPR-38, DPR-47 and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.

  
W. O. Parker, Jr., Vice President

Subscribed and sworn to before me this 2nd day of July, 1981

  
Notarial Seal  
Notary Public

My Commission Expires:

September 20, 1984