

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8112180272 DOC. DATE: 81/12/07 NOTARIZED: YES
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.

DOCKET #
~~05000269~~
 05000270
 05000287

AUTH. NAME AUTHOR AFFILIATION
 STOLZ, J.F. Duke Power Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Application for amend to OL revising Tech Specs re testing
 of automatic initiation circuitry of emergency feedwater
 sys. Fee encl.

DISTRIBUTION CODE: A046S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+1
 TITLE: Response to NUREG -0737/NUREG-0660 TMI Action Plan Rgmts (OL's)

NOTES: AEOD/Ornstein:1cc.
 AEOD/Ornstein:1cc
 AEOD/Ornstein:1cc

05000269
 05000270
 05000287

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
ACTION:	ORB #4 BC 01	7 7		
INTERNAL:	ELD	1 0	IE	12 2 2
	IE/DEP DIR 33	1 1	IE/DEP/EPDB	1 1
	IE/DEP/EPLB	3 3	NRR/DE DIR 21	1 1
	NRR/DE/ADCSE 22	1 1	NRR/DE/ADMGE 23	1 1
	NRR/DE/ADSA 17	1 1	NRR/DHFS DIR 28	1 1
	NRR/DHFS/DEPY29	1 1	NRR/DL DIR 14	1 1
	NRR/DL/ADL 16	1 1	NRR/DL/ADOR 15	1 1
	NRR/DL/ORAB 18	3 3	NRR/DSI ADRS 27	1 1
	NRR/DSI DIR 24	1 1	NRR/DSI/ADGP 31	1 1
	NRR/DSI/ADPS 25	1 1	NRR/DSI/ADRP 26	1 1
	NRR/DSI/RAB	1 1	NRR/DST DIR 30	1 1
	NRR/DST/ADT 32	1 1	REG FILE 04	1 1
EXTERNAL:	ACRS 34	10 10	FEMA-REP DIV	1 1
	INPO, J. STARNES	1 1	LPDR 03	1 1
	NRC PDR 02	1 1	NSIC 05	1 1
	NTIS	1 1		

WITH CHECK \$4800.00

DEC 23 1981

TOTAL NUMBER OF COPIES REQUIRED: LTTR

53
52

ENCL

52
51

UB

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION


December 7, 1981

TELEPHONE: AREA 704
373-4083

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. J. F. Stolz, Chief
Operating Reactors Branch No. 4

Re: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287



Dear Sir:

NUREG-0737, Item II.E.1.2, "Auxiliary Feedwater System Automatic Initiation and Flow Indication", requires that all PWR operating reactors and applicants for operating licenses have a reliable automatic initiation system and that changes be made to the technical specifications.

The following is a revised schedule for implementation of the modification to the initiation test circuitry indicated in Duke Power Company's May 22, 1981 letter:

- Oconee Unit 1: Duke will implement this modification during the first available outage of sufficient length prior to or during the Oconee 1, Cycle 8 refueling outage.
- Oconee Unit 2: This modification will be implemented during the upcoming Oconee 2, Cycle 6 refueling outage.
- Oconee Unit 3: This modification will be implemented during the 1982 Oconee 3, Cycle 7 refueling outage.

Pursuant to 10 CFR 50, §50.90, please find attached a proposed amendment to the Oconee Nuclear Station Facility Operating License and revision to the Technical Specifications. This proposed change fulfills a commitment made in Duke letter dated July 23, 1981 and concerns the testing of the automatic initiation circuitry of the Emergency Feedwater System. The testing schedule included in this revision was approved by the staff letter dated June 3, 1981.


This proposed revision to the Oconee Nuclear Station Technical Specifications is considered to consist of one Class III and two Class I amendments. Therefore, pursuant to 10 CFR 170, §170.12, please find enclosed a check for \$4,800 for all applicable licensing fees.

A046
1/1
w/check:
\$4800.00

8112180272 811207
PDR ADOCK 05000269
PDR

Mr. Harold R. Denton, Director
December 7, 1981
Page 2

Very truly yours,


A handwritten signature in cursive script, appearing to read "William O. Parker, Jr.", written over the typed name.

William O. Parker, Jr.

JLJ/php
Enclosure

Mr. Harold R. Denton, Director
December 7, 1981
Page 3

WILLIAM O. PARKER, JR., being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Technical Specifications, Appendix A to Facility Operating Licenses DPR-38, DPR-47 and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.



William O. Parker, Jr., Vice President

Subscribed and sworn to before me this 7th day of December, 1981



Notary Public

My Commission Expires:

September 20, 1984