

Table 4.1-1 (Continued)

<u>Channel Description</u>	<u>Check</u>	<u>Test</u>	<u>Calibrate</u>	<u>Remarks</u>
49. Emergency Feedwater Flow Indicators	MO	NA	RF	
50. PORV and Safety Valve Position Indicators	MO	NA	RF	
51. RPS Anticipatory Reactor Trip System Loss of Turbine Emergency Trip System Pressure Switches	NA	MO	RF	
52. RPS Anticipatory Reactor Trip System Loss of Main Feedwater				
a) Control Oil Pressure Switches	NA	MO	RF	
*b) Discharge Pressure Switches	NA	MO	RF	
53. Emergency Feedwater Initiation Circuits				
a) Control Oil Pressure Switches	NA	MO	RF	
*b) Discharge Pressure Switches	NA	MO	RF	

ES - Each Shift

DA - Daily

WE - Weekly

MO - Monthly

QU - Quarterly

AN - Annually

PS - Prior to startup, if not performed previous week

NA - Not Applicable

RF - Refueling Outage

\* This Technical Specification will become effective as follows:

Unit 1 - at the first convenient outage prior to or at the end of Oconee 1 Cycle 8 Refueling Outage

Unit 2 - end of Oconee 2 Cycle 6 Refueling Outage

Unit 3 - end of Oconee 3 Cycle 7 Refueling Outage

During the interim period, these discharge pressure switches will be tested during cold shutdown not to exceed once per month.

8112180276 811207/  
PDR ADDCK 05000269  
PDR