

TABLE 1.2-1
LIMITS AND MONITORING REQUIREMENTS ON
CERTAIN CHEMICALS AND p^H OF
WATER RELEASED FROM OCONEE NUCLEAR STATION

<u>Item</u>	<u>Check</u>	<u>Frequency</u>	<u>Limit</u>
1. Waste Water Treatment System ^a	a. p ^H	Daily	6.0-9.0
	b. Hydrazine	Daily	0.7 ppm
2. Low Level Rad Waste System ^b	a. Hydrazine	Prior to Release	0.1 ppm
	b. Boron	Prior to Release	400 lb/day

^a Monitored at point of release to Hartwell Reservoir.

^b Concentrations are measured prior to point of discharge. Limits apply on downstream incremental increases in concentration in the Hartwell Reservoir following dilution in the Keowee tailrace.