

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8209200119 DOC. DATE: 82/09/10 NOTARIZED: YES DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME: TUCKER, H.B. AUTHOR AFFILIATION: Duke Power Co.
 RECIP. NAME: DENTON, H.R. RECIPIENT AFFILIATION: Office of Nuclear Reactor Regulation, Director

SUBJECT: Application to amend Licenses DPR-38,47 & 55 revising Tech Specs to correct designations in Table 4.4-1 re penetrations w/10CFR50, App J test requirements.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+4
 TITLE: OR Submittal: General Distribution

NOTES: AEOD/Ornstein:1cy. 05000269
 AEOD/Ornstein:1cy. 05000270
 AEOD/Ornstein:1cy. 05000287

RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
NRR ORB4 BC 01	7 7		

INTERNAL: ELD/HDS4	1 0	NRR/DHFS DEPY08	1 1
NRR/DL DIR	1 1	NRR/DL/ORAB	1 0
NRR/DSI/RAB	1 1	REG FILE 04	1 1
RGN2	1 1		

EXTERNAL: ACRS 09	10 10	LPDR 03	1 1
NRC PDR 02	1 1	NSIC 05	1 1
NTIS	1 1		

NOTES: 1 1

vh

TOTAL NUMBER OF COPIES REQUIRED: LTR 29 ENCL 27

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

September 10, 1982

TELEPHONE
(704) 373-4531

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. John F. Stolz, Chief
Operating Reactors Branch No. 4

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287


Dear Sir:

Pursuant to 10 CFR 50, §50.90, please find attached a proposed amendment to the Oconee Facility Operating License and revision to the Oconee Technical Specifications. This proposal requests minor changes to Technical Specification 4.4 to correct incorrect designations in Table 4.4-1.

The existing Specification 4.4 was approved by the NRC November 6, 1981. Inadvertently, through an incorrect interpretation of 10 CFR 50, Appendix J local leak testing requirements, certain penetrations were designated as requiring Type B testing when they should have been designated as requiring Type C local leak testing. The penetrations in error have diaphragm isolation valves which was interpreted to require Type B local leak testing. More appropriately though, these penetrations should be Type C tested. Thus, the proposed changes, as indicated in the attached, are requested to correct this error. The penetrations in question are in fact being Type C tested.

This proposed revision to the Oconee Technical Specifications is considered to supplement my request of July 30, 1982. As such, no additional license fees are provided.

Very truly yours,



Hal B. Tucker

RLG/php
Attachment

cc: Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

A001

8209200119 820910
PDR ADOCK 05000269
PDR


Mr. Harold R. Denton, Director
September 10, 1982
Page 2

cc: Mr. W. T. Orders
NRC Resident Inspector
Oconee Nuclear Station

Mr. Philip C. Wagner
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Harold R. Denton, Director
September 10, 1982
Page 3

HAL B. TUCKER, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Technical Specifications, Appendix A to Facility Operating Licenses DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.



Hal B. Tucker, Vice President

Subscribed and sworn to before me this 10th day of September, 1982.


Notary Public

My Commission Expires:

September 20, 1984