

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8210040232 DOC. DATE: 82/09/27 NOTARIZED: YES
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.

DOCKET #
 05000269
 05000270
 05000287

AUTH. NAME: TUCKER, H.B.
 RECIP. NAME: DENTON, H.R.
 STOLZ, J.F.
 AUTHOR AFFILIATION: Duke Power Co.
 RECIPIENT AFFILIATION: Office of Nuclear Reactor Regulation, Director
 Operating Reactors Branch 4

SUBJECT: Application to amend Licenses DPR-38, DPR-47 & DPR-55. Amend requests deletion of Tech Spec 6.4.2 re site emergency drill & definition of time within which redundant component must be performed prior to performing maint per Tech Spec 3.3.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+4
 TITLE: OR Submittal: General Distribution

NOTES: AEOD/Ornstein:1cy.
 AEOD/Ornstein:1cy.
 AEOD/Ornstein:1cy.

05000269
 05000270
 05000287

W/Check: \$4800.00

RECIPIENT		COPIES		RECIPIENT		COPIES	
ID	CODE/NAME	LTTR	ENCL	ID	CODE/NAME	LTTR	ENCL
NRR	ORB4 BC 01	7	7				
INTERNAL:	ELD/HDS4	1	0	NRR/DHFS	DEPY08	1	1
	NRR/DL DIR	1	1	NRR/DL/ORAB		1	0
	NRR/DSI/RAB	1	1	REG FILE	04	1	1
	RGN2	1	1				
EXTERNAL:	ACRS	09	6	LPDR	03	1	1
	NRC PDR	02	1	NSIC	05	1	1
	NTIS		1				
NOTES:		1	1				

DUKE POWER COMPANY

P.O. BOX 33189

CHARLOTTE, N.C. 28242

HAL B. TUCKER

VICE PRESIDENT
NUCLEAR PRODUCTION

September 27, 1982

TELEPHONE
(704) 373-4531

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. John F. Stolz, Chief
Operating Reactors Branch No. 4

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287

Dear Sir:


Pursuant to 10 CFR 50, §50.90, please find attached a proposed amendment to the Oconee Facility Operating License and revision to the Oconee Technical Specifications. This proposal requests deletion of Technical Specification 6.4.2 involving site emergency drills. Also, a clarification to the bases of Technical Specification 3.3 is requested.

The existing Technical Specification 6.4.2 requires quarterly site emergency drills to be conducted. The requirement for and description of site emergency drills are appropriately addressed in the Oconee Nuclear Station Emergency Plan Part N as a semi-annual requirement. This should be the controlling document for this area and the requirements contained therein are consistent with McGuire Nuclear Station and with what is planned for Catawba Nuclear Station.

The change in the bases of Technical Specification 3.3 is to clearly define the time period within which redundant component testing must be performed prior to performance maintenance. The maximum limit of 24 hours allows some flexibility in scheduling of manpower and equipment testing while ensuring that the test is performed directly prior to performing maintenance.

This proposed revision to the Oconee Technical Specifications is considered to consist of one Class III and two Class I license amendments. Accordingly, please find enclosed a check in the amount of \$4800 for the applicable licensing fees.

Very truly yours,



Hal B. Tucker

JFN/php
Attachment

A001
w/Check: \$4800.00

8210040232 820927
PDR ADCK 05000269
P PDR

Mr. Harold R. Denton, Director
September 27, 1982
Page 2


cc: Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Mr. W. T. Orders
NRC Resident Inspector
Oconee Nuclear Station

Mr. Philip C. Wagner
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Harold R. Denton, Director
September 27, 1982
Page 3

HAL B. TUCKER, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this request for amendment of the Oconee Nuclear Station Technical Specifications, Appendix A to Facility Operating Licenses DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth therein are true and correct to the best of his knowledge.



Hal B. Tucker, Vice President

Subscribed and sworn to before me this 27th day of September, 1982.



Notary Public

My Commission Expires:

September 20, 1984