

### 3.1 REACTOR COOLANT SYSTEM

#### Applicability

Applies to the operating status of the reactor coolant system.

#### Objective

To specify those limiting conditions for operation of the reactor coolant system components which must be met to ensure safe reactor operation.

#### Specification

##### 3.1.1 Operational Components

###### a. Reactor Coolant Pumps

1. Whenever the reactor is critical, single pump operation shall be prohibited, single-loop operation shall be restricted to testing, and other pump combinations permissible for given power levels shall be as shown in Table 2.3-1.
2. Except for test purposes and limited by Specification 2.3, power operation with one idle reactor coolant pump in each loop shall be restricted to 24 hours. If the reactor is not returned to an acceptable RC pump operating combination at the end of the 24-hour period, the reactor shall be in a hot shutdown condition within the next 12 hours.
3. The boron concentration in the reactor coolant system shall not be reduced unless at least one reactor coolant pump or one low pressure injection pump is circulating reactor coolant.

###### b. Steam Generator

1. One steam generator shall be operable whenever the reactor coolant average temperature is above 250°F.

###### c. Pressurizer Safety Valves

- \*1. All pressurizer code safety valves shall be operable whenever the reactor is critical.
2. At least one pressurizer code safety valve shall be operable whenever all reactor coolant system openings are closed, except for hydrostatic tests in accordance with the ASME Section III Boiler and Pressure Vessel Code.

\*The code safety valves can be considered operable until 11:59 p.m., October 29, 1982. At such time, any unit with code safety valves without the correct ring settings shall be shutdown.