

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242


WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

February 2, 1981

TELEPHONE: AREA 704
373-4083

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Re: Oconee Nuclear Station
U. S. NRC IE Bulletin 80-11
Docket Nos 50-269, -270, -287



Dear Mr. O'Reilly:

This letter supplements my letters of July, October 28, and November 4, 1980 which previously provided information in response to IE Bulletin 80-11.

During a site visit to Oconee Nuclear Station by Mr. Joe Lenihan of USNRC Atlanta office on 6-9 January 1981, it was determined that several masonry walls at the station had not been surveyed in the conduct of initial as-built surveillance required by the subject bulletin. Review of the events leading up to the initial surveillance revealed that nine areas in the plant were not surveyed because no masonry walls were found in an office search of drawings showing these areas. Subsequent review of these drawings showed the existence of five masonry walls which had not been surveyed.

An exhaustive search of the nine areas concerned was conducted by trained engineers during the period 13-16 January 1981. No masonry walls other than the five which are shown on the as-built plant drawings were found. The additional walls are:

<u>Drawing</u>	<u>Wall Identification*</u>	<u>Priority**</u>
0-13	T1-775.0-2526-HJ-1165	III
	T1-775.0-HJ-2526-1166	III
	T1-775.0-2526-HJ-1167	III
	T1-775.0-HJ-2526-1168	III
0-2018	A3-783.8-PQ-8889-1463	I

* Wall identification is as defined in Duke's 60-day response to the bulletin. (William O. Parker letter dated July 7, 1980)

** The priority system is defined in Duke's 60-day response to the bulletin. (William O. Parker letter dated July 7, 1980)

8102200129

Q

Mr. James P. O'Reilly

Page 2

February 2, 1981

The five additional walls were surveyed in accordance with established procedures and will be included in the review of all masonry walls at Oconee Nuclear Station.

Very truly yours,

A handwritten signature in cursive script, reading "William O. Parker, Jr." followed by a stylized flourish.

William O. Parker, Jr.

RLG:pw

cc: Director
Division of Reactor Operations
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555