

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9301070377 DOC. DATE: 92/12/31 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 AUTH. NAME AUTHOR AFFILIATION
 HAMPTON, J.W. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Submits Category C-3 SG tube insp results, per TS 4.17.6.c.
 All defective tubes will be plugged or repaired prior to
 resumption of plant operation.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR Submittal: General Distribution

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD2-3 LA	1 1	PD2-3 PD	1 1
WIENS, L	2 2		
INTERNAL: ACRS	6 6	NRR/DET/ESGB	1 1
NRR/DOEA/OTSB11	1 1	NRR/DST/SELB 7E	1 1
NRR/DST/SICB8H7	1 1	NRR/DST/SRXB 8E	1 1
NUDOCS-ABSTRACT	1 1	OC/LEMB	1 0
OGC/HDS2	1 0	<u>REG FILE</u> 01	1 1
RES/DSIR/EIB	1 1		
EXTERNAL: NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 22 ENCL 20 0

Duke Power Company
Oconee Nuclear Generation Department
P.O. Box 1439
Seneca, SC 29679

J.W. HAMPTON
Vice President
(803)885-3499 Office
(704)373-5222 FAX



DUKE POWER

December 31, 1992

U.S. Nuclear Regulatory Commission
Attention Document Control Desk
Washington, DC 20555


Subject: Duke Power Company
Oconee Nuclear Station
Docket No. 50-269
Category C-3 Steam Generator Tube Inspection Results

As required by Technical Specification 4.17.6.c, Duke Power is notifying the NRC the results of the Unit 1 EOC 14 Steam Generator Tube Inspection for Steam Generators (SG) "A" and "B" has been classified as Category C-3. 10437 tubes were inspected in "A" SG with 125 tubes found defective (having an imperfection which reduces the nominal tube wall by 40% or greater). 10355 tubes were inspected in SG "B" with 364 tubes found defective. Duke has decided to inspect all remaining tubes in both Steam Generators. It should be understood the completion of the analysis on the initial sample and results from the examination of the additional tubes may cause the numbers of defective tubes relected above to increase or decrease.

All defective tubes will be plugged or repaired prior to resumption of plant operation. The description of investigations conducted to determine cause of tube degradation and corrective measures taken to prevent recurrence will be addressed in the 30 day report to NRC required by Technical Specification 4.17.6.a.

If you have any questions or need further information you may contact M. E. Patrick at (803) 885-3292.

Very truly yours,


J. W. Hampton

9301070377 921231
PDR ADDCK 05000269
P PDR

Printed on recycled paper

070035

A001 1/0

U. S. Nuclear Regulatory Commission
Page 2

xc: Mr. L. A. Wiens
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. S. D. Ebnetter
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission

Mr. P. E. Harmon
Senior NRC Resident Inspector
Oconee Nuclear Station

Mr. Heyward G. Shealy
Bureau of Radiological Health
SC Dept. of Health & Environmental Control
2600 Bull St.
Columbia, SC 29201