

SUMMARY OF SPECIMENS PROVIDED FOR EACH EXPOSURE LOCATION

<u>Capsule Designation</u>	<u>Capsule Location</u>	<u>Type and Quantity of Samples</u>								<u>Total</u>		
		<u>Base Metal</u>			<u>Heat Affected Zone</u>		<u>Weld</u>		<u>Standard</u>	<u>Impact</u>		
		<u>Impact</u>	<u>Impact</u>	<u>Tensile</u>	<u>Impact</u>	<u>Tensile</u>	<u>Impact</u>	<u>Tensile</u>	<u>Impact</u>	<u>(L)</u>	<u>(T)</u>	<u>Tensile</u>
T-330	Thermal(a)	12	12	3	12	3	12	3	-	36	12	9
T-150	Thermal	12	12	3	12	3	12	3	-	36	12	9
A-60	Accelerated(b)(d)	12	-	3	12	3	12	3	12	48	-	9
A-240	Accelerated	12	12	3	12	3	12	3	-	36	12	9
W-290	Vessel(c)	12	12	3	12	3	12	3	-	36	12	9
W-110	Vessel	12	-	3	12	3	12	3	12	48	-	9
W-100	Vessel	12	12	3	12	3	12	3	-	36	12	9
W-280	Vessel	12	12	3	12	3	12	3	-	36	12	9
W-260	Vessel	12	-	3	12	3	12	3	12	48	-	9
W-80	Vessel	12	-	3	12	3	12	3	12	48	-	9
		120	72	30	120	30	120	30	48	408	72	90

(L) = Longitudinal
(T) = Transverse

(a) Thermal Capsules – Located Above the Core

(b) Accelerated Capsules – Located on Outside of Core Support Barrel

(c) Vessel Capsules – Located on Inside Wall of Reactor Vessel

(d) Capsule A-60 has been deleted from the Reactor Vessel Surveillance Capsule Program (see Reference 19)

SUMMARY OF SPECIMENS PROVIDED FOR EACH SUPPLEMENTAL SURVEILLANCE CAPSULE

	SA-60-01			SA-240-1		
MATERIAL	Modified Impact (T)	Standard Impact (L)	Tensile	Modified Impact (T)	Standard Impact (L)	Tensile
W5124	39			42		
34B009	39			36		
27204	36	12	3	36	12	3
HSST 02		12			12	