

REACTOR VESSEL SURVEILLANCE COUPON REMOVAL SCHEDULE

Withdrawal Sequence	Capsule	Removal Time (EFPY)	Capsule Fluence X 10 ¹⁹ (n/cm ²)	Refuel Number
First	A-240	2.26	4.01	2
Second	W-290	5.21	0.926	5
	T-330	5.21		5
Third	W-110	9.95	1.66	10
Fourth	W-100	16.93	2.1	16
Fifth	W-80	~ 31.96	~ 3.06	~ 27
	W-280	Reserved for future use		
	W-260	Reserved for future use		
	T-150	Reserved for future use		

Revision of the removal schedule requires NRC approval prior to implementation per 10CFR50, Appendix H. Schedule approved by NRC August 14, 2007 (TAC No. MD3461).