




**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, D.C. 20555-0001

August 27, 2015

MEMORANDUM TO: Robert J. Pascarelli, Chief
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

FROM: G. Edward Miller, Project Manager
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation 

SUBJECT: SUMMARY OF AUGUST 12, 2015, PUBLIC TELECONFERENCE
REGARDING POTENTIAL SUBMISSION OF A LICENSE
AMENDMENT REQUEST TO ALLOW ALTERNATE
VERIFICATION OF ICE CONDENSER DOOR POSITION

On August 12, 2015, the U. S. Nuclear Regulatory Commission (NRC) staff held a public teleconference¹ with the Duke Energy Carolinas (Duke or licensee). The purpose of the meeting was to discuss Duke's intention to submit a license amendment request that would allow for alternate means of verifying that the inlet door for the ice condenser is closed in the event that a spurious alarm from the normal monitoring system is received.

During the meeting, Duke presented slides² that detailed the containment design and configuration, operating experience that drove the request, the proposed Technical Specification (TS) changes, and additional supporting information to be submitted. During the discussion, the NRC staff asked questions and provided the following suggestions:

- Duke should include a discussion of how many doors are assumed to fail to open in the accident analysis;
- The proposed condition B may be better structured in the manner of the existing condition B (e.g., Inoperable for reasons other than Condition A); and
- Duke should ensure that the TSs are clear that it is the air temperature that is being measured, not the ice temperature.

¹ The original meeting notice is available via the Agencywide Documents Access and Management System (ADAMS) under Accession No. ML15211A008.

² The licensee's slides are available under ADAMS Accession No. ML15230A594.

R. Pascarelli

- 2 -

No regulatory decisions were made and the licensee indicated that they would consider the feedback provided by the NRC staff.

Following the discussion, an opportunity was afforded to any other participants who wished to ask questions or make comments. No questions or comments were received.

CONTACT: G. Edward Miller, NRR/DORL/LPL2-1
301-415-2481

Enclosure:
List of Attendees

R. Pascarelli

- 2 -

No regulatory decisions were made and the licensee indicated that they would consider the feedback provided by the NRC staff.

Following the discussion, an opportunity was afforded to any other participants who wished to ask questions or make comments. No questions or comments were received.

CONTACT: G. Edward Miller, NRR/DORL/LPL2-1
301-415-2481

Enclosure:
List of Attendees

DISTRIBUTION:

PUBLIC

RidsOgcMailCenter Resource

RidsNrrLASFigueora Resource

RidsOpaMail Resource

RidsNrrDorl Resource

RidsAcrcAcnw_MailCTR Resource

CJackson, NRR/DSS

ADAMS Accession No.:ML15229A211

*via e-mail

OFFICE	DORL/LPL2-1/PM	DORL/LPL2-1/LA	DSS/SCVB	DE/EICB	DORL/LPL2-1/BC
NAME	GEMiller	SFigueora	SPeng*	EEagle*	RPascarelli
DATE	08/25/15	08/19/15	08/25/15	08/19/15	08/27/15

OFFICIAL RECORD COPY