

Enclosure 2

MFN 15-050, Revision 1

**Revised GEH Response to Item #4,
Maximum Groundwater Level**

ABWR DCD DRAFT Revision 6 Markups

IMPORTANT NOTICE REGARDING CONTENTS OF THIS DOCUMENT Please Read Carefully

The information contained in this document is furnished solely for the purpose(s) stated in the transmittal letter. The only undertakings of GEH with respect to information in this document are contained in the contracts between GEH and its customers or participating utilities, and nothing contained in this document shall be construed as changing that contract. The use of this information by anyone for any purpose other than that for which it is intended is not authorized; and with respect to any unauthorized use, GEH makes no representation or warranty, and assumes no liability as to the completeness, accuracy, or usefulness of the information contained in this document.

Chapter 2

Table of Contents

2.0	Site Characteristics	2.0-1
2.0.1	Summary.....	2.0-1
2.1	Limits Imposed on SRP Section II Acceptance Criteria by ABWR Standard Plant	2.1-1
2.2	Requirements for Determination of ABWR Site Acceptability	2.2-1
2.2.1	Design Basis Events	2.2-1
2.2.2	Severe Accidents	2.2-1
2.3	COL License Information.....	2.3-1
2.3.1	Envelope of Standard Plant Design Parameters	2.3-1
2.3.2	Standard Review Plant Site Characteristics	2.3-1
2.3.3	CRAC 2 Computer Code Calculations.....	2.3-7
2A	Input to CRAC 2 Computer Code for Determination of ABWR Site Acceptability.....	2A-1
	2.0.2 References	2.0-1

2.0 Site Characteristics

2.0.1 Summary

This section defines the envelope of site-related parameters which the ABWR Standard Plant is designed to accommodate. These parameters envelope most potential sites in the U.S. A summary of the site envelope design parameters is given in Table 2.0-1.

2.0.2 References

2.0.2-1 Electric Power Research Institute, "Advanced Light Water Reactor Utility Requirements Document," Revision 8, March 1999

Copy mark

Table 2.0-1
Envelope of ABWR Standard Plant Site Design Parameters

Maximum Ground Water Level:	61.0 cm below grade
Extreme Wind:	Basic Wind Speed: 177 km/h* / 197 km/h†
Maximum Flood (or Tsunami) Level:‡	30.5 cm below grade
Tornado:	<ul style="list-style-type: none"> – Maximum Tornado Wind Speed: 483 km/h – Maximum Rotational Speed: 386 km/h – Translational Velocity: 97 km/h – Radius: 45.7m – Maximum Pressure Drop: 13.827 kPaD – Rate of Pressure Drop: 8.277 kPa/s – Missile Spectra: Spectrum I^f
Precipitation (for Roof Design):	<ul style="list-style-type: none"> – Maximum Rainfall Rate: 49.3 cm/h** – Maximum Snow Load: 2.394 kPa
Ambient Design Temperature:	1% Exceedance Values <ul style="list-style-type: none"> – Maximum: 37.8°C dry bulb 25°C wet bulb (coincident) 26.7°C wet bulb (non-coincident) – Minimum: –23.3°C 0% Exceedance Values (Historical limit) <ul style="list-style-type: none"> – Maximum 46.1°C dry bulb 26.7°C wet bulb (coincident) 27.2°C wet bulb (non-coincident) – Minimum: –40°C
Soil Properties:	<ul style="list-style-type: none"> – Minimum Static Bearing Capacity: 718.20 kPa†† – Minimum Shear Wave Velocity: 305 m/s‡‡ – Liquification Potential: None at plant site resulting from site specific SSE ground motion

Table 2.0-1
Envelope of ABWR Standard Plant Site Design Parameters (Continued)

Seismology:	– SSE Peak Ground Acceleration:	0.30g ^{ff}
	– SSE Response Spectra:	per RG 1.60
	– SSE Time History:	Envelope SSE Response Spectra
Hazards in Site Vicinity:	– Site Proximity Missiles and Aircraft	
	– Toxic Gases	≤10 ⁻⁷ per year
	– Volcanic Activity	None
	– An area whose boundary has a	None
Exclusion Area Boundary: (EAB)	Chi/Q less than or equal to 1.37 x	
	10 ⁻³ s/m ³	
Meteorological Dispersion (Chi/Q):	– Maximum 2-hour 95% EAB	1.37x10 ⁻³ s/m ³
	– Maximum 2-hour 95% LPZ	4.11x10 ⁻⁴ s/m ³
	– Maximum annual average (8760	1.17x10 ⁻⁶ s/m ³
	hour) LPZ	

* 50-year recurrence interval; value to be utilized for design of non-safety-related structures only.

† 100-year recurrence interval; value to be utilized for design for safety-related structures only.

‡ ~~Probable maximum flood level (PMF), as defined in ANSI/ANS 2.8, "Determining Design Basis Flooding at Power Reactor Sites."~~

f Spectrum I missiles consist of a massive high kinetic energy missile which deforms on impact, a rigid missile to test penetration resistance, and a small rigid missile of a size sufficient to just pass through any openings in protective barriers. These missiles consists of an 1800 kg automobile, a 125 kg, 20 cm diameter armor piercing artillery shell, and a 2.54 cm diameter solid steel sphere, all impacting at 35% of the maximum horizontal windspeed of the design basis tornado. The first two missiles are assumed to impact at normal incidence, the last to impinge upon openings in the most damaging directions.

** Maximum value for 1 hour over 2.6 km² probable maximum precipitation (PMP) with ratio of 5 minutes to 1 hour PMP of 0.32 as found in National Weather Source Publication HMR No. 52. Maximum short term rate: 15.7 cm/5 min.

†† At foundation level of the reactor and control buildings.

‡‡ This is the minimum shear wave velocity at low strains after the soil property uncertainties have been applied.

ff Free-field, at plant grade elevation.

As defined in Table 1.2-6 of Volume II of Reference 2.0.2-1.