

NRR-PMDAPEm Resource

From: Dion, Jeanne
Sent: Tuesday, August 25, 2015 3:00 PM
To: Bryan, Robert H Jr.; Arent, Gordon
Cc: Poole, Justin; Stockton, Rickey A
Subject: RE: RE: WBN 1 draft RAIs MF6191 – Updated Inservice Test Program and Relief Requests for Third Ten Year Interval
Attachments: Final RAI on IST.docx

Gentlemen,
TVA submitted a relief request “Updated Inservice Test Program and Relief Requests for Third Ten Year Interval,” dated April 9, 2015 (Agencywide Document Access and Management System (ADAMS) Accession Number ML151103A322). During the NRC’s review, the staff identified the attached Request for information (RAI) needed to complete the review. Please provide your response no later than Sept 25, 2015.

Jeanne Dion
Project Manager
Watts Bar Special Projects Branch
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation
301-415-1349

From: Bryan, Robert H Jr. [mailto:rhbryan@tva.gov]
Sent: Tuesday, August 25, 2015 2:52 PM
To: Dion, Jeanne ; Arent, Gordon
Cc: Poole, Justin ; Stockton, Rickey A
Subject: [External_Sender] RE: WBN 1 draft RAIs MF6191 – Updated Inservice Test Program and Relief Requests for Third Ten Year Interval

Jeanne,

We understand the question and we do not need a clarification phone call. Please issue with a 30 day response window. Thanks.

Bob Bryan

WBN Manager Licensing Unit 1/ Unit 2
(423) 452-4142

NOTICE: This electronic message transmission contains information which may be TVA SENSITIVE, TVA RESTRICTED or TVA CONFIDENTIAL. Any misuse or unauthorized disclosure can result in both civil and criminal penalties. If you are not the intended recipient, be aware that any disclosure, copying, distribution or use of the content of this information is prohibited. If you have received this communication in error, please notify me immediately by email and delete the original message.

From: Dion, Jeanne [mailto:Jeanne.Dion@nrc.gov]
Sent: Monday, August 03, 2015 11:33 AM
To: Arent, Gordon; Bryan, Robert H Jr.
Cc: Poole, Justin
Subject: WBN 1 draft RAIs MF6191 – Updated Inservice Test Program and Relief Requests for Third Ten Year Interval

TVA External Message. Please use caution when opening.

Gordon,

TVA submitted a relief request “Updated Inservice Test Program and Relief Requests for Third Ten Year Interval,” dated April 9, 2015 (Agencywide Document Access and Management System (ADAMS) Accession Number ML151103A322). During the NRC’s review, the staff identified the attached draft Request for information (RAI). Please let me know if you need any further clarification on this request before we issue them as final RAIs.

Thanks,

**Jeanne Dion
Project Manager
Watts Bar Special Projects Branch
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation
301-415-1349**

Hearing Identifier: NRR_PMDA
Email Number: 2334

Mail Envelope Properties (d89c823080d441beaf0e5fcf3a4daf24)

Subject: RE: RE: WBN 1 draft RAIs MF6191 – Updated Inservice Test Program and Relief Requests for Third Ten Year Interval
Sent Date: 8/25/2015 3:00:17 PM
Received Date: 8/25/2015 3:00:00 PM
From: Dion, Jeanne

Created By: Jeanne.Dion@nrc.gov

Recipients:

"Poole, Justin" <Justin.Poole@nrc.gov>
Tracking Status: None
"Stockton, Rickey A" <rastockton@tva.gov>
Tracking Status: None
"Bryan, Robert H Jr." <rhbryan@tva.gov>
Tracking Status: None
"Arent, Gordon" <garent@tva.gov>
Tracking Status: None

Post Office: HQPWMSMRS08.nrc.gov

Files	Size	Date & Time
MESSAGE	2687	8/25/2015 3:00:00 PM
Final RAI on IST.docx	26121	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

**REQUEST FOR ADDITIONAL INFORMATION(RAI)
TENNESSEE VALLEY AUTHORITY
WATTS BAR NUCLEAR PLANT UNIT 1
RELIEF REQUEST IST-RR-2
DOCKET NUMBER 50-390
(TAC NO. MF6191)**

Reference:

Letter from J. W. Shea of the Tennessee Valley Authority to NRC, "Watts Bar Nuclear Plant, Unit 1 – Updated Inservice Test Program and Relief Requests for Third Ten Year Interval," dated April 9, 2015(Agencywide Document Access and Management System (ADAMS) Accession Number ML151103A322).

RAI IST-RR-2-1

The last time this relief request was submitted and approved, it was stated that for a new essential raw cooling water (ERCW) screen wash pump, the bowl assembly will be tested at the vendor's facility, and the test data is adjusted to account for the pump column in order for the vendor to develop a pump curve. This process is not mentioned in this relief request. Please state if this process will be performed for a new ERCW screen wash pump during this inservice testing interval.