

PRIORITY 1

ACCELERATED RIDS PROCESSING

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9502100253 DOC. DATE: 95/01/27 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 HAMPTON, J.W. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Informs that util has reviewed Keowee operating limits supporting calculation & determined that addl instrument tolerances needed to be incorporated into calculation.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD2-3 LA	1 1	PD2-3 PD	1 1
	WIENS, L	1 1		
INTERNAL:	ACRS	6 6	<u>FILE CENTER</u> 01	1 1
	NRR/DRCH/HICB	1 1	NRR/DSSA/SPLB	1 1
	NRR/DSSA/SRXB	1 1	NUDOCS-ABSTRACT	1 1
	OGC/HDS2	1 0		
EXTERNAL:	NOAC	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 17 ENCL 16 0

MAY

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T

Duke Power Company
Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679

J. W. HAMPTON
Vice President
(803)885-3499 Office
(803)885-3564 Fax



DUKE POWER

January 27, 1995

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Emergency Power System

A conference call was held between Duke and the NRC on 1/27/95. Duke committed to providing a written summary of the Keowee generation limits which were discussed in the conference call. This letter confirms our position on the generation output limits for the Keowee Hydro Station.

As a followup to our meeting with the NRC on 1/19/95, Duke has reviewed the Keowee operating limits supporting calculation and determined that additional instrument tolerances needed to be incorporated into the calculation. The addition of these tolerances will result in a lower output limit for the Keowee unit which generates to the grid. Currently, the Keowee units remain operable for their design basis mode, and are prohibited from generating to the grid by administrative controls. Upon completion of the calculation revision and approval by the Oconee PORC, generation will be resumed using a single Keowee unit. The new generation limit will be based on the 1971 startup test data and will include the additional instrument tolerances. Once the calculation revision is completed, a copy will be provided to the NRC. This new limit will not be further revised without prior discussion with the NRC.

In addition, the calculation for the generation limits associated with the proposed modification, which is under review by the NRC, will be revised. Upon completion of the calculation, a copy will be provided to the NRC for use in completing the review of the modification.

Very truly yours,

J. W. Hampton *for*

9502100253 950127
PDR ADOCK 05000269
P PDR

ADD 1/0

cc: Mr. S. D. Ebnetter, Regional Administrator
U. S. Nuclear Regulatory Commission, Region II

Mr. L. A. Wiens, Project Manager
Office of Nuclear Reactor Regulation

Mr. P. E. Harmon
Senior Resident Inspector
Oconee Nuclear Site