

PRIORITY 1
(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9503140126 DOC. DATE: 95/03/08 NOTARIZED: NO DOCKET #
FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
HAMPTON, J.W. Duke Power Co.
RECIP. NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Discusses 950119 meeting minutes for proposed mod on plant emergency power sys.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 LA	1	PD2-3 PD	1
	WIENS, L	1		
INTERNAL:	ACRS	6	FILE CENTER O.P.	1
	NRR/DRCH/HICB	1	NRR/DSSA/SPLB	1
	NRR/DSSA/SRXB	1	NUDOCS-ABSTRACT	1
	OGC/HDS2	1		
EXTERNAL:	NOAC	1	NRC PDR	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 17 ENCL ~~16~~ 0

may

Duke Power Company
Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679

J. W. HAMPTON
Vice President
(803)885-3499 Office
(803)885-3564 Fax



DUKE POWER

March 8, 1995

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
January 19, 1995 Meeting Minutes for the Proposed
Modification on the Oconee Emergency Power System

In the letter dated January 26, 1995, a summary of the subject meeting was provided. Several statements made by Duke during the meeting are listed in this letter. Two of these statements require additional clarification in order to ensure that the appropriate interpretation is achieved.

The first statement pertains to the fact that the switchyard yellow bus is part of the onsite power system at all times. This should be changed to indicate that the switchyard yellow bus is part of the onsite and offsite power systems. Since the yellow bus is part of the switchyard, it is included in the offsite power system. In addition to being part of the switchyard, the yellow bus is part of the overhead emergency power path following switchyard isolation.

The second statement is that any single failure was assumed to occur simultaneously with the initiating event. This should be changed to indicate that any single failure was assumed to occur immediately upon demand. Therefore, a failure was assumed to occur when the equipment was called upon to perform its safety function. This failure could be simultaneous to the initiating event or at some time during the mitigation of the event.

Very truly yours,

J. W. Hampton, Site Vice President
Oconee Nuclear Station

A001
1/0

cc: Mr. S. D. Ebnetter, Regional Administrator
U. S. Nuclear Regulatory Commission, Region II

Mr. L. A. Wiens, Project Manager
Office of Nuclear Reactor Regulation

Mr. P. E. Harmon
Senior Resident Inspector
Ocone Nuclear Site