

**PRIORITY 1**

(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9508010147      DOC. DATE: 95/07/17      NOTARIZED: NO      DOCKET #  
FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.      05000269      P  
50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.      05000270  
50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.      05000287      R

AUTH. NAME      AUTHOR AFFILIATION  
HAMPTON, J.W.      Duke Power Co.  
RECIP. NAME      RECIPIENT AFFILIATION  
Document Control Branch (Document Control Desk)      I

SUBJECT: Provides list of changes made to Unit 3 Data Point Library.      O

DISTRIBUTION CODE: A026D      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5      R  
TITLE: Emergency Response Data System (ERDS)

NOTES:      I

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
	AEOD/IRB      01	2      2	NRR/PD3-2	1      1	T
	WIENS, L	1      1			Y
INTERNAL:	ACRS	1      1	AEOD	1      1	
	AEOD/DOA/IRB	1      1	<u>FILE CENTER</u>	1      1	
	RGN2      ERC	1      1	RGN2      FILE	1      1	1
EXTERNAL:	NRC PDR	1      1			

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL  
DESK, ROOM OWFN 5D8 (415-2083) TO ELIMINATE YOUR NAME FROM  
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR      11      ENCL      11

*MA4*

Duke Power Company  
Oconee Nuclear Generation Department  
P.O. Box 1439  
Seneca, SC 29679

J.W. HAMPTON  
Vice President  
(803)885-3499 Office  
(704)373-5222 FAX



**DUKE POWER**  
July 17, 1995

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Subject: Oconee Nuclear Station  
Docket Number 50-269, 50-270, 50-287  
Emergency Response Data System


10CFR50, Appendix E, Section VI 3.a. requires that any software change that affects the transmitted data points identified in the ERDS Data Point Library must be submitted to the NCR within 30 days after the changes are completed.

Listed below are the changes that were made to Unit 3 Data Point Library.

<u>DATA POINT</u>	<u>UNIT 3</u>
A1537	06/22/95
A1541	06/22/95
A1031	06/30/95
A1026	06/30/95

If there are questions regarding the Emergency Response Data System, please contact Coleman Jennings at (803) 855-3294.

Very truly yours,

  
J. W. Hampton  
VP, Oconee Nuclear Site

cc: Mr. S. D. Ebnetter, Regional Administrator  
U.S. Nuclear Regulatory Commission, Region II

Mr. L. A. Wiens, Project Manager  
Oconee Project Manager

Mr. Paul Harmon  
Oconee Resident Inspector

Mr. John Jolicoeur  
Office of Analysis & Evaluation

9508010147 950717  
PDR ADOCK 05000269  
P PDR

Printed on recycled paper

A026  
11

=====

**Oconee Emergency Resp**

=====

=====

**onse Data System**

=====

<b>DATE:</b>	<b>7/22/93</b>
<b>REACTOR UNIT:</b>	<b>oc3</b>
<b>DATA FEEDER:</b>	<b>N/A</b>
<b>NRC ERDS PARAMETER:</b>	<b>NI SOURC RNG</b>
<b>POINT ID:</b>	<b>a1537</b>
<b>PLANT SPEC POINT DESC:</b>	
<b>GENERIC/COND DESC:</b>	
<b>ANALOG/DIGITAL:</b>	<b>A</b>
<b>ENGR UNITS/DIG STATES:</b>	<b>CPS</b>
<b>ENGR UNITS CONV:</b>	<b>N/A</b>
<b>MINIMUM INSTR RANGE:</b>	<b>.1</b>
<b>MAXIMUM INSTR RANGE:</b>	<b>1E5</b>
<b>ZERO POINT REFERENCE:</b>	<b>N/A</b>
<b>REFERENCE POINT NOTES:</b>	<b>N/A</b>
<b>PROC OR SENS:</b>	<b>S</b>
<b>NUMBER OF SENSORS:</b>	<b>1</b>
<b>HOW PROCESSED:</b>	<b>N/A</b>
<b>SENSOR LOCATIONS:</b>	<b>OUTSIDE OF RX VESSEL</b>
<b>ALARM/TRIP SET POINTS:</b>	<b>NONE</b>
<b>NI CUTOFF PWR LEVEL:</b>	<b>N/A</b>
<b>NI CUTOFF PWR LEVEL:</b>	<b>N/A</b>
<b>INST FAILURE MODE:</b>	<b>LOW</b>
<b>TEMP COMPENSATION:</b>	<b>N</b>
<b>LEVEL REF LEG:</b>	<b>N/A</b>
<b>UNIQUE SYSTEM DESC:</b>	

=====

**Oconee Emergency Resp**

=====

=====

**onse Data System**

=====

<b>DATE:</b>	<b>1/19/93</b>
<b>REACTOR UNIT:</b>	<b>oc3</b>
<b>DATA FEEDER:</b>	<b>N/A</b>
<b>NRC ERDS PARAMETER:</b>	<b>NI INTER RNG</b>
<b>POINT ID:</b>	<b>a1541</b>
<b>PLANT SPEC POINT DESC:</b>	
<b>GENERIC/COND DESC:</b>	
<b>ANALOG/DIGITAL:</b>	<b>A</b>
<b>ENGR UNITS/DIG STATES:</b>	<b>PCT</b>
<b>ENGR UNITS CONV:</b>	<b>N/A</b>
<b>MINIMUM INSTR RANGE:</b>	<b>1E-8</b>
<b>MAXIMUM INSTR RANGE:</b>	<b>2E2</b>
<b>ZERO POINT REFERENCE:</b>	<b>N/A</b>
<b>REFERENCE POINT NOTES:</b>	<b>N/A</b>
<b>PROC OR SENS:</b>	<b>S</b>
<b>NUMBER OF SENSORS:</b>	<b>1</b>
<b>HOW PROCESSED:</b>	<b>N/A</b>
<b>SENSOR LOCATIONS:</b>	<b>OUTSIDE OF RX VESSEL</b>
<b>ALARM/TRIP SET POINTS:</b>	<b>NONE</b>
<b>NI CUTOFF PWR LEVEL:</b>	<b>N/A</b>
<b>NI CUTOFF PWR LEVEL:</b>	<b>N/A</b>
<b>INST FAILURE MODE:</b>	<b>LOW</b>
<b>TEMP COMPENSATION:</b>	<b>N</b>
<b>LEVEL REF LEG:</b>	<b>N/A</b>
<b>UNIQUE SYSTEM DESC:</b>	

=====

**Oconee Emergency Resp**

=====

=====

**onse Data System**

=====

<b>DATE:</b>	<b>1/19/93</b>
<b>REACTOR UNIT:</b>	<b>oc3</b>
<b>DATA FEEDER:</b>	<b>N/A</b>
<b>NRC ERDS PARAMETER:</b>	<b>SG LEVEL 2/B</b>
<b>POINT ID:</b>	<b>a1031</b>
<b>PLANT SPEC POINT DESC:</b>	
<b>GENERIC/COND DESC:</b>	
<b>ANALOG/DIGITAL:</b>	<b>A</b>
<b>ENGR UNITS/DIG STATES:</b>	<b>INCH</b>
<b>ENGR UNITS CONV:</b>	<b>N/A</b>
<b>MINIMUM INSTR RANGE:</b>	<b>0</b>
<b>MAXIMUM INSTR RANGE:</b>	<b>650</b>
<b>ZERO POINT REFERENCE:</b>	<b>COMPLE</b>
<b>REFERENCE POINT NOTES:</b>	<b>SEE PO/0/A/1108/01, Encl. 3.19</b>
<b>PROC OR SENS:</b>	<b>S</b>
<b>NUMBER OF SENSORS:</b>	<b>1</b>
<b>HOW PROCESSED:</b>	<b>N/A</b>
<b>SENSOR LOCATIONS:</b>	<b>?</b>
<b>ALARM/TRIP SET POINTS:</b>	<b>NONE</b>
<b>NI CUTOFF PWR LEVEL:</b>	<b>N/A</b>
<b>NI CUTOFF PWR LEVEL:</b>	<b>N/A</b>
<b>INST FAILURE MODE:</b>	<b>LOW</b>
<b>TEMP COMPENSATION:</b>	<b>N</b>
<b>LEVEL REF LEG:</b>	<b>N/A</b>
<b>UNIQUE SYSTEM DESC:</b>	<b>From FDWLT0009P</b>

=====

**Oconee Emergency Resp**

=====

=====

**onse Data System**

=====

<b>DATE:</b>	<b>1/19/93</b>
<b>REACTOR UNIT:</b>	<b>oc3</b>
<b>DATA FEEDER:</b>	<b>N/A</b>
<b>NRC ERDS PARAMETER:</b>	<b>SG LEVEL 1/A</b>
<b>POINT ID:</b>	<b>a1026</b>
<b>PLANT SPEC POINT DESC:</b>	
<b>GENERIC/COND DESC:</b>	
<b>ANALOG/DIGITAL:</b>	<b>A</b>
<b>ENGR UNITS/DIG STATES:</b>	<b>INCH</b>
<b>ENGR UNITS CONV:</b>	<b>N/A</b>
<b>MINIMUM INSTR RANGE:</b>	<b>0</b>
<b>MAXIMUM INSTR RANGE:</b>	<b>650</b>
<b>ZERO POINT REFERENCE:</b>	<b>COMPLE</b>
<b>REFERENCE POINT NOTES:</b>	<b>SEE PO/0/A/1108/01, Encl. 3.19</b>
<b>PROC OR SENS:</b>	<b>S</b>
<b>NUMBER OF SENSORS:</b>	<b>1</b>
<b>HOW PROCESSED:</b>	<b>N/A</b>
<b>SENSOR LOCATIONS:</b>	<b>?</b>
<b>ALARM/TRIP SET POINTS:</b>	<b>NONE</b>
<b>NI CUTOFF PWR LEVEL:</b>	<b>N/A</b>
<b>NI CUTOFF PWR LEVEL:</b>	<b>N/A</b>
<b>INST FAILURE MODE:</b>	<b>LOW</b>
<b>TEMP COMPENSATION:</b>	<b>N</b>
<b>LEVEL REF LEG:</b>	<b>N/A</b>
<b>UNIQUE SYSTEM DESC:</b>	<b>From FDWLT0007P</b>