

CATEGORY 1

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9705070270	DOC. DATE: 97/04/28	NOTARIZED: NO	DOCKET #
FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.			05000269
50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.			05000270
50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.			05000287
50-369 William B. McGuire Nuclear Station, Unit 1, Duke Power Co.			05000369
50-370 William B. McGuire Nuclear Station, Unit 2, Duke Power Co.			05000370
50-413 Catawba Nuclear Station, Unit 1, Duke Power Co.			05000413
50-414 Catawba Nuclear Station, Unit 2, Duke Power Co.			05000414

AUTH. NAME	AUTHOR AFFILIATION
TUCKMAN, M.S.	Duke Power Co.
RECIP. NAME	RECIPIENT AFFILIATION
	Document Control Branch (Document Control Desk)

SUBJECT: Responds to GL 97-01, "Degradation of CR Drive Mechanism Nozzle & Other Vessel Closure Head Penetrations."

DISTRIBUTION CODE: A075D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: GL-97-01 Degradation of Control Rod Drive Mechanism & Other Vessel

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
LA/DRPE/PD1-1	1 1	PD2-2 PD	1 1
PD1-1/HAROLD, J	1 0	LABARGE, D	1 1
NERSES, V	1 1	TAM, P.	1 1
INTERNAL: <u>FILE CENTER</u> 01	1 1	NRR/DE/EMCB	3 3
RES/EMMEB	1 1	RGN. <u>II</u>	1 1
EXTERNAL: NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 13 ENCL 6

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

Duke Power Company
P.O. Box 1006
Charlotte, NC 28201-1006

M. S. TUCKMAN
Senior Vice President
Nuclear Generation
(704)382-2200 Office
(704)382-4360 Fax



DUKE POWER

April 28, 1997

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Subject: Catawba Nuclear Station Units 1 & 2
Docket Nos. 50 -413, 414
McGuire Nuclear Station Units 1 & 2
Docket Nos. 50 -369, 370
Oconee Nuclear Station Units 1, 2, & 3
Docket Nos. 50 -269, 270, 287
Response to Generic letter 97-01: Degradation
of Control Rod Drive Mechanism Nozzle and Other
Vessel Closure Head Penetrations

Generic Letter (GL) 97-01, "Degradation of Control Rod Drive Mechanism Nozzle and Other Vessel Closure Head Penetrations," dated April 1, 1997, requested licensees to describe their program for ensuring the timely inspection of PWR control rod drive mechanism (CRDM) and other vessel closure head penetrations. This information is needed by the staff to verify compliance with 10 CFR 50.55a and 10 CFR Part 50, Appendix A, GDC 14, and to determine whether an augmented inspection program, pursuant to 10 CFR 50.55a(g)(6)(ii), is required.

Additionally, the GL required that within 30 days utilities submit a written response indicating whether or not the requested actions will be completed, whether or not requested information will be submitted within the requested time period and discussion of any alternative actions.

Duke Power plans to complete the requested actions and submit the requested information within the requested time period.

9705070270 970428
PDR ADOCK 05000269
P PDR



AD751/0

U.S. NRC
April 28, 1997
Page 2

If you have questions or need additional information, please contact Allison Jones-Young at (704) 382-3154.

Very truly yours,



M.S. Tuckman
Senior Vice President
Nuclear Generation

xc: L.A. Reyes
Regional Administrator, Region II

V. Nerses, ONRR

P.S. Tam, ONRR

D.E. Lebarge, ONRR

S.M. Shaeffer
Senior Resident Inspector (MNS)

R.J. Freudenberger
Senior Resident Inspector (CNS)

M.A. Scott
Senior Resident Inspector (ONS)