

CATEGORY 1

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9707020081 DOC. DATE: 97/06/20 NOTARIZED: NO DOCKET #
FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287
50-369 William B. McGuire Nuclear Station, Unit 1, Duke Power Co. 05000369
50-370 William B. McGuire Nuclear Station, Unit 2, Duke Power Co. 05000370
50-413 Catawba Nuclear Station, Unit 1, Duke Power Co. 05000413
50-414 Catawba Nuclear Station, Unit 2, Duke Power Co. 05000414

AUTH. NAME AUTHOR AFFILIATION
TUCKMAN, M.S. Duke Power Co.
RECIP. NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Forwards request to use alternative to ASME B&PV code,
Section XI.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 6
TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code - GL-89-04

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 LA	1 1	PD2-2 PD	1 1
	LABARGE, D	1 1	NERSES, V	1 1
	TAM, P.	1 1		
INTERNAL:	ACRS	1 1	AEOD/SPD/RAB	1 1
	FILE CENTER	1 1	NRR/DE/EMEB	1 1
	NUDOCS-ABSTRACT	1 1	OGC/HDS2	1 0
	RES/DET/EIB	1 1	RES/DET/EMMEB	1 1
EXTERNAL:	LITCO ANDERSON	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 16 ENCL 15

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

M. S. TUCKMAN
Senior Vice President
Nuclear Generation
(704)382-2200 Office
(704)382-4360 Fax



June 20, 1997

Subject: Duke Energy Corporation
Oconee Nuclear Station, Units 1, 2, and 3
Docket Nos. 50-269, 50-270, 50-287

McGuire Nuclear Station, Units 1 and 2
Docket Nos. 50-369, 50-370

Catawba Nuclear Station, Units 1 and 2
Docket Nos. 50-413, 50-414

Request to use an Alternative to the
ASME Code, Section XI
Duke Energy Corporation Serial Number 97-GO-001

Attached is a Duke Energy Corporation request to use an alternative to the ASME Boiler and Pressure Vessel Code, Section XI. This request, Serial Number 97-GO-001, seeks NRC approval to use Code Case N-566 at Oconee, McGuire, and Catawba Nuclear Stations.

Duke Energy Corporation would like to initially implement Code Case N-566 during the End-of-Cycle Outage Number 17 on Oconee Unit 1. In order to meet this schedule, it is requested that the NRC review and approve 97-GO-001 by September 1, 1997.

Please direct questions on this request to J. S. Warren at (704) 382-4986.

Very truly yours,

M. S. Tuckman

M. S. Tuckman

9707020081 970620
PDR ADOCK 05000269
P PDR



U. S. NRC
June 20, 1997
Page 2

MST/JSW

Attachment:

Duke Energy Corporation
Request for Alternative
ASME Boiler and Pressure Vessel Code, Section XI
Serial Number 97-GO-001

xc w/att: L. A. Reyes
NRC Regional Administrator, Region II

D. E. Labarge (ONS)
V. Nerses (MNS)
P. S. Tam (CNS)
NRC Senior Project Managers
ONRR

R. J. Freudenberger (CNS)
M. A. Scott (ONS)
S. M. Shaeffer (MNS)
NRC Senior Resident Inspectors

Attachment

DUKE ENERGY CORPORATION

Request for Alternative

ASME Boiler and Pressure Vessel Code, Section XI

Background:

Pursuant to 10 CFR 50.55a (a) (3) (i), Duke Energy Corporation requests the use of an alternative to the 1989 Edition of Section XI of the ASME Boiler and Pressure Vessel Code (Code) for Oconee Units 1, 2, and 3; McGuire Units 1 and 2; and Catawba Units 1 and 2. Specifically, Duke Energy Corporation requests approval to use the alternatives of Code Case N-566, *Corrective Actions for Leakage Identified at Bolted Connections*. This Code Case has been approved by the ASME and is scheduled for publication in Supplement 6 of ASME Boiler & Pressure Vessel Code Cases Nuclear Components. It is not listed in the latest published revision of NRC Regulatory Guide 1.147 (Revision 11).

The 1989 Edition of Section XI, (no addenda), paragraph IWA-5250(a)(2) states "if leakage occurs at a bolted connection, the bolting shall be removed, VT-3 visually examined for corrosion, and evaluated in accordance with IWA-3100." Duke Power Company previously requested, and was granted, NRC approval to use the 1990 Addenda as an alternative. The 1990 Addenda allows only the one bolt closest to the leak to be removed and visually examined for corrosion by a VT-3 inspector.

I. Systems/Components for Which Alternative is Requested:

All Class 1, 2, and 3 systems/components subject to IWA-5000 pressure testing.

II. Code Requirement:

Section XI of the ASME Code, 1989 Edition with 1990 addenda, Subsection IWA-5250(a)(2) states: "If leakage occurs at a bolted connection, one of the bolts shall be removed, VT-3 examined, and evaluated in accordance with IWA-3100. The bolt selected shall be the one closest to the source of leakage. When the removed bolt has evidence of degradation, all remaining bolting in

the connection shall be removed, VT-3 examined, and evaluated in accordance with IWA-3100."

III. Requirement for Which Alternative Is Requested:

Relief is requested from the mandatory requirement to remove the bolt closest to the source of leakage when leakage is detected at a mechanical connection.

IV. Basis for Requesting Alternative:

Removal of pressure retaining bolting at mechanical connections for visual, VT-3 examination and subsequent evaluation, in locations where leakage has been identified, is not always the most discerning course of action to determine the acceptability of the bolting. The Code requirement to remove, examine, and evaluate bolting in this situation does not allow the owner to consider other factors which may indicate the acceptability of mechanical joint bolting.

Other factors which should be considered when evaluating bolting acceptability when leakage has been identified at a mechanical joint include, but are not limited to: joint bolting material, service age of joint bolting materials, location of the leakage, history of leakage at the joint, evidence of corrosion with the joint assembled, and corrosiveness of process fluid.

Performance of the pressure test while the system is in service may identify leakage at a bolted connection that, upon evaluation, may conclude the integrity and pressure retaining ability of the joint is not challenged. It would not be prudent to negatively impact the availability of a safety system by removing the system from service to address a leak that does not challenge the system's ability to perform its safety function.

A situation frequently encountered at Duke Energy Corporation is the complete replacement of bolting materials (studs, bolts, nuts, washers, etc.) at mechanical joints during plant outages. When the associated system piping is pressurized during plant start up, leakage may be identified at these joints. The root cause of this leakage is most often due to thermal expansion of the piping and bolting materials at the joint and subsequent fluid seepage at the joint gasket. Proper retorquing of the joint bolting, in most

cases, stops the leakage. Removal of the joint bolting to evaluate for corrosion would be unwarranted in this situation due to the new condition of the bolting materials.

V. Alternative Examinations:

When leakage is identified at bolted connections by visual VT-2 examination during system pressure testing, Code Case N-566 allows the owner to stop the leak and/or evaluate the integrity of the bolted connection. If the leakage is not stopped, an evaluation will be performed to determine the susceptibility of the bolting to corrosion and assess the potential for failure. Consideration may include, but not necessarily be limited to, the following factors when evaluating the acceptability of bolting:

1. Bolting materials
2. Corrosiveness of process fluid leaking
3. Leakage location
4. Leakage history at connection or other system components
5. Visual evidence of corrosion at connection (while connection is assembled)
6. Service age of bolting materials

When the pressure test is performed on a system that is in service or that Technical Specifications require to be operable, and the bolting is susceptible to corrosion, the evaluation shall address the connection's structural integrity until the next component/system outage of sufficient duration. If the evaluation concludes the system can perform its safety related function, removal of the bolt closest to the source of the leakage and VT-3 visual examination of the bolt will be performed when the system or component is taken out of service for a sufficient duration (to accomplish other system maintenance activities).

For bolting that is susceptible to corrosion, and when the initial evaluation indicates that the connection cannot conclusively perform its safety function until the next component/system outage of sufficient duration, the bolt closest to the source of the leakage will be removed, VT-3 visual examined, and will be evaluated in accordance with IWA-3100(a).

VI. Justification for Granting Alternative:

The purpose of the Code required corrective action to remove bolts and visually examine them for degradation, as stated in IWA-5250(a)(2), is to ensure joint integrity. In addition to removing bolts and performing a visual VT-3 examination, Section V above states alternative methods to ensure joint integrity of bolted connections. These alternative methods have been determined to provide an acceptable level of quality and safety.

VII. Implementation Schedule:

Oconee Unit 1 is currently scheduled to begin refueling outage EOC17 on September 6, 1997. Duke Energy Corporation requests that approval be granted to permit use of this alternative examination at that time.