

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8206030107 DOC. DATE: 82/05/25 NOTARIZED: NO DOCKET #  
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269  
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270  
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287  
 AUTH. NAME AUTHOR AFFILIATION  
 PARKER, W.O. Duke Power Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director  
 STOLZ, J.F. Operating Reactors Branch 4

SUBJECT: Forwards response to 820408 request for addl info re seismic qualification of emergency feedwater sys.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4  
 TITLE: General Distribution for after Issuance of Operating License

NOTES: AEOD/Ornstein:1cy. 05000269  
 AEOD/Ornstein:1cy. 05000270  
 AEOD/Ornstein:1cy. 05000287

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL
	ORB	#4 BC 01	7	7					
INTERNAL:	ELD/HDS4		1	0		NRR/DHFS DEPY08	1	1	
	NRR/DL DIR		1	1		NRR/DL/ORAB	1	0	
	NRR/DSI/RAB		1	1		<u>REG FILE</u> 04	1	1	
	RGN2		1	1					
EXTERNAL:	ACRS	09	10	10		LPDR	03	1	1
	NRC PDR	02	1	1		NSIC	05	1	1
	NTIS		1	1					
NOTES:			1	1					

# DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.  
VICE PRESIDENT  
STEAM PRODUCTION

May 25, 1982

TELEPHONE: AREA 704  
373-4083

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555


Attention: Mr. J. F. Stolz, Chief  
Operating Reactors Branch No. 4

Subject: Oconee Nuclear Station  
Docket Nos. 50-269, -270, -287

Dear Sir:

By letter dated April 8, 1982, the NRC requested additional information with regard to the seismic qualification of the Oconee emergency feedwater system. Attached please find our response to that request.

Very truly yours,



William O. Parker, Jr.

RLG/php  
Attachment

cc: Mr. James P. O'Reilly, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Mr. W. T. Orders  
NRC Resident Inspector  
Oconee Nuclear Station

Mr. Philip C. Wagner  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8206030107 820525  
PDR ADDCK 05000269  
PDR

ADD  
S  
1/1

Duke Power Company  
Oconee Nuclear Station  
Response to NRC Request for Information

Seismic Qualification of the Auxiliary Feedwater System

- Question 1: Enclosure 1 of Generic Letter 81-14 (GL 81-14) defines the auxiliary feedwater (AFW) system to be considered as:
- (a) "The AFW system boundary from suction to discharge (including the water source and heat sink) shall include those portions of the system required to accomplish the AFW system function and connected branch piping up to and including the second valve which is normally closed or capable of automatic closure when the safety function is required."
  - (b) "The AFW system boundary shall also include any portion of branch piping that is structurally coupled to the AFW system boundary such that the seismic response of the branch piping transmits loads to the AFW system. As a minimum, this includes the branch lines outside the AFW system boundary to a point of three orthogonal restraints."
  - (c) "All mechanical and electrical equipment, piping (e.g., instrument air), conduits and cable trays, which are necessary or contain items which are necessary for the operation of the AFW system, shall also be considered."
  - (d) "In addition, the structures housing these systems and components shall be included."

Clarify the extent to which your standby shutdown facility boundary, considered in your January 28, 1981 response letter, coincides with the boundary defined in GL 81-14, especially part (b) above.

Response:

The Auxiliary Service Water System (ASW) of the Standby Shutdown Facility (SSF) is defined in Section 4.0 of the document entitled "Information in Support of Standby Shutdown Facility" submitted by letter dated March 28, 1980. The ASW system when installed will tie into the Emergency Feedwater System (EFS) as indicated on the marked Figure 1 (attached) from our January 28, 1982 response letter. At the time of tie-in (ASW to EFW), portions of the EFW will be altered. The area of alterations has been circled on the attached Figure 1. The tie-in point and the entire ASW system are shown in Figure 4-1 of our March 28, 1980 submittal. For seismic considerations the design overlap region at tie-in points is described in the first paragraph of Page 7 of our January 28, 1982 response.

Question 2: Generic Letter 81-14 states:

- (a) "We are also requesting that PWR licensees perform a walk-down of the non-seismically qualified portions of their AFW systems to identify apparent and practically

- correctable deficiencies that may exist."
- (b) "The results of any walk-down are requested within 120 days of receipt of this letter. These results should include all identified deficiencies and all corrective actions taken, or planned along with the schedules for such."

Our review of your response to Generic Letter 81-14 indicates that this information has not been provided for those non-seismically qualified items of your emergency feedwater system. Clarify whether a walk-down was performed and provide the results of any walk-down performed.

Response:

No walkdown was performed due to reliance upon the Standby Shutdown Facility - Auxiliary Service Water System which is seismically qualified and independent of non-seismic portions of the existing EFW system.

Question 3: Generic Letter 81-14, Enclosure 1, Part B states: "Where seismic qualification is indicated by leaving Table 1 blank, provide a description of the methodologies and acceptance criteria used to support your conclusion of seismic qualification, including: seismic analyses methods employed, seismic input, load combinations which include the SSE, allowable stresses, qualification testing and engineering evaluations performed."

Our review of your response to Generic Letter 81-14 indicates that this information has not been provided for power supplies, water and supply paths, and the initiation and control system of your standby shutdown facility. Please correct this deficiency.

Response:

The Standby Shutdown Facility is designed to withstand and is available following a Safe Shutdown Earthquake (SSE).

The power supplies and instrumentation and controls that are required (indicated on Page 6 of our January 28, 1982 response) are designed to withstand the SSE defined in Section 2.2.5, "Seismic Design," of our March 28, 1980 submittal.

The seismic qualification of supply paths (listed under "Mechanical System" on Page 6 of our January 28, 1982 response) is described in detail by our letters of February 16, March 31, and April 13, 1981, related to the SSF design review. The water source, a buried portion of the Condenser Circulating Water (CCW), is designed for seismic conditions.

Analyses performed for consideration of seismic loadings on the CCW Intake Piping are in conformance with the equivalent static loading method, utilizing the MHE acceleration for overburden as defined in Section 5A.2.2 of the Oconee FSAR. Loading combinations include seismically induced loads due to overburden in conjunction with internal piping loads. Allowable stresses are in conformance with those specified in applicable sections of the ASME Boiler & Pressure Vessel Code, Section VIII, 1965 edition.

