

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8208110182 DOC. DATE: 82/08/03 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 TUCKER, H.B. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Informs of planned installation of fire hose cabinets at entrances to cable rooms & of planned utilization of existing turbine bldg hose stations for protection of equipment rooms. Mod affects 771122 commitment.

DISTRIBUTION CODE: A006S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: Fire Protection Information (After Issuance of OP. Lic.)

NOTES: AEOD/Ornstein:1cy. 05000269
 AEOD/Ornstein:1cy. 05000270
 AEOD/Ornstein:1cy. 05000287

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	ORB #4 BC 01		3 3				
INTERNAL:	ELD/HDS4		1 0		IE FILE 06		1 1
	NRR FIORAVANT07		2 2		NRR WAMBACH		1 0
	NRR/DE/CFB 09		2 2		NRR/DL DIR		1 1
	<u>REG FILE</u> 04		1 1		RGN2		1 1
EXTERNAL:	ACRS 11		3 3		LPDR 03		1 1
	NRC PDR 02		1 1		NSIC 05		1 1
	NTIS		1 1				
NOTES:			1 1				

P. O. BOX 33189

DUKE POWER COMPANY

GENERAL OFFICES

422 SOUTH CHURCH STREET

CHARLOTTE, N. C. 28242

TELEPHONE: AREA 704
373-4011

August 3, 1982

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. John F. Stolz, Chief
Operating Reactors Branch No. 4

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287

Dear Sir:


The purpose of this letter is to advise the Staff of a planned modification at Oconee that affects a previously made commitment in the area of fire protection systems.

By letter dated November 22, 1977, Duke committed that manual hose stations would be installed in the Auxiliary Building including the cable spreading and equipment rooms. Such modifications have been completed.

The intended modification is designed to comply with pipe rupture/water spray requirements in these areas. The preferred arrangement is to have fire hose cabinets located outside these areas available as the fire response team enters the room. Optimum hose coverage, consistent with regulatory requirements, can be provided by installation of fire hose cabinets at entrances to cable rooms and by utilizing existing Turbine Building hose stations for protection of equipment rooms.

Unless informed to the contrary, it is considered that these changes are acceptable to the Staff and that no further regulatory actions are necessary.

Very truly yours,



H. B. Tucker, Vice President
Nuclear Production Department

RLG/php

A006

Mr. Harold R. Denton, Director
August 3, 1982
Page 2

cc: Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Mr. W. T. Orders
NRC Resident Inspector
Oconee Nuclear Station

Mr. Philip C. Wagner
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555