



Idaho National Engineering Laboratory

March 12, 1987

Mr. M. Carrington, Project Manager
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

TRANSMITTAL OF FINAL REPORT, "CONFORMANCE TO ITEM 4.5.2 OF GENERIC LETTER 83-28, ARKANSAS NUCLEAR ONE-1, CRYSTAL RIVER-3, DAVIS-BESSE-1, OCONEE-1, -2, AND -3, RANCHO SECO, THREE MILE ISLAND-1, WNP-1," EGG-NTA-7462, MARCH 1987 (FINS D6001 AND D6002) - EWR-48-87

Ref: NRC Form 189, "Evaluation of Conformance to Generic Letter 83-28 For ORs (Project 2)" (D6001); "Evaluation of Conformance to Generic Letter 83-28 For OLs (Project 3)" (D6002)

Dear Mr. Carrington:

Transmitted herewith is the above subject report.

The report documents EG&G Idaho's evaluation of the licensee/applicant actions in response to NRC Generic Letter 83-28, Item 4.5.2, Reactor Trip System On-Line Testing. Based on the licensee/applicant submittals, we conclude that the plants reviewed conform to the generic letter on this item with the exception that Davis-Besse 1 must provide the confirmation addressed in the plant-specific review.

Very truly yours,

E. W. Roberts, Manager
NRC Headquarters Support

FGF:gp

Enclosure:
As Stated

cc: G. L. Jones, DOE-ID
A Toalston, NRR-PAEI
F. Rosa, NRC-DPWR-A
J. O. Zane, EG&G Idaho, Inc. (w/o Encl.)

8706080096 870312
PDR ADDCK 05000269
P PDR



Idaho, Inc.

11428 Rockville Pike

Suite 410

Rockville, MD 20852

902

269
270
287
289
302
312
313
346
382