

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8101130404 DOC.DATE: 81/01/07 NOTARIZED: NO
 FACIL:50-269 Oconee Nuclear Station, Unit 1, Duke Power Co.
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.

DOCKET #
 05000269
 05000270
 05000287

AUTH.NAME AUTHOR AFFILIATION
 PARKER,W.O. Duke Power Co.
 RECIP.NAME RECIPIENT AFFILIATION
 DENTON,H.R. Office of Nuclear Reactor Regulation, Director
 REID,R.W. Operating Reactors Branch 4

SUBJECT: Provides alternate methods of nondestructive exams for welds to be performed in place of hydrostatic testing, following maint or mod.NRC 801107 ltr granted licensee relief from ASME Code requirements re hydrostatic testing.

DISTRIBUTION CODE: A001S COPIES RECEIVED:LTR 1 ENCL 0 SIZE: 2
 TITLE: General Distribution for after Issuance of Operating License

NOTES:M.Cunningham:all amends to FSAR & changes to Tech Specs. 05000269
 AEOD,Ornstein:1cc.
 M.Cunningham:all amends to FSAR & changes to Tech Specs. 05000270
 AEOD,Ornstein:1cc.
 M.Cunningham:all amends to FSAR & changes to Tech Specs. 05000287
 AEOD,Ornstein:1cc

ACTION:	RECIPIENT		COPIES		RECIPIENT	COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME	LTR
	REID,R.	04	13	13			
INTERNAL:	D/DIR,HUM FAC08		1		DIR,DIV OF LIC	1	
	I&E	06	2		NRC PDR	02	1
	DELD	11	1		OR ASSESS BR 10	1	
	REG FILE	01	1				
EXTERNAL:	ACRS	09	16	16	LPDR	03	1
	NSIC	05	1				

JAN 14 1981

TOTAL NUMBER OF COPIES REQUIRED: LTR 46 ENCL 6

1981 JAN 12 AM 11 31
DISTRIBUTION
UNIT

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

US NRC
DISTRIBUTION SERVICES
BRANCH

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

TELEPHONE: AREA 704
373-4083

January 7, 1981

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. Robert W. Reid, Chief
Operating Reactors Branch No. 4

Re: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287

Dear Mr. Denton:

By letter dated November 7, 1980, the NRC responded to certain requests for relief and granted permanent relief from specific requirements of Section XI of the ASME Code which were determined to be impractical for Oconee. Confirming discussions held with your staff recently, the following alternate methods of NDE for welds will be performed in cases where hydrostatic testing following maintenance or modification has been determined to be impractical:

<u>TYPE OF WELD</u>	<u>ALTERNATE NDE TO BE PERFORMED</u>
All Butt Welds	Radiograph and leak test at operating pressure and temperature.
Stainless Steel Socket Welds	PT and leak test at operating pressure and temperature.
Carbon Steel Socket Welds	MT or PT and leak test at operating pressure and temperature.

NOTE: The alternate examinations listed above will be typical for all classes of pipe and will be in addition to the normal NDE required (cleanness inspection, visual, etc.).

Each weld will be hydrostatically tested during normal inservice inspection.


Acc'd
5/10

8101130404

Mr. Harold R. Denton
January 7, 1981
Page 2

These alternate methods of NDE are consistent with those provided in my letters dated July 21, 1978, November 28, 1978, January 26, 1979, and November 27, 1979 which were accepted by the staff. Also, as a result of these discussions, no additional requests for relief from hydrostatic testing need be submitted unless otherwise required.

Very truly yours,



William O. Parker, Jr.

SAG:bj