

**DUKE ENERGY CORPORATION
TOPICAL REPORT
QUALITY ASSURANCE PROGRAM**

DUKE-1-A

9801130228 980108
PDR ADOCK 05000269
P PDR

ABSTRACT

This topical report describes the Duke Energy Corporation quality assurance program for the operational phase of its nuclear power plants. The report is organized like and is generally used for Chapter 17, "Quality Assurance", of Duke's Safety Analysis Reports.

The Duke Quality Assurance Program conforms to applicable regulatory requirements such as 10CFR 50, Appendix B and to approved industry standards such as ANSI N45.2-1971 and ANSI N18.7-1976 and corresponding daughter standards, or to equivalent alternatives. The Duke Energy Corporation Quality Assurance Program also conforms to the regulatory position of the NRC Regulatory Guides listed in Table 17-1 of this report with the exception of the clarifications, modifications, and alternatives stated therein.

The Duke Energy Corporation Quality Assurance Program Policy Statement, issued by the Chairman and Chief Executive Officer, describes the corporate policy and assigns responsibility for implementation of the Quality Assurance Program.


Section "Introduction" describes the purpose of this report, provides definitions, and shows conformance to regulations, standards, and guides.

Section 17.3, "Quality Assurance Program Description" describes the quality assurance program and organization for station operation.


Section 17.3, "Quality Assurance Program Description" follows the format of NUREG-0800, "Standard Review Plan For The Review of Safety Analysis Reports for Nuclear Power Plants", Section 17.3, "Quality Assurance Program Description," except that the Duke Energy Corporation Quality Assurance Program is based on ANSI N18.7-1976 in lieu of ANSI/ASME NQA-1 and NQA-2.

The topical is intended to be a comprehensive up-to-date description of Duke's Quality Assurance Program for nuclear power plants.


W.A. Coley being duly sworn states that he is President, Duke Power Group, of Duke Energy Corporation; that he is authorized on the part of said corporation to sign and file with the Nuclear Regulatory Commission this amendment to its Topical Report, Duke-1-A; and that all statements and matters set forth herein are true and correct to the best of his knowledge.


W. A. Coley

ATTEST:


Patsy A. Baker

Subscribed and sworn to me December 15, 1997
Date


Linda Case Smith, Notary Public

My commission expires: May 6, 2000
Date

TABLE OF CONTENTS

17. QUALITY ASSURANCE	17-1
Introduction	17-1
Definitions	17-2
Explanation of "Quality Assurance"	17-3
Quality Assurance Standards and Guides	17-4
17.1 QUALITY ASSURANCE DURING DESIGN AND CONSTRUCTION	17-12
17.2 OPERATIONAL QUALITY ASSURANCE	17-13
17.3 QUALITY ASSURANCE PROGRAM DESCRIPTION	17-14
17.3.1 MANAGEMENT	17-14
17.3.1.1 Methodology	17-14
17.3.1.2 Organization	17-14
17.3.1.2.1 Corporate Organization	17-14
17.3.1.2.2 Nuclear Generation Department	17-15
17.3.1.2.3 Electric System Support Department	17-16
17.3.1.2.4 Duke Power Group Human Resources	17-16
17.3.1.2.5 Duke Power Group Environmental, Health and Safety Department	17-16
17.3.1.2.6 Shared Services Department	17-16
17.3.1.2.7 Information Management Department	17-17
17.3.1.2.8 Electric Transmission Department	17-17
17.3.1.2.9 Department Interfaces	17-17
17.3.1.3 Responsibility	17-17
17.3.1.4 Authority	17-17
17.3.1.5 Personnel Training and Qualification	17-18
17.3.1.6 Corrective Action	17-18
17.3.1.7 Regulatory Commitments	17-18
17.3.2 PERFORMANCE/VERIFICATION	17-23
17.3.2.1 Methodology	17-23
17.3.2.2 Design Control	17-23
17.3.2.3 Design Verification	17-24
17.3.2.4 Procurement Control	17-26
17.3.2.5 Procurement Verification	17-28
17.3.2.6 Identification and Control of Items	17-29
17.3.2.7 Handling, Storage, and Shipping	17-30
17.3.2.8 Test Control	17-31
17.3.2.9 Measuring and Test Equipment Control	17-32
17.3.2.10 Inspection, Test, and Operating Status	17-33

17.3.2.11 Special Process Control	17-33
17.3.2.12 Inspection	17-34
17.3.2.13 Corrective Action	17-35
17.3.2.14 Document Control	17-36
17.3.2.15 Records	17-39
17.3.3 SELF ASSESSMENT	17-43
17.3.3.1 Methodology	17-43
17.3.3.2 Assessment	17-43
17.3.3.2.1 Nuclear Safety Review Board	17-43
17.3.3.2.2 Plant Operations Review Committee	17-43
17.3.3.2.3 Internal Audits	17-43
17.3.3.2.4 Safety Assurance	17-44
17.3.3.2.5 Corporate Audit	17-45
17.3.3.2.6 Self-Initiated Technical Audits	17-45
17.3.3.2.7 Suppliers	17-45

LIST OF TABLES

17-1.	Conformance of Duke's Program to Quality Assurance Standards, Requirements and Guides	17-5
-------	--	------

LIST OF FIGURES

17-1.	Duke Energy Corporation Quality Assurance Policy Statement	17-19
17-2.	Duke Energy Corporation Corporate Organization	17-20
17-3.	Off-Site Organization	17-21
17-4.	Nuclear Site Organization	17-22

LIST OF EFFECTIVE PAGES

Page No.	Amendment No.	Page No.	Amendment No.
Title Page	22	17-13	22
17-ii	22	17-14	22
17-iii	22	17-15	22
17-iv	22	17-16	22
17-v	22	17-17	22
17-vi	22	17-18	22
17-vii	22	17-19	22
17-viii	22	17-21	22
17-ix	22	17-21	22
17-xi	22	17-22	22
17.0-1	22	17-23	22
17.0-2	22	17-24	22
17.0-3	22	17-25	22
17.0-4	22	17-26	22
17.0-5	22	17-27	22
Table 17-1 (Page 1)	22	17-28	22
Table 17-1 (Page 2)	22	17-29	22
Table 17-1 (Page 3)	22	17-30	22
Table 17-1 (Page 4)	22	17-31	22
Table 17-1 (Page 5)	22	17-32	22
Table 17-1 (Page 6)	22	17-33	22
17-1	22	17-34	22
17-2	22	17-35	22
17-3	22	17-36	22
17-4	22	17-37	22
17-5	22	17-38	22
17-6	22	17-39	22
Figure 17-1	22	17-40	22
Figure 17-2	22	17-41	22
Figure 17-3	22	17-42	22
Figure 17-4	22	17-43	22
17-7	22	17-44	22
17-8	22	17-45	22
17-9	22	17-13	22
17-10	22	17-15	22
17-11	22	17-21	22
17-12	22	17-21	22
		17-25	22
		17-27	22
		17-32	22
		17-33	22
		17-34	22
		17-36	22
		17-40	22
		Figure 17-1	22
		Figure 17-2	22
		Figure 17-3	22

Page No.

Amendment No.

Page No.

Amendment No.

Figure 17-4

22

LIST OF AMENDMENTS

Amendment No.	Amendment Date
Original	March 1, 1974
1	October 1, 1974 (Complete Revision)
2	February 14, 1975
3	November 22, 1976
4	June 29, 1978
5	July 14, 1981
6	February 3, 1983
7	June 22, 1984
8	May 20, 1985
9	July 30, 1985
10	October 17, 1986
11	November 12, 1987
12	March 30, 1989
13	April 18, 1990
14	August 23, 1991
15	August 7, 1992 (Complete Rewrite)
16	June 16, 1994
17	June 16, 1994
18	December 12, 1994
19	March 30, 1995
20	June 29, 1995
21	July 11, 1996
22	November 1, 1997

17. QUALITY ASSURANCE

INTRODUCTION

Duke Energy Corporation maintains full responsibility for assuring that its nuclear power plants are designed, constructed, tested and operated in conformance with good engineering practices, applicable regulatory requirements and specified design bases and in a manner to protect the public health and safety. To this end Duke has established and implemented a quality assurance program which conforms to the criteria established in Appendix B to 10CFR, Part 50, "Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants" published June 27, 1970 (35 F. R. 10499) and amended September 17, 1971 (36 F. R. 18301) and amended January 20, 1975 (40 F. R. 3210D).

This topical report is written in the format of a Safety Analysis Report (SAR) Chapter 17, "Quality Assurance", in accordance with Revision 2 of the NRC's Regulatory Guide 1.70, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants - LWR Edition" and subsequent NRC guidelines. The quality assurance program described herein is applicable to all Duke nuclear power plants as referenced by Chapter 17 of the plants' SAR's.

This Topical Report describes the Quality Assurance Program for those systems, components, items, and services which have been determined to be nuclear safety related (QA Condition 1). In addition, Duke's Quality Assurance Program provides a method of applying a graded Quality Assurance Program to certain non-safety related systems, components, items, and services. These are classified as QA Conditions 2, 3, or 4. This method involves defining a Quality Assurance "Condition" for each level of quality assurance required. These will be designated as "QA Condition ____". The quality of systems, components, items, and services within the scope of QA Conditions 1, 2, 3, and 4 is assured commensurate with the system's, component's, item's, or service's importance to safety. The following conditions have been defined.

QA Condition 1 covers those systems and their attendant components, items, and services which have been determined to be nuclear safety related. These systems are detailed in the Safety Analysis Report applicable to each nuclear station. The Topical Report applies in its entirety to systems, components, items, and services identified as QA Condition 1.

QA Condition 2 covers those systems and their attendant components, items, and structures important to the management and containment of liquid, gaseous, and solid radioactive waste.

QA Condition 3 covers those systems, components, items, and services which are important to fire protection as defined in the Hazards Analysis for each station. The Hazards Analysis is in response to Appendix A of NRC Branch Technical Position APCSB 9.5-1.

QA Condition 4 covers those seismically designed/restrained systems, components, and structures whose continued functions are not required during and after the seismic event. The general scope of these systems, components, and structures, identified as Seismic Category II (SCII) are defined in Regulatory Guide 1.29, Seismic Design Classification.

Subsequent changes to Duke's Quality Assurance Program shall be incorporated in this topical report. The topical report is intended to be a comprehensive up-to-date description of Duke's Quality Assurance Program for nuclear power plants.

Any programmatic changes to the Quality Assurance Program will be submitted for review and acceptance prior to implementation. Significant organizational changes will be submitted no later than thirty (30) days after announcement.

DEFINITIONS

The following definitions are applicable to terms used in this report. Terms used in this report which are not defined in this section are defined in ANSI N45.2.10, "Quality Assurance Terms and Definitions."

Approver - An individual who reviews an activity for concept and conformity with codes and standards; the approver is a person other than the originator or checker.

Audit (Internal) - An activity to determine through investigation the adequacy of, and adherence to, established procedures, instructions, specifications, codes, and other applicable contractual and licensing requirements, and the effectiveness of implementation.

Checker - An individual, other than the originator or approver, who is qualified in the area being checked and who has the responsibility to check the activity and/or all revisions for completeness, clarity, and accuracy.

Designer - The individual who performed the design.

Deficiency - Any condition considered to be adverse to quality including inadequacies of personnel, procedures, systems, methods, or items.

Documents - Any written or pictorial information describing, defining, specifying, reporting, or certifying activities, requirements, procedures, or results. Examples of documents are drawings, specifications, instructions and procedures significant to the design, construction, testing, maintenance and operation of QA Condition 1 equipment and systems.

Hold Point - That point in the manufacturing, preparation, development, installation and construction, inspection, or testing process that requires witnessing or review by qualified Duke personnel.

Item - Any level of unit assembly, including structure, system, subsystem, subassembly, component, part, or material.

Nuclear Station Modification - A planned change in plant design accomplished in accordance with the requirements and limitations of applicable codes, standards, specifications, licenses and predetermined safety restrictions.

Problem Investigation Process - A process used during the operation phase of nuclear stations that documents an occurrence, situation, or nonconformance that resulted in other than expected equipment performance, personnel action, or failure to operate within established limits.

Quality Assurance - The planned and systematic actions necessary to provide adequate confidence that a material, component, system or facility will perform satisfactorily in service. (**Note:** See Section "Explanation of "Quality Assurance"" below for further explanation.)

Quality Assurance Records - Those records which furnish documentary evidence of the quality of items and of activities affecting quality.

Quality Assurance Requirements - Those inspection, test, examination, certification and documentation requirements which are imposed to provide objective evidence of the conformance of an item or activity to established design, engineering, standards, and code requirements.

Quality Control - Those quality assurance actions which provide a means to control and measure the physical characteristics of an item, process or facility to established requirements.

Quality Control Inspector (Inspector) - Any individual certified to the requirements of ANSI N45.2.6 or SNT-TC-1A who performs required inspections, tests or examinations.

Responsible Engineer - The engineer assigned responsibility for an item or service.

Revisions - Any addition, correction, deletion or change.

Services - The performance by a supplier of activities such as design, investigation, inspection, nondestructive examination, software applications, and installation.

Preaward Survey - A documented activity performed in accordance with written procedures or checklists to verify, by examination and evaluation of objective evidence, that the quality assurance program has been developed, documented, and implemented in accordance with specified requirements.

| Variation Notice - A notice to provide a process by which field variations from design drawings and specifications are evaluated and permitted.

Supplier Audit - A documented activity performed in accordance with written procedures or checklists to verify, by examination and evaluation of objective evidence, that applicable elements of the quality assurance program have been developed, documented and implemented in accordance with specified requirements.

Explanation of "Quality Assurance"

| Quality Assurance as used in this document includes: 1) the independent assurance activities associated with items and tasks critical to the safety and integrity of the facility and 2) quality verifications performed by the Regulatory Audits and Supplier Verification Groups and by the Nuclear Safety Review Board in the Nuclear Generation Department. The Quality Assurance program as defined above is not an alternative to good technical work. Rather, it is a system of controls to verify that quality is achieved. The Quality Assurance program places the responsibility on line management of achieving and assuring quality in all areas of their operation. As defined, the President, Duke Power Group has been given the responsibility to develop and manage a Quality Assurance Program for the Corporation.

QUALITY ASSURANCE STANDARDS AND GUIDES

The Duke Quality Assurance Program conforms to Appendix B of 10CFR 50, as discussed in Section 17, "Quality Assurance." The Quality Assurance Program also conforms to applicable NRC Regulatory Guides and approved ANSI Standards, or applicable alternatives. Table 17-1 addresses quality assurance program conformance to the referenced regulatory and program guidance contained in NUREG-0800.

Quality Assurance Program conformance with the documents identified in Table 17-1 may, however, be modified contingent upon future NRC or ANSI action. For example, if a draft document is subsequently approved and issued or if an approved document is revised, provisions of the more recent issue of such a document may be complied with in lieu of those contained in the version listed in Table 17-1, provided the more recent issue has been endorsed by the NRC. Also, formal regulatory actions of the NRC (e.g., issuance or amendment of a station's Facility Operating License) are considered to supersede the contents of Table 17-1, as applicable.

Table 17-1 (Page 1 of 7). Conformance of Duke's Program to Quality Assurance Standards, Requirements and Guides

Standard, Requirement or Guide	Conformance Status	Remarks
Regulatory Guide 1.8 Rev (1-R) - Personnel Selection and Training	Alternative	RG 1.8 Rev (1-R) incorporates ANSI N18.1. Duke's program conforms to ANSI N18.1-1971 except Radiation Protection Manager qualifications are contained in the Technical Specifications.
Regulatory Guide 1.26 Rev (3) - Quality Group Classifications & Standards for Water, Steam, and Radioactive-Waste Containing Components of Nuclear Power Plants	Alternative	Duke's Program conforms to this Regulatory Guide except for additional details and directions noted in Station FSAR's.
Regulatory Guide 1.28 Rev (2) - Quality Assurance Program Requirements (Design and Construction)	Conforms	-----
Regulatory Guide 1.29 Rev (3) - Seismic Design Classification	Alternative	Duke's Program conforms to this Regulatory Guide except for additional details and directions noted in Station FSAR's.
Regulatory Guide 1.30 Rev (0) - Quality Assurance Requirements for the Installation, Inspection and Testing of Instrumentation and Electric Equipment	Conforms	RG 1.30 Rev (0) incorporates ANSI N45.2.4-1972 for both construction and operation
Regulatory Guide 1.33 Rev (2) - Quality Assurance Program Requirements (Operations)	Alternative	RG 1.33 Rev (2) incorporates ANSI N18.7-1976/ANS-3.2. Duke's program conforms to ANSI N18.7-1976 except the frequency of audits of selected aspects of operational phase activities is defined in Section 17.3.3, "Self Assessment" and the frequency for procedure review, as described in Section 17.3.2.14, "Document Control," is based on ANSI N18.7/ANS-3.2 (1988) with appropriate review frequencies established not to exceed 6 years.

Table 17-1 (Page 2 of 7). Conformance of Duke's Program to Quality Assurance Standards, Requirements and Guides

Standard, Requirement or Guide	Conformance Status	Remarks
Regulatory Guide 1.36 Rev. (0) - Nonmetallic Thermal Insulation for Austenitic Stainless Steel	Adopted	Regulatory Guide is adopted for all Austenitic Stainless Steel piping and components located outside containment. Inside containment, reflective Thermal Insulation is used.
Regulatory Guide 1.37 Rev (0) - Quality Assurance Requirements for Cleaning of Fluid Systems and Associated Components of Water-Cooled Nuclear Power Plants	Conforms	RG 1.37 Rev (0) incorporates ANSI N45.2.1-1973 for both construction and operation
Regulatory Guide 1.38 Rev (2) - Quality Assurance Requirements for Packaging, Shipping, Receiving, Storage and Handling of Items for Water-Cooled Nuclear Power Plants	Alternative	RG 1.38 Rev (2) incorporates ANSI N45.2.2-1972. Duke's program conforms to ANSI N45.2.2-1972 except container markings shall be marked on at least one side (A.3.9(1)) and shall be applied with waterproof ink or paint in characters of a legible size, and caps and plugs for pipe and fittings are required unless specified by Engineering, and off-site inspection, examination, and testing is monitored by personnel qualified to ANSI N45.2.12 in lieu of ANSI N45.2.6.
Regulatory Guide 1.39 Rev (2) - Housekeeping Requirements for Water-Cooled Nuclear Power Plants	Conforms	RG 1.39 Rev (2) incorporated ANSI N45.2.3-1973 for both construction and operation
Regulatory Guide 1.54 Rev (0) - Quality Assurance Requirements for Protective Coatings Applied to Water-Cooled Nuclear Power Plants	Alternative	Catawba has adopted the Regulatory Guide. McGuire and Oconee adopt portions of the Regulatory Guide and address alternatives which meet the intent of this Guide, in each respective Station FSAR.

Table 17-1 (Page 3 of 7). Conformance of Duke's Program to Quality Assurance Standards, Requirements and Guides

Standard, Requirement or Guide	Conformance Status	Remarks
Regulatory Guide 1.58 Rev (1) - Qualification of Nuclear Power Plant Inspection, Examination and Testing Personnel	Alternative	RG 1.58 Rev (1) incorporates ANSI N45.2.6-1978 for both construction and operation. Duke's nondestructive examination personnel will meet the qualification requirements of SNT-TC-1A-1980. Duke's operational/functional testing personnel will meet the requirements of ANSI N18.1-1971 rather than ANSI N45.2.6. Also, Duke's Level I inspectors receive a minimum of 4 months experience as Level I before being certified as Level II, in lieu of one year experience recommended by ANSI N45.2.6. Inspectors are only assigned tasks for which they have been qualified.
Regulatory Guide 1.64 Rev (2) - Quality Assurance Requirements for Design of Nuclear Power Plants	Adopted with Clarification	RG 1.64 Rev (2) Incorporates ANSI N45.2.11-1974. The use of the originator's immediate supervisor for design verification shall be restricted to special situations where the immediate supervisor is the only individual capable of performing the verification. Advance justification for such use shall be documented and signed by the supervisor's management. And the frequency and effectiveness of the supervisor's use as design verifier are independently verified to guard against abuse. The supervisor will not be the design verifier on work for which he is the actual performer / originator.
Regulatory Guide 1.74 Rev (0) - Quality Assurance Terms and Definitions	Conforms	RG 1.74 Rev (0) Incorporates ANSI N45.2.10-1973. Some definitions used by Duke's are worded differently than those in this standard; however, the general meanings are the same.

Table 17-1 (Page 4 of 7). Conformance of Duke's Program to Quality Assurance Standards, Requirements and Guides

Standard, Requirement or Guide	Conformance Status	Remarks
Regulatory Guide 1.88 Rev (2) - Collection, Storage, and Maintenance of Nuclear Power Plant Quality Assurance Records	Alternative	RG 1.88 Rev (2) Incorporates ANSI N45.2.9-1974. The Duke Program conforms to RG 1.88 except the records storage facilities have a minimum 3-hour rating. A qualified Fire Protection Engineer will evaluate record storage areas (including satellite files) to assure records are adequately protected from damage. The fire protection engineer shall be a graduate of an engineering curriculum of accepted standing and shall have completed not less than 6 years of engineering attainment indicative of growth in engineering competency and achievement, 3 years of which shall have been in responsible charge of fire protection engineering work.
Regulatory Guide 1.94 Rev (1) - Quality Assurance Requirements for Installation, Inspection, and Testing of Structural Concrete and Structural Steel During the Construction Phase of Nuclear Power Plants	Alternative	RG 1.94 Rev (1) Incorporates ANSI N45.2.5-1974. Duke's program for McGuire and Catawba conforms to ANSI N45.2.5-1974 except the length of bolts shall be flush with the outside face of the nut.
Regulatory Guide 1.116 Rev (0-R) - Quality Assurance Requirements for Installation, Inspections, and Testing of Mechanical Equipment and Systems	Conforms	RG 1.116 Rev (0-R) Incorporates ANSI N45.2.8-1975
Regulatory Guide 1.123 Rev (1) - Quality Assurance Requirements for control of Procurement of Items and Services for Nuclear Plants	Conforms	RG 1.123 Rev (1) Incorporates ANSI N45.2.13-1976

Table 17-1 (Page 5 of 7). Conformance of Duke's Program to Quality Assurance Standards, Requirements and Guides

Standard, Requirement or Guide	Conformance Status	Remarks
Regulatory Guide 1.143 Rev (1) - Design Guidance For Radioactive Waste Management Systems, Structures, and Components Installed in Light-Water-Cooled Nuclear Power Plants	Conforms	-----
Regulatory Guide 1.144 Rev (1) - Auditing of Quality Assurance Programs for Nuclear Power Plants	Alternative	RG 1.144 Rev (1) incorporates ANSI N45.2-12, (1977). Duke's Program conforms to ANSI N45.2.12-1977 for internal/external audits except Section 4.4.6. In lieu of making recommendations for correcting program deficiencies we will identify the deficiencies to the audited organization. For external audits, the results of the audit will be provided to the audited organization in lieu of the audit report. Also, the re-evaluation may be extended to 15 months and the triennial period as specified in the Reg. Guide may be extended by 3 months as described in Section 17.3.2.4, "Procurement Control." Additionally, Duke program meets regulatory position C.3.b of this regulatory guide, as clarified by NRC Information Notice 86-21, Supplement 2. Self Initiated Technical Audits (Section 17.3.3.2.6, "Self-Initiated Technical Audits") shall require a response describing corrective action and implementation schedule as requested by the audit report but not to exceed sixty days of receipt of the audit report.

Table 17-1 (Page 6 of 7). Conformance of Duke's Program to Quality Assurance Standards, Requirements and Guides

Standard, Requirement or Guide	Conformance Status	Remarks
Regulatory Guide 1.146 Rev (0) - Qualification of QA Program Audit Personnel for Nuclear Power Plants	Alternative	Duke's Program conforms to ANSI/ASME N45.2.23 - 1979 except section 2.3.4. In lieu of prospective lead auditors participating in a minimum of five quality assurance audits within a period of three years prior to date of certification, prospective lead auditors shall demonstrate their ability to effectively lead an audit team and shall have participated in at least one nuclear quality assurance audit within one year preceding the individual's effective date of qualification. Upon successful demonstration of the ability to lead audits, and having met the other provisions of ANSI N45.2.23-1977, the individual may be certified as being qualified to lead audits. This process is described in approved procedures which require documentation of the evaluation and demonstration of results.
Regulatory Guide 1.152 Rev (0) - Criteria For Programmatic Digital Computer System Software In safety-Related Systems of Nuclear Power Plants	Not applicable	Regulatory Guide does not apply to plants prior to 11/85
Regulatory Guide 4.15 Rev (1) - Quality Assurance For Radiological Monitoring Program (Normal Operations) - Effluent Streams and the Environment	Adopted	Adopted at Oconee, McGuire, and Catawba via various site procedures that meet the intent of the Regulatory Guide.
Regulatory Guide 7.10 Rev (1) - Establishing Quality Assurance Programs For Packaging Used In The Transport of Radioactive Material	Alternative	Duke's Program conforms to the intent of this Regulatory Guide as addressed in each Station's FSAR
Criteria 1 of Appendix A to 10CFR 50	Conforms	-----

Table 17-1 (Page 7 of 7). Conformance of Duke's Program to Quality Assurance Standards, Requirements and Guides

Standard, Requirement or Guide	Conformance Status	Remarks
10CFR 50, Appendix B - Quality Assurance Criteria for Nuclear Power Plants	Conforms	-----
10CFR 50.55a - Licensing of Production and Utilization Facilities (ASME Boiler and Pressure Vessel Code, Section XI - Rules for Inservice Inspection of Nuclear Reactor Coolant Systems)	Conforms	10CFR 50.55a Specifies ASME Section XI code dates. The Duke program conforms to 10CFR 50.55a with the specific editions and addenda of Section XI specified in the Duke's Inservice Inspection Plan for each station.
10CFR 55 - Operators Licenses	Conforms	-----
10CFR 55, Appendix A - Requalification Programs for Licensed Operators of Production and Utilization Facilities	Conforms	-----
10CFR 50.55(e) - Conditions of Construction Permits	Conforms	-----
10CFR 21	Conforms	-----
Regulatory Positions 2 & 4 of Branch Technical Position CMEB 9.5-1	Conforms	Fire protection controls are in accordance with the intent of regulatory positions 2 & 4 of Branch Technical Position CMEB 9.5-1 as stated in the Safety Evaluation Reports for the respective nuclear stations.
Generic Letter 89-02, NCIG-07.	Conforms	-----

17.1 QUALITY ASSURANCE DURING DESIGN AND CONSTRUCTION

Deleted

17.2 OPERATIONAL QUALITY ASSURANCE

Deleted

17.3 QUALITY ASSURANCE PROGRAM DESCRIPTION

17.3.1 MANAGEMENT

17.3.1.1 Methodology

The President, Duke Power Group is the corporate executive responsible for quality assurance and is the highest level of management responsible for establishing Duke's quality assurance policies, goals, and objectives. The Duke Energy Corporation Quality Assurance Program Policy Statement, issued by the Chairman and Chief Executive Officer as shown in Figure 17-1, assigns this responsibility and requires development of and compliance with procedures in all QA Condition 1 matters. All organizations performing quality affecting activities are bound by this Policy Statement. The Quality Assurance Program has been developed in accordance with this Policy Statement.

The individuals who constitute Duke Energy Corporation have full personal and corporate responsibility to assure that nuclear power plants are designed, constructed, tested and operated in a manner to protect the public health and safety. The comprehensive program to assure this begins with initial design and continues throughout the life of the station.

The Duke Quality Assurance Program must assure that the necessary quality requirements for QA Condition 1 structures, systems, components and materials are achieved. All special equipment, environmental conditions, skills and processes that are determined to be QA Condition 1 will be provided within the scope of the Quality Assurance Program.

A controlled listing of QA Condition structures, systems, and components is approved, issued, and periodically updated. Each Nuclear Site Vice President is responsible for approval and issuance after issuance of the operating license.

This program applies to the QA Condition 1 portions of the plant but may also be optionally applied, in whole or in part, to other selected items necessary for reliable operation.

Section 17, "Quality Assurance" identifies those items currently included under the Duke Energy Corporation Quality Assurance Program.

17.3.1.2 Organization

17.3.1.2.1 Corporate Organization

The Duke Corporate organization is shown in Figure 17-2. The Chairman/Chief Executive Officer and President/Chief Operating Officer have overall responsibility for Design, Construction, and Operation of generation and transmission facilities. Reporting to the Chairman/Chief Executive Officer and President/Chief Operating Officer is the President, Duke Power Group, who has the overall authority and responsibility for the quality assurance program, and who directs several activities including the Nuclear Generation, Electric System Support, Group Human Resources, and Group Environmental, Health and Safety Departments.

Reporting to the Chairman/Chief Executive Officer and President/Chief Operating Officer is the Executive Vice President and Chief Administrative Officer, who directs several activities, including the Information Management and the Shared Services Departments through their respective senior vice presidents.

Reporting to the Chairman/Chief Executive Officer and President/Chief Operating Officer is the President, Energy Transmission who directs several activities, including the Electric Transmission Department through its senior vice president.

Duke's organization reflects the concept of quality assurance as an interdisciplinary function involving various groups. As such, the attainment of quality rests with those assigned the responsibility of performing the activity. The verification of quality is assigned to qualified personnel independent of the responsibility for performance or direct supervision of the activity. The degree of independence varies commensurate with the activity's importance to safety.

The policies described in this document are implemented through departmental program manuals and procedures, and are, therefore, transmitted to all levels of management.

Organization charts for various departments/locations are contained in Chapter 13 of the respective Station Final Safety Analysis Report.

17.3.1.2.2 Nuclear Generation Department

The Nuclear Generation Department has direct line responsibility for all Duke Energy Corporation nuclear station operations. The Nuclear Generation Department is responsible for achieving quality results during engineering, preoperational testing, operation, testing, maintenance and modification of the Corporation's nuclear stations and with complying with applicable codes, standards and NRC regulations. The functions of Nuclear Generation are directed by the Executive Vice President, Nuclear Generation.

The Executive Vice President, Nuclear Generation formulates, recommends, and carries out plans, policies, and programs related to the nuclear generation of electric power; and reports to the President, Duke Power Group. The Executive Vice President, Nuclear Generation is informed of significant problems or occurrences relating to safety and quality assurance through established administrative procedures, and participates directly in their resolution, where necessary.

a) Nuclear Site Organization

The Nuclear Site Vice Presidents (Site Officer) report to the Executive Vice President, Nuclear Generation. The Site Officer is also responsible for the administration, implementation, and assessment of the quality assurance program as it applies to station operation. In the discharge of their responsibilities, the Site Officers direct the activities of the station organizations.

Reporting to the Site Officer for each nuclear station, is a Manager, Nuclear Station who is assigned the direct responsibility for the safe operation of the facility. The qualification requirements for the Manager, Nuclear Station are in accordance with the provisions of ANSI N18.1-1971 and are presented in each station's FSAR.

b) Nuclear Generation Department, Nuclear Generation Office

The Nuclear Generation Department, Nuclear General Office, is divided into three divisions. The activities of each division are directed by a manager who reports to the Executive Vice President, Nuclear Generation. The three divisions within the Nuclear General Office are: 1) Nuclear Engineering, which provides support to the stations in severe accident analysis, safety analysis, nuclear design, fuels/core management, and plant engineering, (2) Station Support, which provides technical support to the stations in work control and human performance, chemistry, radiation protection, steam

generator maintenance, quality assurance services, inservice inspection, procurement engineering, supplier verification, and special projects such as license renewal, RM&C, and steam generator replacement; and (3) Nuclear Assessment and Issues, which provides technical and business support to the stations in operating experience assessment, operations assessment, business/financial support, regulatory/industry affairs, NSRB, and regulatory audits. The Regulatory Audits Group has the authority and organizational freedom to:

- 1) Identify quality problems
- 2) Initiate, recommend or provide solutions to quality problems through designated channels.
- 3) Verify the implementation of solutions to quality problems.
- 4) Ensure cost and schedule do not unduly influence decision making involving quality.

If significant quality problems are identified by Regulatory Audit personnel, the Manager, Nuclear Assessment and Issues Division or designee, has the responsibility and authority to notify management to direct the affected work activity to cease pending satisfactory resolution of the identified problem.

17.3.1.2.3 Electric System Support Department

The Electric System Support Department provides centralized services to the Duke Power Group in areas such as environmental engineering, NDE, measuring and test equipment calibration, craft support, electrical equipment, and others. The Electric System Support Department is directed by the Vice President, Electric System Support who reports to the President, Duke Power Group.

17.3.1.2.4 Duke Power Group Human Resources

The Duke Power Group Human Resources provides input to Duke Power Group and Energy Transmission Group in such areas as Fitness For Duty. The Duke Power Group Human Resources is directed by the Vice President, Group Human Resources who reports to the President, Duke Power Group.

17.3.1.2.5 Duke Power Group Environmental, Health and Safety Department

The Duke Power Group Environmental, Health and Safety Department provides input to the Duke Power Group in such areas as fire protection. The Duke Power Group Environmental, Health and Safety Department is directed by the Vice President, Group Environmental, Health and Safety who reports to the President, Duke Power Group.

17.3.1.2.6 Shared Services Department

Shared Services is responsible for the Materials and Equipment Database (MEDB), which is the computer database containing necessary attributes for the purchase of a commodity; the purchasing function; technical training; environmental services; and document control and records retention services. These activities in Shared Services are directed by the Manager- Business & Technical Services, and the General Manager, General Purchasing respectively, who report to the Senior Vice President, Shared Services. Shared Services is responsible for operation of any central storage facilities not directly assigned as part of a nuclear site. This responsibility is directed by the General Manager, Corporate Materials

Management. The Nuclear Site Organization administers, implements and assesses the Quality Assurance Program at these locations storing QA Condition 1 items.

17.3.1.2.7 Information Management Department

Information Management is responsible for the development and maintenance of mainframe computer software and data which support QA Condition activities. These activities in Information Management are directed by managers and directors reporting to the Senior Vice President, Information Management

17.3.1.2.8 Electric Transmission Department

The Electric Transmission Department provides maintenance and testing services to the nuclear stations for selected electrical equipment. These services are directed by the Senior Vice President, Electric Transmission who reports to the President, Energy Transmission.

17.3.1.2.9 Department Interfaces

Quality related activities are performed by Nuclear Generation, Electric System Support, Duke Power Group Human Resources, Duke Power Group Environmental, Health and Safety, Shared Services and Information Management Departments. Departmental interfaces are identified in the quality assurance program manuals associated with these areas. Quality related activities performed by the Electric Transmission Department are identified by and conducted in accordance with approved departmental interface agreements.

Organization charts for these departments are maintained in appropriate manuals for the respective departments.

17.3.1.3 Responsibility

The individuals who constitute the Duke Energy Corporate Organization have full personal and corporate responsibility to assure nuclear power plants are designed, constructed, maintained, tested and operated in a manner to protect the public health and safety; and to assure the effectiveness of the Quality Assurance Program.

Corporate audits are initiated and directed by the Executive Vice President, Nuclear Generation. This audit is performed annually to assess the adequacy of the Quality Program. This audit is discussed in greater detail in Section 17.3.3.2.5.

Applicable procedures are developed, approved by the responsible implementing manager, issued for use, with sufficient personnel available and trained with necessary resources prior to performing quality affecting activities.

17.3.1.4 Authority

Anyone involved in quality activities in the Duke organization has the authority and responsibility to stop work if they discover deficiencies in quality. Personnel performing quality assurance and quality control functions have the authority and responsibility to stop unsatisfactory work and to assure the item/activity is controlled to prevent further processing, delivery, installation, or use until authorized by appropriate management. If a member of the group performing the work disagrees, they are instructed to take the matter

to their management. The disagreement may either be resolved at this level or at any level up to and including the Chief Executive Officer.

17.3.1.5 Personnel Training and Qualification

A training program is established for each nuclear station and support organization to develop and maintain an organization qualified to be responsible for operation, engineering, testing, inspection, maintenance, modification and other technical aspects of the nuclear station involved. The program is formulated to provide the required training based on individual employee experience and intended position. The program is in compliance with Nuclear Regulatory Commission licensing requirements, where applicable. The training program is such that trained and qualified operating, maintenance, engineering, inspection, testing, technical support and supervisory personnel are available in necessary numbers at the times required. In all cases, the objectives of the training program shall be to assure safe and reliable operation of the station.

The training program is kept current to reflect station modifications and changes in procedures. A continuing effort is used after a station goes into commercial operation for training of replacement personnel and for periodic retraining, reexamining, and/or recertifying as required to assure that personnel remain proficient. Personnel receive formal orientation training in basic quality assurance policies and practices.

Personnel receive additional formal training, as appropriate, which addresses specific topics such as NRC regulations and guides, quality assurance procedures, auditing and applicable codes and standards. Special training of personnel in quality assurance related matters, particularly new or revised requirements, is conducted as necessary. Training and qualification records are maintained for each employee. Documentation of formal training includes the objectives, content of the program, attendees, and date of attendance.

17.3.1.6 Corrective Action

Duke has established a corrective action process whereby all personnel are to assure conditions adverse to quality are promptly identified, controlled, and corrected. This process is administered to correct the problem and its cause rather than establish blame or fault. This process also provides for trending of problems to detect adverse trends in quality performance, including reporting of results to appropriate levels of management. This process is discussed in Section 17.3.2.13, "Corrective Action."

17.3.1.7 Regulatory Commitments

Duke management is committed to applicable quality assurance regulations, codes, and standards as identified in Section "Quality Assurance Standards and Guides" of this report.



Richard B. Priory
*Chairman and
Chief Executive Officer*

Duke Energy Corporation
422 South Church Street
PB03D
P.O. Box 1244
Charlotte, NC 28201-1244

(704) 382-7133

June 18, 1997

DUKE ENERGY CORPORATION
QUALITY ASSURANCE PROGRAM
POLICY STATEMENT

Duke Energy Corporation has developed a comprehensive quality assurance program, described in the Topical Report, to answer our needs and the regulatory requirements established by the Nuclear Regulatory Commission and other jurisdictional authorities for the safe and effective design, construction, operation, and modification of nuclear stations. This program has my unqualified support and is to be followed at all times.

The authority and responsibility to administer the quality assurance program is assigned to the President, Duke Power Group.

This quality assurance program is documented in quality and administrative manuals prepared by the involved departments and approved by the responsible department heads. These manuals delineate the action taken by Duke Energy Corporation personnel during the design, construction, operation, testing, refueling, maintenance, repair, and modification of its nuclear stations.

The department heads of all the corporation's departments engaged in nuclear activities are responsible for implementing procedures required by the quality assurance program.

Duke Energy Corporation personnel are given authority commensurate with their responsibility, including the authority to stop work which does not conform to established requirements. This stop-work authority must be exercised in accordance with approved procedures.

All matters concerning quality which cannot be resolved at the normal interfaces among departments shall be referred to the President, Duke Power Group. Matters that cannot be resolved at this level shall be referred to me for final resolution.

R. B. Priory

TOPICAL REPORT
QUALITY ASSURANCE PROGRAM

Figure 17-1. Duke Energy Corporation Quality Assurance Policy Statement





Figure 17-2. Duke Energy Corporation Corporate Organization

Figure 17-3. Off-Site Organization






Figure 17-4. Nuclear Site Organization

17.3.2 PERFORMANCE/VERIFICATION

17.3.2.1 Methodology

The Duke Energy Corporation operational quality assurance program is described in various Corporation manuals. Procedures and work instructions necessary to implement the requirements of the operational quality assurance program are developed and approved by the organization responsible for the activity. These procedures and instructions may be contained in manuals, station procedures and directives, administrative instructions and/or other documents. These documents identify the criteria to determine acceptable quality for the activity being performed. On-site implementation of procedures and work instructions is the responsibility of the Site Officer. Verification of quality against these documents is performed by means of inspections, tests, audits, and reviews. Procedures for such inspections, audits and reviews are developed and approved by the responsible implementing manager.

The program receives on-going review and is revised as necessary to assure its continued effectiveness.

17.3.2.2 Design Control

In order to provide for the continued safe and reliable operation of a nuclear station's QA Condition 1 structures, systems and components, design control measures commensurate with those applied to the original design are implemented during the operational phase to assure that the quality of such structures, systems and components is not compromised by modifications.

Duke has assigned the responsibility for design activities during the operational phase of nuclear stations to the Nuclear Generation Department.

The operational quality assurance program establishes procedures and instructions for implementation and assurance of design control during the operational phases for QA Condition 1 items. These procedures and instructions assure the design is performed in accordance with approved criteria, and that deviations and nonconformances are controlled.

Each QA Condition 1 design document, such as a calculation, specification, or drawing, is prepared by a qualified individual who specifies and includes the appropriate codes, standards, SAR commitments, and other design input within the design documents. The preparer notes any deviations or changes from such standards within the design documentation package. Each design document is then checked by another individual qualified in the same discipline and is reviewed for concept and conformity with applicable codes, standards, and other design inputs (as specified within the design documentation package). The document is approved by the individual having overall responsibility for the design function. A review of each specification is made to assure incorporation of necessary quality assurance information. The entire review process is documented.

Prior to the release of any QA Condition 1 design document, it is reviewed to assure coordination of disciplines. If the document clearly involves no coordination with the other disciplines, this review may be waived by the sponsor, with documented concurrence by the other disciplines.

In order to assure proper interface control, the responsibilities of the various individuals/organizations involved in modifications are formally identified. The assignment of responsibility for the evaluation and design of a particular modification to a specific individual/organization is documented. Also, the written instructions addressing the control of modifications address the communication of information between involved individuals/organizations and, where appropriate, require documentation of such communications.

For each proposed modification, the individual/organization assigned responsibility for evaluation and design of the modification considers the following in the design of the modification:

- a) Necessary design analyses, e.g., physics, stress, thermal, hydraulic, accident, etc.
- b) Compatibility of materials.
- c) Accessibility for operation, testing, maintenance, inservice inspection, etc.
- d) Necessary installation and periodic inspections and tests, and acceptance criteria therefor.
- e) The suitability of application of materials, parts, components, and processes that are essential to the function of the structure(s), system(s) and/or component(s) to be modified.

Final approval prior to implementation of each station modification shall be by the Station Manager or the Manager of Engineering; or for the Station Manager by the Operations Superintendent, the Maintenance Superintendent, the Work Control Superintendent, or the On-Duty Emergency Coordinator as previously designated by the Station Manager. Modifications are then executed in accordance with approved checklists, instructions, procedures, drawings, etc., appropriate to the nature of the work to be performed. These checklists, instructions, procedures, drawings, etc. include criteria for determining the acceptability of the modification.

Errors and deficiencies noted in the design of a modification are corrected by means of a variation notice or a revision to the modification. The control measures applied to each such modification revision or variation notice are equivalent to the control measures applied to the modification originally. Each modification revision or variation notice and the review and approval thereof, is documented.

Prior to a modification being declared operable and returned to service, all procedures governing the operation of the modification are reviewed and revised as necessary. If the modification significantly alters the function, operating procedure, or operating equipment, then additional training is administered as necessary.

Adequate identification and retrievable documentation of station modifications is retained for the life of the station.

Computer programs are controlled in accordance with appropriate department procedures, whereby programs are certified to demonstrate their applicability and validity.

17.3.2.3 Design Verification

During the check and review, of design documents, particular emphasis is placed on assuring conformance with applicable codes, standards, SAR design commitments, and

other design input. The individuals assigned to perform the check and review of a QA Condition 1 document have full authority to withhold approval of the document until every question concerning the work has been resolved. If required, the matter can be carried up to the Executive Vice President, Nuclear Generation Department by individuals in Nuclear General Office or to the Site Officer by individuals in Site Engineering for resolution. The checker verifies calculations by checking or by alternate computations. Analytical models, theories, examples, tables, codes, computer programs, etc., used as bases for design must be referenced in the design document and their application verified during check and review. Model tests, when required, to prove the adequacy of concept or design are reviewed and approved by the responsible engineer. The tests used for design verification must meet all the requirements of the designing activity. Computer programs are controlled in accordance with the applicable Quality Assurance Manual whereby programs are certified to demonstrate their applicability and validity.

Design verification may consist of reviews, alternate calculations, and/or qualification testing. Design reviews are intended to verify the correctness of design inputs, logic, calculations, and analyses. Calculations by alternate methods provide assurance that, for instance, computer codes are performing as expected, and that no systematic error in calculation procedures exist. Qualification testing, when suitable, is guided by Duke's adoption of various regulatory guides which deal with qualification testing. Qualification testing will simulate the most adverse design conditions that are expected to be encountered. Design verification is performed by qualified individuals in accordance with approved procedures which identify the responsibilities, features and pertinent considerations to be verified such as verification method, design parameters, acceptance criteria, and documentation requirements. Design verification is required to be completed before relying on the item to perform its function and before its installation becomes irreversible. The use of the originator's immediate supervisor for verification is: 1) restricted and justified to special situations where the immediate supervisor is the only individual capable of performing the verification 2) the need is individually documented and approved in advance by the supervisor's management and 3) the frequency and effectiveness of the supervisor's use as design verifier are independently verified to guard against abuse.

The individual/organization assigned responsibility for evaluation and design of a modification performs a safety evaluation of the proposed modification. This evaluation provides the bases for the determination that the modification does or does not involve an unreviewed safety question. This evaluation is reviewed by an individual/group other than the individual/group performing the safety evaluation, but who may be from the same organization as the individual/group which performed the safety evaluation. This evaluation and the review thereof are documented.

Following completion of design and evaluation of a modification, the responsible individual/organization summarizes the modification design and identifies the design documents and information required for modification implementation. This addresses such items as:

- a) A description of the modification.
- b) References utilized in the evaluation and design of the modification, and necessary for the implementation of the modification.
- c) Special installation instructions.
- d) Operational, test, maintenance and inspection requirements.

- e) Materials, parts and components required in order to implement the modification.
- f) Drawings revised and/or requiring revision.
- g) FSAR revision(s) and/or Technical Specifications amendment(s) necessary.
- h) Whether or not the modification involves an unreviewed safety question.

The reviews of the proposed modification, including applicable implementing procedures associated therewith, certifies that quality assurance requirements have been met and determines inspection requirements prior to implementation of the modification. Modifications which are determined to involve an unreviewed safety question are reviewed by the Nuclear Safety Review Board and must be authorized by the Nuclear Regulatory Commission prior to implementation.

17.3.2.4 Procurement Control

Duke's Quality Assurance Program requires the control of QA Condition 1 items or services purchased from a supplier, subsupplier or consultant.

The Quality Assurance Program supplements appropriately the ASME QA requirements with the regulatory guides listed in Table 17-1, with the clarifications or alternatives stated therein.

Procurement of QA items is to the quality program requirements in effect at the time of purchase.

Nuclear Generation or Electric System Support is responsible for the technical qualification of suppliers and control of the initial procurement of all QA Condition 1 items and services. Procurement requirements/specifications are prepared, checked, and approved by appropriate personnel and forwarded to the Shared Services Department, who prepares an inquiry and forwards it to approved suppliers. The Nuclear General Office, Supplier Verification Section is responsible for qualification of supplier's quality assurance programs.

QA Condition 1 material, equipment and services procured as basic components may only be procured from qualified suppliers. Supplier qualification is accomplished by a Supplier Verification Section evaluation of the supplier's quality assurance program. An audit or pre-award survey is performed by the Supplier Verification Section when required. The audit or pre-award survey is carried out in accordance with a comprehensive audit checklist to determine the ability of the supplier's quality assurance program and manual(s) to meet applicable criteria of 10CFR50, Appendix B, the ASME Code when required, and any other codes and standards determined to be appropriate for the prospective scope of supply. The audit or survey includes a review of the supplier's QA program manuals. The audit team prepares a formal audit report which states whether or not the supplier is qualified to supply the specific items or services. The audit report is reviewed and approved or disapproved by the Supplier Verification Manager. Approved suppliers of basic components will then be included on the Approved Supplier's List. Technical qualifications are determined by engineering personnel. Commercial qualification is determined by the Shared Services Department following evaluation of bids from qualified suppliers. Bid evaluation includes evaluation of the technical, quality and commercial qualifications of the prospective suppliers.

When QA Condition 1 basic components and services are procured from a supplier whose quality performance has not been verified by audit, additional assurance of product quality shall be obtained by supplier surveillance, inspection or test.

The Supplier Verification Manager may place a supplier on the Approved Suppliers list following review, approval and acceptance of an audit performed by another licensed nuclear utility or joint utility audit team. Review of such third party audits shall ensure that items to be procured are within the audit scope and any unique plant quality and technical requirements are adequately addressed by such audits.

The Supplier Verification Section shall complete a satisfactory re-evaluation of a supplier every 12 months in order to maintain the supplier on the Approved Suppliers List. Annual re-evaluations may be extended by 3 months, from 12 to 15 months, with written approval of the Supplier Verification Manager. Additionally, suppliers shall be re-evaluated by means of an audit at least triennially, if initial approval was by audit or survey. The triennial audit requirement may be extended by 3 months, from 36 to 39 months, with written approval of the Supplier Verification Manager. Extensions would be on an infrequent basis for reasons such as: accommodating manufacturing schedules, synchronizing with other utility audits, or allowing time for implementation of supplier QA program changes.

Materials, parts and components shall be procured to specified technical and quality requirements at least equivalent to those applicable to the original equipment or those specified by a properly reviewed and approved revision. As required by the applicable purchase documents, suppliers furnish documentation which identifies the material and equipment purchased and the specific procurement requirements met by the items. Also, as required by the applicable purchase documents, suppliers will provide documentation which identifies any procurement requirements which have not been complied with, together with a description of any deviations and repair records.

When QA Condition 1 products/services are not supplied as a basic component and meet the definition of commercial grade, the item may be procured without the performance of a supplier qualification audit or the existence of a documented supplier Quality Assurance Program. These commercial grade items used in QA Condition 1 applications require evaluation, dedication and approval by Nuclear Generation Department personnel. Supplier selection for commercial grade items is the responsibility of the responsible engineering personnel. These items are subject to the same verification and checking process for suitability of application as other QA Condition 1 items.

Critical characteristics for the dedication of Commercial Grade Items are determined by engineering technical sponsors and approved by the responsible engineering personnel based on the manufacturer's published specifications and the intended safety function for the items. Critical characteristics used for acceptance and dedication of commercial grade items are selected to provide reasonable assurance that the items will meet their catalog or manufacturer specifications and will perform the necessary safety functions in the intended applications. Verification of critical characteristic acceptability will be by manufacturer/supplier survey, manufacturing surveillance, receipt tests or inspections, or post installation testing. Historical data, when documented, will represent industry wide experience.

If verification of a critical characteristic is to be by supplier survey, Supplier Verification is responsible for verifying the acceptability of the supplier control of the identified critical characteristic.

Procurement of materials, parts, components and services associated with a station's QA Condition 1 structures, systems, and components is controlled during the operational life of the station so as to assure the suitability for their intended service and that the safety and reliability of the station are not compromised.

Each procurement information for materials, parts, and components associated with QA Condition 1 structures, systems and components is identifiably designated as such. The procurement requirements applicable to each item are determined by a cognizant individual. This determination is reviewed by another cognizant individual who may be from the same organization as the individual/group making the determination.

Procurement information must include or reference other documents such that to assure sufficient information is fully identified to specify the items being procured. Subsequent to preparation, procurement information is approved by the Procurement Engineering Manager or designee who is qualified by experience and training for the function.

Procurement information for QA Condition 1 materials, parts and components is reviewed to assure that quality assurance, technical and regulatory requirements including supplier documentation requirements are adequately incorporated into the purchase document(s). Significant changes to the content of such purchasing information are reviewed and approved in a manner consistent with the original.

Where necessary, procurement documents require that QA Condition 1 materials, parts, and components be acquired from suppliers determined to be acceptable by the Nuclear General Office, Supplier Verification Section - see Section 17.3.3.2.7. Determination of acceptability requires that a supplier provide Duke the right of access to the supplier's facilities and records for inspection and audit.

Except for some commercial grade items each shipment of items procured from a supplier must be accompanied by a certificate of conformance (or equivalent) which identifies the applicable procurement documents and item(s). The certificate and supplier documentation specifies that the item meets the procurement requirements and includes repair records and a description of any deviations. This documentary evidence must be on site (any location under the QA Program) and all procurement, inspection, and testing requirements satisfied before the item is placed in service or used.

Nuclear Generation Department or Electric System Support Department personnel will review and approve this documentary evidence of item conformance with procurement requirements.

17.3.2.5 Procurement Verification

The approved procurement documents along with all quality and technical requirements are provided to the supplier by the Nuclear Generation and/or Shared Services Departments. Procurement information is provided to the Supplier Verification Section and the receiving location.

As required by procurement criteria, in order to assure that material and equipment are fabricated in accordance with applicable requirements, supplier review, audit and surveillance are performed by the Nuclear General Office, Supplier Verification Section. The review, audit and surveillance may include witnessing of tests, observation of

fabrication checkpoints, and documentation review. Evaluation of overall supplier performance is performed at intervals and to a depth consistent with the item or service's importance to safety, complexity, and the quantity and frequency of procurement.

Procedures are established which implement the surveillance program for suppliers. This assures that items and services procured for use in nuclear QA Condition 1 applications are in compliance with applicable procurement requirements/specifications.

These procedures provide for surveillance of those characteristics or processes to be witnessed, inspected or verified. Surveillance activities assure that the supplier complies with all quality requirements outlined in the procurement document(s). The surveillance report becomes a part of the Nuclear General Office, Supplier Verification Section files. The surveillance representative has the authority and responsibility to stop work when the required quality standards are not met.

Upon receipt, QA Condition 1 materials, parts and components are placed in a controlled, designated area and are subjected to a receipt inspection. This inspection is intended to determine whether or not each item received conforms with applicable procurement requirements. Such inspections and the subsequent determination of conformance or nonconformance are documented by means of reports, which are retained on file and as appropriate, by tags attached to the items. Until a determination of conformance is made, a QA Condition 1 material, part or component cannot be issued and installed.

17.3.2.6 Identification and Control of Items

Control of materials, parts, and components at nuclear sites is the ultimate responsibility of the Executive Vice President, Nuclear Generation Department with responsibilities delegated to each nuclear Site Officer.

Identification requirements for materials, parts and components important to nuclear safety are stated in specifications, drawings and purchase documents. Specific identification requirements are as follows:

- a) Materials, parts, components, assemblies, and subassemblies shall be identified either on the item or records traceable to the item to show that only correct items are received, issued and installed.
- b) Some components, such as pressure vessels are identifiable by nameplates as required by applicable codes, or Duke specifications. Materials, parts, and components are traceable from such identification to a specific purchase order to manufacturer's records and to quality assurance records and documentation.
- c) When required by procurement documents, materials are identified by heat, batch or lot numbers which are traceable to the original material at receipt. Upon receipt, a unique tracking number is assigned to provide traceability. When several parts are assembled, a list of parts and corresponding numbers is included in the documentation.
- d) When required by specifications or codes and standards, identification of material or equipment with the corresponding mill test reports, certifications and other required documentation is maintained throughout the life of the material or equipment by a unique tracking number.
- e) Sufficient precautions will be taken to preclude identifying materials in a manner that will affect the function or quality of the item being identified.

Control of material, parts and components is governed by approved procedures. Specific control requirements include:

- a) Nonconforming or rejected materials, parts, or components are identified to assure that they will not be inadvertently used.
- b) The verification of correct identification of material, parts, and components is required prior to release for assembling, shipping and installation.
- c) Upon receipt, procedures require that materials, parts or components undergo a receipt inspection to assure they are properly identified and that the supporting documentation is available as required by the procurement requirements/specifications. Items having limited shelf or service life are identified and controlled.
- d) Each organization which performs an operation that results in a change in the material, part or component is required to make corresponding revisions and/or additions to the documentation record as applicable.

Following QA receipt inspection, materials, parts and components which are determined to be acceptable are assigned an identifying designation such as a unique tracking number in order to provide traceability of each item. This traceability is maintained for QA Condition items. In the event that the identification of an item becomes lost or illegible, the item is considered nonconforming and not utilized until proper resolution of the nonconformance. When a designated item is subdivided, each subdivision is identified in accordance with the above requirements. Where physical identification of an item is impractical or insufficient, physical separation, administrative controls or other appropriate means are utilized.

17.3.2.7 Handling, Storage, and Shipping

The quality assurance program requires that QA Condition 1 materials, parts and components be handled, stored, issued and shipped in such a manner that the serviceability and quality assurance traceability of an item is not impaired. Handling, storage and shipping of an item is in accordance with any special requirements identified in documents pertaining to the item. Such requirements may include special handling tools and equipment, special protective coverings and/or special protective environments. Items are to be marked or labeled to preserve the item's integrity and indicate the need for any special controls. Procedures identify predetermined requirements for handling, preservation, storage, cleaning, packaging, issuing and shipping and are utilized by suitably trained individuals.

Conforming QA Condition 1 materials, parts and components are stored in controlled, segregated areas designated for the storage of such items. Inspections and examinations are performed on a periodic basis to assure that recommended shelf life of chemicals, reagents, and other consumable materials is not exceeded. Hazardous items are stored in suitable environments with controls to prevent contamination of QA Condition 1 structures, systems, or components.

Nonconforming items are identified, segregated, or otherwise controlled in such a manner as to preclude their inadvertent substitution for and use as conforming materials parts and components.

17.3.2.8 Test Control

The operational quality assurance program addresses both preoperational and periodic (surveillance) testing. The program requires that such testing associated with QA Condition 1 structures, systems and components be accomplished in accordance with approved, written procedures and that schedules be provided and maintained in order to assure that all necessary testing is performed and properly evaluated on a timely basis.

Test controls include requirements on the review and approval of test procedures, and on the review and approval of changes to such procedures, as discussed in Section 17.3.2.14, "Document Control." Also, specific criteria are established with regard to procedure content. Examples of items which must be considered in the preparation and review of procedures include:

- a) References to material necessary in the preparation and performance of the procedure, including applicable design documents.
- b) Tests which are required to be completed prior to, or concurrently with, the specified testing.
- c) Special test equipment required to perform the specified testing.
- d) Limits and precautions associated with the testing.
- e) Station, unit and/or system status or conditions necessary to perform the specified testing.
- f) Criteria for evaluating the acceptability of the results of the specified testing, compatible with any applicable design specifications.

Test procedures contain the following information or require this information be documented:

- a) Requirements and acceptance limits contained in applicable Design and procurement documents.
- b) Instructions for performing the test.
- c) Test prerequisites such as calibrated instrumentation, adequate test equipment and instrumentation including their accuracy requirements, completeness of the item to be tested, suitable and controlled environmental conditions, and provisions for data collection and storage.
- d) Mandatory inspection hold points.
- e) Acceptance and rejection criteria.
- f) Methods of documenting or recording test data and results.
- g) Provisions to assure test prerequisites have been met.

Requirements are also established for verification of test completion and for determining acceptability of tests results. Test results are reviewed and accepted by the testing organization and the organization responsible for the item being tested. In the event that test results do not meet test acceptance criteria, a review of the test, test procedure and/or test results is conducted to determine the cause, required corrective action, and retest as necessary.

In addition to the above, after maintenance to, or modification of, QA Condition 1 structures, systems and components certain proof tests, electrical tests, operational tests or other special tests are performed and documented as required to verify the satisfactory performance of the affected items.

17.3.2.9 Measuring and Test Equipment Control

The organizations performing QA Condition 1 work activities have the responsibility to assure the required accuracy of tools, gauges, instruments, radiation measuring equipment, non-destructive testing equipment and other measuring and test devices affecting the proper functioning of QA Condition 1 structures, systems and components and that a program of control and calibration for such devices is provided. This program includes the following:

- a) Devices are assigned permanent, identifying designations.
- b) Devices are calibrated at prescribed intervals, and/or prior to use, against certified equipment having known, valid relationships to nationally recognized standards. The calibration interval for a device is based on the applicable manufacturer's recommendations. If experience dictates that the manufacturer's recommendations are not appropriate, the calibration interval is changed as necessary.
- c) Devices that have been acceptably calibrated are affixed, where practical, with a tag, or tags, showing the date of calibration, the date the next calibration is due, an indication that the device is within calibration specifications and the identification of the individual who was responsible for performing the calibration. When attaching tags is not practical, the device is traceable by unique identification to the applicable calibration records.
- d) Devices which fail to meet calibration specifications are affixed with a tag, or tags, showing the date of rejection, the reason for rejection and the identification of the individual rejecting the device. "Accepted" and "Rejected" calibration tags are sufficiently different to preclude confusion between them.
- e) Items and processes determined to be acceptable based on measurements made with devices subsequently found to be out of calibration are re-evaluated.
- f) Devices stored under conditions which are in accordance with, or more conservative than, the applicable manufacturer's recommendations.
- g) Devices are issued under the control of responsible personnel so as to preclude unauthorized use.
- h) Devices are shipped in a manner that is in accordance with, or more conservative than, the applicable manufacturer's recommendations.
- i) Records are maintained on each device which identify such items as the device designation and the calibration frequency and specifications. Records are maintained to reflect current calibration status.
- j) As a rule, the calibration program achieves a minimum ratio of 4-to-1 calibration standard accuracy to measuring and test equipment accuracy unless limited by the state of the art; however, when an accuracy ratio of less than 4-to-1 is utilized, an evaluation of the specific case is made and documented.

Installed instrumentation is subject to the requirements of the Technical Specification and is not subject to the tagging requirements discussed in (c) and (d) above. The Nuclear

General Office, Regulatory Audits Section verifies implementation of the calibration program through periodic audits.

The basis for this exception on the installed Technical Specification required equipment is the PMPT, Preventive Maintenance Periodic Testing program. This is a computerized scheduling program that automatically schedules PMPT using SWR's, Standing Work Requests. When devices have been acceptably calibrated, the clock starts for the next calibration due date. The indication that the device is within calibration specifications and identification of the individual who was responsible for performing the calibration is documented within the calibration procedure for the device. If the device fails to meet calibration specifications, it will be repaired, replaced and/or engineering involvement will be requested to further evaluate. The PMPT program along with the calibration procedures address all the requirements in Topical Report Section 17.3.2.9 c and d. Therefore, there is no need to place tags on the devices to identify the calibration status.

17.3.2.10 Inspection, Test, and Operating Status

In order to assure that equipment status is clearly evident, and to prevent inadvertent operation, the operational quality assurance program requires QA Condition 1 structures, systems and components which are in an other than operable status to be identified as such. This identification may be means of tags, labels, stamps or other suitable methods. Where appropriate, an independent verification of the correct implementation of such identification measures is performed. When tags, labels or stamps are utilized for the identification of equipment status, the issuance and removal thereof is documented in order to assure proper control of such identification measures. Also, procedures require that the operability of an item removed from operation for maintenance or testing be verified prior to returning the item to normal service.

Inspections and tests required by the written approved procedures which address work activities are infrequently, temporarily deferred. When such a deferral does occur, a discrepancy is considered to exist and documentation of the acceptable completion of the affected work activity is not performed until the discrepancy is resolved.

Measures taken to identify equipment inspection and test status by Nuclear Generation Department personnel are controlled by the Nuclear Generation Department. Measures taken by Electric System Support Department personnel, during the performance of required inspections and quality control activities, to identify equipment status are controlled by the Electric System Support Department.

17.3.2.11 Special Process Control

The Nuclear Station Manager is responsible for directing the organization and performance of the station's program for the control of special processes, and for assuring the necessary qualified personnel are available.

Electric System Support and Nuclear Generation are responsible for furnishing qualified personnel, performance of and documentation of Non Destructive Examination (NDE).

The operational quality assurance program contains or references procedures for the control of special processes such as welding, heat treating, non-destructive examination, coatings, crimping, and cleaning. The program requires that approved, written procedures, qualified in accordance with applicable codes and standards, be utilized when the performance of such processes affects the proper functioning of a station's QA Condition 1

structures, systems, and components. These procedures shall provide for documented evidence of acceptable accomplishment of special processes using qualified procedures, equipment, and personnel.

Personnel performing such activities must be qualified in accordance with applicable codes and standards. Adequate documentation of personnel qualifications is required prior to performance of the applicable special process. Non-destructive examination personnel are certified to required codes and standards.

17.3.2.12 Inspection

In order to assure safe and reliable operation, a program of inspections for QA Condition 1 structures, systems and components is established at each nuclear station. The program addresses:

- a) Inservice inspections required by Section XI of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code.
- b) Inspections to verify compliance with cleanliness criteria.
- c) Inspections to verify compliance with certain instrument and maintenance procedures.
- d) Inspections to verify conformance of materials, parts, and components received at a nuclear station with applicable specifications and requirements.
- e) Inspections to verify the integrity of QA Condition 1 structures, systems and components during and/or after maintenance and modification.

The personnel performing these inspections are examined and certified in their particular category. Current qualification and certification files are maintained for each inspector. Nondestructive examination inspectors are certified in accordance with American Society for Non-destructive Testing (SNT-TC-1A) recommended practice. Written procedures require the test and certification of inspectors in other categories such as Mechanical, Electrical, and Structural as described in the appropriate quality assurance manual. For cases where inspectors will perform limited functions within a category, they are tested and certified to those limitations. These inspectors are only allowed to perform inspections specifically defined in this limited certification.

Certification procedures and certifications are approved by Nuclear Generation or Electric System Support personnel responsible for these processes. These procedures comply with the requirements of applicable codes and standards.

Modifications, repairs and replacements are inspected in accordance with the original design and inspection requirements, or acceptable alternatives. Mandatory inspection hold points are included in the documents addressing the activities being performed, as necessary, and work does not proceed beyond such hold points until satisfactory completion of the required inspection, disposition of any item not meeting the acceptance criteria, and any required reinspection. Inspection procedures, instructions, and checklists contain the following information or require this information on inspection reports:

- a) Characteristics to be inspected.
- b) Method of inspection.
- c) Measuring and test equipment information.

commitments which specifically involve other Department(s) require written notification by the other Department(s) of the satisfactory completion thereof.

Electronic processes are used to track, trend, and to facilitate in the resolution of site problems. Additionally, these electronic processes are used to measure and classify nuclear performance. Identified problems are considered for generic implications. Monthly reports are processed electronically and are also provided directly to senior management and the NSRB.

Discrepancies revealed during the performance of station operation, maintenance, inspection and testing activities must be resolved prior to verification of the completion of the activity being performed. In the event of the failure of QA Condition 1 structures, systems, and components, the cause of the failure is evaluated and appropriate corrective action taken. Items of the same type are evaluated to determine whether or not they can be expected to continue to function in an appropriate manner. This evaluation is documented in accordance with applicable procedures.

QA Condition 1 materials, parts and components which are determined to be nonconforming are identified, segregated or otherwise controlled in such a manner as to prevent installation and/or use. The determination of an item's nonconformance is documented and is retained on file by the Nuclear Generation Department and, as appropriate, by tags attached to the item. Nuclear Generation Department personnel are notified of any nonconformances identified in accordance with approved procedures.

The Nuclear Generation Department maintains a listing of the status of all nonconformance documents. These reports, when complete, identify the nonconforming material, part or component; applicable inspection requirements; and the resolution, and approval thereof, of the nonconformance. Provisions are established for identifying those personnel with the responsibility and authority for approving the resolution of nonconformances. Until a determination of conformance is made, a QA Condition 1 material, part or component cannot be issued or installed. Tags which are placed on items to identify nonconformances are removed upon resolution.

Information relating to nonconforming materials, parts and components is analyzed by Safety Assurance to determine if any discernible trends which might affect quality exist. When recurring nonconformances indicate possible supplier deficiencies, such information is considered in evaluation of supplier acceptability by the Nuclear General Office, Supplier Verification Section.

Significant trends will be/are reported to appropriate levels of management.

17.3.2.14 Document Control

The Topical Report describes Duke's Quality Assurance Program for all phases of Duke's Nuclear Power Plants. This document is certified to meet NRC Quality Assurance Regulations by the President, Duke Power Group. The Nuclear Policy Manual establishes the policies and instructions governing activities associated with Duke's nuclear stations and identifies the various departments performing these activities. This manual is approved by the Executive Vice President, Nuclear Generation, or the Site Vice Presidents, or designee. These manuals are considered controlled documents and copies are distributed by distribution indices from the Manager, Nuclear Assessment and Issues Division or designee.

- d) Responsibility for the inspection.
- e) Acceptance or rejection criteria.
- f) Identification of required procedures, drawings, specifications, etc..
- g) Signature or initials of inspector.
- h) Record of results of the inspection.

After inspection data is collected and reviewed by the inspector, the reports are technically reviewed by personnel designated to perform that quality assurance function.

Inspection activities involving the supplier quality assurance program are evaluated and approved by the Nuclear General Office, Supplier Verification Section.

17.3.2.13 Corrective Action

Station personnel are responsible for the implementation of the quality assurance program as it pertains to the performance of their activities. Specific to this responsibility is the requirement for informing the responsible supervisory personnel and/or for taking appropriate corrective action whenever any deficiency in the implementation of the requirements of the program is determined.

Procedures require that conditions adverse to quality be corrected. In the case of significant conditions adverse to quality (more significant events), the procedures assure that the cause of the condition is determined and action be taken to preclude repetition. Performance and verification personnel are to:

- a) Identify conditions that are adverse to quality.
- b) Suggest, recommend, or provide solutions to the problems.
- c) Verify resolution of the issue.

Additionally, performance and verification personnel are to ensure that reworked, repaired, and replacement items are to be inspected and tested in accordance with the original inspection and test requirements or specified alternatives.

For significant incidents occurring during operation which are, or could be, related to the nuclear safety of the station, reports are generated. These reports:

- a) Contain a summary description of the information relating to the subject incident.
- b) Contain an evaluation of the effects of the incident.
- c) Describe corrective action taken or recommended as a result of the incident.
- d) Describe, analyze and evaluate any significant QA Condition 1 implications of the incident.

Such reports shall be approved by the Manager, Safety Assurance and provided to the Site Vice President, the Plant Operations Review Committee, and to the Nuclear Safety Review Board. Outstanding corrective action commitments made with regard to such incidents are identified and periodically reviewed to assure that the identified corrective actions are properly completed and documented. An identified corrective action commitment is closed out upon written notification by a cognizant, responsible individual or other written documentation, of the satisfactory completion thereof. Closure of corrective action

The station Technical Specifications are considered Nuclear Regulatory Commission controlled documents and are distributed within Duke Energy Corporation by cover letter from the Site Officer or designee. Proposed changes to the station Technical Specifications shall be prepared in accordance with the station Technical Specifications and appropriate administrative controls. Proposed changes to the station Technical Specifications shall be approved by the Station Manager, or for the Station Manager by a designated manager or corporate officer. Submittal cover letters for proposed changes to the station Technical Specifications shall be signed by an officer of Duke Energy Corporation.

The Safety Analysis Reports are considered controlled documents and are distributed by cover letter from the Site Officer or his designee.

The Duke Power Group Nuclear Policy Manual and the manuals listed below specify the requirements for the development, review, approval, issue, control, and use of manuals and procedures to implement the requirements contained within the Topical Report.

The Nuclear Policy Manual provides the governing procedures for the Assessment Organization, the Plant Operations Review Committee and the Nuclear Safety Review Board. This manual is approved by the Site Vice Presidents, except for the Nuclear Safety Review Board procedure, which is approved by the Executive Vice President, Nuclear Generation.

The Nuclear Procurement Engineering Program Manual (NPEP) contains the policies and procedures that control nuclear procurement and supplier qualification. This manual imposes requirements on all departments involved with procurement, including Shared Services. This manual is approved by the Executive Vice President, Nuclear Generation or designee.

The Information Management Quality Manual (IMQM) provides governing procedures for the development and maintenance of software by Information Management which supports QA Condition activities (activities associated with nuclear safety, radwaste, fire protection, and seismic structures, systems, and components) as identified in each station's Quality Standards Manual. This manual is approved by the Senior Vice President, Information Management or designee.

The ESS Department Quality Assurance Program Manual in conjunction with ESS functional area manuals, applicable nuclear system directives, and applicable station procedures contain the policies and procedures governing the functions that this department performs in support of the nuclear sites. These functions include such activities as NDE, calibration, soils testing, and electrical equipment maintenance and testing. The ESS Department Quality Assurance Program Manual and the ESS functional area manuals are approved by the Vice President, ESS or designee.

The Duke Power Group Human Resources Department Manual contains the policies and procedures governing the functions that this department performs such as fitness for duty. This manual is approved by the Vice President, Group Human Resources or designee.

The policies and procedures governing the fire protection functions of the Duke Power Group Environmental, Health and Safety Department are contained in the Safe Work Practices Manual and the Safety and Industrial Hygiene Compliance Manual. Both of these manuals are approved by the President, Duke Power Group.

With regard to specific operational activities associated with QA Condition 1 structures, systems and components, it is required that such activities be accomplished in accordance with procedures, instructions, drawings, checklists, etc. appropriate to the nature of the activities being performed. As necessary, such documents identify equipment necessary to perform an activity, specify conditions which must exist prior to and during performance of an activity, and include quantitative and/or qualitative acceptance criteria, compatible with any applicable design specifications, for determining that the activity addressed is satisfactorily accomplished. Also, the procedure will require independent verification by qualified personnel of the performance of specific procedural steps. Examples of documents established concerning quality related operational activities are:

- a) Preoperational Test Procedures
- b) Periodic Test Procedures
- c) Operating Procedures
- d) Emergency Procedures
- e) Maintenance Procedures
- f) Instrument Procedures
- g) Radiation Protection Procedures
- h) Alarm Responses
- i) Chemistry Procedures

The frequency of procedure reviews shall be specified and may vary depending on the type and complexity of the activity involved, and may vary with time, not exceeding 6 years, as a given plant reaches operational maturity. Review of procedures can be accomplished in several ways, including (but not necessarily limited to) documented step-by-step use of the procedure (such as occurs when the procedure has a step-by-step checkoff associated with it), or detailed scrutiny of the procedure as part of a documented training program, drill, simulator exercise, or other such activity. A revision of a procedure can constitute a procedure review.

In addition to the above, files of drawings and supplier documents applicable to the station's structures, systems and components are maintained at each nuclear station and are utilized, as appropriate, in the performance of quality related activities.

Station procedures which address activities associated with QA Condition 1 structures, systems and components are subjected to a well-defined, established review and approval process. This process includes the requirement that each procedure be reviewed for adequacy by an individual/group other than the individual/group which prepared the procedure, but who may be from the same organization as the individual/group which prepared the procedure. As appropriate, such procedures are also reviewed by personnel from the Nuclear General Office, by other departments within the Corporation, by the Nuclear Safety Review Board or by vendor personnel. Each procedure as required by station Technical Specifications, and changes thereto, shall be reviewed and approved by an appropriate division manager, superintendent/manager, or one of their designated direct reports prior to implementation. For procedures which implement offsite environmental, technical, and laboratory activities, the above approval may be performed by the General Manager, Environmental Services or designee. Maintenance, instrumentation and modification procedures are reviewed by cognizant station personnel to determine the need for inspections. Procedures developed and implemented for inspection identify the

certifications, inspection methods, acceptance criteria, and provide means for documenting inspection results.

In the case of station activities of a non-recurring nature, e.g., preoperational tests, only an original copy of an approved procedure is available for use. Such copies are controlled and are replaced whenever the procedure is superseded by a new issue. For activities which are of a recurring nature, e.g., surveillance testing, current original copies of approved procedures are maintained in a controlled manner. Copies of these original copies are then utilized in the performance of work activities. When such "working copies" involve the documentation of compliance with acceptance criteria contained in the procedure, the "working copy" of the procedure utilized is compared with the applicable original copy to assure validity. Station procedures administratively control and provide means to document this comparison. Such completed procedures are retained - See Section 17.3.2.15, "Records." When recurring work activities do not involve documentation of compliance with acceptance criteria within the procedure, e.g., certain operating activities, issuance of the applicable "working copies" is controlled to assure that only current copies are available for use.

Drawings and supplier documents, as-built drawings and changes thereto, are normally received from Engineering for distribution and use. Distribution indices are established and utilized for such documents within each station in order to assure their proper distribution and use. A master file of drawings is maintained and a master index, updated regularly, is used to identify drawings, revisions, number of copies, and distribution. Design and procurement documents are maintained, controlled, and are updated, as necessary, by Engineering. As documents are received from Engineering all superseded copies shall be destroyed or clearly marked superseded.

A master copy of all controlled documents is maintained in the document control area of each station. Copies of controlled documents are distributed by station document control personnel utilizing a distribution index to assure proper distribution and use. Reviews are performed regularly and documented to assure proper functioning of the control system.

17.3.2.15 Records

Each nuclear station is required to maintain adequate identifiable and retrievable quality assurance records. Such records are managed in a controlled and systematic manner by means of a station Master File Index. Access to, and use of, this file is controlled. Records required to be retained include:

- a) QA Condition 1 preoperational testing records.
- b) Records of modifications to station QA Condition 1 structures, systems and components.
- c) Radiation monitoring records.
- d) Personnel radiation exposure records.
- e) Records of radioactive releases and waste disposal.
- f) Isotopic and physical inventory records of special nuclear materials.
- g) Records of the qualifications, experience and training of appropriate station personnel.
- h) Current calibrations for measuring and test devices.

- i) Copies of approved purchasing documents for items requiring quality assurance certification.
- j) Maintenance histories on QA Condition 1 instrumentation and electrical and mechanical equipment.
- k) Records of special processes affecting QA Condition 1 structures, systems and components.
- l) Copies of purchase specifications.
- m) Operating records and logbooks.
- n) Periodic testing records.
- o) Records of inspections.
- p) Copies of approved and of completed station procedures.
- q) Copies of audit reports received from the Nuclear General Office, Regulatory Audits Section, and responses thereto.
- r) Copies of reports concerning station activities sent to the Nuclear Regulatory Commission.
- s) Copies of drawings and vendor documents.
- t) Copies of reports of significant events.
- u) Records of inservice inspections.
- v) Records of quality control inspections.
- w) Records such as vendor documentation packages and inspection reports, piping isometric drawings, welding records, etc. compiled during the design and construction of a nuclear station.
- x) Records of in-plant reviews performed on station activities.
- y) Records of the qualifications of quality control and other appropriate personnel.

| Test, inspection, and NDE records maintained by the station contain the following:

- a) A description of the activity performed.
- b) The date and results of the activity.
- c) Information relating to discrepancies identified with regard to the activity.
- d) An identification of the data recorder(s) or inspector(s) involved in the activity.
- e) Evidence of the completion, and verification thereof, of the activity.
- f) An identification of the acceptability of the results of the activity.

Records of activities within the purview of the Nuclear Safety Review Board are maintained. These records include:

- a) Nuclear Safety Review Board meeting minutes.
- b) Nuclear Safety Review Board Reports.
- c) Audit reports for audits conducted under the cognizance of the Nuclear Safety Review Board.

Records of activities within the purview of the Plant Operations Committees are maintained. These records document the meetings of the Plant Operations Review Committees. These records include:

- a) Identification of the chairperson for each meeting.
- b) A listing of the Plant Operations Review Committee members present at each meeting.
- c) A listing of others present at each meeting.
- d) A summary of the items/issue(s) discussed during each meeting.
- e) The decisions/approvals reached by the Plant Operations Review Committee during each meeting.

Records of activities within the purview of the Nuclear General Office are maintained. These records include:

- a) Supplier audit reports and surveillances.
- b) Audit reports of Duke Energy Corporation activities.
- c) Audit and Supplier personnel qualification records.

Records of activities within the purview of the Electric System Support Department are maintained by the Electric System Support Department in a manner similar to that described above for station quality assurance records. These records include:

- a) NDE inspection personnel certification records.
- b) Calibration standard records and Measuring and Test Equipment (M & T E) calibration records.
- c) Environmental compliance records.

Records of activities within the purview of the Information Management Department are maintained by the Information Management Department in a manner similar to that described above for station quality assurance records. These records include:

- a) Software requirements.
- b) Software test plans.
- c) Software test results.
- d) Program/Module specifications and source codes.

Records of activities within the purview of the Shared Services Department are maintained by the Shared Services Department in a manner similar to that described above for station quality assurance records. These records include:

- a) Records of Materials and Equipment (MEDB) Catalog.
- b) Purchase Orders/Contracts (Plant)

The retention times for the various quality assurance records are in accordance with corporate retention policies. The development of these retention policies includes applicable requirements, including those of the Code of Federal Regulations, a station's Technical Specifications and established national codes and standards. To the maximum

extent practicable, records are stored such that they are protected from possible destruction by causes such as fire, flooding, theft, insects and rodents and from possible deterioration due to a combination of extreme variations in temperature and humidity conditions.

Record storage areas shall be evaluated by a qualified Fire Protection Engineer to assure the records are adequately protected from damage. The evaluation shall include the following considerations as a minimum:

- a) Structural collapse.
- b) Unprotected steel (suspended floor slab or roof).
- c) Fire frequency of similar occupancies.
- d) Quantities of combustible materials.
- e) Ceiling height/Room configuration which would contribute to heat dissipation.
- f) Fire detection.
- g) Fixed fire suppression systems.
- h) On-site fire fighting organizations including available equipment.

This evaluation shall be documented for each record storage area (includes satellite file locations).

17.3.3 SELF ASSESSMENT

17.3.3.1 Methodology

The Self-Assessment process encompasses internal and corporate audits, independent review committee activities, in-plant reviews, and other independent assessments. This process is to confirm to management that activities affecting quality comply with the quality assurance program and that the quality assurance program has been implemented effectively. These functions are directed by the Manager, Nuclear Assessment & Issues Division and the Managers of Safety Assurance. The assessment activities are performed in accordance with instructions and procedures by organizations independent of the areas being assessed. Organizations performing self-assessment activities are technically and performance oriented, with the primary focus on the quality of the end product and a secondary focus on procedures and processes.

17.3.3.2 Assessment

17.3.3.2.1 Nuclear Safety Review Board

The Executive Vice President, Nuclear Generation, appoints a Nuclear Safety Review Board (NSRB) to serve as a nuclear safety review and audit backup to the normal operating organization. The Nuclear Safety Review Board reviews proposed changes to the stations' technical specifications and operating licenses, proposed tests and experiments, proposed station modifications, and proposed changes to procedures, when such involve an unreviewed safety question. Also, the Board reviews reportable occurrences, violations of a station's technical specifications, other events and trends of nuclear-safety significance and makes recommendations to prevent recurrence. Functions, operations and responsibilities of the NSRB are detailed in Chapter 6 of the technical specifications for each station.

17.3.3.2.2 Plant Operations Review Committee

The Site Vice President appoints a Plant Operations Review Committee (PORC) to review selected nuclear safety related issues. The PORC is composed of specified senior members of the site management team most responsible for the safe and reliable operation of the station. The PORC also reviews the effectiveness of corrective actions taken for specified reportable events.

17.3.3.2.3 Internal Audits

Duke's Quality Assurance Program requires a comprehensive system of planned and periodic internal audits for all phases of station operations and supporting activities.

All organizational units conducting quality assurance activities are evaluated with a system of audits. These audits are performed to determine the effective implementation of all applicable criteria of 10CFR 50, Appendix B. Periodic audits of activities or records of processes (e.g., welding, maintenance, development of design, record management, or system testing), to verify compliance and effectiveness of the implementation of the Quality Assurance Program are performed. Internal audits are initiated under the direction of the Manager, Regulatory Audits. The Manager, Nuclear Assessment and Issues Division may initiate special audits or expand upon the scope of an existing audit. The scope of each audit is determined by the responsible Lead Auditor, under the direction of the Manager, Regulatory Audits Group. Additionally, the scope of audits performed under the

cognizance of the Nuclear Safety Review Board (NSRB) is reviewed by the NSRB staff. The lead auditor directs the audit team in developing checklists, instructions, plans and in the performance of the audit. The audit shall be conducted in accordance with checklists; the scope may be expanded upon by the audit team during the audit, if needed. One or more persons comprise an audit team, one of whom shall be qualified lead auditor.

Audits of selected aspects of operational phase activities are performed with a frequency commensurate with safety significance and in such a manner as to assure that an audit of all QA Condition 1 functions is completed within a period of two (2) years. The audit system is reviewed periodically and revised as necessary to assure coverage commensurate with current and planned activities.

The audit team concludes with a post-audit conference between the audit team and responsible management. The conference includes a brief discussion of audit results, including any deficiencies and recommendations. The audit results are documented in a report.

Within thirty (30) days of the post-audit conference, a report is issued to the responsible management with copies sent to the Vice President of the audited Site or department and other management as appropriate.

Within thirty days after receipt of the audit report, responsible management replies in writing to the Manager, Regulatory Audits Group, describing corrective action and an implementation schedule. The established electronic corrective action process may be used to convey this information. When necessary, after receipt of the management reply, a re-evaluation is made to verify implementation of corrective action. This re-evaluation is documented. The audit is closed with a letter to the responsible management. All pertinent correspondence, checklists, and reports related to the audit are filed.

Audit data are analyzed and the resulting reports on the effectiveness of the QA program, including any quality problems, are reported to management for review and assessment through periodic performance trend summaries. This data is also used to modify the audit schedule as necessary to assess potential weaknesses.

17.3.3.2.4 Safety Assurance

Safety Assurance, through the Safety Review Group, and Regulatory Compliance, monitors the day to day and overall performance of each nuclear station.

The Safety Review Group investigates significant occurrences and problems to determine the root cause(s) and to identify actions necessary to prevent recurrence. The Safety Review Group also performs in-plant reviews including checking documents, records, and work in progress to determine that quality assurance requirements are being properly implemented. Work in progress includes such activities as welding, maintenance, system testing, station operation, station modifications, refueling, and record management. These investigations and reviews are documented in reports and submitted to Management, NRC, and other authorities as appropriate. The Safety Review Group also coordinates the development of corrective actions for significant occurrences and problems.

The Regulatory Compliance Group is responsible for the preparation, issue, and maintenance of all site licensing documents; providing site personnel with interpretations on the licensing documents, the preparation and submittal of violation responses, and coordination of NRC inspection activities on site.