

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 1 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
1	1	06/95 RFO	Bobbin	ODI	26	0.85	13TH TSP	+3.93
		06/95 RFO	Bobbin	ODI	38	0.72	13TH TSP	+4.24
1	2	06/95 RFO	Bobbin	ODI	5	1.64	14TH TSP	+33.01
1	3	06/95 RFO	Bobbin	ODI	5	1.26	14TH TSP	+31.47
1	4	06/95 RFO	Bobbin	NQI		0.78	UTSF	-0.54
		06/95 RFO	Bobbin	ODI	22	1.34	14TH TSP	+31.39
1	5	06/95 RFO	Bobbin	ODI	12	0.90	15TH TSP	+1.88
1	8	06/95 RFO	Bobbin	ADI		1.07	15TH TSP	+7.96 to +12.43
1	13	06/95 RFO	Bobbin	ODI	19	1.14	11TH TSP	+3.86
1	16	06/95 RFO	Bobbin	ODI	8	0.31	15TH TSP	+25.82
		06/95 RFO	Bobbin	ODI	8	0.35	11TH TSP	+2.49
2	1	06/95 RFO	Bobbin	NQI		0.73	13TH TSP	+5.51
		06/95 RFO	Bobbin	ODI	9	1.27	14TH TSP	+3.15
		06/95 RFO	Bobbin	ODI	16	1.43	15TH TSP	+1.88
		06/95 RFO	Bobbin	ODI	19	0.86	14TH TSP	+29.20
		06/95 RFO	Bobbin	ODI	33	0.59	12TH TSP	+8.13
		06/95 RFO	Bobbin	ADI		0.98	11TH TSP	+14.20 to +26.02
2	2	06/95 RFO	Bobbin	NQI		0.65	13TH TSP	+5.67
		06/95 RFO	Bobbin	ODI	20	0.75	12TH TSP	+8.89
		06/95 RFO	Bobbin	ODI	28	0.50	12TH TSP	+7.00
		06/95 RFO	Bobbin	ADI		1.22	11TH TSP	+11.21 to +22.67
2	7	06/95 RFO	Bobbin	ODI	30	0.34	15TH TSP	-1.19
2	8	06/95 RFO	Bobbin	ODI	13	0.49	15TH TSP	-1.37
2	11	06/95 RFO	Bobbin	NQI		0.96	15TH TSP	+31.42
2	12	06/95 RFO	Bobbin	ODI	30	1.15	10TH TSP	+1.27
2	15	06/95 RFO	Bobbin	NQI		0.65	10TH TSP	+0.61
2	19	06/95 RFO	Bobbin	NQI		1.35	10TH TSP	+0.45
2	23	06/95 RFO	Bobbin	ODI	4	1.16	11TH TSP	+3.24
2	24	06/95 RFO	Bobbin	ODI	8	0.69	11TH TSP	+2.79
2	26	06/95 RFO	Bobbin	ODI	1	1.30	10TH TSP	+10.81
		06/95 RFO	Bobbin	ODI	30	1.86	14TH TSP	+0.67
3	3	06/95 RFO	Bobbin	NQI		0.81	14TH TSP	+30.38
		06/95 RFO	Bobbin	ODI	18	1.49	13TH TSP	+4.58
3	4	06/95 RFO	Bobbin	ODI	33	0.41	14TH TSP	+1.49
3	6	06/95 RFO	Bobbin	ODI	18	1.33	15TH TSP	-1.03
3	9	06/95 RFO	Bobbin	NQI		1.23	15TH TSP	+2.21
3	10	06/95 RFO	Bobbin	ODI	16	6.00	15TH TSP	-1.10
3	13	06/95 RFO	Bobbin	NQI		0.47	13TH TSP	-0.50
3	14	06/95 RFO	Bobbin	NQI		3.78	15TH TSP	+0.63
3	25	06/95 RFO	Bobbin	NQI		0.39	10TH TSP	+0.38
3	27	06/95 RFO	Bobbin	NQI		0.87	3RD TSP	+3.45
3	29	06/95 RFO	Bobbin	NQI		1.24	11TH TSP	-0.76
3	30	06/95 RFO	Bobbin	NQI		0.53	11TH TSP	-0.76
4	1	06/95 RFO	Bobbin	NQI		1.18	15TH TSP	+24.34
		06/95 RFO	Bobbin	NQI		1.19	15TH TSP	+25.96
		06/95 RFO	Bobbin	NQI		31.75	15TH TSP	+19.48
		06/95 RFO	Bobbin	ODI	12	0.32	15TH TSP	+14.68
		06/95 RFO	Bobbin	ODI	15	0.45	15TH TSP	+23.70
4	2	06/95 RFO	Bobbin	NQI		25.55	15TH TSP	+19.88
		06/95 RFO	Bobbin	ODI	12	1.27	15TH TSP	+23.96
		06/95 RFO	Bobbin	ODI	21	1.16	15TH TSP	+25.24
4	11	06/95 RFO	Bobbin	ODI	8	0.28	14TH TSP	+24.32
4	12	06/95 RFO	Bobbin	ODI	3	0.89	14TH TSP	+0.81
4	16	06/95 RFO	Bobbin	ODI	14	0.55	LTSF	+9.57
4	27	06/95 RFO	Bobbin	ODI	18	0.32	4TH TSP	-0.26
4	31	06/95 RFO	Bobbin	NQI		0.32	9TH TSP	+0.24
4	36	06/95 RFO	Bobbin	ODI	33	0.53	14TH TSP	+29.65
4	39	06/95 RFO	Bobbin	NQI		0.42	8TH TSP	-0.68
		06/95 RFO	Bobbin	ODI	20	0.35	2ND TSP	+37.40
5	2	06/95 RFO	Bobbin	NQI		0.32	15TH TSP	+22.73
		06/95 RFO	Bobbin	ODI	8	0.44	15TH TSP	+23.66
		06/95 RFO	Bobbin	ODI	22	1.20	15TH TSP	+24.24
5	3	06/95 RFO	Bobbin	NQI		1.60	15TH TSP	+18.54
		06/95 RFO	Bobbin	ODI	36	0.82	15TH TSP	+22.73
5	4	06/95 RFO	Bobbin	ODI	10	0.44	15TH TSP	+1.27

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 2 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
5	8	06/95 RFO	Bobbin	ODI	22	0.61	15TH TSP	+12.57
5	9	06/95 RFO	Bobbin	NQI		0.54	15TH TSP	+12.62
5	11	06/95 RFO	Bobbin	NQI		0.62	5TH TSP	+34.81
5	12	06/95 RFO	Bobbin	NQI		0.40	15TH TSP	+1.78
5	13	06/95 RFO	Bobbin	ADI		5.00	LTSF	+21.66 to +29.30
5	40	06/95 RFO	Bobbin	NQI		0.55	9TH TSP	+0.24
5	42	06/95 RFO	Bobbin	ODI	33	0.50	3RD TSP	+35.69
6	8	06/95 RFO	Bobbin	ODI	36	0.72	9TH TSP	+1.43
6	22	06/95 RFO	Bobbin	ODI	2	0.73	9TH TSP	+0.32
6	34	06/95 RFO	Bobbin	NQI		0.60	9TH TSP	+0.42
		06/95 RFO	Bobbin	ODI	35	0.67	9TH TSP	-0.57
6	35	06/95 RFO	Bobbin	ODI	13	0.54	9TH TSP	+0.31
7	13	06/95 RFO	Bobbin	NQI		0.46	13TH TSP	+22.68
7	19	06/95 RFO	Bobbin	ODI	6	0.71	9TH TSP	-0.58
7	45	06/95 RFO	Bobbin	NQI		0.66	9TH TSP	-0.60
7	46	06/95 RFO	Bobbin	ODI	53	0.58	2ND TSP	+12.10
		06/95 RFO	Bobbin	WAR	44	1.86	9TH TSP	+0.00
7	48	06/95 RFO	Bobbin	ODI	37	0.59	5TH TSP	+1.09
7	54	06/95 RFO	Bobbin	ODI	8	1.20	14TH TSP	+1.07
8	7	06/95 RFO	Bobbin	NQI		0.44	7TH TSP	+21.50
8	14	06/95 RFO	Bobbin	ODI	8	0.73	9TH TSP	+25.61
		06/95 RFO	Bobbin	ODI	18	0.68	9TH TSP	+0.52
8	27	06/95 RFO	Bobbin	ODI	27	0.30	14TH TSP	+1.27
8	42	06/95 RFO	Bobbin	NQI		0.70	9TH TSP	-0.60
8	46	06/95 RFO	Bobbin	ODI	26	0.43	9TH TSP	+0.28
8	49	06/95 RFO	Bobbin	NQI		0.49	9TH TSP	-0.85
9	10	06/95 RFO	Bobbin	NQI		0.72	9TH TSP	+25.96
9	12	06/95 RFO	Bobbin	ODI	7	0.86	9TH TSP	+23.91
9	13	06/95 RFO	Bobbin	NQI		1.01	9TH TSP	+24.09
9	15	06/95 RFO	Bobbin	NQI		0.49	9TH TSP	+32.54
		06/95 RFO	Bobbin	ODI	32	0.99	9TH TSP	+22.20
9	16	06/95 RFO	Bobbin	ODI	6	0.75	9TH TSP	+21.64
9	21	06/95 RFO	Bobbin	ODI	35	0.41	2ND TSP	+22.46
9	29	06/95 RFO	Bobbin	ODI	12	0.99	14TH TSP	+1.26
9	43	06/95 RFO	Bobbin	NQI		0.69	14TH TSP	+0.78
9	47	06/95 RFO	Bobbin	NQI		0.30	9TH TSP	+0.40
9	61	06/95 RFO	Bobbin	ADI		1.06	15TH TSP	+7.51
		06/95 RFO	Bobbin	ADI		1.75	15TH TSP	+6.59
9	62	06/95 RFO	Bobbin	ODI	11	1.05	11TH TSP	-0.78
		06/95 RFO	Bobbin	ODI	26	1.13	15TH TSP	+2.04
10	12	06/95 RFO	Bobbin	NQI		0.41	15TH TSP	+1.09
		06/95 RFO	Bobbin	ODI	29	0.69	4TH TSP	+17.71
		06/95 RFO	Bobbin	ODI	15	1.20	15TH TSP	+35.93
10	13	06/95 RFO	Bobbin	NQI		1.33	LTSF	+19.42
10	19	06/95 RFO	Bobbin	ODI	20	1.32	9TH TSP	-0.50
10	44	06/95 RFO	Bobbin	ODI	30	0.86	9TH TSP	+0.31
10	47	06/95 RFO	Bobbin	ODI	30	0.45	7TH TSP	+19.79
10	63	06/95 RFO	Bobbin	NQI		7.04	15TH TSP	+0.76
10	65	06/95 RFO	Bobbin	ODI	59	2.96	15TH TSP	+0.85
11	28	06/95 RFO	Bobbin	ODI	15	0.67	7TH TSP	+23.72
11	59	06/95 RFO	Bobbin	ADI		1.09	9TH TSP	+10.64 to +32.25
11	61	06/95 RFO	Bobbin	ODI	14	0.72	9TH TSP	+29.88
11	63	06/95 RFO	Bobbin	ODI	24	1.10	15TH TSP	+3.19
11	64	06/95 RFO	Bobbin	ODI	2	0.75	10TH TSP	+0.48
		06/95 RFO	Bobbin	ODI	7	0.42	11TH TSP	-0.79
11	65	06/95 RFO	Bobbin	ADI		2.22	15TH TSP	+2.47 to +4.88
11	66	06/95 RFO	Bobbin	ODI	17	1.07	14TH TSP	+1.10
		06/95 RFO	Bobbin	ODI	38	1.22	15TH TSP	+4.70
11	68	06/95 RFO	Bobbin	NQI		0.43	15TH TSP	+22.10
12	1	06/95 RFO	Bobbin	NQI		0.59	UTSF	-1.15
12	14	06/95 RFO	Bobbin	NQI		0.67	15TH TSP	+0.38
12	57	06/95 RFO	Bobbin	WAR	3	0.91	7TH TSP	+0.00
12	60	06/95 RFO	Bobbin	ADI		1.75	9TH TSP	+12.43 to +28.74
12	61	06/95 RFO	Bobbin	ODI	5	0.56	9TH TSP	+20.29
12	62	06/95 RFO	Bobbin	ADI		0.83	9TH TSP	+22.42 to +32.23

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 3 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
12	65	06/95 RFO	Bobbin	ODI	23	0.62	15TH TSP	+3.72
12	66	06/95 RFO	Bobbin	ODI	21	1.04	15TH TSP	+3.08
12	67	06/95 RFO	Bobbin	ODI	19	0.83	15TH TSP	+4.26
12	69	06/95 RFO	Bobbin	NQI		0.44	10TH TSP	+15.14
		06/95 RFO	Bobbin	ODI	3	0.33	9TH TSP	+35.36
		06/95 RFO	Bobbin	ODI	5	0.31	7TH TSP	-0.60
12	70	06/95 RFO	Bobbin	NQI		0.76	8TH TSP	-0.59
13	36	06/95 RFO	Bobbin	ODI	20	1.11	4TH TSP	+12.45
13	47	06/95 RFO	Bobbin	ODI	5	0.62	14TH TSP	+1.08
13	63	06/95 RFO	Bobbin	ODI	13	0.75	9TH TSP	+21.18
		06/95 RFO	Bobbin	ODI	31	0.28	10TH TSP	+6.30
13	66	06/95 RFO	Bobbin	NQI		0.40	14TH TSP	+23.37
		06/95 RFO	Bobbin	NQI		0.41	14TH TSP	+16.93
		06/95 RFO	Bobbin	ODI	28	0.76	9TH TSP	+27.12
		06/95 RFO	Bobbin	ODI	24	0.59	14TH TSP	+20.22
		06/95 RFO	Bobbin	ODI	36	0.57	14TH TSP	+24.73
13	68	06/95 RFO	Bobbin	NQI		1.15	11TH TSP	+16.25
13	69	06/95 RFO	Bobbin	NQI		0.28	3RD TSP	+10.86
		06/95 RFO	Bobbin	ODI	17	0.40	9TH TSP	+35.93
13	73	06/95 RFO	Bobbin	ODI	13	0.58	7TH TSP	+5.65
13	74	06/95 RFO	Bobbin	ODI	13	0.28	10TH TSP	+21.03
		06/95 RFO	Bobbin	ODI	30	0.26	10TH TSP	+19.81
14	9	06/95 RFO	Bobbin	ODI	35	0.37	15TH TSP	+0.32
14	37	06/95 RFO	Bobbin	ODI	32	1.88	14TH TSP	+1.17
14	53	06/95 RFO	Bobbin	NQI		0.44	3RD TSP	+22.80
14	57	06/95 RFO	Bobbin	NQI		0.36	4TH TSP	+22.30
14	58	06/95 RFO	Bobbin	NQI		0.34	10TH TSP	+16.83
14	61	06/95 RFO	Bobbin	NQI		0.51	7TH TSP	+0.60
14	67	06/95 RFO	Bobbin	ODI	21	0.52	9TH TSP	+21.10
		06/95 RFO	Bobbin	ODI	27	0.28	14TH TSP	+19.81
		06/95 RFO	Bobbin	ODI	34	0.33	14TH TSP	+23.17
14	68	06/95 RFO	Bobbin	NQI		0.25	14TH TSP	+24.58
		06/95 RFO	Bobbin	NQI		0.28	14TH TSP	+22.89
		06/95 RFO	Bobbin	NQI		0.70	14TH TSP	+17.87
		06/95 RFO	Bobbin	NQI		0.85	14TH TSP	+25.74
		06/95 RFO	Bobbin	ODI	10	0.66	14TH TSP	+20.08
		06/95 RFO	Bobbin	ODI	14	0.32	14TH TSP	+31.86
		06/95 RFO	Bobbin	ODI	27	0.26	14TH TSP	+21.08
14	69	06/95 RFO	Bobbin	ODI	16	0.46	9TH TSP	+30.29
14	70	06/95 RFO	Bobbin	ODI	12	0.96	9TH TSP	+32.28
14	71	06/95 RFO	Bobbin	ODI	29	0.51	9TH TSP	+34.95
15	5	06/95 RFO	Bobbin	ODI	1	1.12	9TH TSP	+0.43
15	9	06/95 RFO	Bobbin	NQI		0.44	9TH TSP	-0.80
15	28	06/95 RFO	Bobbin	ADI		13.02	LTSP	+21.77 to +26.58
15	49	06/95 RFO	Bobbin	ODI	60	0.63	2ND TSP	+2.37
15	68	06/95 RFO	Bobbin	ODI	14	0.50	9TH TSP	+27.53
15	69	06/95 RFO	Bobbin	ODI	19	0.90	9TH TSP	+23.26
15	70	06/95 RFO	Bobbin	ODI	16	0.79	9TH TSP	+22.50
15	72	06/95 RFO	Bobbin	NQI		0.50	9TH TSP	+27.54
15	74	06/95 RFO	Bobbin	NQI		0.46	13TH TSP	+10.06
15	77	06/95 RFO	Bobbin	ODI	17	1.17	LTSP	+0.54
		06/95 RFO	Bobbin	ODI	35	0.40	12TH TSP	+25.73
16	3	06/95 RFO	Bobbin	NQI		0.68	9TH TSP	+0.60
16	12	06/95 RFO	Bobbin	NQI		0.33	12TH TSP	+26.01
16	19	06/95 RFO	Bobbin	NQI		0.39	5TH TSP	+6.75
16	30	06/95 RFO	Bobbin	NQI		0.41	9TH TSP	+11.54
		06/95 RFO	Bobbin	NQI		0.56	9TH TSP	+10.33
		06/95 RFO	Bobbin	NQI		0.63	9TH TSP	+1.41
		06/95 RFO	Bobbin	NQI		0.31	15TH TSP	+10.62
		06/95 RFO	Bobbin	ODI	27	0.51	9TH TSP	+6.07
		06/95 RFO	Bobbin	ODI	1	0.68	10TH TSP	+15.17
16	42	06/95 RFO	Bobbin	NQI		0.46	14TH TSP	+15.78
16	46	06/95 RFO	Bobbin	NQI		0.40	LTSP	+25.26
16	64	06/95 RFO	Bobbin	NQI		0.18	2ND TSP	+17.42
16	70	06/95 RFO	Bobbin	ODI	23	0.22	14TH TSP	+28.23

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 4 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
16	71	06/95 RFO	Bobbin	ODI	1	0.82	14TH TSP	+33.58
		06/95 RFO	Bobbin	ADI		2.06	9TH TSP	+11.38 to +31.09
16	72	06/95 RFO	Bobbin	NQI		0.63	9TH TSP	+21.27
		06/95 RFO	Bobbin	ODI	2	0.82	9TH TSP	+21.68
16	74	06/95 RFO	Bobbin	NQI		0.38	11TH TSP	+19.83
		06/95 RFO	Bobbin	ODI	23	0.74	9TH TSP	+27.55
		06/95 RFO	Bobbin	ODI	29	0.63	9TH TSP	+25.68
16	78	06/95 RFO	Bobbin	ODI	36	0.25	1ST TSP	+6.73
		06/95 RFO	Bobbin	ODI	18	0.49	14TH TSP	+0.72
17	1	06/95 RFO	Bobbin	NQI		0.61	14TH TSP	+9.94
17	2	06/95 RFO	Bobbin	ODI	18	0.89	10TH TSP	+0.48
17	6	06/95 RFO	Bobbin	ODI	25	0.71	9TH TSP	-0.49
		06/95 RFO	Bobbin	ODI	27	2.22	12TH TSP	+0.71
17	10	06/95 RFO	Bobbin	ODI	10	0.74	9TH TSP	-0.83
17	12	06/95 RFO	Bobbin	ADI		1.39	LTSF	+22.10 to +29.98
17	46	06/95 RFO	Bobbin	ODI	60	0.71	9TH TSP	+15.34
17	49	06/95 RFO	Bobbin	ODI	22	0.29	14TH TSP	+0.39
17	53	06/95 RFO	Bobbin	ODI	6	2.39	7TH TSP	+0.79
17	60	06/95 RFO	Bobbin	NQI		0.36	1ST TSP	+36.21
17	72	06/95 RFO	Bobbin	ODI	3	0.53	9TH TSP	+20.43
17	73	06/95 RFO	Bobbin	ODI	22	0.63	9TH TSP	+23.19
17	74	06/95 RFO	Bobbin	ODI	11	0.72	9TH TSP	+22.44
		06/95 RFO	Bobbin	ODI	29	0.71	11TH TSP	-0.85
17	75	06/95 RFO	Bobbin	NQI		1.57	9TH TSP	+21.01
		06/95 RFO	Bobbin	ODI	12	1.27	9TH TSP	+23.14
17	76	06/95 RFO	Bobbin	ODI	5	0.83	9TH TSP	+25.07
17	77	06/95 RFO	Bobbin	NQI		0.74	9TH TSP	+22.33
		06/95 RFO	Bobbin	ODI	16	0.79	9TH TSP	+26.44
17	78	06/95 RFO	Bobbin	ODI	21	0.80	9TH TSP	+22.30
		06/95 RFO	Bobbin	ODI	35	0.36	9TH TSP	-0.58
17	79	06/95 RFO	Bobbin	ODI	5	2.23	14TH TSP	+0.78
18	10	06/95 RFO	Bobbin	NQI		0.71	9TH TSP	-0.82
18	23	06/95 RFO	Bobbin	ADI		1.08	15TH TSP	+20.52
18	62	06/95 RFO	Bobbin	NQI		0.35	15TH TSP	+0.28
18	75	06/95 RFO	Bobbin	NQI		0.23	14TH TSP	+1.02
18	77	06/95 RFO	Bobbin	ODI	29	0.66	14TH TSP	+0.70
18	79	06/95 RFO	Bobbin	ODI	23	0.61	9TH TSP	+20.87
		06/95 RFO	Bobbin	ODI	31	0.54	9TH TSP	+23.62
18	80	06/95 RFO	Bobbin	NQI		0.26	15TH TSP	+0.32
18	85	06/95 RFO	Bobbin	ODI	22	0.45	3RD TSP	+33.29
19	6	06/95 RFO	Bobbin	NQI		0.47	9TH TSP	-0.42
19	8	06/95 RFO	Bobbin	ODI	48	0.62	11TH TSP	+36.16
19	77	06/95 RFO	Bobbin	NQI		0.72	14TH TSP	+1.03
20	6	06/95 RFO	Bobbin	NQI		0.83	9TH TSP	-0.60
20	10	06/95 RFO	Bobbin	NQI		0.25	14TH TSP	+0.22
20	17	06/95 RFO	Bobbin	ADI		16.30	LTSF	+22.64 to +29.91
20	38	06/95 RFO	Bobbin	NQI		0.45	14TH TSP	+0.29
20	40	06/95 RFO	Bobbin	NQI		0.56	14TH TSP	+0.56
21	4	06/95 RFO	Bobbin	ODI	29	0.52	9TH TSP	+0.51
21	5	06/95 RFO	Bobbin	ODI	24	0.90	9TH TSP	-0.60
21	6	06/95 RFO	Bobbin	NQI		0.51	7TH TSP	+34.63
21	8	06/95 RFO	Bobbin	ODI	51	0.54	14TH TSP	+32.52
21	27	06/95 RFO	Bobbin	NQI		0.20	15TH TSP	-0.05
21	34	06/95 RFO	Bobbin	ODI	35	0.28	14TH TSP	+0.47
21	62	06/95 RFO	Bobbin	ODI	36	0.58	14TH TSP	+27.76
21	65	06/95 RFO	Bobbin	NQI		0.24	10TH TSP	+14.84
		06/95 RFO	Bobbin	NQI		0.28	11TH TSP	-0.22
		06/95 RFO	Bobbin	NQI		0.38	10TH TSP	+16.45
22	1	06/95 RFO	Bobbin	NQI		0.47	15TH TSP	+0.13
		06/95 RFO	Bobbin	NQI		0.70	15TH TSP	+1.29
22	26	06/95 RFO	Bobbin	NQI		0.41	14TH TSP	+9.93
22	41	06/95 RFO	Bobbin	NQI		0.54	15TH TSP	+32.54
22	69	06/95 RFO	Bobbin	NQI		0.82	3RD TSP	+27.70
22	74	06/95 RFO	Bobbin	ODI	31	0.35	13TH TSP	+11.93
22	75	06/95 RFO	Bobbin	ODI	34	0.27	10TH TSP	+26.54

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 5 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
22	80	06/95 RFO	Bobbin	ADI		10.64	LTSF	+22.63 to +28.66 FL
22	91	06/95 RFO	Bobbin	NQI		0.52	10TH TSP	+0.53 FL
22	93	06/95 RFO	Bobbin	ODI	18	0.71	15TH TSP	+15.84 FL
23	1	06/95 RFO	Bobbin	NQI		1.32	UTSF	+0.55 FL
		06/95 RFO	Bobbin	NQI		0.51	9TH TSP	-0.32 FL
23	2	06/95 RFO	Bobbin	ODI	24	0.63	10TH TSP	+0.37 FL
23	5	06/95 RFO	Bobbin	NQI		0.61	9TH TSP	-0.61 FL
23	24	06/95 RFO	Bobbin	NQI		0.51	4TH TSP	+7.34 FL
23	26	06/95 RFO	Bobbin	NQI		0.22	15TH TSP	+41.97 FL
23	50	06/95 RFO	Bobbin	ODI	25	1.88	LTSF	+22.36 to +30.25 FL
23	65	06/95 RFO	Bobbin	NQI		0.26	14TH TSP	+0.36 FL
23	80	06/95 RFO	Bobbin	ODI	15	0.50	3RD TSP	+29.21 FL
23	82	06/95 RFO	Bobbin	ODI	12	0.22	9TH TSP	-0.17 FL
23	91	06/95 RFO	Bobbin	NQI		0.44	9TH TSP	-0.50 FL
23	93	06/95 RFO	Bobbin	NQI		0.59	15TH TSP	+14.75 FL
23	94	06/95 RFO	Bobbin	ODI	3	0.74	11TH TSP	-0.82 FL
24	2	06/95 RFO	Bobbin	ODI	27	0.64	10TH TSP	+0.55 FL
24	3	06/95 RFO	Bobbin	ODI	36	0.29	10TH TSP	+0.60 FL
24	4	06/95 RFO	Bobbin	ODI	35	0.49	9TH TSP	+0.48 FL
24	5	06/95 RFO	Bobbin	NQI		0.34	9TH TSP	-0.56 FL
		06/95 RFO	Bobbin	NQI		0.56	9TH TSP	-0.34 FL
		06/95 RFO	Bobbin	ODI	31	0.48	15TH TSP	+0.00 FL
24	8	06/95 RFO	Bobbin	NQI		0.45	5TH TSP	-0.84 FL
24	14	06/95 RFO	Bobbin	NQI		0.75	4TH TSP	+10.08 FL
24	25	06/95 RFO	Bobbin	NQI		0.49	6TH TSP	+26.73 FL
24	44	06/95 RFO	Bobbin	ODI	18	0.61	14TH TSP	+0.19 FL
25	4	06/95 RFO	Bobbin	NQI		0.85	13TH TSP	-0.89 FL
25	26	06/95 RFO	Bobbin	NQI		0.31	13TH TSP	+31.62 FL
25	41	06/95 RFO	Bobbin	NQI		0.32	9TH TSP	+18.66 FL
		06/95 RFO	Bobbin	ODI	31	0.33	7TH TSP	+36.77 FL
25	65	06/95 RFO	Bobbin	NQI		4.33	15TH TSP	+33.27 FL
25	91	06/95 RFO	Bobbin	NQI		0.44	12TH TSP	+23.97 FL
25	94	06/95 RFO	Bobbin	ODI	15	0.88	9TH TSP	-0.64 FL
		06/95 RFO	Bobbin	ODI	25	0.98	9TH TSP	+0.53 FL
25	95	06/95 RFO	Bobbin	NQI		0.65	8TH TSP	+0.48 FL
26	3	06/95 RFO	Bobbin	ODI	13	0.77	10TH TSP	+0.54 FL
26	5	06/95 RFO	Bobbin	NQI		0.81	13TH TSP	-0.86 FL
26	7	06/95 RFO	Bobbin	ODI	26	0.49	10TH TSP	+0.73 FL
26	26	06/95 RFO	Bobbin	ODI	46	0.70	15TH TSP	+21.23 FL
26	37	06/95 RFO	Bobbin	NQI		0.64	2ND TSP	+15.43 FL
26	45	06/95 RFO	Bobbin	ODI	36	0.28	14TH TSP	+0.05 FL
26	54	06/95 RFO	Bobbin	NQI		0.54	10TH TSP	+16.95 FL
26	91	06/95 RFO	Bobbin	NQI		0.33	12TH TSP	+9.95 FL
26	92	06/95 RFO	Bobbin	NQI		0.90	8TH TSP	-0.49 FL
27	2	06/95 RFO	Bobbin	NQI		0.40	10TH TSP	+0.57 FL
27	3	06/95 RFO	Bobbin	ODI	24	0.93	10TH TSP	+0.62 FL
27	7	06/95 RFO	Bobbin	NQI		0.58	7TH TSP	+28.88 FL
		06/95 RFO	Bobbin	NQI		0.36	12TH TSP	+0.68 FL
27	30	06/95 RFO	Bobbin	NQI		1.46	14TH TSP	+0.82 FL
27	57	06/95 RFO	Bobbin	NQI		0.43	4TH TSP	+16.88 FL
27	68	06/95 RFO	Bobbin	NQI		0.53	14TH TSP	+2.31 FL
		06/95 RFO	Bobbin	NQI		0.56	14TH TSP	+0.43 FL
27	72	06/95 RFO	Bobbin	ODI	29	0.34	15TH TSP	+0.51 FL
27	78	06/95 RFO	Bobbin	ODI	16	0.49	6TH TSP	+34.21 FL
27	80	06/95 RFO	Bobbin	ODI	39	1.40	9TH TSP	+32.36 FL
		06/95 RFO	Bobbin	ODI	63	1.18	9TH TSP	+32.71 FL
27	92	06/95 RFO	Bobbin	ODI	10	0.50	10TH TSP	+11.08 FL
27	98	06/95 RFO	Bobbin	NQI		0.72	11TH TSP	-0.77 FL
		06/95 RFO	Bobbin	ODI	28	0.64	14TH TSP	+33.18 FL
28	1	06/95 RFO	Bobbin	ODI	20	0.21	12TH TSP	+0.14 FL
28	2	06/95 RFO	Bobbin	ODI	34	0.45	10TH TSP	+0.49 FL
28	3	06/95 RFO	Bobbin	ODI	34	0.53	10TH TSP	+0.63 FL
28	5	06/95 RFO	Bobbin	ODI	9	0.33	10TH TSP	+0.48 FL
28	6	06/95 RFO	Bobbin	ODI	13	0.60	9TH TSP	-0.59 FL
28	31	06/95 RFO	Bobbin	ODI	48	1.46	14TH TSP	+0.99 FL

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 6 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
28	55	06/95 RFO	Bobbin	NQI		0.48	6TH TSP	+20.63
28	56	06/95 RFO	Bobbin	NQI		0.45	12TH TSP	+20.49
28	64	06/95 RFO	Bobbin	NQI		0.33	11TH TSP	+20.11
28	79	06/95 RFO	Bobbin	ODI	16	0.47	LTSP	+37.87
28	90	06/95 RFO	Bobbin	NQI		0.53	1ST TSP	+0.37
28	91	06/95 RFO	Bobbin	NQI		0.37	7TH TSP	+26.26
		06/95 RFO	Bobbin	ODI	17	0.49	6TH TSP	+8.77
		06/95 RFO	Bobbin	ODI	22	0.42	7TH TSP	+34.88
28	96	06/95 RFO	Bobbin	NQI		0.64	15TH TSP	+22.79
28	99	06/95 RFO	Bobbin	ODI	3	0.36	8TH TSP	+9.61
29	1	06/95 RFO	Bobbin	ODI	33	2.75	15TH TSP	+1.07
29	2	06/95 RFO	Bobbin	NQI		0.22	11TH TSP	-0.51
		06/95 RFO	Bobbin	ODI	16	1.14	10TH TSP	-0.22
29	8	06/95 RFO	Bobbin	NQI		0.30	6TH TSP	-0.86
29	12	06/95 RFO	Bobbin	ODI	30	0.38	10TH TSP	+22.16
29	25	06/95 RFO	Bobbin	NQI		0.36	11TH TSP	+3.31
29	31	06/95 RFO	Bobbin	NQI		0.76	LTPF	+19.43
29	50	06/95 RFO	Bobbin	NQI		0.45	LTSP	+8.06
29	56	06/95 RFO	Bobbin	ODI	20	0.52	14TH TSP	+1.11
29	57	06/95 RFO	Bobbin	ODI	33	1.02	14TH TSP	+1.06
29	74	06/95 RFO	Bobbin	ODI	13	0.20	14TH TSP	+0.46
29	102	06/95 RFO	Bobbin	ODI	12	0.22	10TH TSP	-0.19
30	1	06/95 RFO	Bobbin	NQI		3.57	15TH TSP	+1.08
30	6	06/95 RFO	Bobbin	NQI		0.29	10TH TSP	+0.48
30	7	06/95 RFO	Bobbin	ODI	39	0.41	14TH TSP	+0.46
30	27	06/95 RFO	Bobbin	ODI	52	0.58	14TH TSP	+1.08
30	44	06/95 RFO	Bobbin	ODI	34	0.27	15TH TSP	+0.00
30	80	06/95 RFO	Bobbin	ODI	36	1.01	14TH TSP	+1.09
31	1	06/95 RFO	Bobbin	ODI	26	0.47	7TH TSP	+0.40
31	2	06/95 RFO	Bobbin	NQI		0.71	12TH TSP	+0.72
31	7	06/95 RFO	Bobbin	ODI	37	0.44	9TH TSP	+0.40
31	8	06/95 RFO	Bobbin	NQI		0.39	11TH TSP	+26.51
31	9	06/95 RFO	Bobbin	ODI	6	0.36	9TH TSP	+0.56
31	15	06/95 RFO	Bobbin	ODI	1	0.21	14TH TSP	+0.13
31	25	06/95 RFO	Bobbin	NQI		0.39	8TH TSP	+0.44
31	26	06/95 RFO	Bobbin	ODI	31	0.20	7TH TSP	+1.01
31	57	06/95 RFO	Bobbin	NQI		0.53	11TH TSP	+24.26
		06/95 RFO	Bobbin	ODI	8	0.32	14TH TSP	-0.43
31	59	06/95 RFO	Bobbin	NQI		0.26	11TH TSP	+9.24
		06/95 RFO	Bobbin	NQI		0.31	11TH TSP	+7.15
31	61	06/95 RFO	Bobbin	NQI		0.42	11TH TSP	+3.03
31	74	06/95 RFO	Bobbin	ODI	25	0.49	9TH TSP	+24.12
		06/95 RFO	Bobbin	ODI	39	0.85	6TH TSP	+17.01
31	90	06/95 RFO	Bobbin	ODI	38	0.46	6TH TSP	+28.10
31	99	06/95 RFO	Bobbin	ODI	33	1.72	1ST TSP	+0.72
32	1	06/95 RFO	Bobbin	NQI		0.47	15TH TSP	+17.46
32	3	06/95 RFO	Bobbin	ODI	6	1.82	10TH TSP	+0.63
32	5	06/95 RFO	Bobbin	ODI	32	0.31	10TH TSP	+0.48
32	14	06/95 RFO	Bobbin	ODI	28	0.67	7TH TSP	+21.84
32	19	06/95 RFO	Bobbin	ODI	28	0.54	10TH TSP	+30.79
32	36	06/95 RFO	Bobbin	ODI	16	0.35	6TH TSP	+30.79
32	41	06/95 RFO	Bobbin	ODI	12	5.69	LTSP	+21.69 to +29.70
32	59	06/95 RFO	Bobbin	ODI	29	0.30	12TH TSP	+28.30
32	66	06/95 RFO	Bobbin	ODI	52	0.75	15TH TSP	+5.96
32	69	06/95 RFO	Bobbin	NQI		0.37	7TH TSP	+23.82
		06/95 RFO	Bobbin	ODI	12	0.36	14TH TSP	+5.91
32	88	06/95 RFO	Bobbin	ADI		11.77	LTSP	+20.58 to +27.50
33	1	06/95 RFO	Bobbin	ODI	32	0.60	12TH TSP	+0.60
33	3	06/95 RFO	Bobbin	NQI		0.62	10TH TSP	-0.37
		06/95 RFO	Bobbin	ODI	32	0.78	10TH TSP	+0.63
33	6	06/95 RFO	Bobbin	NQI		0.46	10TH TSP	+0.50
33	13	06/95 RFO	Bobbin	NQI		0.84	8TH TSP	-0.78
33	21	06/95 RFO	Bobbin	NQI		0.69	14TH TSP	+0.94
33	41	06/95 RFO	Bobbin	ODI	45	0.47	15TH TSP	+0.41
33	52	06/95 RFO	Bobbin	ODI	37	0.99	13TH TSP	+18.18

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 7 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
33	74	06/95 RFO	Bobbin	NQI		0.25	4TH TSP	-0.27
33	76	06/95 RFO	Bobbin	ODI	18	0.29	6TH TSP	+33.90
33	80	06/95 RFO	Bobbin	NQI		0.33	14TH TSP	+17.52
		06/95 RFO	Bobbin	NQI		0.43	14TH TSP	+26.83
33	98	06/95 RFO	Bobbin	NQI		0.71	3RD TSP	+19.21
33	100	06/95 RFO	Bobbin	NQI		0.43	LTSF	+8.91
34	1	06/95 RFO	Bobbin	ODI	32	0.23	12TH TSP	+0.34
34	6	06/95 RFO	Bobbin	NQI		0.48	8TH TSP	+37.46
34	64	06/95 RFO	Bobbin	NQI		0.80	4TH TSP	+9.87
34	73	06/95 RFO	Bobbin	NQI		0.45	3RD TSP	+34.38
34	84	06/95 RFO	Bobbin	NQI		0.59	4TH TSP	+14.52
34	87	06/95 RFO	Bobbin	ODI	25	0.70	15TH TSP	+0.28
34	101	06/95 RFO	Bobbin	ODI	37	0.33	11TH TSP	+15.43
35	1	06/95 RFO	Bobbin	ODI	6	0.59	7TH TSP	+30.76
35	2	06/95 RFO	Bobbin	ODI	20	1.24	15TH TSP	+35.48
35	5	06/95 RFO	Bobbin	NQI		0.43	6TH TSP	+33.12
35	10	06/95 RFO	Bobbin	NQI		0.28	14TH TSP	+0.92
35	39	06/95 RFO	Bobbin	ODI	23	0.33	6TH TSP	+32.98
35	41	06/95 RFO	Bobbin	NQI		0.65	15TH TSP	+0.64
35	42	06/95 RFO	Bobbin	ODI	37	0.70	14TH TSP	+0.33
35	54	06/95 RFO	Bobbin	NQI		0.47	13TH TSP	+2.55
35	73	06/95 RFO	Bobbin	NQI		0.27	3RD TSP	+0.35
35	77	06/95 RFO	Bobbin	ODI	25	0.31	1ST TSP	+36.24
35	98	06/95 RFO	Bobbin	NQI		0.32	13TH TSP	+28.36
35	100	06/95 RFO	Bobbin	ODI	13	0.33	9TH TSP	+29.17
35	101	06/95 RFO	Bobbin	ODI	14	0.57	3RD TSP	+35.17
35	103	06/95 RFO	Bobbin	NQI		0.37	11TH TSP	+13.02
35	108	06/95 RFO	Bobbin	ADI		2.53	15TH TSP	+32.24
36	17	06/95 RFO	Bobbin	ODI	47	0.64	LTSF	+9.34
36	44	06/95 RFO	Bobbin	NQI		0.70	15TH TSP	+0.36
36	61	06/95 RFO	Bobbin	NQI		0.75	LTSF	+6.81
		06/95 RFO	Bobbin	NQI		0.76	LTSF	+14.34
36	68	06/95 RFO	Bobbin	ODI	22	0.33	6TH TSP	+10.49
36	78	06/95 RFO	Bobbin	ODI	35	0.50	3RD TSP	+20.08
36	90	06/95 RFO	Bobbin	ADI		5.27	LTSF	+22.33 to +29.63
36	96	06/95 RFO	Bobbin	NQI		0.82	10TH TSP	+29.07
36	106	06/95 RFO	Bobbin	ODI	52	0.53	1ST TSP	+13.20
		06/95 RFO	Bobbin	ODI	25	0.81	12TH TSP	+1.18
36	111	06/95 RFO	Bobbin	ODI	8	0.55	11TH TSP	-0.88
36	113	06/95 RFO	Bobbin	ODI	29	0.51	15TH TSP	+34.42
37	4	06/95 RFO	Bobbin	ODI	12	0.66	14TH TSP	+1.09
37	7	06/95 RFO	Bobbin	ODI	20	0.37	9TH TSP	+0.43
37	13	06/95 RFO	Bobbin	NQI		0.26	15TH TSP	+0.28
37	20	06/95 RFO	Bobbin	ADI		9.33	LTSF	+22.75 to +30.59
		06/95 RFO	Bobbin	ADI		2.57	2ND TSP	+0.66 to +6.44
37	22	06/95 RFO	Bobbin	ODI	28	0.64	8TH TSP	+5.14
37	23	06/95 RFO	Bobbin	ODI	37	0.28	13TH TSP	+4.72
37	41	06/95 RFO	Bobbin	NQI		0.32	5TH TSP	+7.00
37	47	06/95 RFO	Bobbin	ODI	39	0.54	1ST TSP	+27.95
37	66	06/95 RFO	Bobbin	ODI	15	0.38	1ST TSP	+12.96
37	74	06/95 RFO	Bobbin	NQI		0.22	7TH TSP	+30.93
		06/95 RFO	Bobbin	NQI		0.25	8TH TSP	+17.86
		06/95 RFO	Bobbin	ODI	38	0.19	8TH TSP	+31.89
37	77	06/95 RFO	Bobbin	ODI	22	0.32	6TH TSP	+32.34
37	79	06/95 RFO	Bobbin	NQI		0.11	3RD TSP	-0.76
37	105	06/95 RFO	Bobbin	ODI	37	0.63	7TH TSP	+21.00
37	113	06/95 RFO	Bobbin	ODI	28	4.25	13TH TSP	+1.18
37	114	06/95 RFO	Bobbin	ODI	33	2.11	11TH TSP	+0.90
38	1	06/95 RFO	Bobbin	ODI	70	0.93	15TH TSP	+17.73
38	2	06/95 RFO	Bobbin	ODI	20	0.86	15TH TSP	+1.81
38	4	06/95 RFO	Bobbin	ODI	16	1.79	14TH TSP	+1.15
38	42	06/95 RFO	Bobbin	NQI		0.53	13TH TSP	+1.62
		06/95 RFO	Bobbin	NQI		0.71	12TH TSP	+14.81
		06/95 RFO	Bobbin	ODI	33	0.32	12TH TSP	+21.63
		06/95 RFO	Bobbin	ODI	37	0.34	11TH TSP	+8.89

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 8 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		06/95 RFO	Bobbin	ODI	44	0.38	13TH TSP	+33.12
		06/95 RFO	Bobbin	ODI	52	0.35	13TH TSP	+21.97
		06/95 RFO	Bobbin	ODI	52	0.38	12TH TSP	+6.30
		06/95 RFO	Bobbin	ODI	56	0.42	13TH TSP	+16.24
		06/95 RFO	Bobbin	ODI	60	0.48	12TH TSP	+30.81
		06/95 RFO	Bobbin	ODI	61	0.40	12TH TSP	+25.58
		06/95 RFO	Bobbin	ODI	63	0.49	12TH TSP	+8.06
		06/95 RFO	Bobbin	ODI	75	0.32	13TH TSP	+7.22
		06/95 RFO	Bobbin	ODI	79	0.33	13TH TSP	-0.48
		06/95 RFO	Bobbin	ODI	84	0.24	13TH TSP	+25.28
38	68	06/95 RFO	Bobbin	ODI	56	0.39	LTSP	+18.51
38	115	06/95 RFO	Bobbin	NQI		0.86	7TH TSP	-0.89
39	73	06/95 RFO	Bobbin	ODI	65	0.41	14TH TSP	+21.91
39	78	06/95 RFO	Bobbin	ODI	69	0.45	14TH TSP	+15.43
39	85	06/95 RFO	Bobbin	ODI	63	0.70	1ST TSP	+34.45
39	92	06/95 RFO	Bobbin	ADI		6.11	LTSP	+23.11
39	114	06/95 RFO	Bobbin	ODI	24	0.90	13TH TSP	+0.90
39	116	06/95 RFO	Bobbin	ODI	20	0.56	8TH TSP	+3.31
40	2	06/95 RFO	Bobbin	ODI	27	0.68	15TH TSP	+0.98
40	22	06/95 RFO	Bobbin	ADI		6.11	LTSP	+22.86 to +30.81
		06/95 RFO	Bobbin	ADI		4.25	2ND TSP	+0.68 to +6.07
40	39	06/95 RFO	Bobbin	ODI	33	0.29	14TH TSP	+7.75
40	76	06/95 RFO	Bobbin	NQI		0.26	14TH TSP	+0.39
40	79	06/95 RFO	Bobbin	ODI	10	0.41	11TH TSP	+35.08
40	93	06/95 RFO	Bobbin	ODI	9	0.74	LTSP	+22.03
40	103	06/95 RFO	Bobbin	ODI	66	0.56	3RD TSP	+35.61
41	1	06/95 RFO	Bobbin	ODI	26	0.55	UTSF	-0.79
41	29	06/95 RFO	Bobbin	ODI	22	0.32	15TH TSP	+16.85
41	71	06/95 RFO	Bobbin	NQI		0.19	14TH TSP	+14.18
41	83	06/95 RFO	Bobbin	NQI		0.19	8TH TSP	+6.84
		06/95 RFO	Bobbin	ODI	39	0.25	8TH TSP	+3.78
		06/95 RFO	Bobbin	ODI	48	0.23	8TH TSP	+24.38
		06/95 RFO	Bobbin	ODI	54	0.34	7TH TSP	+19.12
41	86	06/95 RFO	Bobbin	ODI	24	0.32	6TH TSP	+30.71
41	103	06/95 RFO	Bobbin	NQI		0.72	6TH TSP	+25.60
42	1	06/95 RFO	Bobbin	ODI	14	1.17	15TH TSP	+31.21
42	12	06/95 RFO	Bobbin	ODI	17	1.30	LTSP	+22.67 to +30.56
42	20	06/95 RFO	Bobbin	NQI		0.31	4TH TSP	-0.42
42	36	06/95 RFO	Bobbin	ODI	34	0.37	6TH TSP	+5.88
42	83	06/95 RFO	Bobbin	ODI	58	0.64	12TH TSP	+29.51
43	1	06/95 RFO	Bobbin	NQI		0.82	13TH TSP	-0.88
43	6	06/95 RFO	Bobbin	NQI		0.88	5TH TSP	+26.06
43	7	06/95 RFO	Bobbin	NQI		0.50	8TH TSP	+0.63
43	14	06/95 RFO	Bobbin	ADI		13.37	LTSP	+22.65 to +30.62
		06/95 RFO	Bobbin	ADI		7.72	2ND TSP	+0.00 to +6.38
43	116	06/95 RFO	Bobbin	ODI	15	1.20	9TH TSP	-0.53
44	1	06/95 RFO	Bobbin	ODI	20	0.26	15TH TSP	+0.26
44	4	06/95 RFO	Bobbin	ODI	9	1.01	10TH TSP	+1.16
44	29	06/95 RFO	Bobbin	ODI	34	0.35	15TH TSP	+31.66
44	31	06/95 RFO	Bobbin	NQI		0.20	7TH TSP	+4.20
44	34	06/95 RFO	Bobbin	ODI	10	0.68	7TH TSP	+3.88
44	53	06/95 RFO	Bobbin	NQI		0.28	13TH TSP	+25.42
44	66	06/95 RFO	Bobbin	NQI		0.57	6TH TSP	+25.75
44	115	06/95 RFO	Bobbin	ODI	20	0.32	9TH TSP	+0.21
45	1	06/95 RFO	Bobbin	NQI		0.41	15TH TSP	+23.49
45	4	06/95 RFO	Bobbin	ODI	36	1.45	14TH TSP	+1.09
45	19	06/95 RFO	Bobbin	ODI	42	0.54	8TH TSP	+21.82
45	32	06/95 RFO	Bobbin	NQI		0.42	14TH TSP	-0.16
45	42	06/95 RFO	Bobbin	NQI		0.56	2ND TSP	+3.23
45	59	06/95 RFO	Bobbin	ODI	33	0.75	15TH TSP	+1.67
45	64	06/95 RFO	Bobbin	NQI		0.47	9TH TSP	+26.30
45	72	06/95 RFO	Bobbin	NQI		0.60	11TH TSP	+18.69
45	101	06/95 RFO	Bobbin	NQI		0.32	7TH TSP	+12.15
45	110	06/95 RFO	Bobbin	ODI	26	0.82	12TH TSP	+4.48
45	112	06/95 RFO	Bobbin	ODI	12	0.55	2ND TSP	+35.58

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
45	113	06/95 RFO	Bobbin	ODI	30	0.66	3RD TSP	+0.65 FL
45	116	06/95 RFO	Bobbin	ODI	14	2.74	14TH TSP	+0.58 FL
45	117	06/95 RFO	Bobbin	ODI	34	0.50	14TH TSP	+0.89 FL
46	5	06/95 RFO	Bobbin	ODI	25	0.72	14TH TSP	+1.03 FL
46	7	06/95 RFO	Bobbin	ODI	20	0.75	15TH TSP	+1.14 FL
46	14	06/95 RFO	Bobbin	ODI	36	0.33	12TH TSP	+33.19 FL
46	20	06/95 RFO	Bobbin	ODI	39	0.33	4TH TSP	-0.37 FL
46	39	06/95 RFO	Bobbin	NQI		0.51	14TH TSP	+0.98 FL
46	41	06/95 RFO	Bobbin	NQI		2.48	UTSF	+0.59 FL
46	59	06/95 RFO	Bobbin	ODI	3	1.34	15TH TSP	+1.73 FL
46	60	06/95 RFO	Bobbin	NQI		0.27	15TH TSP	+0.93 FL
		06/95 RFO	Bobbin	NQI		0.30	15TH TSP	+0.51 FL
46	64	06/95 RFO	Bobbin	ODI	53	0.65	14TH TSP	+27.59 FL
46	77	06/95 RFO	Bobbin	ODI	23	0.45	14TH TSP	+0.52 FL
46	78	06/95 RFO	Bobbin	ODI	6	0.18	14TH TSP	+0.35 FL
46	105	06/95 RFO	Bobbin	ODI	30	0.48	15TH TSP	+36.55 FL
46	116	06/95 RFO	Bobbin	ODI	24	0.29	6TH TSP	-0.41 FL
46	119	06/95 RFO	Bobbin	ODI	3	0.52	10TH TSP	+0.51 FL
47	1	06/95 RFO	Bobbin	ODI	1	1.28	15TH TSP	+16.85 FL
47	31	06/95 RFO	Bobbin	NQI		0.17	14TH TSP	+0.34 FL
47	35	06/95 RFO	Bobbin	ODI	28	2.17	LTSP	+30.24 FL
47	57	06/95 RFO	Bobbin	NQI		0.55	15TH TSP	+30.76 FL
47	77	06/95 RFO	Bobbin	ODI	47	0.75	14TH TSP	+4.99 FL
47	80	06/95 RFO	Bobbin	NQI		0.31	9TH TSP	+37.04 FL
47	102	06/95 RFO	Bobbin	NQI		0.29	3RD TSP	+26.72 FL
47	104	06/95 RFO	Bobbin	NQI		0.52	15TH TSP	+13.46 FL
47	122	06/95 RFO	Bobbin	ODI	10	0.69	10TH TSP	+3.88 FL
48	1	06/95 RFO	Bobbin	NQI		0.62	12TH TSP	-0.79 FL
48	3	06/95 RFO	Bobbin	ODI	31	0.63	9TH TSP	+36.58 FL
48	15	06/95 RFO	Bobbin	NQI		0.50	11TH TSP	+26.24 FL
48	31	06/95 RFO	Bobbin	NQI		0.24	7TH TSP	+4.19 FL
		06/95 RFO	Bobbin	ODI	39	0.69	15TH TSP	+0.48 FL
48	33	06/95 RFO	Bobbin	ODI	15	0.30	6TH TSP	+31.63 FL
48	51	06/95 RFO	Bobbin	ODI	4	1.18	12TH TSP	+17.54 FL
48	81	06/95 RFO	Bobbin	ODI	20	0.29	15TH TSP	+0.46 FL
48	117	06/95 RFO	Bobbin	ODI	11	0.23	15TH TSP	-0.15 FL
48	123	06/95 RFO	Bobbin	ODI	10	0.49	UTSF	-0.64 FL
		06/95 RFO	Bobbin	ODI	17	0.98	15TH TSP	+18.51 FL
49	1	06/95 RFO	Bobbin	NQI		0.38	15TH TSP	-0.05 FL
		06/95 RFO	Bobbin	ODI	19	0.70	10TH TSP	+8.56 FL
49	2	06/95 RFO	Bobbin	NQI		1.34	15TH TSP	+30.02 FL
49	4	06/95 RFO	Bobbin	ODI	16	0.59	9TH TSP	+37.31 FL
49	7	06/95 RFO	Bobbin	NQI		0.49	9TH TSP	+24.86 FL
49	16	06/95 RFO	Bobbin	NQI		0.56	5TH TSP	+21.06 FL
49	21	06/95 RFO	Bobbin	NQI		0.26	4TH TSP	-0.41 FL
49	22	06/95 RFO	Bobbin	ODI	23	0.27	4TH TSP	-0.34 FL
49	46	06/95 RFO	Bobbin	NQI		0.32	9TH TSP	+0.29 FL
		06/95 RFO	Bobbin	ODI	31	0.45	9TH TSP	+21.99 FL
49	59	06/95 RFO	Bobbin	NQI		0.31	7TH TSP	+4.95 FL
49	106	06/95 RFO	Bobbin	ODI	9	0.60	6TH TSP	+32.63 FL
50	3	06/95 RFO	Bobbin	NQI		0.50	15TH TSP	+0.13 FL
50	4	06/95 RFO	Bobbin	NQI		0.70	10TH TSP	+0.55 FL
50	13	06/95 RFO	Bobbin	ODI	10	0.63	6TH TSP	+34.61 FL
50	22	06/95 RFO	Bobbin	NQI		0.27	4TH TSP	-0.43 FL
50	23	06/95 RFO	Bobbin	NQI		0.43	15TH TSP	+4.51 FL
50	73	06/95 RFO	Bobbin	ODI	26	0.43	6TH TSP	+30.92 FL
50	95	06/95 RFO	Bobbin	ODI	29	0.48	14TH TSP	+0.54 FL
		06/95 RFO	Bobbin	ADI		6.50	LTSP	+21.96 to +28.65 FL
51	5	06/95 RFO	Bobbin	NQI		0.56	9TH TSP	+16.88 FL
51	12	06/95 RFO	Bobbin	NQI		0.38	12TH TSP	+8.09 FL
51	29	06/95 RFO	Bobbin	NQI		0.37	14TH TSP	+0.42 FL
51	37	06/95 RFO	Bobbin	NQI		0.22	3RD TSP	-0.03 FL
51	56	06/95 RFO	Bobbin	NQI		0.60	1ST TSP	+23.06 FL
51	62	06/95 RFO	Bobbin	NQI		0.36	2ND TSP	+22.10 FL
		06/95 RFO	Bobbin	NQI		0.40	12TH TSP	+32.31 FL

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 10 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
51	65	06/95 RFO	Bobbin	NQI		0.45	7TH TSP	+20.15
51	85	06/95 RFO	Bobbin	ODI	67	0.46	14TH TSP	+8.38
51	91	06/95 RFO	Bobbin	ODI	75	0.76	3RD TSP	+2.85
51	123	06/95 RFO	Bobbin	ODI	28	0.23	10TH TSP	+0.29
52	2	06/95 RFO	Bobbin	ODI	12	0.77	11TH TSP	+0.57
52	46	06/95 RFO	Bobbin	NQI		0.39	5TH TSP	+34.08
52	52	06/95 RFO	Bobbin	NQI		0.33	15TH TSP	+13.97
52	71	06/95 RFO	Bobbin	NQI		0.55	3RD TSP	+28.15
52	72	06/95 RFO	Bobbin	NQI		0.46	2ND TSP	+29.12
52	76	06/95 RFO	Bobbin	ODI	58	0.44	6TH TSP	+31.71
52	83	06/95 RFO	Bobbin	ODI	25	0.42	14TH TSP	+0.00
52	84	06/95 RFO	Bobbin	NQI		0.41	14TH TSP	+0.33
52	119	06/95 RFO	Bobbin	ODI	39	0.32	15TH TSP	+0.17
52	122	06/95 RFO	Bobbin	ODI	27	0.30	11TH TSP	-0.82
53	1	06/95 RFO	Bobbin	NQI		0.89	13TH TSP	-0.62
53	2	06/95 RFO	Bobbin	ODI	17	0.69	11TH TSP	+0.52
53	3	06/95 RFO	Bobbin	NQI		0.48	11TH TSP	+0.63
53	26	06/95 RFO	Bobbin	NQI		0.31	4TH TSP	+21.02
		06/95 RFO	Bobbin	NQI		0.43	7TH TSP	+30.42
53	36	06/95 RFO	Bobbin	NQI		0.41	7TH TSP	+18.44
		06/95 RFO	Bobbin	ODI	7	0.46	7TH TSP	+19.23
53	56	06/95 RFO	Bobbin	NQI		0.50	5TH TSP	+7.13
53	70	06/95 RFO	Bobbin	ODI	65	1.30	10TH TSP	+11.79
53	105	06/95 RFO	Bobbin	ODI	14	0.60	7TH TSP	+22.26
53	109	06/95 RFO	Bobbin	ODI	30	0.46	10TH TSP	+34.55
53	122	06/95 RFO	Bobbin	NQI		0.68	15TH TSP	+0.21
53	124	06/95 RFO	Bobbin	ODI	27	0.81	2ND TSP	+34.76
53	125	06/95 RFO	Bobbin	ODI	3	0.43	10TH TSP	+18.86
		06/95 RFO	Bobbin	ODI	6	0.51	10TH TSP	+23.96
		06/95 RFO	Bobbin	ODI	26	0.43	10TH TSP	+18.18
54	2	06/95 RFO	Bobbin	ODI	17	3.01	13TH TSP	-0.80
54	3	06/95 RFO	Bobbin	ODI	11	1.28	11TH TSP	+0.65
54	5	06/95 RFO	Bobbin	ODI	1	0.58	15TH TSP	+23.24
		06/95 RFO	Bobbin	ODI	8	0.38	15TH TSP	+34.58
54	18	06/95 RFO	Bobbin	NQI		0.35	6TH TSP	+23.43
54	52	06/95 RFO	Bobbin	NQI		1.79	15TH TSP	+24.54
54	60	06/95 RFO	Bobbin	ODI	17	0.45	15TH TSP	+5.90
54	73	06/95 RFO	Bobbin	NQI		0.41	13TH TSP	+26.09
54	80	06/95 RFO	Bobbin	ODI	20	0.67	3RD TSP	+8.15
54	126	06/95 RFO	Bobbin	ODI	18	0.65	10TH TSP	+19.01
55	1	06/95 RFO	Bobbin	NQI		0.51	12TH TSP	-0.76
		06/95 RFO	Bobbin	ODI	16	0.59	14TH TSP	+5.86
55	4	06/95 RFO	Bobbin	NQI		0.67	15TH TSP	+1.89
55	5	06/95 RFO	Bobbin	ODI	17	0.97	15TH TSP	+0.91
55	11	06/95 RFO	Bobbin	ODI	38	0.95	11TH TSP	+31.76
55	12	06/95 RFO	Bobbin	NQI		0.39	14TH TSP	+0.39
55	28	06/95 RFO	Bobbin	ODI	57	0.63	15TH TSP	+33.48
55	29	06/95 RFO	Bobbin	NQI		0.46	7TH TSP	+35.01
		06/95 RFO	Bobbin	NQI		0.50	8TH TSP	+22.67
55	34	06/95 RFO	Bobbin	ODI	31	0.50	7TH TSP	+36.73
55	46	06/95 RFO	Bobbin	NQI		0.53	13TH TSP	-0.44
55	77	06/95 RFO	Bobbin	ODI	35	0.31	6TH TSP	+32.22
55	107	06/95 RFO	Bobbin	ODI	65	0.61	LTSF	+33.36
55	113	06/95 RFO	Bobbin	NQI		0.55	3RD TSP	+10.80
55	115	06/95 RFO	Bobbin	NQI		0.41	9TH TSP	+24.49
55	123	06/95 RFO	Bobbin	ODI	1	0.62	9TH TSP	-0.63
		06/95 RFO	Bobbin	ODI	6	1.06	9TH TSP	+23.17
56	1	06/95 RFO	Bobbin	ADI		1.59	14TH TSP	+5.56
		06/95 RFO	Bobbin	NQI		0.19	12TH TSP	+7.90
		06/95 RFO	Bobbin	ODI	18	0.52	12TH TSP	+7.02
		06/95 RFO	Bobbin	ODI	41	2.13	13TH TSP	-0.52
56	2	06/95 RFO	Bobbin	ODI	1	0.45	10TH TSP	+6.52
56	4	06/95 RFO	Bobbin	ODI	22	0.89	11TH TSP	-0.77
56	6	06/95 RFO	Bobbin	ADI		1.24	LTSF	+21.42 to +29.31
56	15	06/95 RFO	Bobbin	NQI		0.75	5TH TSP	+12.97

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 11 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
56	18	06/95 RFO	Bobbin	NQI		16.73	LTSP	+22.52 to +30.41 FL
56	25	06/95 RFO	Bobbin	NQI		0.48	8TH TSP	+29.62 FL
56	28	06/95 RFO	Bobbin	NQI		0.42	7TH TSP	+36.27 FL
		06/95 RFO	Bobbin	NQI		0.57	1ST TSP	+21.24 FL
56	36	06/95 RFO	Bobbin	ODI	13	1.88	2ND TSP	-1.38 FL
		06/95 RFO	Bobbin	ADI		3.06	LTSP	+23.93 to +30.78 FL
		06/95 RFO	Bobbin	ODI	20	2.95	2ND TSP	+0.88 to +5.83 FL
56	71	06/95 RFO	Bobbin	ODI	61	0.55	14TH TSP	+32.40 FL
56	84	06/95 RFO	Bobbin	ODI	4	5.63	LTSP	+21.27 FL
		06/95 RFO	Bobbin	ODI	17	8.46	LTSP	+22.62 FL
		06/95 RFO	Bobbin	ODI	21	0.56	LTSP	+22.03 FL
56	121	06/95 RFO	Bobbin	ODI	26	0.76	9TH TSP	-0.65 FL
56	124	06/95 RFO	Bobbin	ODI	29	0.28	10TH TSP	+0.41 FL
56	126	06/95 RFO	Bobbin	ODI	29	0.38	10TH TSP	+21.38 FL
56	127	06/95 RFO	Bobbin	ODI	5	1.24	10TH TSP	+31.05 FL
57	1	06/95 RFO	Bobbin	NQI		0.39	14TH TSP	-0.45 FL
		06/95 RFO	Bobbin	NQI		0.87	14TH TSP	+30.04 FL
		06/95 RFO	Bobbin	NQI		1.40	14TH TSP	+6.93 FL
57	2	06/95 RFO	Bobbin	ODI	10	1.94	13TH TSP	-0.72 FL
57	3	06/95 RFO	Bobbin	ODI	15	1.00	14TH TSP	+1.11 FL
57	12	06/95 RFO	Bobbin	ODI	28	1.24	4TH TSP	+26.39 FL
57	25	06/95 RFO	Bobbin	NQI		0.34	7TH TSP	+4.07 FL
57	32	06/95 RFO	Bobbin	NQI		0.65	4TH TSP	+23.84 FL
57	34	06/95 RFO	Bobbin	NQI		0.77	6TH TSP	+32.73 FL
57	79	06/95 RFO	Bobbin	NQI		0.43	8TH TSP	+2.99 FL
57	102	06/95 RFO	Bobbin	NQI		0.58	14TH TSP	+3.90 FL
57	112	06/95 RFO	Bobbin	NQI		0.48	3RD TSP	+2.69 FL
57	124	06/95 RFO	Bobbin	ODI	15	0.87	9TH TSP	+23.01 FL
57	125	06/95 RFO	Bobbin	ODI	18	0.53	9TH TSP	+28.35 FL
57	127	06/95 RFO	Bobbin	ODI	12	0.47	10TH TSP	+27.21 FL
58	1	06/95 RFO	Bobbin	NQI		0.45	14TH TSP	+6.12 FL
		06/95 RFO	Bobbin	NQI		0.54	12TH TSP	+7.31 FL
		06/95 RFO	Bobbin	NQI		0.81	14TH TSP	+30.57 FL
		06/95 RFO	Bobbin	NQI		0.88	14TH TSP	+6.95 FL
58	2	06/95 RFO	Bobbin	NQI		0.60	14TH TSP	-0.61 FL
		06/95 RFO	Bobbin	ODI	14	1.57	13TH TSP	-0.71 FL
58	3	06/95 RFO	Bobbin	NQI		0.95	UTSF	+0.15 FL
		06/95 RFO	Bobbin	NQI		0.44	12TH TSP	+0.97 FL
		06/95 RFO	Bobbin	ODI	39	1.43	11TH TSP	-0.44 FL
58	12	06/95 RFO	Bobbin	ODI	13	0.88	15TH TSP	+2.18 FL
58	20	06/95 RFO	Bobbin	ODI	25	0.39	10TH TSP	+29.18 FL
58	67	06/95 RFO	Bobbin	NQI		0.53	LTSP	+30.52 FL
		06/95 RFO	Bobbin	NQI		0.46	1ST TSP	-0.35 FL
58	86	06/95 RFO	Bobbin	ADI		0.38	6TH TSP	+17.62 FL
58	90	06/95 RFO	Bobbin	ODI	16	0.94	11TH TSP	+13.87 FL
58	103	06/95 RFO	Bobbin	NQI		0.42	8TH TSP	+3.64 FL
58	122	06/95 RFO	Bobbin	ODI	9	0.99	9TH TSP	-0.70 FL
58	125	06/95 RFO	Bobbin	NQI		1.01	9TH TSP	-0.70 FL
58	126	06/95 RFO	Bobbin	ODI	6	0.70	9TH TSP	+34.47 FL
		06/95 RFO	Bobbin	ODI	29	0.43	9TH TSP	+32.04 FL
		06/95 RFO	Bobbin	NQI		0.27	9TH TSP	+36.79 to +38.27 FL
58	128	06/95 RFO	Bobbin	ODI	28	0.58	10TH TSP	+31.38 FL
		06/95 RFO	Bobbin	ADI		3.05	10TH TSP	+30.65 to +34.52 FL
58	129	06/95 RFO	Bobbin	ODI	2	1.37	14TH TSP	+33.14 FL
59	3	06/95 RFO	Bobbin	NQI		0.85	15TH TSP	-0.34 FL
59	9	06/95 RFO	Bobbin	NQI		0.46	12TH TSP	+18.17 FL
59	10	06/95 RFO	Bobbin	NQI		0.37	4TH TSP	-0.78 FL
59	29	06/95 RFO	Bobbin	NQI		0.37	5TH TSP	-0.64 FL
59	31	06/95 RFO	Bobbin	ADI		7.18	LTSP	+21.82 to +29.42 FL
59	36	06/95 RFO	Bobbin	ODI	5	1.52	LTSP	+29.95 FL
59	40	06/95 RFO	Bobbin	ODI	9	0.42	11TH TSP	+6.93 FL
59	58	06/95 RFO	Bobbin	NQI		0.42	6TH TSP	+24.11 FL
		06/95 RFO	Bobbin	NQI		0.48	7TH TSP	+25.46 FL
59	74	06/95 RFO	Bobbin	ODI	1	1.11	15TH TSP	-0.39 FL
59	81	06/95 RFO	Bobbin	ODI	65	0.45	10TH TSP	+34.43 FL

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 12 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		06/95 RFO	Bobbin	ODI	73	0.74	10TH TSP	+21.99 FL
59	120	06/95 RFO	Bobbin	NQI		0.33	9TH TSP	+22.78 FL
		06/95 RFO	Bobbin	NQI		0.81	9TH TSP	-0.75 FL
59	121	06/95 RFO	Bobbin	ODI	14	0.50	10TH TSP	+0.38 FL
60	1	06/95 RFO	Bobbin	ADI		1.42	14TH TSP	+6.63 FL
		06/95 RFO	Bobbin	NQI		0.82	15TH TSP	-1.22 FL
		06/95 RFO	Bobbin	NQI		1.30	15TH TSP	-1.54 FL
		06/95 RFO	Bobbin	NQI		1.33	12TH TSP	+0.73 FL
		06/95 RFO	Bobbin	ODI	7	0.31	14TH TSP	+0.24 FL
60	2	06/95 RFO	Bobbin	ODI	55	1.27	11TH TSP	+0.68 FL
		06/95 RFO	Bobbin	ODI	62	2.16	13TH TSP	-0.66 FL
60	3	06/95 RFO	Bobbin	NQI		1.15	11TH TSP	-0.63 FL
60	18	06/95 RFO	Bobbin	NQI		0.97	15TH TSP	+0.74 FL
60	20	06/95 RFO	Bobbin	ADI		15.82	LTSF	+23.05 to +30.18 FL
60	35	06/95 RFO	Bobbin	NQI		0.41	12TH TSP	+32.18 FL
60	52	06/95 RFO	Bobbin	NQI		0.62	8TH TSP	+35.86 FL
60	128	06/95 RFO	Bobbin	ODI	3	0.41	15TH TSP	-0.70 FL
61	1	06/95 RFO	Bobbin	NQI		0.47	14TH TSP	+4.59 FL
		06/95 RFO	Bobbin	WAR	20	0.42	11TH TSP	+0.00 FL
61	2	06/95 RFO	Bobbin	ODI	70	1.78	11TH TSP	-0.29 FL
61	3	06/95 RFO	Bobbin	ODI	1	1.91	13TH TSP	-0.71 FL
61	4	06/95 RFO	Bobbin	ODI	37	0.38	12TH TSP	+1.23 FL
61	6	06/95 RFO	Bobbin	ODI	65	1.55	9TH TSP	+1.24 FL
61	32	06/95 RFO	Bobbin	ODI	25	0.41	9TH TSP	+16.48 FL
61	86	06/95 RFO	Bobbin	NQI		0.64	15TH TSP	+0.92 FL
61	98	06/95 RFO	Bobbin	NQI		0.43	14TH TSP	+14.29 FL
		06/95 RFO	Bobbin	NQI		0.82	15TH TSP	+9.69 FL
61	116	06/95 RFO	Bobbin	NQI		0.43	15TH TSP	+14.01 FL
61	119	06/95 RFO	Bobbin	NQI		0.22	LTSF	+3.31 FL
61	121	06/95 RFO	Bobbin	ODI	18	0.87	14TH TSP	+1.26 FL
61	125	06/95 RFO	Bobbin	NQI		0.15	2ND TSP	+11.78 FL
		06/95 RFO	Bobbin	NQI		0.22	10TH TSP	+20.29 FL
		06/95 RFO	Bobbin	ODI	5	0.18	11TH TSP	+34.85 FL
		06/95 RFO	Bobbin	ODI	14	0.75	11TH TSP	+0.60 FL
62	20	06/95 RFO	Bobbin	NQI		0.90	15TH TSP	+36.05 FL
62	21	06/95 RFO	Bobbin	ODI	52	0.40	2ND TSP	+22.97 FL
62	23	06/95 RFO	Bobbin	NQI		0.54	15TH TSP	+35.26 FL
62	29	06/95 RFO	Bobbin	ODI	77	0.57	8TH TSP	+11.14 FL
62	115	06/95 RFO	Bobbin	NQI		1.20	3RD TSP	+32.56 FL
62	119	06/95 RFO	Bobbin	ODI	59	0.54	1ST TSP	+12.66 FL
62	125	06/95 RFO	Bobbin	ODI	6	0.56	9TH TSP	+26.90 FL
63	2	06/95 RFO	Bobbin	NQI		0.84	12TH TSP	+0.70 14TH TSP
63	5	06/95 RFO	Bobbin	NQI		0.99	12TH TSP	+0.86 FL
63	21	06/95 RFO	Bobbin	NQI		0.48	3RD TSP	+17.41 FL
		06/95 RFO	Bobbin	NQI		0.54	2ND TSP	+13.11 FL
63	25	06/95 RFO	Bobbin	ADI		1.86	15TH TSP	+34.30 FL
63	34	06/95 RFO	Bobbin	ODI	27	3.58	LTSF	+22.11 FL
		06/95 RFO	Bobbin	ODI	22	12.36	LTSF	+22.99 to +29.64 FL
63	43	06/95 RFO	Bobbin	ODI	24	0.15	10TH TSP	+0.06 FL
64	2	06/95 RFO	Bobbin	NQI		1.32	11TH TSP	+0.53 14TH TSP
64	12	06/95 RFO	Bobbin	ODI	22	0.68	UTSF	-0.41 FL
64	16	06/95 RFO	Bobbin	ODI	17	0.76	15TH TSP	+36.76 FL
64	18	06/95 RFO	Bobbin	ODI	14	0.88	15TH TSP	+36.22 FL
64	20	06/95 RFO	Bobbin	ODI	8	0.47	15TH TSP	+35.23 FL
64	37	06/95 RFO	Bobbin	ODI	31	0.42	11TH TSP	+33.41 FL
64	40	06/95 RFO	Bobbin	ODI	51	0.70	8TH TSP	+17.49 FL
64	48	06/95 RFO	Bobbin	NQI		0.91	8TH TSP	+28.48 FL
64	120	06/95 RFO	Bobbin	ODI	17	0.31	8TH TSP	+25.36 FL
64	125	06/95 RFO	Bobbin	NQI		0.43	9TH TSP	+12.31 FL
65	2	06/95 RFO	Bobbin	NQI		0.79	11TH TSP	-0.55 14TH TSP
		06/95 RFO	Bobbin	NQI		0.94	11TH TSP	+0.58 14TH TSP
65	3	06/95 RFO	Bobbin	ODI	1	0.71	13TH TSP	-0.85 14TH TSP
65	5	06/95 RFO	Bobbin	NQI		6.11	UTSF	-0.20 FL
65	38	06/95 RFO	Bobbin	ODI	8	2.64	LTSF	+22.32 FL
		06/95 RFO	Bobbin	ADI		4.33	LTSF	+23.04 to +30.44 FL

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 13 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
65	40	06/95 RFO	Bobbin	ODI	4	0.63	7TH TSP	+16.34
65	43	06/95 RFO	Bobbin	ODI	28	0.50	6TH TSP	+0.78
65	50	06/95 RFO	Bobbin	NQI		0.65	10TH TSP	+28.48
65	63	06/95 RFO	Bobbin	ODI	29	0.62	6TH TSP	+28.92
65	67	06/95 RFO	Bobbin	NQI		0.42	2ND TSP	+12.34
65	109	06/95 RFO	Bobbin	NQI		0.40	6TH TSP	+12.84
65	130	06/95 RFO	Bobbin	NQI		1.65	11TH TSP	+0.09
66	13	06/95 RFO	Bobbin	ODI	30	0.17	9TH TSP	+0.79
66	18	06/95 RFO	Bobbin	NQI		30.94	LTSP	+21.79 to +29.34
66	20	06/95 RFO	Bobbin	NQI		0.29	8TH TSP	+22.34
66	45	06/95 RFO	Bobbin	ODI	5	0.39	6TH TSP	+0.63
66	79	06/95 RFO	Bobbin	ODI	3	0.49	6TH TSP	+26.92
66	91	06/95 RFO	Bobbin	ODI	16	0.42	12TH TSP	+19.73
66	117	06/95 RFO	Bobbin	NQI		0.45	15TH TSP	+36.74
66	126	06/95 RFO	Bobbin	ODI	15	0.64	8TH TSP	+0.60
66	127	06/95 RFO	Bobbin	ODI	3	0.78	14TH TSP	+1.68
67	2	06/95 RFO	Bobbin	ODI	6	0.75	10TH TSP	+5.66
		06/95 RFO	Bobbin	ODI	18	0.67	10TH TSP	+6.97
67	7	06/95 RFO	Bobbin	ODI	17	0.46	4TH TSP	-0.75
67	15	06/95 RFO	Bobbin	ODI	32	0.32	11TH TSP	+0.20
67	18	06/95 RFO	Bobbin	NQI		0.23	10TH TSP	+0.75
67	68	06/95 RFO	Bobbin	NQI		0.45	15TH TSP	+10.25
67	89	06/95 RFO	Bobbin	ODI	14	0.52	6TH TSP	+25.15
68	2	06/95 RFO	Bobbin	NQI		0.99	11TH TSP	+0.63
		06/95 RFO	Bobbin	NQI		1.09	11TH TSP	-0.66
		06/95 RFO	Bobbin	ODI	6	0.93	13TH TSP	+15.07
68	5	06/95 RFO	Bobbin	NQI		1.42	10TH TSP	+0.64
68	8	06/95 RFO	Bobbin	NQI		0.44	10TH TSP	-0.59
68	10	06/95 RFO	Bobbin	NQI		0.78	10TH TSP	-0.67
68	12	06/95 RFO	Bobbin	WAR	20	0.82	10TH TSP	+0.00
68	13	06/95 RFO	Bobbin	WAR	35	1.04	10TH TSP	+0.00
68	14	06/95 RFO	Bobbin	NQI		0.43	15TH TSP	+0.08
68	20	06/95 RFO	Bobbin	ODI	13	1.03	8TH TSP	-0.69
68	21	06/95 RFO	Bobbin	ODI	53	0.46	10TH TSP	+12.01
68	64	06/95 RFO	Bobbin	NQI		0.49	6TH TSP	+0.52
68	65	06/95 RFO	Bobbin	NQI		0.58	2ND TSP	+25.61
68	66	06/95 RFO	Bobbin	NQI		0.66	4TH TSP	+0.75
68	75	06/95 RFO	Bobbin	ODI	3	0.30	8TH TSP	+35.11
68	82	06/95 RFO	Bobbin	ODI	26	0.28	13TH TSP	+15.33
68	83	06/95 RFO	Bobbin	NQI		0.26	LTSP	+30.06
68	94	06/95 RFO	Bobbin	ODI	53	0.41	13TH TSP	+23.83
68	98	06/95 RFO	Bobbin	ODI	31	0.23	13TH TSP	+31.29
68	100	06/95 RFO	Bobbin	ODI	15	0.64	15TH TSP	+0.64
68	105	06/95 RFO	Bobbin	ODI	16	0.32	15TH TSP	+42.59
68	110	06/95 RFO	Bobbin	ODI	33	0.79	6TH TSP	+11.23
68	112	06/95 RFO	Bobbin	ODI	77	0.33	15TH TSP	+13.49
68	122	06/95 RFO	Bobbin	ODI	15	0.32	13TH TSP	+2.79
68	127	06/95 RFO	Bobbin	NQI		0.92	8TH TSP	+0.12
68	129	06/95 RFO	Bobbin	NQI		0.22	8TH TSP	-0.21
		06/95 RFO	Bobbin	NQI		0.85	7TH TSP	+0.65
68	130	06/95 RFO	Bobbin	ODI	14	0.72	11TH TSP	-0.37
69	12	06/95 RFO	Bobbin	NQI		0.58	10TH TSP	-0.50
69	15	06/95 RFO	Bobbin	NQI		0.52	8TH TSP	-0.60
		06/95 RFO	Bobbin	ODI	16	1.19	15TH TSP	+1.52
69	22	06/95 RFO	Bobbin	NQI		0.26	10TH TSP	+0.13
69	23	06/95 RFO	Bobbin	ODI	37	0.30	1ST TSP	+16.78
		06/95 RFO	Bobbin	ODI	9	0.41	11TH TSP	+0.41
69	44	06/95 RFO	Bobbin	NQI		0.72	6TH TSP	+0.63
69	46	06/95 RFO	Bobbin	ODI	11	0.62	6TH TSP	+0.65
69	78	06/95 RFO	Bobbin	NQI		0.35	10TH TSP	+14.95
69	88	06/95 RFO	Bobbin	ODI	7	0.50	6TH TSP	+19.77
69	109	06/95 RFO	Bobbin	ODI	18	0.54	LTSP	+16.63
69	129	06/95 RFO	Bobbin	ODI	5	0.35	13TH TSP	+1.17
69	131	06/95 RFO	Bobbin	NQI		0.77	10TH TSP	+0.43
		06/95 RFO	Bobbin	ODI	3	0.73	11TH TSP	-0.67

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 14 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
69	132	06/95 RFO	Bobbin	ODI	11	0.98	14TH TSP	+32.40
70	3	06/95 RFO	Bobbin	ODI	6	1.26	11TH TSP	-0.26
		06/95 RFO	Bobbin	ODI	22	0.40	11TH TSP	+0.45
70	5	06/95 RFO	Bobbin	ODI	20	0.95	11TH TSP	+1.08
70	6	06/95 RFO	Bobbin	ADI		1.77	11TH TSP	+3.51
70	7	06/95 RFO	Bobbin	ODI	20	0.79	10TH TSP	+0.42
70	8	06/95 RFO	Bobbin	ODI	14	0.89	11TH TSP	+0.75
70	9	06/95 RFO	Bobbin	ODI	10	0.62	11TH TSP	+5.45
70	11	06/95 RFO	Bobbin	NQI		0.45	14TH TSP	-0.72
		06/95 RFO	Bobbin	ODI	14	0.60	12TH TSP	-1.52
70	12	06/95 RFO	Bobbin	ODI	38	1.35	13TH TSP	-0.66
70	16	06/95 RFO	Bobbin	NQI		0.60	11TH TSP	+0.53
70	22	06/95 RFO	Bobbin	ODI	37	1.18	11TH TSP	+0.48
70	24	06/95 RFO	Bobbin	ODI	37	0.33	12TH TSP	-0.02
70	30	06/95 RFO	Bobbin	NQI		0.47	11TH TSP	+0.50
70	32	06/95 RFO	Bobbin	NQI		0.66	10TH TSP	+4.34
70	40	06/95 RFO	Bobbin	NQI		0.56	9TH TSP	-0.68
70	43	06/95 RFO	Bobbin	ODI	15	0.97	9TH TSP	-0.80
70	45	06/95 RFO	Bobbin	ODI	26	0.75	9TH TSP	-0.82
70	59	06/95 RFO	Bobbin	ODI	70	0.50	10TH TSP	+26.30
70	65	06/95 RFO	Bobbin	NQI		0.45	2ND TSP	+33.78
		06/95 RFO	Bobbin	ODI	50	1.02	4TH TSP	+10.18
70	98	06/95 RFO	Bobbin	ODI	30	0.62	7TH TSP	+26.94
70	108	06/95 RFO	Bobbin	ODI	53	0.64	3RD TSP	+6.61
70	124	06/95 RFO	Bobbin	ODI	36	0.73	2ND TSP	+33.90
		06/95 RFO	Bobbin	ODI	36	0.96	2ND TSP	+9.61
70	128	06/95 RFO	Bobbin	NQI		1.25	8TH TSP	-0.63
71	3	06/95 RFO	Bobbin	NQI		0.36	10TH TSP	-0.34
		06/95 RFO	Bobbin	ODI	12	0.46	13TH TSP	-0.55
71	6	06/95 RFO	Bobbin	ODI	6	2.51	13TH TSP	-0.81
71	9	06/95 RFO	Bobbin	ODI	25	0.62	11TH TSP	+34.03
		06/95 RFO	Bobbin	ODI	28	0.77	11TH TSP	+0.74
71	10	06/95 RFO	Bobbin	NQI		0.76	14TH TSP	-0.65
71	11	06/95 RFO	Bobbin	ODI	65	1.16	14TH TSP	-0.58
71	12	06/95 RFO	Bobbin	NQI		0.35	10TH TSP	+0.21
		06/95 RFO	Bobbin	NQI		0.78	14TH TSP	-0.64
71	13	06/95 RFO	Bobbin	ODI	32	1.20	14TH TSP	-0.64
		06/95 RFO	Bobbin	ODI	35	0.59	10TH TSP	+0.52
71	14	06/95 RFO	Bobbin	ODI	29	0.77	15TH TSP	-0.74
71	15	06/95 RFO	Bobbin	NQI		0.28	10TH TSP	+0.16
		06/95 RFO	Bobbin	NQI		1.38	14TH TSP	-0.75
71	16	06/95 RFO	Bobbin	ODI	9	0.68	12TH TSP	-1.43
71	17	06/95 RFO	Bobbin	ODI	7	0.89	15TH TSP	+26.83
71	18	06/95 RFO	Bobbin	ODI	12	0.43	12TH TSP	-1.12
71	19	06/95 RFO	Bobbin	NQI		1.25	12TH TSP	-1.10
		06/95 RFO	Bobbin	ODI	23	0.83	15TH TSP	+26.15
71	21	06/95 RFO	Bobbin	NQI		0.74	10TH TSP	+0.41
		06/95 RFO	Bobbin	ODI	10	1.30	12TH TSP	+2.28
71	22	06/95 RFO	Bobbin	ODI	12	1.06	12TH TSP	+6.06
71	23	06/95 RFO	Bobbin	ODI	2	0.98	11TH TSP	+0.49
		06/95 RFO	Bobbin	ODI	7	0.99	12TH TSP	+9.39
71	25	06/95 RFO	Bobbin	NQI		1.35	12TH TSP	-1.09
71	26	06/95 RFO	Bobbin	NQI		0.34	13TH TSP	+0.63
71	29	06/95 RFO	Bobbin	NQI		0.58	12TH TSP	+0.52
		06/95 RFO	Bobbin	ODI	37	0.43	13TH TSP	+0.65
71	30	06/95 RFO	Bobbin	ODI	16	0.36	10TH TSP	+0.46
71	33	06/95 RFO	Bobbin	NQI		0.82	12TH TSP	+0.46
71	39	06/95 RFO	Bobbin	ODI	28	0.47	10TH TSP	+10.05
71	40	06/95 RFO	Bobbin	ODI	23	0.51	9TH TSP	+0.43
71	42	06/95 RFO	Bobbin	NQI		0.41	12TH TSP	+30.79
71	44	06/95 RFO	Bobbin	NQI		0.57	9TH TSP	+0.63
71	45	06/95 RFO	Bobbin	ODI	19	0.73	8TH TSP	+0.64
71	46	06/95 RFO	Bobbin	NQI		0.30	6TH TSP	+0.63
		06/95 RFO	Bobbin	NQI		0.96	8TH TSP	-0.76
		06/95 RFO	Bobbin	ODI	2	0.82	7TH TSP	-0.65

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 15 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
71	48	06/95 RFO	Bobbin	NQI		0.56	9TH TSP	-0.80
71	49	06/95 RFO	Bobbin	ODI	7	0.33	LTSF	+4.69
71	60	06/95 RFO	Bobbin	NQI		0.71	1ST TSP	+33.89
71	77	06/95 RFO	Bobbin	NQI		0.31	14TH TSP	-0.19
71	96	06/95 RFO	Bobbin	NQI		0.59	11TH TSP	+35.41
71	97	06/95 RFO	Bobbin	ODI	26	0.38	12TH TSP	+21.60
71	101	06/95 RFO	Bobbin	NQI		0.29	10TH TSP	+26.93
		06/95 RFO	Bobbin	NQI		0.83	10TH TSP	+31.90
71	112	06/95 RFO	Bobbin	NQI		0.30	4TH TSP	-0.32
71	115	06/95 RFO	Bobbin	NQI		1.17	9TH TSP	+27.37
71	128	06/95 RFO	Bobbin	NQI		0.33	8TH TSP	-0.30
72	4	06/95 RFO	Bobbin	NQI		0.42	11TH TSP	-0.39
		06/95 RFO	Bobbin	NQI		1.11	14TH TSP	-0.73
72	18	06/95 RFO	Bobbin	NQI		0.71	15TH TSP	-0.58
72	20	06/95 RFO	Bobbin	ODI	19	0.42	15TH TSP	+23.70
72	23	06/95 RFO	Bobbin	NQI		1.01	15TH TSP	+22.82
		06/95 RFO	Bobbin	ODI	27	0.48	15TH TSP	+0.54
72	24	06/95 RFO	Bobbin	NQI		0.65	15TH TSP	+0.53
72	25	06/95 RFO	Bobbin	ODI	2	0.91	13TH TSP	+0.54
72	26	06/95 RFO	Bobbin	NQI		0.33	12TH TSP	+12.60
		06/95 RFO	Bobbin	NQI		0.47	12TH TSP	+10.82
72	28	06/95 RFO	Bobbin	ADI		1.01	15TH TSP	+22.09
		06/95 RFO	Bobbin	ODI	12	0.92	12TH TSP	+8.54
72	31	06/95 RFO	Bobbin	NQI		0.43	12TH TSP	+0.40
		06/95 RFO	Bobbin	ODI	11	0.55	12TH TSP	+0.12
72	32	06/95 RFO	Bobbin	NQI		0.66	15TH TSP	+20.15
		06/95 RFO	Bobbin	NQI		0.85	10TH TSP	+0.34
		06/95 RFO	Bobbin	ODI	10	0.73	15TH TSP	+21.38
		06/95 RFO	Bobbin	ODI	19	1.20	12TH TSP	+3.76
72	34	06/95 RFO	Bobbin	ODI	19	0.53	15TH TSP	-0.42
72	35	06/95 RFO	Bobbin	NQI		0.28	8TH TSP	-0.80
		06/95 RFO	Bobbin	NQI		0.35	15TH TSP	-0.55
		06/95 RFO	Bobbin	ODI	25	0.50	12TH TSP	+5.80
72	37	06/95 RFO	Bobbin	ODI	18	0.29	11TH TSP	+0.55
72	39	06/95 RFO	Bobbin	NQI		0.32	13TH TSP	+0.54
		06/95 RFO	Bobbin	NQI		0.61	12TH TSP	+0.46
72	58	06/95 RFO	Bobbin	ODI	10	0.36	12TH TSP	+14.99
		06/95 RFO	Bobbin	ODI	16	0.30	13TH TSP	+13.75
72	70	06/95 RFO	Bobbin	NQI		0.16	14TH TSP	+0.18
72	72	06/95 RFO	Bobbin	NQI		0.35	7TH TSP	+37.97
		06/95 RFO	Bobbin	NQI		0.37	8TH TSP	+29.52
		06/95 RFO	Bobbin	NQI		0.37	9TH TSP	+11.94
		06/95 RFO	Bobbin	NQI		0.41	8TH TSP	+15.83
		06/95 RFO	Bobbin	NQI		0.50	8TH TSP	+35.28
		06/95 RFO	Bobbin	NQI		0.57	8TH TSP	+17.81
72	79	06/95 RFO	Bobbin	ODI	27	0.54	14TH TSP	+29.41
72	80	06/95 RFO	Bobbin	NQI		0.44	3RD TSP	+6.74
72	124	06/95 RFO	Bobbin	WAR	22	1.99	14TH TSP	+0.00
72	125	06/95 RFO	Bobbin	NQI		1.69	14TH TSP	+0.74
72	128	06/95 RFO	Bobbin	ODI	20	1.28	8TH TSP	-0.67
72	130	06/95 RFO	Bobbin	NQI		0.32	15TH TSP	+32.33
73	4	06/95 RFO	Bobbin	ODI	36	1.08	13TH TSP	-0.60
73	5	06/95 RFO	Bobbin	ODI	12	1.56	14TH TSP	-0.63
73	7	06/95 RFO	Bobbin	ODI	9	0.38	11TH TSP	+0.36
73	16	06/95 RFO	Bobbin	NQI		0.24	9TH TSP	+0.39
73	22	06/95 RFO	Bobbin	NQI		0.73	15TH TSP	-1.31
73	46	06/95 RFO	Bobbin	NQI		0.41	10TH TSP	+9.91
		06/95 RFO	Bobbin	NQI		0.54	10TH TSP	+9.32
		06/95 RFO	Bobbin	NQI		0.61	10TH TSP	+0.56
		06/95 RFO	Bobbin	NQI		0.65	10TH TSP	+10.37
73	48	06/95 RFO	Bobbin	ODI	10	0.37	9TH TSP	+0.41
73	50	06/95 RFO	Bobbin	NQI		0.61	9TH TSP	+0.56
73	52	06/95 RFO	Bobbin	NQI		0.39	8TH TSP	+0.52
		06/95 RFO	Bobbin	ODI	61	0.63	15TH TSP	+35.78
73	72	06/95 RFO	Bobbin	NQI		0.89	9TH TSP	+31.04

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 16 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
73	98	06/95 RFO	Bobbin	NQI		0.77	LTSF	+34.79
73	102	06/95 RFO	Bobbin	NQI		0.48	13TH TSP	+20.45
73	116	06/95 RFO	Bobbin	NQI		0.60	14TH TSP	+14.21
74	18	06/95 RFO	Bobbin	ODI	48	0.57	LTSF	+20.58
74	46	06/95 RFO	Bobbin	ODI	12	0.63	13TH TSP	+10.87
74	47	06/95 RFO	Bobbin	ODI	57	0.42	15TH TSP	+0.31
74	48	06/95 RFO	Bobbin	ODI	33	0.86	1ST TSP	+16.88
74	54	06/95 RFO	Bobbin	ADI		18.55	LTSF	+22.22
		06/95 RFO	Bobbin	ODI	12	3.52	LTSF	+24.49
74	79	06/95 RFO	Bobbin	NQI		0.34	5TH TSP	+30.64
74	108	06/95 RFO	Bobbin	NQI		0.83	13TH TSP	+7.46
74	112	06/95 RFO	Bobbin	NQI		0.41	11TH TSP	+29.51
74	121	06/95 RFO	Bobbin	ODI	35	0.39	1ST TSP	+24.82
74	124	06/95 RFO	Bobbin	NQI		1.05	8TH TSP	+32.23
74	125	06/95 RFO	Bobbin	ODI	5	0.60	10TH TSP	+0.14
75	65	06/95 RFO	Bobbin	NQI		0.42	8TH TSP	+31.66
75	87	06/95 RFO	Bobbin	ODI	56	0.56	15TH TSP	+10.34
75	119	06/95 RFO	Bobbin	ODI	26	0.65	14TH TSP	+1.05
75	120	06/95 RFO	Bobbin	ODI	10	0.57	14TH TSP	+1.14
75	122	06/95 RFO	Bobbin	ODI	40	1.28	14TH TSP	+1.07
75	123	06/95 RFO	Bobbin	WAR	22	0.42	9TH TSP	-0.69
75	124	06/95 RFO	Bobbin	NQI		1.76	14TH TSP	+0.65
75	126	06/95 RFO	Bobbin	ODI	5	1.00	15TH TSP	+22.30
76	123	06/95 RFO	Bobbin	ODI	19	0.78	10TH TSP	+0.55
77	2	06/95 RFO	Bobbin	NQI		0.58	LTSF	+26.08
77	7	06/95 RFO	Bobbin	NQI		0.56	LTSF	+26.19
77	49	06/95 RFO	Bobbin	NQI		0.33	7TH TSP	+15.16
77	75	06/95 RFO	Bobbin	NQI		0.58	4TH TSP	-0.85
77	82	06/95 RFO	Bobbin	NQI		0.46	3RD TSP	+14.27
		06/95 RFO	Bobbin	ODI	9	0.62	6TH TSP	+23.58
		06/95 RFO	Bobbin	ODI	14	0.47	3RD TSP	+17.17
77	106	06/95 RFO	Bobbin	NQI		1.19	2ND TSP	+13.42
77	112	06/95 RFO	Bobbin	ODI	6	0.64	12TH TSP	+31.00
77	125	06/95 RFO	Bobbin	NQI		0.65	15TH TSP	-0.05
77	126	06/95 RFO	Bobbin	NQI		0.68	14TH TSP	+1.24
		06/95 RFO	Bobbin	NQI		0.76	14TH TSP	+1.05
		06/95 RFO	Bobbin	NQI		1.30	15TH TSP	+31.30
78	34	06/95 RFO	Bobbin	NQI		0.59	14TH TSP	+17.97
78	79	06/95 RFO	Bobbin	ODI	3	0.44	6TH TSP	+22.74
		06/95 RFO	Bobbin	ODI	26	0.37	5TH TSP	+20.15
		06/95 RFO	Bobbin	ODI	51	0.41	11TH TSP	+20.69
78	82	06/95 RFO	Bobbin	NQI		0.20	1ST TSP	+10.98
78	84	06/95 RFO	Bobbin	ODI	13	0.54	6TH TSP	+17.96
78	89	06/95 RFO	Bobbin	ODI	57	0.47	15TH TSP	+14.76
78	101	06/95 RFO	Bobbin	ODI	21	3.13	14TH TSP	+1.28
78	105	06/95 RFO	Bobbin	ODI	24	0.47	14TH TSP	+4.08
78	120	06/95 RFO	Bobbin	ODI	22	0.78	14TH TSP	+0.91
78	121	06/95 RFO	Bobbin	ODI	3	0.53	14TH TSP	+0.64
78	125	06/95 RFO	Bobbin	ODI	15	0.26	8TH TSP	-0.54
		06/95 RFO	Bobbin	ODI	18	0.64	15TH TSP	-0.07
78	126	06/95 RFO	Bobbin	NQI		0.63	8TH TSP	-0.47
		06/95 RFO	Bobbin	NQI		0.51	14TH TSP	+0.99
		06/95 RFO	Bobbin	ODI	21	0.76	14TH TSP	+1.23
79	4	06/95 RFO	Bobbin	NQI		0.42	14TH TSP	+0.58
		06/95 RFO	Bobbin	NQI		0.63	12TH TSP	-0.76
		06/95 RFO	Bobbin	NQI		0.79	14TH TSP	-0.65
79	6	06/95 RFO	Bobbin	NQI		1.72	14TH TSP	-0.67
		06/95 RFO	Bobbin	ODI	2	0.96	12TH TSP	-0.53
		06/95 RFO	Bobbin	ODI	4	1.83	13TH TSP	-0.79
79	7	06/95 RFO	Bobbin	ODI	52	0.51	10TH TSP	+2.94
79	13	06/95 RFO	Bobbin	NQI		0.22	13TH TSP	+0.32
79	22	06/95 RFO	Bobbin	NQI		0.82	15TH TSP	+19.41
79	38	06/95 RFO	Bobbin	NQI		0.56	6TH TSP	+11.90
79	40	06/95 RFO	Bobbin	NQI		0.50	12TH TSP	+16.46
		06/95 RFO	Bobbin	NQI		0.84	15TH TSP	+14.75

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Ocone Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 17 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
79	41	06/95 RFO	Bobbin	NQI		0.28	12TH TSP	+26.38 FL
		06/95 RFO	Bobbin	NQI		0.54	12TH TSP	+28.51 FL
		06/95 RFO	Bobbin	ODI	42	0.74	12TH TSP	+23.21 FL
79	43	06/95 RFO	Bobbin	NQI		0.56	15TH TSP	+0.70 FL
79	50	06/95 RFO	Bobbin	NQI		0.36	11TH TSP	+16.82 FL
79	75	06/95 RFO	Bobbin	NQI		0.28	6TH TSP	+30.83 FL
79	78	06/95 RFO	Bobbin	ODI	14	0.34	6TH TSP	+30.19 FL
79	83	06/95 RFO	Bobbin	ODI	3	0.25	LTSF	+27.70 FL
79	107	06/95 RFO	Bobbin	NQI		0.33	6TH TSP	+13.15 FL
79	108	06/95 RFO	Bobbin	NQI		0.30	10TH TSP	+14.79 FL
79	117	06/95 RFO	Bobbin	NQI		0.82	6TH TSP	+27.49 FL
79	118	06/95 RFO	Bobbin	NQI		0.39	15TH TSP	+0.36 FL
79	122	06/95 RFO	Bobbin	ODI	24	0.59	15TH TSP	+13.92 FL
79	127	06/95 RFO	Bobbin	ODI	5	0.88	14TH TSP	+0.44 FL
79	130	06/95 RFO	Bobbin	NQI		0.66	15TH TSP	+17.43 FL
		06/95 RFO	Bobbin	ODI	19	0.35	8TH TSP	-0.14 FL
80	1	06/95 RFO	Bobbin	NQI		0.60	7TH TSP	+5.30 14TH TSP
		06/95 RFO	Bobbin	NQI		0.64	13TH TSP	+18.96 14TH TSP
80	5	06/95 RFO	Bobbin	ODI	9	3.19	12TH TSP	-0.78 14TH TSP
80	9	06/95 RFO	Bobbin	NQI		0.70	14TH TSP	-0.73 FL
		06/95 RFO	Bobbin	ODI	26	0.38	10TH TSP	+27.97 FL
		06/95 RFO	Bobbin	ODI	28	0.47	10TH TSP	+23.54 FL
80	10	06/95 RFO	Bobbin	NQI		0.69	14TH TSP	-0.57 FL
80	12	06/95 RFO	Bobbin	NQI		0.99	15TH TSP	-0.52 FL
80	13	06/95 RFO	Bobbin	NQI		0.51	12TH TSP	+0.41 FL
		06/95 RFO	Bobbin	ODI	27	1.42	14TH TSP	-0.44 FL
80	15	06/95 RFO	Bobbin	ODI	28	0.98	15TH TSP	+25.34 FL
80	17	06/95 RFO	Bobbin	ODI	3	1.03	15TH TSP	+20.84 FL
80	19	06/95 RFO	Bobbin	ODI	23	0.99	15TH TSP	+21.41 FL
80	20	06/95 RFO	Bobbin	ODI	4	0.91	15TH TSP	+21.21 FL
80	21	06/95 RFO	Bobbin	ODI	7	1.82	15TH TSP	+19.96 FL
80	22	06/95 RFO	Bobbin	ODI	16	5.65	15TH TSP	+20.25 FL
80	23	06/95 RFO	Bobbin	ODI	2	2.23	15TH TSP	+19.50 FL
80	24	06/95 RFO	Bobbin	ODI	5	3.65	15TH TSP	+19.30 FL
80	25	06/95 RFO	Bobbin	ODI	12	1.01	15TH TSP	+17.03 FL
		06/95 RFO	Bobbin	ODI	14	0.65	15TH TSP	+17.72 FL
80	26	06/95 RFO	Bobbin	ODI	5	1.44	15TH TSP	+17.91 FL
		06/95 RFO	Bobbin	ODI	8	3.06	15TH TSP	+16.98 FL
80	27	06/95 RFO	Bobbin	NQI		0.69	15TH TSP	+16.86 FL
		06/95 RFO	Bobbin	ODI	6	0.48	15TH TSP	+17.52 FL
		06/95 RFO	Bobbin	ODI	33	0.80	15TH TSP	+16.28 FL
80	28	06/95 RFO	Bobbin	ODI	22	1.93	15TH TSP	+16.79 FL
80	29	06/95 RFO	Bobbin	ODI	4	1.31	15TH TSP	+16.01 FL
80	30	06/95 RFO	Bobbin	NQI		0.60	15TH TSP	+16.64 FL
		06/95 RFO	Bobbin	ODI	1	3.50	15TH TSP	+16.01 FL
80	31	06/95 RFO	Bobbin	NQI		1.50	15TH TSP	+14.81 FL
80	32	06/95 RFO	Bobbin	ODI	3	1.42	15TH TSP	+15.33 FL
		06/95 RFO	Bobbin	ODI	4	1.76	15TH TSP	+15.57 FL
80	33	06/95 RFO	Bobbin	NQI		0.32	15TH TSP	+13.96 FL
		06/95 RFO	Bobbin	NQI		0.58	15TH TSP	+14.47 FL
		06/95 RFO	Bobbin	ODI	4	0.45	11TH TSP	+11.97 FL
		06/95 RFO	Bobbin	ODI	12	0.49	15TH TSP	+15.22 FL
80	34	06/95 RFO	Bobbin	ODI	7	1.95	15TH TSP	+12.93 FL
		06/95 RFO	Bobbin	ODI	22	1.11	15TH TSP	+14.67 FL
80	35	06/95 RFO	Bobbin	NQI		0.29	11TH TSP	+11.42 FL
		06/95 RFO	Bobbin	ODI	9	0.61	15TH TSP	+13.99 FL
		06/95 RFO	Bobbin	ODI	18	0.55	15TH TSP	+13.00 FL
80	36	06/95 RFO	Bobbin	ODI	22	2.73	15TH TSP	+13.22 FL
80	37	06/95 RFO	Bobbin	ODI	14	0.77	15TH TSP	+13.91 FL
		06/95 RFO	Bobbin	ODI	24	0.29	14TH TSP	-0.31 FL
80	38	06/95 RFO	Bobbin	ODI	8	0.82	15TH TSP	+14.53 FL
80	39	06/95 RFO	Bobbin	ODI	23	1.14	15TH TSP	+13.87 FL
80	40	06/95 RFO	Bobbin	ODI	16	0.87	15TH TSP	+14.80 FL
80	47	06/95 RFO	Bobbin	ODI	4	0.61	9TH TSP	-0.69 FL
80	48	06/95 RFO	Bobbin	NQI		0.58	9TH TSP	-0.73 FL

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 18 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
80	76	06/95 RFO	Bobbin	ODI	43	0.37	15TH TSP	+10.35 FL
80	85	06/95 RFO	Bobbin	NQI		0.54	10TH TSP	+0.98 FL
80	103	06/95 RFO	Bobbin	ODI	73	0.61	7TH TSP	+13.04 FL
80	106	06/95 RFO	Bobbin	ODI	35	0.48	10TH TSP	+17.99 FL
80	114	06/95 RFO	Bobbin	ODI	33	0.25	LTSF	+2.82 FL
80	125	06/95 RFO	Bobbin	NQI		0.58	14TH TSP	+0.81 FL
80	126	06/95 RFO	Bobbin	ODI	22	0.61	14TH TSP	+1.54 FL
81	5	06/95 RFO	Bobbin	ODI	24	0.52	10TH TSP	+33.95 14TH TSP
81	6	06/95 RFO	Bobbin	NQI		1.01	12TH TSP	+0.00 14TH TSP
81	7	06/95 RFO	Bobbin	NQI		0.56	11TH TSP	+1.78 14TH TSP
		06/95 RFO	Bobbin	ODI	8	0.76	11TH TSP	+1.32 14TH TSP
		06/95 RFO	Bobbin	ODI	13	0.90	11TH TSP	+1.08 14TH TSP
81	9	06/95 RFO	Bobbin	ODI	17	0.49	14TH TSP	-0.71 FL
		06/95 RFO	Bobbin	ODI	20	1.30	13TH TSP	-0.73 FL
81	10	06/95 RFO	Bobbin	ODI	15	1.31	13TH TSP	-0.71 FL
81	11	06/95 RFO	Bobbin	ODI	12	1.83	13TH TSP	-0.73 FL
81	13	06/95 RFO	Bobbin	NQI		0.85	13TH TSP	-0.75 FL
		06/95 RFO	Bobbin	ODI	6	0.89	15TH TSP	+23.81 FL
81	14	06/95 RFO	Bobbin	ODI	10	0.98	13TH TSP	-0.72 FL
81	15	06/95 RFO	Bobbin	NQI		0.29	11TH TSP	+7.71 FL
		06/95 RFO	Bobbin	ODI	9	0.90	15TH TSP	+24.60 FL
		06/95 RFO	Bobbin	ODI	22	0.41	11TH TSP	+13.01 FL
81	16	06/95 RFO	Bobbin	NQI		0.72	11TH TSP	+12.63 FL
81	19	06/95 RFO	Bobbin	ODI	6	0.51	15TH TSP	+23.31 FL
81	22	06/95 RFO	Bobbin	ODI	22	0.59	11TH TSP	+13.62 FL
81	24	06/95 RFO	Bobbin	ODI	19	0.49	15TH TSP	+21.77 FL
81	25	06/95 RFO	Bobbin	NQI		0.50	10TH TSP	-0.83 FL
81	26	06/95 RFO	Bobbin	NQI		0.43	11TH TSP	+12.26 FL
		06/95 RFO	Bobbin	NQI		0.45	15TH TSP	+18.85 FL
81	29	06/95 RFO	Bobbin	ODI	30	0.51	15TH TSP	+18.84 FL
		06/95 RFO	Bobbin	ODI	38	0.29	15TH TSP	+17.57 FL
81	30	06/95 RFO	Bobbin	NQI		0.77	15TH TSP	+0.52 FL
81	36	06/95 RFO	Bobbin	NQI		0.33	13TH TSP	+31.18 FL
81	37	06/95 RFO	Bobbin	ODI	5	0.33	14TH TSP	+0.30 FL
81	39	06/95 RFO	Bobbin	ADI		0.75	10TH TSP	+10.00 to +12.47 FL
81	40	06/95 RFO	Bobbin	ODI	11	1.32	10TH TSP	+0.47 FL
81	42	06/95 RFO	Bobbin	NQI		1.19	9TH TSP	+0.00 FL
81	43	06/95 RFO	Bobbin	NQI		1.13	8TH TSP	+0.65 FL
81	45	06/95 RFO	Bobbin	NQI		0.99	10TH TSP	+0.50 FL
81	48	06/95 RFO	Bobbin	NQI		0.71	8TH TSP	+0.57 FL
		06/95 RFO	Bobbin	ODI	23	1.10	9TH TSP	-0.64 FL
81	52	06/95 RFO	Bobbin	ODI	31	0.47	15TH TSP	+43.86 FL
81	54	06/95 RFO	Bobbin	ODI	18	0.50	8TH TSP	-0.55 FL
81	55	06/95 RFO	Bobbin	NQI		0.81	8TH TSP	+0.51 FL
81	56	06/95 RFO	Bobbin	NQI		0.55	7TH TSP	+0.46 FL
		06/95 RFO	Bobbin	NQI		0.57	9TH TSP	-0.72 FL
		06/95 RFO	Bobbin	NQI		0.58	8TH TSP	-0.63 FL
		06/95 RFO	Bobbin	NQI		1.08	7TH TSP	-0.65 FL
81	57	06/95 RFO	Bobbin	NQI		0.91	5TH TSP	+0.59 FL
81	59	06/95 RFO	Bobbin	NQI		1.10	5TH TSP	+0.60 FL
81	63	06/95 RFO	Bobbin	ODI	31	0.41	15TH TSP	+44.41 FL
81	91	06/95 RFO	Bobbin	ODI	59	0.35	14TH TSP	+18.45 FL
		06/95 RFO	Bobbin	ODI	66	0.53	14TH TSP	+22.13 FL
81	97	06/95 RFO	Bobbin	ODI	23	0.55	LTSF	+38.42 FL
81	102	06/95 RFO	Bobbin	ODI	74	0.45	4TH TSP	+10.29 FL
81	120	06/95 RFO	Bobbin	ODI	11	0.54	1ST TSP	+12.00 FL
81	130	06/95 RFO	Bobbin	NQI		0.31	13TH TSP	+0.99 FL
81	131	06/95 RFO	Bobbin	NQI		0.39	15TH TSP	+9.74 FL
		06/95 RFO	Bobbin	NQI		0.39	15TH TSP	+13.39 FL
		06/95 RFO	Bobbin	NQI		0.48	15TH TSP	+28.69 FL
82	1	06/95 RFO	Bobbin	WAR	43	0.80	11TH TSP	+0.64 14TH TSP
82	4	06/95 RFO	Bobbin	ODI	19	0.63	11TH TSP	-1.44 14TH TSP
82	5	06/95 RFO	Bobbin	ODI	7	1.16	10TH TSP	+33.51 14TH TSP
82	6	06/95 RFO	Bobbin	NQI		1.07	11TH TSP	+1.16 14TH TSP
82	7	06/95 RFO	Bobbin	ODI	42	0.69	10TH TSP	-0.49 FL

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 19 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
82	8	06/95 RFO	Bobbin	ODI	35	0.54	11TH TSP	+1.86 FL
82	9	06/95 RFO	Bobbin	NQI		1.43	11TH TSP	+0.68 FL
82	11	06/95 RFO	Bobbin	NQI		0.67	10TH TSP	+4.80 FL
		06/95 RFO	Bobbin	ODI	47	0.80	3RD TSP	+37.09 FL
82	12	06/95 RFO	Bobbin	ODI	15	1.62	11TH TSP	+12.19 FL
82	16	06/95 RFO	Bobbin	ODI	19	0.74	11TH TSP	+14.17 FL
82	32	06/95 RFO	Bobbin	NQI		0.71	10TH TSP	+0.55 FL
82	38	06/95 RFO	Bobbin	ODI	15	0.47	LTSF	+21.16 FL
		06/95 RFO	Bobbin	ODI	14	1.71	14TH TSP	+18.28 FL
82	39	06/95 RFO	Bobbin	ODI	18	0.35	10TH TSP	+0.46 FL
82	40	06/95 RFO	Bobbin	ODI	34	0.36	10TH TSP	+0.36 FL
82	41	06/95 RFO	Bobbin	NQI		0.50	8TH TSP	+0.70 FL
		06/95 RFO	Bobbin	NQI		0.56	8TH TSP	-0.77 FL
		06/95 RFO	Bobbin	NQI		0.51	10TH TSP	+0.51 FL
82	42	06/95 RFO	Bobbin	NQI		1.32	9TH TSP	-0.28 FL
82	43	06/95 RFO	Bobbin	NQI		0.79	9TH TSP	-0.67 FL
		06/95 RFO	Bobbin	ODI	6	0.62	7TH TSP	-0.76 FL
		06/95 RFO	Bobbin	ODI	34	0.84	10TH TSP	+0.54 FL
82	44	06/95 RFO	Bobbin	NQI		1.06	9TH TSP	-0.67 FL
		06/95 RFO	Bobbin	NQI		1.28	8TH TSP	-0.67 FL
		06/95 RFO	Bobbin	ODI	23	0.86	10TH TSP	+0.52 FL
82	45	06/95 RFO	Bobbin	ODI	16	0.47	8TH TSP	+0.61 FL
82	48	06/95 RFO	Bobbin	ODI	26	0.80	8TH TSP	-0.62 FL
82	51	06/95 RFO	Bobbin	NQI		0.33	4TH TSP	+0.58 FL
82	55	06/95 RFO	Bobbin	NQI		0.60	14TH TSP	+2.83 FL
82	63	06/95 RFO	Bobbin	ODI	28	0.41	7TH TSP	+15.52 FL
82	80	06/95 RFO	Bobbin	NQI		0.46	5TH TSP	+28.24 FL
82	82	06/95 RFO	Bobbin	ODI	52	0.61	11TH TSP	+27.06 FL
82	88	06/95 RFO	Bobbin	ODI	40	0.58	6TH TSP	+26.92 FL
		06/95 RFO	Bobbin	ODI	43	0.44	6TH TSP	+19.85 FL
		06/95 RFO	Bobbin	ODI	56	0.37	6TH TSP	+15.77 FL
		06/95 RFO	Bobbin	ODI	63	0.43	6TH TSP	+4.18 FL
		06/95 RFO	Bobbin	ODI	5	0.41	12TH TSP	+30.65 FL
		06/95 RFO	Bobbin	ODI	21	0.51	12TH TSP	+17.37 FL
		06/95 RFO	Bobbin	ODI	56	0.31	12TH TSP	+13.41 FL
		06/95 RFO	Bobbin	ODI	59	0.47	12TH TSP	+26.15 FL
		06/95 RFO	Bobbin	ODI	86	0.48	12TH TSP	+24.72 FL
82	92	06/95 RFO	Bobbin	ODI	31	0.37	7TH TSP	+14.96 FL
82	96	06/95 RFO	Bobbin	NQI		0.54	15TH TSP	+36.52 FL
82	106	06/95 RFO	Bobbin	ODI	52	0.64	2ND TSP	+33.49 FL
82	125	06/95 RFO	Bobbin	NQI		0.63	14TH TSP	+0.66 FL
83	3	06/95 RFO	Bobbin	NQI		0.63	10TH TSP	-0.39 14TH TSP
		06/95 RFO	Bobbin	NQI		0.99	14TH TSP	-0.77 14TH TSP
		06/95 RFO	Bobbin	ODI	30	0.30	7TH TSP	+25.78 14TH TSP
		06/95 RFO	Bobbin	ODI	33	0.85	10TH TSP	+0.05 14TH TSP
83	6	06/95 RFO	Bobbin	ODI	22	1.12	10TH TSP	+33.86 14TH TSP
83	8	06/95 RFO	Bobbin	ODI	32	1.04	10TH TSP	+0.47 FL
		06/95 RFO	Bobbin	ODI	32	1.89	10TH TSP	+0.00 FL
83	12	06/95 RFO	Bobbin	ODI	15	0.61	10TH TSP	-0.03 FL
83	22	06/95 RFO	Bobbin	NQI		0.41	10TH TSP	+11.48 FL
83	26	06/95 RFO	Bobbin	ODI	8	0.72	10TH TSP	+0.60 FL
		06/95 RFO	Bobbin	ODI	32	0.84	10TH TSP	+0.30 FL
83	28	06/95 RFO	Bobbin	NQI		0.43	10TH TSP	+16.37 FL
83	30	06/95 RFO	Bobbin	ODI	19	0.41	10TH TSP	+12.84 FL
83	31	06/95 RFO	Bobbin	NQI		0.50	9TH TSP	+0.62 FL
83	34	06/95 RFO	Bobbin	ODI	12	0.71	10TH TSP	+0.60 FL
83	37	06/95 RFO	Bobbin	ODI	12	0.23	10TH TSP	+0.39 FL
83	51	06/95 RFO	Bobbin	NQI		0.59	9TH TSP	+11.67 FL
83	59	06/95 RFO	Bobbin	ODI	55	0.36	9TH TSP	+4.65 FL
		06/95 RFO	Bobbin	ODI	42	0.34	12TH TSP	+18.89 FL
83	80	06/95 RFO	Bobbin	ODI	73	0.44	5TH TSP	+28.91 FL
83	84	06/95 RFO	Bobbin	ODI	53	0.49	13TH TSP	+13.99 FL
83	104	06/95 RFO	Bobbin	ODI	20	0.51	10TH TSP	+5.35 FL
83	111	06/95 RFO	Bobbin	NQI		0.31	15TH TSP	+10.63 FL
83	118	06/95 RFO	Bobbin	ODI	60	0.63	2ND TSP	+5.59 FL

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 20 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
83	119	06/95 RFO	Bobbin	NQI		0.97	3RD TSP	+24.67
		06/95 RFO	Bobbin	ODI	3	0.90	14TH TSP	+0.77
83	132	06/95 RFO	Bobbin	NQI		0.37	15TH TSP	+18.47
		06/95 RFO	Bobbin	NQI		0.56	15TH TSP	+27.08
		06/95 RFO	Bobbin	NQI		0.58	15TH TSP	+26.87
		06/95 RFO	Bobbin	NQI		0.61	15TH TSP	+12.99
		06/95 RFO	Bobbin	NQI		0.78	15TH TSP	+18.70
		06/95 RFO	Bobbin	NQI		1.37	15TH TSP	+17.93
84	2	06/95 RFO	Bobbin	NQI		0.54	10TH TSP	-0.26
84	3	06/95 RFO	Bobbin	NQI		0.45	10TH TSP	+8.22
		06/95 RFO	Bobbin	NQI		0.90	10TH TSP	+0.47
84	6	06/95 RFO	Bobbin	ODI	18	1.20	10TH TSP	+3.65
84	9	06/95 RFO	Bobbin	ODI	8	0.76	10TH TSP	+0.46
84	19	06/95 RFO	Bobbin	NQI		0.35	11TH TSP	+0.66
84	26	06/95 RFO	Bobbin	NQI		0.68	10TH TSP	+0.45
84	28	06/95 RFO	Bobbin	NQI		0.45	10TH TSP	+0.43
84	30	06/95 RFO	Bobbin	NQI		0.62	8TH TSP	+20.30
84	31	06/95 RFO	Bobbin	NQI		0.60	4TH TSP	-0.81
84	32	06/95 RFO	Bobbin	NQI		0.57	8TH TSP	+16.75
84	35	06/95 RFO	Bobbin	NQI		0.40	8TH TSP	+15.22
84	54	06/95 RFO	Bobbin	ODI	1	2.04	15TH TSP	+11.95
84	55	06/95 RFO	Bobbin	NQI		0.96	5TH TSP	+0.63
84	90	06/95 RFO	Bobbin	ODI	13	0.48	12TH TSP	+23.42
84	95	06/95 RFO	Bobbin	ODI	51	0.44	1ST TSP	+23.86
84	102	06/95 RFO	Bobbin	ODI	47	0.35	4TH TSP	+26.45
84	114	06/95 RFO	Bobbin	ADI		0.93	LTSP	+21.80 to +29.93
84	115	06/95 RFO	Bobbin	ODI	20	0.50	7TH TSP	+25.23
84	117	06/95 RFO	Bobbin	ODI	31	0.67	6TH TSP	+33.93
84	118	06/95 RFO	Bobbin	ODI	30	1.35	14TH TSP	+0.72
84	125	06/95 RFO	Bobbin	NQI		0.99	14TH TSP	+1.11
84	126	06/95 RFO	Bobbin	ODI	63	21.44	14TH TSP	+0.62
84	130	06/95 RFO	Bobbin	ODI	3	0.70	11TH TSP	+1.11
85	4	06/95 RFO	Bobbin	NQI		0.46	8TH TSP	+11.21
		06/95 RFO	Bobbin	NQI		0.64	14TH TSP	+26.96
		06/95 RFO	Bobbin	ODI	5	1.44	10TH TSP	+1.76
85	9	06/95 RFO	Bobbin	NQI		0.64	9TH TSP	-0.66
85	13	06/95 RFO	Bobbin	NQI		0.38	3RD TSP	+10.56
85	22	06/95 RFO	Bobbin	ODI	31	0.42	11TH TSP	+5.54
85	26	06/95 RFO	Bobbin	ODI	27	0.67	10TH TSP	+0.63
85	34	06/95 RFO	Bobbin	ODI	20	0.43	9TH TSP	-0.73
85	36	06/95 RFO	Bobbin	NQI		0.46	9TH TSP	-0.74
85	42	06/95 RFO	Bobbin	NQI		0.63	8TH TSP	-0.74
		06/95 RFO	Bobbin	NQI		0.92	9TH TSP	-0.74
85	44	06/95 RFO	Bobbin	NQI		0.62	8TH TSP	-0.70
85	51	06/95 RFO	Bobbin	ODI	35	0.42	10TH TSP	+9.06
85	53	06/95 RFO	Bobbin	ADI		0.73	6TH TSP	+6.22
		06/95 RFO	Bobbin	ADI		1.70	LTSP	+22.17 to +28.90
85	55	06/95 RFO	Bobbin	ADI		9.71	LTSP	+22.34 to +26.41
85	56	06/95 RFO	Bobbin	ODI	22	0.21	15TH TSP	+0.11
85	62	06/95 RFO	Bobbin	NQI		0.29	LTSP	+19.08
85	91	06/95 RFO	Bobbin	NQI		0.46	12TH TSP	+18.56
85	94	06/95 RFO	Bobbin	ODI	6	0.33	6TH TSP	+23.60
85	95	06/95 RFO	Bobbin	ODI	30	0.50	7TH TSP	+8.78
85	118	06/95 RFO	Bobbin	ODI	37	0.88	2ND TSP	+32.81
85	123	06/95 RFO	Bobbin	ODI	6	4.10	14TH TSP	+1.10
		06/95 RFO	Bobbin	ODI	48	0.83	15TH TSP	+2.45
85	127	06/95 RFO	Bobbin	ODI	57	2.59	14TH TSP	+0.67
85	130	06/95 RFO	Bobbin	NQI		0.55	9TH TSP	+0.00
86	3	06/95 RFO	Bobbin	NQI		0.32	12TH TSP	+32.66
86	7	06/95 RFO	Bobbin	ODI	24	0.54	11TH TSP	+0.57
86	11	06/95 RFO	Bobbin	NQI		0.97	10TH TSP	-0.59
86	25	06/95 RFO	Bobbin	ODI	12	0.34	10TH TSP	-0.05
86	26	06/95 RFO	Bobbin	NQI		0.70	14TH TSP	+27.85
86	28	06/95 RFO	Bobbin	NQI		0.24	9TH TSP	-0.48
86	34	06/95 RFO	Bobbin	NQI		0.94	9TH TSP	-0.72

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 21 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
86	51	06/95 RFO	Bobbin	ODI	15	0.39	8TH TSP	+35.81 FL
86	55	06/95 RFO	Bobbin	NQI		0.87	5TH TSP	-0.77 FL
86	67	06/95 RFO	Bobbin	NQI		0.39	4TH TSP	-0.76 FL
		06/95 RFO	Bobbin	NQI		0.48	4TH TSP	-0.78 FL
86	79	06/95 RFO	Bobbin	ODI	4	0.57	5TH TSP	+27.82 FL
86	87	06/95 RFO	Bobbin	ODI	64	0.40	9TH TSP	+26.89 FL
86	103	06/95 RFO	Bobbin	ODI	25	0.66	15TH TSP	+30.91 FL
86	105	06/95 RFO	Bobbin	NQI		0.36	1ST TSP	+27.92 FL
86	131	06/95 RFO	Bobbin	ODI	19	0.36	13TH TSP	+1.43 FL
87	13	06/95 RFO	Bobbin	ODI	4	1.32	LTSF	+24.37 FL
		06/95 RFO	Bobbin	ODI	25	0.42	10TH TSP	-0.41 FL
87	19	06/95 RFO	Bobbin	NQI		0.39	LTSF	+26.21 FL
87	54	06/95 RFO	Bobbin	NQI		0.42	5TH TSP	+0.67 FL
		06/95 RFO	Bobbin	ODI	7	0.46	5TH TSP	+26.44 FL
87	122	06/95 RFO	Bobbin	NQI		0.61	2ND TSP	+0.68 FL
87	125	06/95 RFO	Bobbin	ODI	4	0.57	14TH TSP	+1.02 FL
87	126	06/95 RFO	Bobbin	ODI	21	1.34	14TH TSP	+1.73 FL
87	130	06/95 RFO	Bobbin	ADI		3.63	12TH TSP	+15.21 FL
88	1	06/95 RFO	Bobbin	ODI	12	0.54	14TH TSP	+31.82 FL
		06/95 RFO	Bobbin	ODI	26	0.27	10TH TSP	+26.05 FL
88	2	06/95 RFO	Bobbin	NQI		0.70	10TH TSP	+0.64 FL
		06/95 RFO	Bobbin	ODI	22	1.73	10TH TSP	+5.48 FL
88	3	06/95 RFO	Bobbin	ADI		2.59	10TH TSP	+3.42 FL
		06/95 RFO	Bobbin	NQI		0.79	12TH TSP	-0.76 FL
		06/95 RFO	Bobbin	ODI	32	0.79	11TH TSP	+0.69 FL
88	5	06/95 RFO	Bobbin	NQI		0.46	10TH TSP	+24.88 FL
88	9	06/95 RFO	Bobbin	ODI	39	1.18	12TH TSP	+31.55 FL
88	66	06/95 RFO	Bobbin	NQI		0.33	5TH TSP	+31.70 FL
		06/95 RFO	Bobbin	NQI		0.42	5TH TSP	+31.63 FL
88	69	06/95 RFO	Bobbin	IDI	35	2.16	13TH TSP	+32.36 FL
88	107	06/95 RFO	Bobbin	ODI	60	0.51	13TH TSP	+5.45 FL
88	122	06/95 RFO	Bobbin	NQI		0.57	15TH TSP	+0.51 FL
88	127	06/95 RFO	Bobbin	NQI		1.34	14TH TSP	+1.32 FL
88	129	06/95 RFO	Bobbin	NQI		0.54	8TH TSP	+0.52 FL
89	4	06/95 RFO	Bobbin	NQI		0.77	9TH TSP	+21.00 FL
89	8	06/95 RFO	Bobbin	ODI	35	1.23	14TH TSP	+0.77 FL
89	17	06/95 RFO	Bobbin	ODI	15	0.65	9TH TSP	-0.79 FL
89	61	06/95 RFO	Bobbin	NQI		0.36	6TH TSP	+30.52 FL
89	78	06/95 RFO	Bobbin	NQI		0.27	15TH TSP	+31.23 FL
		06/95 RFO	Bobbin	NQI		0.42	15TH TSP	+32.50 FL
		06/95 RFO	Bobbin	ODI	33	0.44	15TH TSP	+30.48 FL
89	82	06/95 RFO	Bobbin	ODI	35	0.38	10TH TSP	+15.32 FL
89	90	06/95 RFO	Bobbin	NQI		0.59	6TH TSP	+20.33 FL
89	100	06/95 RFO	Bobbin	ODI	44	0.31	14TH TSP	+26.27 FL
89	105	06/95 RFO	Bobbin	NQI		0.42	1ST TSP	+5.22 FL
89	111	06/95 RFO	Bobbin	ADI		2.15	LTSF	+22.04 to +29.72 FL
89	117	06/95 RFO	Bobbin	ODI	58	0.59	7TH TSP	+27.27 FL
		06/95 RFO	Bobbin	ODI	20	0.67	14TH TSP	+1.09 FL
		06/95 RFO	Bobbin	ODI	24	0.38	15TH TSP	+22.53 FL
89	127	06/95 RFO	Bobbin	NQI		0.52	9TH TSP	+7.56 FL
89	130	06/95 RFO	Bobbin	ODI	9	0.66	8TH TSP	+0.49 FL
90	6	06/95 RFO	Bobbin	NQI		0.58	9TH TSP	-0.65 FL
90	18	06/95 RFO	Bobbin	ADI		2.17	LTSF	+21.14 to +30.10 FL
90	19	06/95 RFO	Bobbin	ODI	38	0.48	6TH TSP	-0.64 FL
90	20	06/95 RFO	Bobbin	NQI		0.93	2ND TSP	+16.57 FL
90	33	06/95 RFO	Bobbin	NQI		0.36	LTSF	+6.04 FL
90	43	06/95 RFO	Bobbin	NQI		2.19	15TH TSP	+0.70 FL
90	55	06/95 RFO	Bobbin	ODI	54	0.44	1ST TSP	+19.08 FL
		06/95 RFO	Bobbin	ODI	45	0.37	14TH TSP	+12.03 FL
90	57	06/95 RFO	Bobbin	NQI		0.22	8TH TSP	+24.96 FL
		06/95 RFO	Bobbin	ODI	26	0.42	8TH TSP	+24.76 FL
		06/95 RFO	Bobbin	ODI	31	0.34	11TH TSP	+14.79 FL
90	102	06/95 RFO	Bobbin	ODI	41	0.53	15TH TSP	+39.90 FL
90	115	06/95 RFO	Bobbin	ODI	26	1.74	14TH TSP	+1.10 FL
91	1	06/95 RFO	Bobbin	NQI		1.91	15TH TSP	-1.35 FL

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		06/95 RFO	Bobbin	ODI	33	0.55	15TH TSP	+3.30
91	2	06/95 RFO	Bobbin	NQI		2.05	11TH TSP	+0.59
91	17	06/95 RFO	Bobbin	ODI	9	0.93	15TH TSP	+0.53
91	19	06/95 RFO	Bobbin	ODI	50	0.49	12TH TSP	+25.80
91	52	06/95 RFO	Bobbin	NQI		0.27	6TH TSP	+33.25
91	83	06/95 RFO	Bobbin	NQI		0.60	8TH TSP	+9.01 to +14.47
		06/95 RFO	Bobbin	NQI		0.84	7TH TSP	+5.33 to +12.21
91	84	06/95 RFO	Bobbin	ODI	35	0.44	2ND TSP	+33.25
91	119	06/95 RFO	Bobbin	ODI	19	1.52	15TH TSP	-0.68
91	124	06/95 RFO	Bobbin	ODI	38	3.20	14TH TSP	+1.05
91	125	06/95 RFO	Bobbin	NQI		0.69	9TH TSP	+0.51
		06/95 RFO	Bobbin	ODI	9	0.83	14TH TSP	+2.24
		06/95 RFO	Bobbin	ODI	23	0.73	14TH TSP	+2.44
92	50	06/95 RFO	Bobbin	ODI	23	0.49	6TH TSP	-1.76
92	56	06/95 RFO	Bobbin	ODI	28	0.33	2ND TSP	+29.59
92	58	06/95 RFO	Bobbin	NQI		0.18	10TH TSP	-0.33
92	61	06/95 RFO	Bobbin	ODI	24	0.48	6TH TSP	+31.54
92	85	06/95 RFO	Bobbin	ODI	18	0.53	12TH TSP	+9.44
		06/95 RFO	Bobbin	NQI		0.50	11TH TSP	+18.05 to +19.54
		06/95 RFO	Bobbin	NQI		0.67	10TH TSP	+21.14 to +34.22
92	109	06/95 RFO	Bobbin	NQI		0.63	12TH TSP	+30.90
92	127	06/95 RFO	Bobbin	NQI		1.39	14TH TSP	+0.76
92	128	06/95 RFO	Bobbin	ODI	18	2.28	14TH TSP	+0.61
93	1	06/95 RFO	Bobbin	NQI		0.40	10TH TSP	+0.44
		06/95 RFO	Bobbin	NQI		0.78	15TH TSP	-0.38
93	11	06/95 RFO	Bobbin	NQI		0.42	1ST TSP	+27.59
93	12	06/95 RFO	Bobbin	ODI	22	0.79	3RD TSP	+8.58
93	16	06/95 RFO	Bobbin	ADI		18.64	LTSF	+21.44 to +29.44
93	35	06/95 RFO	Bobbin	ODI	23	0.29	11TH TSP	+28.51
93	81	06/95 RFO	Bobbin	NQI		0.33	1ST TSP	+16.86
		06/95 RFO	Bobbin	NQI		0.39	10TH TSP	+11.06
93	82	06/95 RFO	Bobbin	NQI		0.46	8TH TSP	+32.55
		06/95 RFO	Bobbin	ODI	14	0.73	6TH TSP	+21.67
		06/95 RFO	Bobbin	ODI	20	0.35	9TH TSP	+12.86
		06/95 RFO	Bobbin	ODI	23	0.32	9TH TSP	+2.73
		06/95 RFO	Bobbin	NQI		0.59	7TH TSP	+1.59 to +11.48
		06/95 RFO	Bobbin	NQI		0.32	12TH TSP	+1.07 to +9.78
		06/95 RFO	Bobbin	NQI		0.50	11TH TSP	+1.42 to +23.76
		06/95 RFO	Bobbin	NQI		0.72	10TH TSP	+18.73 to +29.91
93	86	06/95 RFO	Bobbin	ODI	65	1.12	4TH TSP	+9.03
93	93	06/95 RFO	Bobbin	NQI		0.35	7TH TSP	+32.41
		06/95 RFO	Bobbin	NQI		0.46	9TH TSP	+18.17
		06/95 RFO	Bobbin	NQI		0.57	9TH TSP	+19.50
		06/95 RFO	Bobbin	ODI	6	0.35	7TH TSP	+37.10
		06/95 RFO	Bobbin	ODI	23	0.24	9TH TSP	+2.88
		06/95 RFO	Bobbin	NQI		0.43	8TH TSP	+27.93 to +34.92
93	113	06/95 RFO	Bobbin	NQI		0.39	3RD TSP	+26.43
93	123	06/95 RFO	Bobbin	NQI		1.25	9TH TSP	+0.60
		06/95 RFO	Bobbin	NQI		1.38	11TH TSP	-0.79
		06/95 RFO	Bobbin	ODI	30	2.69	9TH TSP	+1.05
93	124	06/95 RFO	Bobbin	NQI		0.29	13TH TSP	+1.32
94	2	06/95 RFO	Bobbin	ODI	27	1.31	11TH TSP	+0.74
94	17	06/95 RFO	Bobbin	ODI	7	1.52	LTSF	+21.68
94	25	06/95 RFO	Bobbin	ODI	41	1.07	14TH TSP	+0.98
94	26	06/95 RFO	Bobbin	ODI	32	1.08	14TH TSP	+0.72
94	59	06/95 RFO	Bobbin	ODI	3	0.63	8TH TSP	+8.30
94	84	06/95 RFO	Bobbin	NQI		0.80	9TH TSP	+34.85
		06/95 RFO	Bobbin	NQI		0.45	10TH TSP	+22.49
		06/95 RFO	Bobbin	NQI		0.63	10TH TSP	+12.52
94	85	06/95 RFO	Bobbin	ODI	14	0.42	11TH TSP	+4.77
94	122	06/95 RFO	Bobbin	ODI	32	0.60	14TH TSP	+1.25
94	124	06/95 RFO	Bobbin	NQI		0.47	1ST TSP	+10.12
		06/95 RFO	Bobbin	NQI		0.78	8TH TSP	+18.70
94	127	06/95 RFO	Bobbin	ODI	9	0.44	9TH TSP	+1.58
95	56	06/95 RFO	Bobbin	ADI		1.72	LTSF	+29.70

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 23 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN
 QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
95	66	06/95 RFO	Bobbin	NQI		0.45	6TH TSP	+25.49
		06/95 RFO	Bobbin	NQI		0.49	6TH TSP	+25.69
95	78	06/95 RFO	Bobbin	ODI	7	0.39	15TH TSP	+22.90
95	102	06/95 RFO	Bobbin	NQI		0.38	LTSF	+31.35
95	112	06/95 RFO	Bobbin	NQI		0.77	11TH TSP	+32.12
95	117	06/95 RFO	Bobbin	NQI		0.85	14TH TSP	+10.12
96	4	06/95 RFO	Bobbin	ODI	18	0.62	4TH TSP	-0.79
96	25	06/95 RFO	Bobbin	ODI	25	0.36	14TH TSP	+4.21
96	48	06/95 RFO	Bobbin	ODI	22	0.44	10TH TSP	+5.47
96	61	06/95 RFO	Bobbin	ODI	58	0.40	6TH TSP	+31.70
96	63	06/95 RFO	Bobbin	ODI	23	0.46	14TH TSP	+10.40
97	2	06/95 RFO	Bobbin	NQI		0.85	6TH TSP	+0.89
		06/95 RFO	Bobbin	NQI		0.82	10TH TSP	+0.54
97	14	06/95 RFO	Bobbin	ODI	8	22.67	13TH TSP	+18.74
		06/95 RFO	Bobbin	ODI	11	1.20	15TH TSP	+8.58
97	31	06/95 RFO	Bobbin	ODI	29	0.44	14TH TSP	+10.08
97	76	06/95 RFO	Bobbin	NQI		0.59	LTSF	+5.85
97	106	06/95 RFO	Bobbin	NQI		1.60	15TH TSP	+39.59
98	3	06/95 RFO	Bobbin	ODI	20	0.52	9TH TSP	+16.18
		06/95 RFO	Bobbin	ODI	24	0.80	10TH TSP	+0.60
98	4	06/95 RFO	Bobbin	ODI	22	0.33	10TH TSP	+4.89
98	11	06/95 RFO	Bobbin	ODI	18	0.52	LTSF	+26.16
		06/95 RFO	Bobbin	ODI	46	0.52	15TH TSP	+30.42
98	77	06/95 RFO	Bobbin	NQI		0.43	5TH TSP	+29.92
98	85	06/95 RFO	Bobbin	ADI		0.97	LTSF	+22.54
98	91	06/95 RFO	Bobbin	NQI		0.78	13TH TSP	+24.59
98	122	06/95 RFO	Bobbin	NQI		0.68	14TH TSP	+1.21
98	126	06/95 RFO	Bobbin	NQI		3.02	LTSF	+0.92
98	127	06/95 RFO	Bobbin	NQI		1.04	LTSF	+0.90
99	2	06/95 RFO	Bobbin	NQI		1.22	LTPF	+19.62
		06/95 RFO	Bobbin	ODI	10	0.64	10TH TSP	+0.54
99	3	06/95 RFO	Bobbin	NQI		0.59	10TH TSP	+0.64
		06/95 RFO	Bobbin	ODI	36	0.89	9TH TSP	+13.11
99	11	06/95 RFO	Bobbin	ODI	35	0.63	LTSF	+40.39
99	14	06/95 RFO	Bobbin	NQI		1.98	14TH TSP	+0.64
99	44	06/95 RFO	Bobbin	NQI		0.46	14TH TSP	+18.06
99	49	06/95 RFO	Bobbin	ODI	30	0.38	3RD TSP	+20.54
99	53	06/95 RFO	Bobbin	ODI	28	0.78	14TH TSP	-0.18
99	55	06/95 RFO	Bobbin	ADI		12.02	LTSF	+21.89 to +29.54
99	56	06/95 RFO	Bobbin	ODI	20	0.49	10TH TSP	+32.19
99	97	06/95 RFO	Bobbin	NQI		0.59	LTSF	+33.02
100	7	06/95 RFO	Bobbin	NQI		0.44	10TH TSP	+4.62
100	50	06/95 RFO	Bobbin	ODI	10	0.41	2ND TSP	+33.60
		06/95 RFO	Bobbin	ODI	25	0.29	11TH TSP	+23.17
100	51	06/95 RFO	Bobbin	ODI	1	2.12	LTSF	+24.25
100	65	06/95 RFO	Bobbin	NQI		0.49	7TH TSP	+32.13
		06/95 RFO	Bobbin	NQI		0.72	7TH TSP	+32.25
100	72	06/95 RFO	Bobbin	NQI		0.66	4TH TSP	-0.36
100	90	06/95 RFO	Bobbin	ODI	57	0.45	LTSF	+23.80
100	121	06/95 RFO	Bobbin	NQI		0.42	13TH TSP	+12.28
100	124	06/95 RFO	Bobbin	NQI		0.42	10TH TSP	-0.60
101	6	06/95 RFO	Bobbin	NQI		0.42	8TH TSP	+22.56
101	16	06/95 RFO	Bobbin	ODI	8	0.51	9TH TSP	+20.09
101	21	06/95 RFO	Bobbin	ADI		8.57	LTSF	+22.02 to +29.87
101	25	06/95 RFO	Bobbin	ODI	38	0.38	8TH TSP	+19.61
101	33	06/95 RFO	Bobbin	NQI		0.46	12TH TSP	+1.43
101	37	06/95 RFO	Bobbin	ODI	36	0.48	LTSF	+27.54
101	92	06/95 RFO	Bobbin	ODI	14	0.61	LTSF	+23.24
		06/95 RFO	Bobbin	ODI	9	2.73	2ND TSP	+5.60
101	121	06/95 RFO	Bobbin	ODI	25	0.46	8TH TSP	-0.70
102	2	06/95 RFO	Bobbin	NQI		0.86	10TH TSP	+0.56
102	7	06/95 RFO	Bobbin	NQI		0.35	9TH TSP	-0.94
102	8	06/95 RFO	Bobbin	ODI	22	0.80	13TH TSP	+1.09
102	14	06/95 RFO	Bobbin	NQI		0.33	14TH TSP	+8.93
		06/95 RFO	Bobbin	NQI		0.43	14TH TSP	+20.94

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 24 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		06/95 RFO	Bobbin	ODI	10	0.34	13TH TSP	+10.30
		06/95 RFO	Bobbin	ODI	19	0.34	13TH TSP	+19.20
		06/95 RFO	Bobbin	ODI	24	0.37	12TH TSP	+28.30
102	25	06/95 RFO	Bobbin	ODI	14	0.40	14TH TSP	+0.86
102	85	06/95 RFO	Bobbin	NQI		0.43	3RD TSP	+29.65
102	87	06/95 RFO	Bobbin	NQI		0.46	4TH TSP	+13.52
102	99	06/95 RFO	Bobbin	ODI	43	0.75	3RD TSP	+7.11
102	105	06/95 RFO	Bobbin	NQI		0.85	4TH TSP	+26.90
102	109	06/95 RFO	Bobbin	NQI		0.70	LTSF	+19.76
		06/95 RFO	Bobbin	ODI	21	0.58	12TH TSP	+4.93
103	2	06/95 RFO	Bobbin	NQI		0.59	10TH TSP	+0.55
103	3	06/95 RFO	Bobbin	ODI	18	1.84	10TH TSP	+0.61
103	13	06/95 RFO	Bobbin	ODI	16	1.93	LTSF	+23.96
		06/95 RFO	Bobbin	NQI		0.28	8TH TSP	-0.83
		06/95 RFO	Bobbin	ADI		2.82	LTSF	+21.69 to +29.46
103	36	06/95 RFO	Bobbin	ODI	27	32.29	LTSF	+22.93 to +29.81
103	51	06/95 RFO	Bobbin	ODI	3	1.94	LTSF	+24.47
		06/95 RFO	Bobbin	ODI	27	0.63	LTSF	+24.13
		06/95 RFO	Bobbin	NQI		0.36	8TH TSP	+35.28
		06/95 RFO	Bobbin	NQI		0.40	8TH TSP	+23.76
103	53	06/95 RFO	Bobbin	ODI	19	0.49	LTSF	+10.15
103	72	06/95 RFO	Bobbin	ODI	30	0.51	4TH TSP	+9.54
103	82	06/95 RFO	Bobbin	NQI		0.27	11TH TSP	+3.98
103	104	06/95 RFO	Bobbin	NQI		0.62	2ND TSP	+34.38
103	115	06/95 RFO	Bobbin	NQI		0.46	15TH TSP	+42.41
104	3	06/95 RFO	Bobbin	ODI	27	0.25	10TH TSP	+13.48
104	20	06/95 RFO	Bobbin	NQI		0.46	2ND TSP	+15.18
104	78	06/95 RFO	Bobbin	NQI		0.40	2ND TSP	+31.74
104	86	06/95 RFO	Bobbin	NQI		0.36	15TH TSP	+7.14
104	102	06/95 RFO	Bobbin	NQI		0.43	12TH TSP	+20.77
104	112	06/95 RFO	Bobbin	NQI		0.35	15TH TSP	+0.00
104	120	06/95 RFO	Bobbin	ODI	29	0.61	9TH TSP	-0.70
104	122	06/95 RFO	Bobbin	NQI		0.78	10TH TSP	-0.60
105	17	06/95 RFO	Bobbin	ODI	14	6.25	LTSF	+24.56
		06/95 RFO	Bobbin	ADI		4.80	LTSF	+21.80 to +29.91
105	35	06/95 RFO	Bobbin	ODI	19	0.41	9TH TSP	+5.91
105	100	06/95 RFO	Bobbin	NQI		0.46	6TH TSP	+27.54
105	103	06/95 RFO	Bobbin	NQI		0.55	15TH TSP	+36.63
105	105	06/95 RFO	Bobbin	ODI	7	0.65	15TH TSP	+15.21
106	61	06/95 RFO	Bobbin	NQI		0.40	2ND TSP	+37.41
		06/95 RFO	Bobbin	ODI	21	0.54	2ND TSP	+37.31
106	113	06/95 RFO	Bobbin	NQI		0.31	3RD TSP	-0.07
107	19	06/95 RFO	Bobbin	NQI		0.54	4TH TSP	+16.57
107	46	06/95 RFO	Bobbin	ODI	30	0.47	13TH TSP	+3.69
107	48	06/95 RFO	Bobbin	NQI		0.52	6TH TSP	+32.83
107	55	06/95 RFO	Bobbin	ODI	6	0.35	5TH TSP	+26.36
107	58	06/95 RFO	Bobbin	NQI		2.44	LTSF	+4.12
107	61	06/95 RFO	Bobbin	NQI		1.12	4TH TSP	+6.43
		06/95 RFO	Bobbin	ODI	8	0.93	4TH TSP	+6.24
107	104	06/95 RFO	Bobbin	ODI	33	0.31	9TH TSP	+3.99
107	118	06/95 RFO	Bobbin	NQI		0.49	9TH TSP	-0.58
107	120	06/95 RFO	Bobbin	ODI	17	0.44	2ND TSP	+10.65
108	2	06/95 RFO	Bobbin	NQI		0.20	2ND TSP	+0.91
108	4	06/95 RFO	Bobbin	WAR	3	0.81	9TH TSP	+0.00
108	12	06/95 RFO	Bobbin	NQI		0.32	LTSF	+29.28
108	15	06/95 RFO	Bobbin	ODI	6	0.21	15TH TSP	+14.14
		06/95 RFO	Bobbin	ODI	19	0.45	15TH TSP	+14.34
108	41	06/95 RFO	Bobbin	NQI		0.48	12TH TSP	+8.64
108	42	06/95 RFO	Bobbin	NQI		0.81	13TH TSP	-0.09
108	88	06/95 RFO	Bobbin	NQI		0.33	6TH TSP	+7.63
108	93	06/95 RFO	Bobbin	NQI		0.77	2ND TSP	+31.89
		06/95 RFO	Bobbin	NQI		0.37	12TH TSP	+35.66
		06/95 RFO	Bobbin	NQI		0.55	14TH TSP	+13.71
		06/95 RFO	Bobbin	NQI		0.57	14TH TSP	+13.87
108	100	06/95 RFO	Bobbin	NQI		0.38	10TH TSP	-0.22

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 25 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
108	108	06/95 RFO	Bobbin	NQI		0.39	13TH TSP	+15.19
109	2	06/95 RFO	Bobbin	ODI	45	0.50	1ST TSP	+6.74
109	9	06/95 RFO	Bobbin	NQI		0.96	LTPF	+17.93
109	11	06/95 RFO	Bobbin	ODI	39	0.48	15TH TSP	+39.37
109	13	06/95 RFO	Bobbin	ODI	29	0.44	15TH TSP	+27.84
		06/95 RFO	Bobbin	ODI	65	0.34	12TH TSP	+5.17
109	30	06/95 RFO	Bobbin	ODI	15	1.50	12TH TSP	+22.28
109	49	06/95 RFO	Bobbin	ADI		5.29	LTSP	+22.22 to +29.95
109	60	06/95 RFO	Bobbin	NQI		0.56	2ND TSP	+28.74
109	76	06/95 RFO	Bobbin	NQI		0.46	8TH TSP	+36.22
109	88	06/95 RFO	Bobbin	ODI	11	0.76	2ND TSP	+13.39
109	93	06/95 RFO	Bobbin	ADI		0.66	1ST TSP	+12.61 to +20.74
109	105	06/95 RFO	Bobbin	ODI	42	0.76	14TH TSP	+0.53
109	110	06/95 RFO	Bobbin	ODI	22	0.30	10TH TSP	+18.45
110	44	06/95 RFO	Bobbin	ODI	4	0.47	6TH TSP	+26.45
110	49	06/95 RFO	Bobbin	NQI		0.29	13TH TSP	+0.09
		06/95 RFO	Bobbin	ODI	8	0.40	14TH TSP	+13.23
		06/95 RFO	Bobbin	ODI	18	0.47	12TH TSP	+21.54
		06/95 RFO	Bobbin	ODI	20	0.46	11TH TSP	+30.65
		06/95 RFO	Bobbin	ODI	25	0.35	13TH TSP	+1.25
		06/95 RFO	Bobbin	ODI	36	0.41	13TH TSP	+12.39
110	50	06/95 RFO	Bobbin	ODI	6	0.47	3RD TSP	+27.98
110	58	06/95 RFO	Bobbin	NQI		0.50	7TH TSP	+8.33
110	63	06/95 RFO	Bobbin	NQI		0.48	6TH TSP	+26.49
110	71	06/95 RFO	Bobbin	NQI		0.48	2ND TSP	+6.11
110	92	06/95 RFO	Bobbin	ODI	56	0.46	3RD TSP	+24.11
110	97	06/95 RFO	Bobbin	NQI		0.31	6TH TSP	+29.86
110	103	06/95 RFO	Bobbin	ODI	20	0.48	6TH TSP	+36.58
110	104	06/95 RFO	Bobbin	ODI	44	0.44	LTSP	+20.58
110	105	06/95 RFO	Bobbin	NQI		0.72	14TH TSP	+0.95
111	2	06/95 RFO	Bobbin	NQI		0.26	6TH TSP	+0.30
		06/95 RFO	Bobbin	NQI		0.33	11TH TSP	+10.33
111	5	06/95 RFO	Bobbin	NQI		0.58	12TH TSP	+8.17
111	11	06/95 RFO	Bobbin	NQI		0.34	2ND TSP	+14.07
111	39	06/95 RFO	Bobbin	ODI	14	0.41	7TH TSP	+7.31
111	40	06/95 RFO	Bobbin	NQI		0.48	3RD TSP	+27.31
111	46	06/95 RFO	Bobbin	ADI		4.50	LTSP	+22.06 to +29.51
111	72	06/95 RFO	Bobbin	ODI	57	0.57	1ST TSP	+27.17
111	111	06/95 RFO	Bobbin	ODI	36	1.78	12TH TSP	+1.00
112	1	06/95 RFO	Bobbin	WAR	33	0.78	8TH TSP	+0.00
		06/95 RFO	Bobbin	ODI	8	1.40	15TH TSP	+15.74
		06/95 RFO	Bobbin	ODI	18	0.62	11TH TSP	+0.89
112	2	06/95 RFO	Bobbin	ODI	16	0.35	2ND TSP	+33.71
112	14	06/95 RFO	Bobbin	ODI	47	0.80	11TH TSP	+12.82
		06/95 RFO	Bobbin	ODI	55	0.65	11TH TSP	+12.88
112	16	06/95 RFO	Bobbin	ODI	39	0.34	12TH TSP	+22.66
112	18	06/95 RFO	Bobbin	ODI	22	0.58	11TH TSP	+9.01
112	49	06/95 RFO	Bobbin	ODI	8	0.25	6TH TSP	+34.05
112	67	06/95 RFO	Bobbin	NQI		0.70	5TH TSP	+33.06
112	69	06/95 RFO	Bobbin	ODI	34	0.56	6TH TSP	+23.87
112	83	06/95 RFO	Bobbin	ODI	69	0.42	9TH TSP	+2.69
112	95	06/95 RFO	Bobbin	ODI	59	0.30	9TH TSP	+8.70
112	116	06/95 RFO	Bobbin	NQI		0.43	14TH TSP	-1.00
113	4	06/95 RFO	Bobbin	NQI		0.69	8TH TSP	+0.54
113	7	06/95 RFO	Bobbin	NQI		1.05	9TH TSP	-0.85
113	62	06/95 RFO	Bobbin	NQI		0.45	14TH TSP	+0.60
113	76	06/95 RFO	Bobbin	ODI	18	0.45	6TH TSP	+26.65
113	77	06/95 RFO	Bobbin	ODI	6	15.55	LTSP	+21.51
		06/95 RFO	Bobbin	ODI	18	2.56	LTSP	+26.32
		06/95 RFO	Bobbin	ODI	26	4.73	LTSP	+25.95
		06/95 RFO	Bobbin	ODI	63	0.66	15TH TSP	+29.58
113	91	06/95 RFO	Bobbin	ODI	52	0.43	LTSP	+0.84
113	93	06/95 RFO	Bobbin	ODI	7	0.39	12TH TSP	+19.22
113	95	06/95 RFO	Bobbin	ODI	32	0.60	9TH TSP	+1.99
113	111	06/95 RFO	Bobbin	NQI		0.38	12TH TSP	-0.55

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 26 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
113	112	06/95 RFO	Bobbin	NQI		0.53	12TH TSP	+1.06
114	1	06/95 RFO	Bobbin	ODI	16	0.47	15TH TSP	+14.77
114	4	06/95 RFO	Bobbin	ODI	5	0.48	8TH TSP	-0.11
		06/95 RFO	Bobbin	ODI	27	0.43	11TH TSP	+11.20
114	14	06/95 RFO	Bobbin	ODI	41	0.59	11TH TSP	+29.34
114	44	06/95 RFO	Bobbin	NQI		0.50	3RD TSP	+18.03
114	52	06/95 RFO	Bobbin	NQI		0.26	14TH TSP	+0.26
114	63	06/95 RFO	Bobbin	ODI	25	0.28	6TH TSP	+7.95
114	84	06/95 RFO	Bobbin	NQI		0.46	1ST TSP	+19.89
114	95	06/95 RFO	Bobbin	ODI	38	0.34	15TH TSP	+28.60
114	114	06/95 RFO	Bobbin	NQI		0.53	10TH TSP	+0.63
114	115	06/95 RFO	Bobbin	ODI	13	0.94	10TH TSP	+7.94
		06/95 RFO	Bobbin	ODI	19	0.45	15TH TSP	+21.39
115	3	06/95 RFO	Bobbin	NQI		0.71	LTPF	+8.64
115	13	06/95 RFO	Bobbin	NQI		0.23	14TH TSP	+0.13
115	40	06/95 RFO	Bobbin	ODI	21	0.48	6TH TSP	+19.25
115	60	06/95 RFO	Bobbin	NQI		0.91	2ND TSP	+32.80
		06/95 RFO	Bobbin	ODI	18	1.01	2ND TSP	+34.65
		06/95 RFO	Bobbin	ODI	69	1.37	2ND TSP	+34.12
		06/95 RFO	Bobbin	ODI	87	0.99	2ND TSP	+31.56
115	66	06/95 RFO	Bobbin	ODI	38	0.46	10TH TSP	+26.33
115	70	06/95 RFO	Bobbin	ODI	23	0.37	3RD TSP	+24.19
115	83	06/95 RFO	Bobbin	ODI	45	0.80	14TH TSP	+2.33
115	93	06/95 RFO	Bobbin	NQI		0.42	3RD TSP	+11.04
115	102	06/95 RFO	Bobbin	NQI		0.85	2ND TSP	+10.02
115	112	06/95 RFO	Bobbin	WAR	16	1.10	10TH TSP	+0.00
115	113	06/95 RFO	Bobbin	NQI		0.51	10TH TSP	+0.53
115	114	06/95 RFO	Bobbin	ODI	5	1.40	10TH TSP	+8.12
		06/95 RFO	Bobbin	ODI	13	0.84	10TH TSP	+8.86
		06/95 RFO	Bobbin	ODI	17	0.67	10TH TSP	+9.34
116	21	06/95 RFO	Bobbin	ODI	20	0.53	14TH TSP	+0.44
116	41	06/95 RFO	Bobbin	NQI		0.20	14TH TSP	-0.02
116	50	06/95 RFO	Bobbin	ADI		2.98	8TH TSP	+14.71
116	71	06/95 RFO	Bobbin	NQI		0.40	6TH TSP	+22.16
116	77	06/95 RFO	Bobbin	NQI		0.42	3RD TSP	+21.20
116	95	06/95 RFO	Bobbin	ODI	27	1.17	14TH TSP	+0.93
116	98	06/95 RFO	Bobbin	ODI	17	0.63	7TH TSP	+34.07
116	101	06/95 RFO	Bobbin	NQI		0.36	14TH TSP	+27.38
116	107	06/95 RFO	Bobbin	ODI	22	0.56	9TH TSP	-0.60
116	113	06/95 RFO	Bobbin	NQI		13.11	15TH TSP	+21.26
117	5	06/95 RFO	Bobbin	ODI	55	0.38	12TH TSP	+0.00
117	6	06/95 RFO	Bobbin	ODI	13	0.33	8TH TSP	+0.46
117	14	06/95 RFO	Bobbin	ADI		3.39	1ST TSP	+35.84
		06/95 RFO	Bobbin	ADI		0.72	LTSP	+21.59 to +29.30
117	22	06/95 RFO	Bobbin	NQI		0.44	6TH TSP	+36.38
117	89	06/95 RFO	Bobbin	ODI	15	0.54	15TH TSP	+0.48
117	90	06/95 RFO	Bobbin	NQI		1.26	15TH TSP	+0.72
117	107	06/95 RFO	Bobbin	ODI	22	0.45	10TH TSP	+19.55
118	3	06/95 RFO	Bobbin	ODI	4	0.52	9TH TSP	-0.82
118	17	06/95 RFO	Bobbin	NQI		0.38	7TH TSP	+20.92
118	21	06/95 RFO	Bobbin	ODI	34	0.51	10TH TSP	+14.16
118	56	06/95 RFO	Bobbin	NQI		0.61	11TH TSP	+5.93
		06/95 RFO	Bobbin	ODI	84	0.78	10TH TSP	-0.28
118	62	06/95 RFO	Bobbin	NQI		0.55	6TH TSP	+18.39
118	83	06/95 RFO	Bobbin	ODI	28	0.33	8TH TSP	+36.71
118	88	06/95 RFO	Bobbin	ODI	21	0.55	15TH TSP	+15.66
118	90	06/95 RFO	Bobbin	NQI		0.53	11TH TSP	+32.83
118	100	06/95 RFO	Bobbin	NQI		0.47	10TH TSP	+14.07
118	104	06/95 RFO	Bobbin	NQI		0.36	2ND TSP	+8.74
118	105	06/95 RFO	Bobbin	NQI		0.49	12TH TSP	+26.46
119	1	06/95 RFO	Bobbin	ODI	55	0.64	15TH TSP	+2.61
119	11	06/95 RFO	Bobbin	ADI		3.41	LTSP	+21.68 to +29.09
119	24	06/95 RFO	Bobbin	NQI		0.44	8TH TSP	+6.66
119	40	06/95 RFO	Bobbin	ODI	9	0.65	6TH TSP	+31.80
119	45	06/95 RFO	Bobbin	ODI	18	0.35	6TH TSP	+29.66

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 27 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
119	55	06/95 RFO	Bobbin	NQI		0.60	3RD TSP	+0.48
119	69	06/95 RFO	Bobbin	ADI		4.46	2ND TSP	+22.54
119	74	06/95 RFO	Bobbin	ODI	52	1.05	11TH TSP	+22.40
119	79	06/95 RFO	Bobbin	ODI	65	0.56	15TH TSP	+2.72
119	85	06/95 RFO	Bobbin	ODI	25	0.43	13TH TSP	+28.71
119	93	06/95 RFO	Bobbin	NQI		0.31	8TH TSP	+8.83
119	103	06/95 RFO	Bobbin	ODI	12	0.61	9TH TSP	+20.19
		06/95 RFO	Bobbin	ODI	14	0.34	9TH TSP	+19.54
		06/95 RFO	Bobbin	ODI	23	0.53	9TH TSP	+21.42
120	3	06/95 RFO	Bobbin	NQI		0.23	12TH TSP	+23.55
120	22	06/95 RFO	Bobbin	NQI		0.36	15TH TSP	+18.32
120	55	06/95 RFO	Bobbin	NQI		0.45	11TH TSP	+2.49
		06/95 RFO	Bobbin	ODI	22	0.31	12TH TSP	+5.41
120	69	06/95 RFO	Bobbin	NQI		0.54	3RD TSP	+35.99
120	101	06/95 RFO	Bobbin	NQI		0.87	3RD TSP	+14.28
121	2	06/95 RFO	Bobbin	NQI		0.49	14TH TSP	+4.08
121	42	06/95 RFO	Bobbin	ODI	37	0.48	7TH TSP	+34.92
121	45	06/95 RFO	Bobbin	NQI		0.25	14TH TSP	+0.19
121	50	06/95 RFO	Bobbin	NQI		0.34	2ND TSP	+10.03
121	66	06/95 RFO	Bobbin	ODI	39	0.37	9TH TSP	+6.31
121	76	06/95 RFO	Bobbin	ADI		14.11	LTSP	+21.65 to +29.27
121	79	06/95 RFO	Bobbin	ODI	18	0.41	6TH TSP	+36.34
121	100	06/95 RFO	Bobbin	NQI		0.57	8TH TSP	+18.85
121	104	06/95 RFO	Bobbin	NQI		0.31	12TH TSP	+19.52
		06/95 RFO	Bobbin	NQI		0.39	10TH TSP	+17.58
		06/95 RFO	Bobbin	NQI		0.41	10TH TSP	+29.68
		06/95 RFO	Bobbin	NQI		0.57	11TH TSP	+32.18
		06/95 RFO	Bobbin	NQI		0.63	10TH TSP	+19.13
		06/95 RFO	Bobbin	NQI		0.67	10TH TSP	+5.35
		06/95 RFO	Bobbin	NQI		0.69	10TH TSP	+16.22
		06/95 RFO	Bobbin	NQI		0.75	10TH TSP	+5.54
		06/95 RFO	Bobbin	ODI	14	0.54	10TH TSP	+22.49
		06/95 RFO	Bobbin	ODI	17	0.59	10TH TSP	+8.52
		06/95 RFO	Bobbin	ODI	21	0.57	10TH TSP	+21.67
		06/95 RFO	Bobbin	ODI	44	1.08	11TH TSP	+31.87
121	106	06/95 RFO	Bobbin	NQI		0.56	15TH TSP	+1.26
		06/95 RFO	Bobbin	ODI	10	0.82	10TH TSP	+17.19
		06/95 RFO	Bobbin	ODI	12	0.44	12TH TSP	+26.89
		06/95 RFO	Bobbin	ODI	14	0.45	12TH TSP	+21.38
		06/95 RFO	Bobbin	ODI	23	0.44	11TH TSP	+15.24
		06/95 RFO	Bobbin	ODI	27	0.93	11TH TSP	+17.22
		06/95 RFO	Bobbin	ODI	35	0.57	10TH TSP	+32.16
122	1	06/95 RFO	Bobbin	ODI	39	0.46	11TH TSP	+24.12
122	8	06/95 RFO	Bobbin	NQI		0.41	LTSP	+39.98
122	15	06/95 RFO	Bobbin	ODI	52	0.59	13TH TSP	+23.46
122	37	06/95 RFO	Bobbin	ODI	20	0.28	LTSP	+36.64
122	73	06/95 RFO	Bobbin	ADI		5.99	LTSP	+21.49 to +25.77
122	99	06/95 RFO	Bobbin	ODI	27	0.52	8TH TSP	+27.26
122	101	06/95 RFO	Bobbin	NQI		0.43	11TH TSP	+15.85
122	102	06/95 RFO	Bobbin	NQI		0.41	9TH TSP	+18.34
122	104	06/95 RFO	Bobbin	NQI		0.35	13TH TSP	-0.68
122	105	06/95 RFO	Bobbin	NQI		0.46	10TH TSP	+13.95
123	5	06/95 RFO	Bobbin	ODI	29	0.41	2ND TSP	+22.03
123	29	06/95 RFO	Bobbin	ODI	18	0.56	15TH TSP	+0.52
123	43	06/95 RFO	Bobbin	ODI	34	0.39	6TH TSP	+25.86
123	55	06/95 RFO	Bobbin	ODI	28	0.41	6TH TSP	+12.86
123	61	06/95 RFO	Bobbin	ODI	78	0.63	11TH TSP	+29.08
123	77	06/95 RFO	Bobbin	ODI	12	0.39	9TH TSP	+25.16
123	95	06/95 RFO	Bobbin	NQI		0.35	14TH TSP	+31.03
123	97	06/95 RFO	Bobbin	NQI		0.38	8TH TSP	+25.92
123	101	06/95 RFO	Bobbin	NQI		0.22	10TH TSP	+23.56
		06/95 RFO	Bobbin	NQI		0.23	11TH TSP	+10.93
		06/95 RFO	Bobbin	NQI		0.24	11TH TSP	+17.49
		06/95 RFO	Bobbin	NQI		0.25	11TH TSP	+13.05
		06/95 RFO	Bobbin	NQI		0.25	11TH TSP	+16.72

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 28 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		06/95 RFO	Bobbin	NQI		0.27	11TH TSP	+15.47
		06/95 RFO	Bobbin	NQI		0.28	11TH TSP	+18.04
		06/95 RFO	Bobbin	NQI		0.31	10TH TSP	+5.69
		06/95 RFO	Bobbin	NQI		0.34	10TH TSP	+3.69
		06/95 RFO	Bobbin	NQI		0.63	10TH TSP	+2.18
123	103	06/95 RFO	Bobbin	NQI		0.44	11TH TSP	+0.58
		06/95 RFO	Bobbin	NQI		0.66	15TH TSP	+0.54
123	104	06/95 RFO	Bobbin	ODI	12	0.34	5TH TSP	+4.02
124	4	06/95 RFO	Bobbin	ODI	4	0.86	10TH TSP	+0.55
124	53	06/95 RFO	Bobbin	NQI		0.32	13TH TSP	+21.60
124	65	06/95 RFO	Bobbin	ODI	58	0.74	6TH TSP	+5.17
124	72	06/95 RFO	Bobbin	NQI		0.36	11TH TSP	+20.03
124	73	06/95 RFO	Bobbin	ODI	18	3.80	LTSP	+21.46 to +26.50
124	85	06/95 RFO	Bobbin	NQI		0.42	3RD TSP	-0.79
124	90	06/95 RFO	Bobbin	NQI		0.46	10TH TSP	+8.77
124	93	06/95 RFO	Bobbin	ODI	21	1.70	LTSP	+24.28
124	99	06/95 RFO	Bobbin	NQI		0.29	10TH TSP	-0.02
		06/95 RFO	Bobbin	ODI	23	0.31	11TH TSP	+10.07
124	100	06/95 RFO	Bobbin	NQI		0.38	10TH TSP	+19.47
125	1	06/95 RFO	Bobbin	NQI		0.42	1ST TSP	+29.44
125	4	06/95 RFO	Bobbin	ODI	9	1.06	10TH TSP	+0.57
125	36	06/95 RFO	Bobbin	NQI		0.94	15TH TSP	+0.56
125	50	06/95 RFO	Bobbin	ODI	39	0.63	10TH TSP	+33.16
125	86	06/95 RFO	Bobbin	ODI	19	0.63	1ST TSP	+10.10
125	94	06/95 RFO	Bobbin	ODI	14	0.40	8TH TSP	+18.67
		06/95 RFO	Bobbin	ODI	10	0.43	14TH TSP	+24.45
		06/95 RFO	Bobbin	ODI	45	0.92	15TH TSP	+8.42
125	99	06/95 RFO	Bobbin	ODI	26	0.41	11TH TSP	+0.67
		06/95 RFO	Bobbin	ADI		1.56	10TH TSP	+15.55 to +23.77
125	100	06/95 RFO	Bobbin	NQI		0.82	11TH TSP	+4.99
126	4	06/95 RFO	Bobbin	ODI	7	0.80	10TH TSP	+0.54
126	5	06/95 RFO	Bobbin	NQI		0.94	10TH TSP	+0.54
126	92	06/95 RFO	Bobbin	NQI		0.45	LTSP	+31.76
		06/95 RFO	Bobbin	ODI	38	6.67	13TH TSP	+0.88
126	94	06/95 RFO	Bobbin	NQI		0.24	8TH TSP	+19.85
126	98	06/95 RFO	Bobbin	ADI		0.92	10TH TSP	+17.28 to +24.83
127	3	06/95 RFO	Bobbin	NQI		1.18	15TH TSP	-0.34
127	5	06/95 RFO	Bobbin	ODI	1	1.52	10TH TSP	+0.59
127	40	06/95 RFO	Bobbin	ODI	50	0.58	6TH TSP	+25.76
127	92	06/95 RFO	Bobbin	ODI	18	0.43	9TH TSP	+0.53
127	98	06/95 RFO	Bobbin	ADI		5.50	11TH TSP	+4.53
128	4	06/95 RFO	Bobbin	ODI	22	0.47	10TH TSP	+0.35
128	90	06/95 RFO	Bobbin	NQI		0.47	8TH TSP	+15.38
128	92	06/95 RFO	Bobbin	NQI		0.43	8TH TSP	-0.72
129	1	06/95 RFO	Bobbin	ODI	10	0.58	10TH TSP	+19.59
		06/95 RFO	Bobbin	ODI	12	0.83	10TH TSP	+20.56
129	10	06/95 RFO	Bobbin	NQI		1.55	15TH TSP	+13.96 to +44.78
129	25	06/95 RFO	Bobbin	ODI	6	0.75	15TH TSP	-0.94
129	33	06/95 RFO	Bobbin	ODI	11	0.31	14TH TSP	+0.38
129	76	06/95 RFO	Bobbin	NQI		0.54	14TH TSP	+1.23
129	86	06/95 RFO	Bobbin	NQI		0.39	15TH TSP	+24.85
129	92	06/95 RFO	Bobbin	NQI		0.34	10TH TSP	+30.54
129	93	06/95 RFO	Bobbin	NQI		0.46	7TH TSP	-0.50
		06/95 RFO	Bobbin	NQI		0.27	10TH TSP	+24.75
129	94	06/95 RFO	Bobbin	NQI		6.08	15TH TSP	+0.64
130	1	06/95 RFO	Bobbin	ODI	4	1.49	14TH TSP	+31.54
		06/95 RFO	Bobbin	ODI	6	3.16	13TH TSP	+2.50
130	9	06/95 RFO	Bobbin	ODI	34	0.73	13TH TSP	+30.59
130	11	06/95 RFO	Bobbin	NQI		0.49	11TH TSP	+19.15
130	26	06/95 RFO	Bobbin	ODI	18	0.28	14TH TSP	+0.36
130	60	06/95 RFO	Bobbin	NQI		0.37	1ST TSP	+2.41
130	93	06/95 RFO	Bobbin	NQI		8.23	15TH TSP	+0.70
131	5	06/95 RFO	Bobbin	ODI	37	0.57	9TH TSP	+0.36
131	27	06/95 RFO	Bobbin	NQI		0.29	9TH TSP	+27.16
		06/95 RFO	Bobbin	NQI		0.54	15TH TSP	+0.48

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 29 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
131	42	06/95 RFO	Bobbin	ODI	3	0.46	7TH TSP	+6.33 FL
131	68	06/95 RFO	Bobbin	ODI	34	0.53	15TH TSP	+15.17 FL
131	80	06/95 RFO	Bobbin	NQI		0.63	11TH TSP	+35.27 FL
131	83	06/95 RFO	Bobbin	NQI		0.53	4TH TSP	+0.79 FL
131	88	06/95 RFO	Bobbin	ODI	21	0.89	14TH TSP	+27.51 FL
132	75	06/95 RFO	Bobbin	ODI	21	0.83	8TH TSP	+11.53 FL
132	80	06/95 RFO	Bobbin	ODI	30	0.75	8TH TSP	-0.82 FL
132	82	06/95 RFO	Bobbin	NQI		0.90	9TH TSP	+0.67 FL
133	62	06/95 RFO	Bobbin	NQI		0.27	15TH TSP	-0.19 FL
		06/95 RFO	Bobbin	NQI		0.53	15TH TSP	-0.54 FL
133	77	06/95 RFO	Bobbin	NQI		1.51	LTSP	-0.37 FL
134	19	06/95 RFO	Bobbin	ODI	52	0.68	9TH TSP	+17.30 FL
134	32	06/95 RFO	Bobbin	ODI	37	0.95	7TH TSP	+17.48 FL
134	37	06/95 RFO	Bobbin	NQI		0.72	10TH TSP	+15.03 FL
134	70	06/95 RFO	Bobbin	NQI		0.64	UTSF	+0.42 FL
134	84	06/95 RFO	Bobbin	NQI		0.33	10TH TSP	+0.56 FL
135	2	06/95 RFO	Bobbin	ODI	16	0.35	2ND TSP	+6.27 FL
135	3	06/95 RFO	Bobbin	NQI		0.77	4TH TSP	+19.55 FL
135	6	06/95 RFO	Bobbin	NQI		0.79	9TH TSP	+0.49 FL
135	75	06/95 RFO	Bobbin	NQI		0.59	7TH TSP	+24.81 FL
		06/95 RFO	Bobbin	NQI		0.70	7TH TSP	+3.08 FL
135	81	06/95 RFO	Bobbin	ODI	38	3.87	10TH TSP	-0.63 FL
136	4	06/95 RFO	Bobbin	NQI		0.40	14TH TSP	-0.75 FL
136	9	06/95 RFO	Bobbin	NQI		0.62	LTSP	+22.93 FL
136	20	06/95 RFO	Bobbin	ODI	8	0.41	14TH TSP	+0.35 FL
136	29	06/95 RFO	Bobbin	NQI		0.50	15TH TSP	+0.49 FL
136	54	06/95 RFO	Bobbin	NQI		0.78	6TH TSP	+7.79 FL
136	61	06/95 RFO	Bobbin	ODI	35	0.45	9TH TSP	+2.39 FL
136	76	06/95 RFO	Bobbin	ODI	27	0.96	9TH TSP	-0.72 FL
137	3	06/95 RFO	Bobbin	ODI	1	1.23	10TH TSP	-0.71 FL
137	60	06/95 RFO	Bobbin	NQI		0.87	4TH TSP	-0.64 FL
137	78	06/95 RFO	Bobbin	ODI	24	1.02	10TH TSP	-0.26 FL
138	1	06/95 RFO	Bobbin	WAR	70	0.52	14TH TSP	+0.00 FL
138	3	06/95 RFO	Bobbin	NQI		0.49	10TH TSP	+0.62 FL
138	4	06/95 RFO	Bobbin	ODI	9	0.42	1ST TSP	+21.28 FL
138	18	06/95 RFO	Bobbin	ODI	24	0.44	LTSP	+20.61 FL
138	49	06/95 RFO	Bobbin	NQI		0.48	2ND TSP	+27.52 FL
138	62	06/95 RFO	Bobbin	NQI		0.60	6TH TSP	+25.92 FL
138	74	06/95 RFO	Bobbin	NQI		0.74	8TH TSP	+25.86 FL
139	3	06/95 RFO	Bobbin	NQI		0.57	10TH TSP	+0.49 FL
139	4	06/95 RFO	Bobbin	ODI	2	0.44	10TH TSP	+0.69 FL
139	8	06/95 RFO	Bobbin	ODI	33	0.47	13TH TSP	+33.44 FL
139	17	06/95 RFO	Bobbin	NQI		0.43	8TH TSP	+29.32 FL
		06/95 RFO	Bobbin	NQI		0.40	11TH TSP	+4.52 FL
		06/95 RFO	Bobbin	NQI		0.41	12TH TSP	+23.01 FL
		06/95 RFO	Bobbin	NQI		0.44	10TH TSP	+17.39 FL
		06/95 RFO	Bobbin	NQI		0.47	14TH TSP	+0.46 FL
		06/95 RFO	Bobbin	NQI		0.58	13TH TSP	+24.18 FL
		06/95 RFO	Bobbin	ODI	18	0.44	9TH TSP	+16.13 FL
		06/95 RFO	Bobbin	ODI	20	0.43	12TH TSP	+16.01 FL
		06/95 RFO	Bobbin	ODI	20	0.49	12TH TSP	+14.54 FL
		06/95 RFO	Bobbin	ODI	33	0.42	12TH TSP	+3.99 FL
		06/95 RFO	Bobbin	ODI	35	0.62	15TH TSP	+8.02 FL
		06/95 RFO	Bobbin	ODI	38	0.49	12TH TSP	+22.68 FL
		06/95 RFO	Bobbin	ODI	43	0.82	12TH TSP	+28.19 FL
139	20	06/95 RFO	Bobbin	NQI		0.40	11TH TSP	+35.56 FL
		06/95 RFO	Bobbin	NQI		0.44	10TH TSP	+31.38 FL
139	38	06/95 RFO	Bobbin	ODI	23	0.49	6TH TSP	+28.46 FL
139	43	06/95 RFO	Bobbin	NQI		0.30	15TH TSP	+4.82 FL
139	61	06/95 RFO	Bobbin	ODI	4	0.40	12TH TSP	+8.01 FL
140	3	06/95 RFO	Bobbin	ODI	27	0.73	10TH TSP	-0.38 FL
140	5	06/95 RFO	Bobbin	NQI		0.49	9TH TSP	+0.56 FL
140	6	06/95 RFO	Bobbin	ODI	27	0.24	9TH TSP	-0.03 FL
140	12	06/95 RFO	Bobbin	NQI		0.43	8TH TSP	+26.42 FL
		06/95 RFO	Bobbin	ODI	16	0.33	9TH TSP	+4.56 FL

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 30 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
140	16	06/95 RFO	Bobbin	ODI	12	0.42	9TH TSP	+22.32
		06/95 RFO	Bobbin	ODI	30	0.47	11TH TSP	+21.05
140	34	06/95 RFO	Bobbin	NQI		0.40	9TH TSP	-0.11
140	35	06/95 RFO	Bobbin	NQI		0.45	6TH TSP	+18.95
140	62	06/95 RFO	Bobbin	ODI	41	0.85	8TH TSP	-0.75
140	71	06/95 RFO	Bobbin	NQI		0.42	UTSF	-0.61
141	1	06/95 RFO	Bobbin	WAR	34	0.91	14TH TSP	+0.00
141	46	06/95 RFO	Bobbin	NQI		0.49	1ST TSP	+2.10
141	55	06/95 RFO	Bobbin	ODI	27	0.25	15TH TSP	+0.37
141	59	06/95 RFO	Bobbin	ODI	39	1.09	8TH TSP	-0.62
141	63	06/95 RFO	Bobbin	ODI	18	0.99	7TH TSP	+9.81
141	66	06/95 RFO	Bobbin	ODI	16	0.93	7TH TSP	+34.47
142	8	06/95 RFO	Bobbin	ODI	27	0.75	8TH TSP	-0.54
142	12	06/95 RFO	Bobbin	NQI		0.31	14TH TSP	+0.22
142	40	06/95 RFO	Bobbin	NQI		0.36	13TH TSP	+1.60
142	41	06/95 RFO	Bobbin	NQI		0.44	13TH TSP	+29.17
142	48	06/95 RFO	Bobbin	ODI	14	1.51	LTSP	-0.34
142	54	06/95 RFO	Bobbin	NQI		0.33	15TH TSP	+0.34
142	61	06/95 RFO	Bobbin	NQI		0.21	14TH TSP	+0.38
142	62	06/95 RFO	Bobbin	ODI	8	0.31	15TH TSP	+1.94
143	3	06/95 RFO	Bobbin	ODI	13	0.48	14TH TSP	-0.79
143	8	06/95 RFO	Bobbin	ODI	14	0.84	8TH TSP	+0.53
143	14	06/95 RFO	Bobbin	NQI		0.55	13TH TSP	+6.35
143	27	06/95 RFO	Bobbin	ODI	24	0.55	13TH TSP	+12.33
		06/95 RFO	Bobbin	ODI	33	0.48	13TH TSP	+16.82
143	28	06/95 RFO	Bobbin	NQI		0.35	9TH TSP	+18.67
		06/95 RFO	Bobbin	ODI	12	0.57	9TH TSP	+21.84
		06/95 RFO	Bobbin	ODI	56	0.71	9TH TSP	+17.33
143	38	06/95 RFO	Bobbin	NQI		0.79	3RD TSP	+21.97
143	49	06/95 RFO	Bobbin	ODI	30	0.52	13TH TSP	+1.30
144	1	06/95 RFO	Bobbin	NQI		0.56	3RD TSP	+13.11
144	10	06/95 RFO	Bobbin	NQI		0.54	8TH TSP	-0.68
144	11	06/95 RFO	Bobbin	NQI		0.50	8TH TSP	-0.69
144	13	06/95 RFO	Bobbin	NQI		0.42	11TH TSP	+9.33
		06/95 RFO	Bobbin	ODI	12	0.65	11TH TSP	+18.76
144	15	06/95 RFO	Bobbin	ODI	24	0.59	8TH TSP	-0.55
144	31	06/95 RFO	Bobbin	ODI	13	1.81	1ST TSP	+0.90
144	46	06/95 RFO	Bobbin	ODI	31	0.87	13TH TSP	+0.97
144	47	06/95 RFO	Bobbin	ODI	45	1.22	13TH TSP	+0.93
144	49	06/95 RFO	Bobbin	ODI	1	1.02	8TH TSP	-0.50
145	1	06/95 RFO	Bobbin	NQI		1.38	13TH TSP	-0.78
145	13	06/95 RFO	Bobbin	ODI	31	0.44	14TH TSP	+9.82
145	16	06/95 RFO	Bobbin	NQI		0.55	7TH TSP	+5.14
		06/95 RFO	Bobbin	ODI	7	0.46	8TH TSP	-0.62
145	36	06/95 RFO	Bobbin	NQI		0.44	14TH TSP	-0.35
145	46	06/95 RFO	Bobbin	ODI	48	1.14	9TH TSP	-0.56
145	47	06/95 RFO	Bobbin	ODI	13	0.63	8TH TSP	+0.62
145	51	06/95 RFO	Bobbin	ODI	7	0.40	10TH TSP	+10.54
		06/95 RFO	Bobbin	ODI	11	0.55	10TH TSP	+9.53
145	52	06/95 RFO	Bobbin	ODI	1	0.33	13TH TSP	+2.26
		06/95 RFO	Bobbin	ODI	28	0.46	13TH TSP	+2.51
146	1	06/95 RFO	Bobbin	ODI	15	1.32	10TH TSP	+7.71
146	12	06/95 RFO	Bobbin	NQI		0.44	1ST TSP	+6.65
146	13	06/95 RFO	Bobbin	ODI	14	1.03	8TH TSP	+0.64
146	14	06/95 RFO	Bobbin	ODI	20	1.07	8TH TSP	-0.51
146	21	06/95 RFO	Bobbin	NQI		0.41	8TH TSP	+0.41
146	22	06/95 RFO	Bobbin	NQI		0.63	9TH TSP	+7.94
146	29	06/95 RFO	Bobbin	ODI	8	0.75	8TH TSP	-0.62
146	30	06/95 RFO	Bobbin	ODI	36	0.47	8TH TSP	+21.34
146	36	06/95 RFO	Bobbin	NQI		0.46	5TH TSP	+20.43
		06/95 RFO	Bobbin	ODI	18	0.33	9TH TSP	+0.61
146	43	06/95 RFO	Bobbin	ODI	10	1.10	9TH TSP	+0.64
		06/95 RFO	Bobbin	ODI	32	0.57	9TH TSP	-0.10
146	46	06/95 RFO	Bobbin	ODI	11	0.40	8TH TSP	-0.03
146	48	06/95 RFO	Bobbin	ODI	32	0.62	8TH TSP	+34.58

BWNT TUBAN II (Version 2.1) 07/18/1995 08:33:55
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO
 Bobbin

Page 31 of 31

ATTACHMENT #1 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
146	51	06/95 RFO	Bobbin	ODI	9	0.77	10TH TSP	+1.34 FL
147	1	06/95 RFO	Bobbin	ODI	22	0.27	5TH TSP	+0.28 FL
147	5	06/95 RFO	Bobbin	NQI		0.44	15TH TSP	+3.91 FL
147	6	06/95 RFO	Bobbin	NQI		0.24	11TH TSP	+15.10 FL
147	12	06/95 RFO	Bobbin	NQI		0.47	10TH TSP	-0.80 FL
147	15	06/95 RFO	Bobbin	NQI		0.35	5TH TSP	+0.98 FL
147	27	06/95 RFO	Bobbin	ODI	25	0.34	9TH TSP	-0.10 FL
147	28	06/95 RFO	Bobbin	NQI		0.73	9TH TSP	+0.56 FL
148	3	06/95 RFO	Bobbin	ODI	12	0.24	15TH TSP	+26.55 FL
148	21	06/95 RFO	Bobbin	NQI		0.32	8TH TSP	+14.81 FL
		06/95 RFO	Bobbin	ODI	7	0.38	9TH TSP	-0.50 FL
148	23	06/95 RFO	Bobbin	NQI		0.41	9TH TSP	+0.50 FL
148	32	06/95 RFO	Bobbin	ODI	15	1.33	12TH TSP	+1.23 FL
148	35	06/95 RFO	Bobbin	NQI		0.54	10TH TSP	+0.70 FL
149	1	06/95 RFO	Bobbin	ODI	26	0.44	LTSF	+35.41 FL
149	8	06/95 RFO	Bobbin	NQI		0.59	9TH TSP	+0.51 FL
149	10	06/95 RFO	Bobbin	ODI	26	2.17	14TH TSP	+1.19 FL
149	12	06/95 RFO	Bobbin	NQI		0.41	8TH TSP	+27.41 FL
149	17	06/95 RFO	Bobbin	NQI		0.48	9TH TSP	+14.39 FL
149	25	06/95 RFO	Bobbin	NQI		0.51	10TH TSP	+0.10 FL
		06/95 RFO	Bobbin	NQI		0.53	10TH TSP	+0.41 FL
149	28	06/95 RFO	Bobbin	ODI	13	0.38	10TH TSP	+16.04 FL
		06/95 RFO	Bobbin	ODI	20	0.60	11TH TSP	+6.17 FL
149	29	06/95 RFO	Bobbin	ODI	1	0.66	10TH TSP	+18.48 FL
		06/95 RFO	Bobbin	ODI	9	1.29	10TH TSP	+19.74 FL
149	30	06/95 RFO	Bobbin	ODI	11	0.51	13TH TSP	+1.32 FL
149	31	06/95 RFO	Bobbin	NQI		0.33	12TH TSP	+3.43 FL
		06/95 RFO	Bobbin	NQI		0.36	10TH TSP	+0.46 FL
150	3	06/95 RFO	Bobbin	ODI	12	0.42	15TH TSP	+17.17 FL
150	7	06/95 RFO	Bobbin	ODI	9	0.62	6TH TSP	+0.56 FL
150	8	06/95 RFO	Bobbin	NQI		0.53	10TH TSP	+0.59 FL
150	9	06/95 RFO	Bobbin	NQI		0.54	10TH TSP	-0.58 FL
150	11	06/95 RFO	Bobbin	NQI		0.59	10TH TSP	+0.74 FL
150	12	06/95 RFO	Bobbin	ODI	26	1.12	10TH TSP	+0.68 FL
150	14	06/95 RFO	Bobbin	NQI		0.41	6TH TSP	+0.69 FL
150	16	06/95 RFO	Bobbin	NQI		0.98	10TH TSP	-0.42 FL
		06/95 RFO	Bobbin	ODI	15	0.93	14TH TSP	+1.13 FL
		06/95 RFO	Bobbin	ODI	20	0.83	14TH TSP	+1.36 FL
		06/95 RFO	Bobbin	ODI	40	1.59	14TH TSP	+0.93 FL
150	17	06/95 RFO	Bobbin	ODI	26	1.16	14TH TSP	+1.20 FL
		06/95 RFO	Bobbin	ODI	40	1.25	14TH TSP	+1.00 FL
150	18	06/95 RFO	Bobbin	ODI	50	1.29	10TH TSP	+0.39 FL
150	19	06/95 RFO	Bobbin	ODI	23	0.53	11TH TSP	-0.17 FL
150	20	06/95 RFO	Bobbin	ODI	15	0.62	10TH TSP	+16.30 FL
		06/95 RFO	Bobbin	ODI	22	0.54	11TH TSP	+6.41 FL
150	21	06/95 RFO	Bobbin	NQI		0.49	10TH TSP	+17.30 FL
150	23	06/95 RFO	Bobbin	ADI		2.07	13TH TSP	+2.52 FL
150	27	06/95 RFO	Bobbin	ODI	15	0.48	13TH TSP	+3.59 FL
151	5	06/95 RFO	Bobbin	NQI		0.97	12TH TSP	+0.00 FL
		06/95 RFO	Bobbin	WAR	38	1.48	13TH TSP	+0.00 FL
151	10	06/95 RFO	Bobbin	NQI		0.37	12TH TSP	+12.14 FL
		06/95 RFO	Bobbin	NQI		0.60	14TH TSP	-0.63 FL
		06/95 RFO	Bobbin	WAR	78	1.23	11TH TSP	+0.00 FL
151	11	06/95 RFO	Bobbin	ODI	25	0.79	14TH TSP	+1.31 FL
		06/95 RFO	Bobbin	ODI	38	0.26	10TH TSP	+19.03 FL
151	12	06/95 RFO	Bobbin	ODI	11	0.47	12TH TSP	+4.56 FL
151	15	06/95 RFO	Bobbin	ADI		2.61	11TH TSP	+9.34 to +15.36 FL
		06/95 RFO	Bobbin	ADI		6.03	13TH TSP	+2.95 to +6.95 FL
151	16	06/95 RFO	Bobbin	ADI		2.79	12TH TSP	+4.02 FL
		06/95 RFO	Bobbin	ODI	27	3.14	13TH TSP	+4.07 FL

Total Indications Found = 2010
 Total Tubes Found = 1549

ATTACHMENT 2

26 Pages

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 1 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
1	1	06/95 RFO	Bobbin	NQI		0.84	10TH TSP	-0.27
1	2	06/95 RFO	Bobbin	NQI		0.62	15TH TSP	+22.12
1	4	06/95 RFO	Bobbin	NQI		1.11	15TH TSP	-0.42
1	5	06/95 RFO	Bobbin	NQI		0.82	15TH TSP	-0.56
1	8	06/95 RFO	Bobbin	ODI	6	0.43	10TH TSP	+33.26
1	11	06/95 RFO	Bobbin	ODI	21	0.58	11TH TSP	+0.57
2	1	06/95 RFO	Bobbin	NQI		0.43	15TH TSP	+17.19
2	2	06/95 RFO	Bobbin	NQI		0.78	15TH TSP	+17.87
		06/95 RFO	Bobbin	ODI	20	0.69	15TH TSP	+17.51
2	3	06/95 RFO	Bobbin	ODI	18	0.69	15TH TSP	+18.20
2	5	06/95 RFO	Bobbin	NQI		0.76	15TH TSP	+17.46
		06/95 RFO	Bobbin	ODI	2	0.58	15TH TSP	+18.40
2	6	06/95 RFO	Bobbin	ODI	35	0.28	11TH TSP	+9.89
2	8	06/95 RFO	Bobbin	NQI		0.56	5TH TSP	+19.96
2	11	06/95 RFO	Bobbin	ODI	18	0.84	10TH TSP	+3.57
3	1	06/95 RFO	Bobbin	NQI		0.67	15TH TSP	+13.99
3	2	06/95 RFO	Bobbin	ADI		3.83	15TH TSP	+30.31
3	29	06/95 RFO	Bobbin	ADI		1.88	15TH TSP	+32.44
3	30	06/95 RFO	Bobbin	ADI		1.37	15TH TSP	+31.81
4	11	06/95 RFO	Bobbin	NQI		1.51	9TH TSP	+37.22
4	19	06/95 RFO	Bobbin	ODI	27	0.73	14TH TSP	+32.61
4	25	06/95 RFO	Bobbin	NQI		0.34	14TH TSP	+8.83
5	6	06/95 RFO	Bobbin	NQI		0.35	14TH TSP	-0.25
		06/95 RFO	Bobbin	ODI	20	1.99	10TH TSP	-1.31
5	7	06/95 RFO	Bobbin	ADI		8.96	9TH TSP	+37.90
5	9	06/95 RFO	Bobbin	ODI	4	1.65	10TH TSP	-1.44
5	16	06/95 RFO	Bobbin	ODI	34	1.20	10TH TSP	+1.93
6	6	06/95 RFO	Bobbin	ODI	10	1.69	9TH TSP	+37.53
6	8	06/95 RFO	Bobbin	NQI		0.37	14TH TSP	+14.86
6	15	06/95 RFO	Bobbin	ODI	27	0.54	9TH TSP	+37.80
6	37	06/95 RFO	Bobbin	NQI		1.03	UTSF	+0.62
6	41	06/95 RFO	Bobbin	NQI		0.81	8TH TSP	-0.49
6	45	06/95 RFO	Bobbin	NQI		0.96	11TH TSP	-0.73
7	2	06/95 RFO	Bobbin	ODI	17	0.41	10TH TSP	+0.61
7	5	06/95 RFO	Bobbin	NQI		0.27	4TH TSP	+16.51
		06/95 RFO	Bobbin	NQI		0.41	12TH TSP	+28.84
7	8	06/95 RFO	Bobbin	ODI	26	0.39	10TH TSP	+5.41
7	10	06/95 RFO	Bobbin	NQI		0.36	14TH TSP	-0.15
7	11	06/95 RFO	Bobbin	NQI		0.27	13TH TSP	+24.56
		06/95 RFO	Bobbin	NQI		0.41	15TH TSP	+3.68
		06/95 RFO	Bobbin	NQI		0.48	14TH TSP	+2.71
		06/95 RFO	Bobbin	NQI		0.79	14TH TSP	+13.31
		06/95 RFO	Bobbin	ODI	5	0.68	14TH TSP	+11.20
		06/95 RFO	Bobbin	ODI	9	0.60	13TH TSP	+5.06
		06/95 RFO	Bobbin	ODI	18	0.48	15TH TSP	+14.92
		06/95 RFO	Bobbin	ODI	24	1.00	15TH TSP	+12.01
		06/95 RFO	Bobbin	ODI	25	0.38	13TH TSP	+23.53
		06/95 RFO	Bobbin	ODI	30	0.68	15TH TSP	+11.04
7	12	06/95 RFO	Bobbin	ADI		2.72	10TH TSP	+3.60
		06/95 RFO	Bobbin	NQI		0.56	13TH TSP	+1.70
7	13	06/95 RFO	Bobbin	NQI		0.44	10TH TSP	+3.90
		06/95 RFO	Bobbin	ODI	38	0.56	10TH TSP	+4.51
7	14	06/95 RFO	Bobbin	NQI		0.55	9TH TSP	+36.20
		06/95 RFO	Bobbin	ODI	12	0.50	10TH TSP	+5.79
7	15	06/95 RFO	Bobbin	NQI		0.65	9TH TSP	+34.26
		06/95 RFO	Bobbin	NQI		0.74	9TH TSP	+30.93
7	16	06/95 RFO	Bobbin	NQI		0.73	9TH TSP	+1.42
7	17	06/95 RFO	Bobbin	NQI		0.53	9TH TSP	+30.18
7	19	06/95 RFO	Bobbin	NQI		0.55	9TH TSP	+23.47
7	34	06/95 RFO	Bobbin	NQI		0.41	9TH TSP	-0.62
7	45	06/95 RFO	Bobbin	NQI		0.58	11TH TSP	-0.76
7	51	06/95 RFO	Bobbin	NQI		0.31	LTSF	+35.72
8	2	06/95 RFO	Bobbin	NQI		0.29	10TH TSP	+0.60
8	5	06/95 RFO	Bobbin	NQI		0.74	14TH TSP	+0.78
		06/95 RFO	Bobbin	ODI	9	0.75	14TH TSP	+1.13

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 2 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
8	7	06/95 RFO	Bobbin	NQI		0.48	9TH TSP	+28.67
8	9	06/95 RFO	Bobbin	NQI		0.20	LTSF	+44.37
		06/95 RFO	Bobbin	NQI		0.65	LTSF	+42.04
8	13	06/95 RFO	Bobbin	NQI		0.54	9TH TSP	+30.69
		06/95 RFO	Bobbin	ODI	31	0.24	14TH TSP	+0.07
8	14	06/95 RFO	Bobbin	NQI		0.82	12TH TSP	+1.82
		06/95 RFO	Bobbin	ODI	38	0.60	9TH TSP	+33.57
		06/95 RFO	Bobbin	ODI	29	1.40	13TH TSP	+24.99
8	18	06/95 RFO	Bobbin	ODI	28	0.63	9TH TSP	+28.39
		06/95 RFO	Bobbin	ODI	24	0.39	10TH TSP	+0.56
8	48	06/95 RFO	Bobbin	NQI		0.61	8TH TSP	+0.61
8	57	06/95 RFO	Bobbin	NQI		0.41	13TH TSP	+2.88
		06/95 RFO	Bobbin	ODI	10	1.22	15TH TSP	+1.65
9	3	06/95 RFO	Bobbin	ODI	40	5.15	LTSF	+0.43
		06/95 RFO	Bobbin	ODI	28	0.80	14TH TSP	+1.07
9	5	06/95 RFO	Bobbin	NQI		0.59	LTSF	+21.78
		06/95 RFO	Bobbin	ODI	14	0.38	LTSF	+30.20
		06/95 RFO	Bobbin	ODI	25	0.31	LTSF	+17.23
9	9	06/95 RFO	Bobbin	ODI	12	0.71	9TH TSP	+22.01
9	11	06/95 RFO	Bobbin	NQI		0.48	9TH TSP	+22.22
9	15	06/95 RFO	Bobbin	ODI	26	0.62	14TH TSP	-0.10
		06/95 RFO	Bobbin	ADI		0.37	13TH TSP	+17.77 to +33.67
		06/95 RFO	Bobbin	ADI		0.79	14TH TSP	+0.00 to +31.31
9	17	06/95 RFO	Bobbin	NQI		0.51	9TH TSP	+29.40
		06/95 RFO	Bobbin	NQI		0.22	14TH TSP	+1.00
		06/95 RFO	Bobbin	NQI		0.80	11TH TSP	+6.38
9	19	06/95 RFO	Bobbin	ADI		1.41	9TH TSP	+19.13 to +28.67
9	20	06/95 RFO	Bobbin	ADI		1.17	9TH TSP	+17.18 to +28.10
9	57	06/95 RFO	Bobbin	NQI		0.71	2ND TSP	+23.64
9	62	06/95 RFO	Bobbin	ODI	3	1.42	13TH TSP	+4.00
		06/95 RFO	Bobbin	ODI	8	1.89	14TH TSP	+2.43
10	1	06/95 RFO	Bobbin	ODI	18	0.53	9TH TSP	+38.09
10	2	06/95 RFO	Bobbin	NQI		0.39	11TH TSP	-0.79
10	4	06/95 RFO	Bobbin	NQI		0.30	11TH TSP	+31.84
10	7	06/95 RFO	Bobbin	NQI		0.67	9TH TSP	+0.49
10	8	06/95 RFO	Bobbin	NQI		0.72	9TH TSP	+0.00
10	9	06/95 RFO	Bobbin	NQI		1.01	9TH TSP	-0.70
10	11	06/95 RFO	Bobbin	ODI	18	0.52	9TH TSP	+13.20
10	13	06/95 RFO	Bobbin	ODI	38	0.40	15TH TSP	+10.57
10	14	06/95 RFO	Bobbin	NQI		0.34	11TH TSP	+15.38
10	18	06/95 RFO	Bobbin	ODI	17	0.29	9TH TSP	+0.36
		06/95 RFO	Bobbin	ODI	20	0.64	9TH TSP	+24.85
10	20	06/95 RFO	Bobbin	ODI	12	0.56	9TH TSP	+26.83
10	21	06/95 RFO	Bobbin	NQI		0.41	9TH TSP	+0.41
10	24	06/95 RFO	Bobbin	ODI	17	0.23	9TH TSP	+0.21
10	25	06/95 RFO	Bobbin	NQI		0.59	9TH TSP	+0.52
10	31	06/95 RFO	Bobbin	ADI		8.86	1ST TSP	+35.60
		06/95 RFO	Bobbin	ADI		12.04	LTSF	+21.10 to +27.73
		06/95 RFO	Bobbin	ADI		3.33	2ND TSP	+0.00 to +4.67
10	59	06/95 RFO	Bobbin	NQI		0.87	9TH TSP	+24.81
10	62	06/95 RFO	Bobbin	ODI	32	0.95	15TH TSP	+1.50
10	63	06/95 RFO	Bobbin	ODI	18	0.62	10TH TSP	+5.54
10	65	06/95 RFO	Bobbin	ADI		2.07	15TH TSP	+14.76
		06/95 RFO	Bobbin	ODI	7	5.47	13TH TSP	+4.49
11	10	06/95 RFO	Bobbin	NQI		0.19	15TH TSP	+29.11
		06/95 RFO	Bobbin	NQI		0.43	15TH TSP	+29.58
		06/95 RFO	Bobbin	ODI	9	0.45	15TH TSP	+11.42
11	20	06/95 RFO	Bobbin	NQI		0.73	8TH TSP	+6.26
11	21	06/95 RFO	Bobbin	ODI	35	0.50	8TH TSP	+10.22
11	28	06/95 RFO	Bobbin	NQI		0.73	10TH TSP	+27.74
11	65	06/95 RFO	Bobbin	NQI		1.63	15TH TSP	-0.41
11	68	06/95 RFO	Bobbin	ODI	8	0.55	11TH TSP	+13.50
12	2	06/95 RFO	Bobbin	ODI	7	0.71	10TH TSP	-1.34
12	20	06/95 RFO	Bobbin	ODI	14	0.43	9TH TSP	+0.46
12	58	06/95 RFO	Bobbin	ODI	12	0.67	9TH TSP	-0.61

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 3 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
12	68	06/95 RFO	Bobbin	ODI	18	0.52	9TH TSP	-0.62
12	69	06/95 RFO	Bobbin	NQI		0.88	15TH TSP	+2.49
12	70	06/95 RFO	Bobbin	ODI	5	1.52	11TH TSP	+9.80
		06/95 RFO	Bobbin	ODI	13	1.01	14TH TSP	+30.12
12	71	06/95 RFO	Bobbin	NQI		0.40	11TH TSP	+9.76
		06/95 RFO	Bobbin	NQI		0.59	11TH TSP	+10.94
		06/95 RFO	Bobbin	ODI	8	0.90	11TH TSP	+12.34
		06/95 RFO	Bobbin	ODI	33	0.43	12TH TSP	+0.97
13	4	06/95 RFO	Bobbin	ODI	32	0.45	9TH TSP	+37.96
13	5	06/95 RFO	Bobbin	ODI	2	0.65	10TH TSP	-0.61
13	19	06/95 RFO	Bobbin	NQI		0.89	7TH TSP	-0.79
13	20	06/95 RFO	Bobbin	NQI		0.51	7TH TSP	-0.68
13	64	06/95 RFO	Bobbin	ODI	27	0.68	9TH TSP	+21.27
13	65	06/95 RFO	Bobbin	ODI	15	0.87	9TH TSP	+24.16
13	67	06/95 RFO	Bobbin	ODI	5	1.08	9TH TSP	+35.27
13	71	06/95 RFO	Bobbin	ODI	11	1.65	9TH TSP	+37.46
		06/95 RFO	Bobbin	ODI	23	1.00	9TH TSP	+38.48
13	73	06/95 RFO	Bobbin	ODI	9	0.83	11TH TSP	+8.20
14	13	06/95 RFO	Bobbin	NQI		0.28	LTSF	+7.54
14	56	06/95 RFO	Bobbin	ODI	16	0.50	14TH TSP	+30.91
		06/95 RFO	Bobbin	ODI	18	0.48	12TH TSP	+13.62
14	67	06/95 RFO	Bobbin	ODI	17	0.85	9TH TSP	+24.82
14	75	06/95 RFO	Bobbin	ODI	9	2.07	14TH TSP	+30.97
		06/95 RFO	Bobbin	ODI	17	0.61	14TH TSP	+31.50
15	1	06/95 RFO	Bobbin	ODI	7	1.58	10TH TSP	+7.00
15	10	06/95 RFO	Bobbin	NQI		0.32	1ST TSP	+25.55
15	15	06/95 RFO	Bobbin	ODI	35	0.31	7TH TSP	-0.51
15	18	06/95 RFO	Bobbin	NQI		0.40	12TH TSP	+9.69
15	21	06/95 RFO	Bobbin	NQI		0.69	12TH TSP	+7.01
15	34	06/95 RFO	Bobbin	NQI		0.34	9TH TSP	+33.17
15	67	06/95 RFO	Bobbin	NQI		0.65	9TH TSP	+20.79
15	68	06/95 RFO	Bobbin	ADI		1.55	9TH TSP	+23.80
15	71	06/95 RFO	Bobbin	ODI	4	0.73	9TH TSP	+38.41
15	75	06/95 RFO	Bobbin	ODI	11	1.55	9TH TSP	+37.20
15	77	06/95 RFO	Bobbin	ODI	15	0.87	10TH TSP	+6.83
16	1	06/95 RFO	Bobbin	ODI	3	1.73	10TH TSP	+7.21
16	2	06/95 RFO	Bobbin	NQI		7.74	15TH TSP	+0.82
16	5	06/95 RFO	Bobbin	ODI	17	0.45	9TH TSP	+15.34
16	42	06/95 RFO	Bobbin	NQI		0.39	14TH TSP	+23.93
16	66	06/95 RFO	Bobbin	NQI		0.54	9TH TSP	+0.67
16	78	06/95 RFO	Bobbin	ODI	12	0.50	10TH TSP	+5.12
16	79	06/95 RFO	Bobbin	ADI		1.60	10TH TSP	+3.28 to +7.05
16	81	06/95 RFO	Bobbin	ODI	2	2.92	14TH TSP	+32.20
17	2	06/95 RFO	Bobbin	NQI		0.35	10TH TSP	+0.56
17	18	06/95 RFO	Bobbin	NQI		0.53	3RD TSP	-1.47
17	72	06/95 RFO	Bobbin	ODI	16	0.37	3RD TSP	+9.77
		06/95 RFO	Bobbin	ODI	22	0.71	9TH TSP	+21.04 to +26.96
17	73	06/95 RFO	Bobbin	ODI	12	0.87	9TH TSP	+0.64
		06/95 RFO	Bobbin	ADI		2.16	9TH TSP	+21.19 to +28.65
17	74	06/95 RFO	Bobbin	NQI		0.72	9TH TSP	+0.64
		06/95 RFO	Bobbin	ODI	5	2.25	9TH TSP	+24.73 to +30.30
17	75	06/95 RFO	Bobbin	NQI		1.07	8TH TSP	-0.76
		06/95 RFO	Bobbin	ODI	15	0.91	9TH TSP	+25.19 to +27.12
17	76	06/95 RFO	Bobbin	NQI		0.52	9TH TSP	+36.62
17	78	06/95 RFO	Bobbin	ODI	38	0.54	9TH TSP	+37.68
		06/95 RFO	Bobbin	ODI	25	0.42	10TH TSP	+2.59
17	80	06/95 RFO	Bobbin	ODI	9	0.58	10TH TSP	+3.27
17	81	06/95 RFO	Bobbin	ODI	1	1.42	10TH TSP	+4.35
18	1	06/95 RFO	Bobbin	ODI	8	0.72	10TH TSP	+9.86
18	2	06/95 RFO	Bobbin	NQI		0.71	14TH TSP	+0.56
18	3	06/95 RFO	Bobbin	ODI	20	0.44	LTSF	+22.69
18	5	06/95 RFO	Bobbin	ODI	12	0.26	15TH TSP	-0.39
18	16	06/95 RFO	Bobbin	NQI		0.62	4TH TSP	+2.70
18	22	06/95 RFO	Bobbin	NQI		0.71	12TH TSP	+28.48
18	56	06/95 RFO	Bobbin	NQI		0.50	3RD TSP	+2.51

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 4 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
18	62	06/95 RFO	Bobbin	ADI		1.90	9TH TSP	+11.09
		06/95 RFO	Bobbin	ODI	13	2.00	9TH TSP	+7.91
18	66	06/95 RFO	Bobbin	ODI	38	0.56	13TH TSP	+24.03
18	74	06/95 RFO	Bobbin	ODI	15	0.52	9TH TSP	+21.97
18	75	06/95 RFO	Bobbin	ODI	21	1.93	9TH TSP	+22.57
18	76	06/95 RFO	Bobbin	ADI		1.40	9TH TSP	+23.69
		06/95 RFO	Bobbin	ODI	13	0.71	9TH TSP	+27.44
18	77	06/95 RFO	Bobbin	ADI		1.73	9TH TSP	+24.77
18	79	06/95 RFO	Bobbin	NQI		0.52	10TH TSP	+0.57
		06/95 RFO	Bobbin	NQI		0.68	10TH TSP	+0.11
		06/95 RFO	Bobbin	ODI	20	1.05	9TH TSP	+25.67 to +27.86
18	80	06/95 RFO	Bobbin	NQI		0.89	9TH TSP	-0.68
18	81	06/95 RFO	Bobbin	NQI		0.62	9TH TSP	+0.57
		06/95 RFO	Bobbin	NQI		1.08	9TH TSP	-0.66
18	83	06/95 RFO	Bobbin	ODI	13	1.37	10TH TSP	+9.05
		06/95 RFO	Bobbin	ADI		3.27	LTSF	+22.31 to +27.14
18	84	06/95 RFO	Bobbin	ODI	33	0.95	10TH TSP	+13.86
18	85	06/95 RFO	Bobbin	NQI		0.87	14TH TSP	+33.15
19	4	06/95 RFO	Bobbin	NQI		0.49	9TH TSP	+0.54
19	5	06/95 RFO	Bobbin	NQI		0.66	9TH TSP	+0.48
19	11	06/95 RFO	Bobbin	NQI		0.49	7TH TSP	-0.77
19	17	06/95 RFO	Bobbin	NQI		0.35	11TH TSP	+6.06
19	33	06/95 RFO	Bobbin	NQI		1.00	15TH TSP	+0.76
19	67	06/95 RFO	Bobbin	NQI		0.53	14TH TSP	+0.45
19	71	06/95 RFO	Bobbin	NQI		0.77	13TH TSP	+0.79
		06/95 RFO	Bobbin	ODI	38	0.26	1ST TSP	+14.61
19	77	06/95 RFO	Bobbin	NQI		0.74	8TH TSP	-0.64
19	78	06/95 RFO	Bobbin	NQI		1.08	8TH TSP	-0.66
19	79	06/95 RFO	Bobbin	NQI		0.92	8TH TSP	-0.66
		06/95 RFO	Bobbin	ADI		0.76	9TH TSP	+21.46 to +26.59
19	80	06/95 RFO	Bobbin	ODI	13	0.87	9TH TSP	+23.87
19	81	06/95 RFO	Bobbin	ADI		1.42	9TH TSP	+23.47 to +30.38
19	82	06/95 RFO	Bobbin	NQI		0.56	9TH TSP	+0.69
		06/95 RFO	Bobbin	NQI		1.44	10TH TSP	+0.47
		06/95 RFO	Bobbin	ADI		1.93	LTSF	+22.66 to +26.64
19	83	06/95 RFO	Bobbin	NQI		0.47	9TH TSP	+0.69
19	86	06/95 RFO	Bobbin	ADI		0.92	10TH TSP	+10.64
		06/95 RFO	Bobbin	NQI		3.03	15TH TSP	+0.87
20	16	06/95 RFO	Bobbin	ODI	3	2.54	10TH TSP	+29.32
20	19	06/95 RFO	Bobbin	NQI		0.52	14TH TSP	+16.23
20	30	06/95 RFO	Bobbin	ODI	36	0.44	11TH TSP	+35.22
20	73	06/95 RFO	Bobbin	NQI		0.62	8TH TSP	+0.60
20	75	06/95 RFO	Bobbin	ODI	39	0.30	8TH TSP	+0.62
20	77	06/95 RFO	Bobbin	ODI	7	0.74	8TH TSP	-0.50
20	78	06/95 RFO	Bobbin	NQI		1.43	8TH TSP	-0.58
		06/95 RFO	Bobbin	ODI	37	0.72	9TH TSP	+0.66
20	79	06/95 RFO	Bobbin	NQI		0.52	8TH TSP	+0.67
		06/95 RFO	Bobbin	NQI		0.81	8TH TSP	-0.54
20	80	06/95 RFO	Bobbin	NQI		0.80	9TH TSP	-0.75
		06/95 RFO	Bobbin	ODI	2	0.64	12TH TSP	+1.17
20	81	06/95 RFO	Bobbin	NQI		0.55	9TH TSP	-0.72
		06/95 RFO	Bobbin	NQI		0.65	9TH TSP	+0.66
20	82	06/95 RFO	Bobbin	NQI		0.91	9TH TSP	-0.71
20	83	06/95 RFO	Bobbin	NQI		0.30	14TH TSP	+31.04
20	84	06/95 RFO	Bobbin	ADI		2.99	10TH TSP	+11.53
21	1	06/95 RFO	Bobbin	ODI	8	0.14	13TH TSP	-0.28
21	2	06/95 RFO	Bobbin	NQI		0.22	6TH TSP	+32.28
21	5	06/95 RFO	Bobbin	ODI	24	0.46	8TH TSP	+23.53
21	8	06/95 RFO	Bobbin	NQI		0.34	12TH TSP	+31.22
21	11	06/95 RFO	Bobbin	NQI		0.26	12TH TSP	-0.25
21	15	06/95 RFO	Bobbin	NQI		1.06	7TH TSP	-0.79
21	70	06/95 RFO	Bobbin	NQI		0.42	15TH TSP	+7.01
21	72	06/95 RFO	Bobbin	NQI		0.64	11TH TSP	-0.77
21	77	06/95 RFO	Bobbin	NQI		0.53	11TH TSP	-0.75
21	78	06/95 RFO	Bobbin	NQI		0.63	9TH TSP	+0.65

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 5 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
21	84	06/95 RFO	Bobbin	NQI		1.22	8TH TSP	-0.57
21	85	06/95 RFO	Bobbin	NQI		0.41	8TH TSP	-0.48
		06/95 RFO	Bobbin	NQI		0.58	9TH TSP	+0.67
21	88	06/95 RFO	Bobbin	ADI		1.06	10TH TSP	+4.65
21	90	06/95 RFO	Bobbin	ADI		1.39	10TH TSP	+10.31
		06/95 RFO	Bobbin	NQI		0.72	14TH TSP	+31.76
		06/95 RFO	Bobbin	ODI	12	1.98	6TH TSP	+1.10
22	2	06/95 RFO	Bobbin	NQI		0.46	10TH TSP	+0.51
22	70	06/95 RFO	Bobbin	NQI		0.79	11TH TSP	-0.77
22	73	06/95 RFO	Bobbin	NQI		0.25	1ST TSP	+22.05
22	74	06/95 RFO	Bobbin	NQI		0.33	LTSF	+35.60
		06/95 RFO	Bobbin	ADI		3.20	LTSF	+20.80 to +28.72
22	90	06/95 RFO	Bobbin	WAR	28	1.01	9TH TSP	+0.00
22	92	06/95 RFO	Bobbin	ADI		1.44	10TH TSP	+10.59
		06/95 RFO	Bobbin	ODI	20	2.09	6TH TSP	+1.34
23	36	06/95 RFO	Bobbin	NQI		0.43	14TH TSP	+1.29
23	55	06/95 RFO	Bobbin	NQI		0.86	11TH TSP	-0.79
23	89	06/95 RFO	Bobbin	NQI		0.25	14TH TSP	+31.10
		06/95 RFO	Bobbin	NQI		0.59	14TH TSP	+32.31
		06/95 RFO	Bobbin	NQI		0.66	14TH TSP	+32.66
23	93	06/95 RFO	Bobbin	ODI	2	1.64	6TH TSP	+1.52
23	94	06/95 RFO	Bobbin	ADI		1.49	10TH TSP	+9.81
24	7	06/95 RFO	Bobbin	ODI	26	0.30	11TH TSP	+24.90
24	12	06/95 RFO	Bobbin	NQI		0.43	14TH TSP	+0.71
24	13	06/95 RFO	Bobbin	ODI	38	0.96	14TH TSP	+20.02
24	17	06/95 RFO	Bobbin	NQI		0.41	14TH TSP	+8.44
24	19	06/95 RFO	Bobbin	NQI		0.29	7TH TSP	-0.49
24	74	06/95 RFO	Bobbin	NQI		0.42	14TH TSP	+21.69
24	95	06/95 RFO	Bobbin	NQI		0.64	10TH TSP	+8.04
25	3	06/95 RFO	Bobbin	NQI		0.61	9TH TSP	+1.17
25	4	06/95 RFO	Bobbin	NQI		0.58	9TH TSP	+0.56
		06/95 RFO	Bobbin	ADI		0.73	9TH TSP	+15.12 to +16.07
25	21	06/95 RFO	Bobbin	NQI		0.20	13TH TSP	+0.73
		06/95 RFO	Bobbin	ODI	18	0.44	11TH TSP	+26.87
25	24	06/95 RFO	Bobbin	ODI	12	0.20	9TH TSP	+17.88
		06/95 RFO	Bobbin	ODI	38	0.41	12TH TSP	+2.97
25	69	06/95 RFO	Bobbin	ODI	37	0.58	4TH TSP	+8.86
25	71	06/95 RFO	Bobbin	NQI		0.44	6TH TSP	-0.85
		06/95 RFO	Bobbin	NQI		0.58	11TH TSP	-0.83
25	96	06/95 RFO	Bobbin	NQI		0.49	12TH TSP	+9.00
		06/95 RFO	Bobbin	ADI		3.88	8TH TSP	+1.07 to +5.86
		06/95 RFO	Bobbin	ADI		4.24	7TH TSP	+38.05 to +38.72
26	56	06/95 RFO	Bobbin	ODI	4	0.54	13TH TSP	+0.72
		06/95 RFO	Bobbin	ODI	31	0.79	13TH TSP	+0.75
26	67	06/95 RFO	Bobbin	NQI		0.29	12TH TSP	+24.26
26	75	06/95 RFO	Bobbin	NQI		1.00	4TH TSP	+19.13
		06/95 RFO	Bobbin	NQI		0.75	11TH TSP	+22.61
26	76	06/95 RFO	Bobbin	NQI		0.47	1ST TSP	+35.96
26	81	06/95 RFO	Bobbin	ODI	13	0.33	7TH TSP	+15.68
26	87	06/95 RFO	Bobbin	NQI		0.46	LTSF	+19.14
26	96	06/95 RFO	Bobbin	ODI	15	0.88	9TH TSP	+9.17
26	98	06/95 RFO	Bobbin	ODI	23	0.67	12TH TSP	+1.49
27	1	06/95 RFO	Bobbin	NQI		0.51	14TH TSP	+0.68
27	32	06/95 RFO	Bobbin	NQI		0.30	10TH TSP	+20.73
27	33	06/95 RFO	Bobbin	NQI		0.44	11TH TSP	-0.82
27	73	06/95 RFO	Bobbin	ODI	36	0.40	3RD TSP	+32.53
27	78	06/95 RFO	Bobbin	NQI		0.73	4TH TSP	-0.75
27	79	06/95 RFO	Bobbin	NQI		0.28	12TH TSP	-1.02
27	81	06/95 RFO	Bobbin	ODI	16	0.67	15TH TSP	+29.66
27	91	06/95 RFO	Bobbin	NQI		0.39	13TH TSP	+8.39
27	100	06/95 RFO	Bobbin	ODI	38	0.93	10TH TSP	+0.77
28	12	06/95 RFO	Bobbin	ODI	37	0.35	12TH TSP	+30.32
28	43	06/95 RFO	Bobbin	NQI		0.63	5TH TSP	+10.75
28	60	06/95 RFO	Bobbin	NQI		0.69	11TH TSP	-0.81
28	87	06/95 RFO	Bobbin	ODI	25	0.64	13TH TSP	+1.07

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 6 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
28	96	06/95 RFO	Bobbin	NQI		0.88	10TH TSP	+6.32
29	1	06/95 RFO	Bobbin	NQI		0.75	15TH TSP	-1.21
29	2	06/95 RFO	Bobbin	ODI	20	0.69	11TH TSP	+0.61
29	5	06/95 RFO	Bobbin	ODI	38	0.57	9TH TSP	+0.62
29	39	06/95 RFO	Bobbin	ODI	4	0.22	14TH TSP	-0.20
29	49	06/95 RFO	Bobbin	NQI		0.42	12TH TSP	+19.69
29	76	06/95 RFO	Bobbin	NQI		0.65	13TH TSP	+6.38
29	83	06/95 RFO	Bobbin	NQI		0.88	11TH TSP	-0.65
29	102	06/95 RFO	Bobbin	ADI		2.07	8TH TSP	+6.49
		06/95 RFO	Bobbin	NQI		0.53	11TH TSP	+21.51
		06/95 RFO	Bobbin	ODI	6	1.43	4TH TSP	+36.93
		06/95 RFO	Bobbin	ODI	7	1.25	8TH TSP	+27.01
		06/95 RFO	Bobbin	ODI	9	3.52	5TH TSP	+14.68
		06/95 RFO	Bobbin	ODI	18	1.02	8TH TSP	+7.12
		06/95 RFO	Bobbin	ODI	19	1.19	8TH TSP	+5.39
		06/95 RFO	Bobbin	ODI	25	1.30	8TH TSP	+9.08
30	6	06/95 RFO	Bobbin	ODI	6	0.49	8TH TSP	-1.16
30	21	06/95 RFO	Bobbin	ODI	24	0.46	7TH TSP	-0.80
30	38	06/95 RFO	Bobbin	NQI		0.48	3RD TSP	+5.08
30	57	06/95 RFO	Bobbin	NQI		0.33	7TH TSP	+20.39
30	86	06/95 RFO	Bobbin	NQI		0.44	12TH TSP	+12.09
30	103	06/95 RFO	Bobbin	ODI	20	0.54	8TH TSP	-0.56
30	104	06/95 RFO	Bobbin	NQI		0.58	8TH TSP	-0.50
		06/95 RFO	Bobbin	NQI		0.78	10TH TSP	+0.54
31	1	06/95 RFO	Bobbin	NQI		0.63	14TH TSP	+33.35
31	4	06/95 RFO	Bobbin	NQI		0.72	9TH TSP	+23.93
31	8	06/95 RFO	Bobbin	NQI		0.68	9TH TSP	+0.62
31	40	06/95 RFO	Bobbin	NQI		0.41	11TH TSP	+19.66
		06/95 RFO	Bobbin	ODI	6	0.29	13TH TSP	-0.08
		06/95 RFO	Bobbin	ODI	36	0.69	11TH TSP	+18.70
31	49	06/95 RFO	Bobbin	ODI	11	0.77	6TH TSP	+34.64
31	76	06/95 RFO	Bobbin	ODI	34	0.93	11TH TSP	-0.81
31	85	06/95 RFO	Bobbin	NQI		0.49	14TH TSP	+11.52
31	102	06/95 RFO	Bobbin	NQI		0.57	8TH TSP	+13.56
31	103	06/95 RFO	Bobbin	ODI	27	0.73	8TH TSP	+34.98
31	104	06/95 RFO	Bobbin	ODI	18	0.64	14TH TSP	+1.29
32	4	06/95 RFO	Bobbin	NQI		0.58	5TH TSP	+1.97
32	5	06/95 RFO	Bobbin	ODI	38	0.77	9TH TSP	+0.61
32	6	06/95 RFO	Bobbin	ODI	61	0.82	8TH TSP	-0.43
32	7	06/95 RFO	Bobbin	NQI		0.32	2ND TSP	+6.69
32	15	06/95 RFO	Bobbin	NQI		0.56	7TH TSP	-0.80
32	58	06/95 RFO	Bobbin	ODI	24	0.31	10TH TSP	+33.55
32	60	06/95 RFO	Bobbin	ODI	28	0.19	13TH TSP	-0.09
32	61	06/95 RFO	Bobbin	NQI		0.34	7TH TSP	+6.88
32	104	06/95 RFO	Bobbin	ODI	7	0.21	8TH TSP	+0.41
32	105	06/95 RFO	Bobbin	NQI		0.47	8TH TSP	+14.75
33	1	06/95 RFO	Bobbin	ODI	26	0.37	2ND TSP	+25.50
33	2	06/95 RFO	Bobbin	NQI		0.59	9TH TSP	+38.03
		06/95 RFO	Bobbin	ODI	29	0.48	14TH TSP	+0.23
33	4	06/95 RFO	Bobbin	NQI		0.94	10TH TSP	-0.56
33	6	06/95 RFO	Bobbin	NQI		0.97	8TH TSP	-0.55
33	30	06/95 RFO	Bobbin	ODI	35	0.95	13TH TSP	-0.15
33	81	06/95 RFO	Bobbin	ODI	18	0.66	11TH TSP	+28.26
33	106	06/95 RFO	Bobbin	NQI		0.68	9TH TSP	-0.20
33	107	06/95 RFO	Bobbin	NQI		0.44	5TH TSP	+1.17
		06/95 RFO	Bobbin	NQI		0.89	8TH TSP	-0.63
34	1	06/95 RFO	Bobbin	ADI		1.00	15TH TSP	+31.40
34	3	06/95 RFO	Bobbin	ODI	35	0.38	10TH TSP	+2.70
34	6	06/95 RFO	Bobbin	NQI		0.58	8TH TSP	-0.43
34	20	06/95 RFO	Bobbin	NQI		1.28	12TH TSP	+0.80
34	22	06/95 RFO	Bobbin	NQI		0.79	11TH TSP	+4.66
34	23	06/95 RFO	Bobbin	NQI		0.64	7TH TSP	-0.74
34	43	06/95 RFO	Bobbin	NQI		0.31	3RD TSP	-0.82
		06/95 RFO	Bobbin	NQI		0.36	2ND TSP	-0.86
		06/95 RFO	Bobbin	ODI	24	0.19	4TH TSP	-0.82

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 7 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
34	57	06/95 RFO	Bobbin	NQI		0.44	8TH TSP	+16.29
		06/95 RFO	Bobbin	ODI	28	0.25	8TH TSP	+17.56
34	70	06/95 RFO	Bobbin	NQI		0.34	7TH TSP	+4.62
34	73	06/95 RFO	Bobbin	ODI	29	3.18	LTSP	+21.57
34	83	06/95 RFO	Bobbin	NQI		0.37	9TH TSP	+32.39
34	87	06/95 RFO	Bobbin	ODI	49	1.01	15TH TSP	+0.33
34	88	06/95 RFO	Bobbin	NQI		0.60	15TH TSP	+0.29
34	91	06/95 RFO	Bobbin	ODI	16	0.49	14TH TSP	+1.41
35	5	06/95 RFO	Bobbin	NQI		0.40	8TH TSP	-0.71
35	6	06/95 RFO	Bobbin	NQI		0.45	8TH TSP	-0.51
35	73	06/95 RFO	Bobbin	NQI		0.54	13TH TSP	-0.20
35	75	06/95 RFO	Bobbin	ODI	12	1.51	2ND TSP	+18.97
		06/95 RFO	Bobbin	ODI	13	5.22	2ND TSP	+21.22
		06/95 RFO	Bobbin	ODI	13	6.99	2ND TSP	+23.93
35	84	06/95 RFO	Bobbin	ODI	17	0.46	8TH TSP	-0.80
35	92	06/95 RFO	Bobbin	NQI		0.26	LTSP	+19.03
35	108	06/95 RFO	Bobbin	ODI	32	0.87	8TH TSP	+0.43
36	1	06/95 RFO	Bobbin	ODI	5	1.07	14TH TSP	+33.02
		06/95 RFO	Bobbin	ODI	29	0.56	10TH TSP	+9.90
36	4	06/95 RFO	Bobbin	ODI	40	1.16	14TH TSP	+1.41
36	8	06/95 RFO	Bobbin	ODI	1	1.29	8TH TSP	-0.61
36	9	06/95 RFO	Bobbin	ODI	13	0.69	8TH TSP	-0.71
36	75	06/95 RFO	Bobbin	NQI		0.24	10TH TSP	+24.59
36	81	06/95 RFO	Bobbin	ODI	8	10.96	UTSP	+18.06
		06/95 RFO	Bobbin	ODI	14	0.26	9TH TSP	+16.00
		06/95 RFO	Bobbin	ODI	34	0.31	11TH TSP	+18.50
36	82	06/95 RFO	Bobbin	NQI		0.21	15TH TSP	+0.07
36	85	06/95 RFO	Bobbin	NQI		0.75	6TH TSP	+15.93
36	109	06/95 RFO	Bobbin	ODI	19	3.87	10TH TSP	+24.22
37	2	06/95 RFO	Bobbin	ODI	22	1.05	14TH TSP	+1.48
37	5	06/95 RFO	Bobbin	ODI	8	3.32	14TH TSP	+1.33
37	7	06/95 RFO	Bobbin	NQI		0.66	12TH TSP	+1.08
37	8	06/95 RFO	Bobbin	ODI	59	0.66	14TH TSP	+20.07
37	20	06/95 RFO	Bobbin	ODI	35	0.84	LTSP	+12.95
37	21	06/95 RFO	Bobbin	ODI	64	0.46	11TH TSP	+22.78
37	22	06/95 RFO	Bobbin	ODI	5	0.51	13TH TSP	+1.94
37	25	06/95 RFO	Bobbin	ODI	13	0.44	10TH TSP	+30.28
37	32	06/95 RFO	Bobbin	NQI		0.26	8TH TSP	+15.13
		06/95 RFO	Bobbin	NQI		0.31	8TH TSP	+28.11
		06/95 RFO	Bobbin	ODI	33	0.45	10TH TSP	+1.53
37	109	06/95 RFO	Bobbin	ODI	20	5.41	12TH TSP	+25.85
37	113	06/95 RFO	Bobbin	NQI		0.74	8TH TSP	-0.70
37	114	06/95 RFO	Bobbin	NQI		0.56	8TH TSP	-0.66
38	3	06/95 RFO	Bobbin	ODI	58	3.22	14TH TSP	+0.66
38	4	06/95 RFO	Bobbin	ODI	44	14.41	14TH TSP	+1.38
38	5	06/95 RFO	Bobbin	NQI		0.57	9TH TSP	+0.67
38	7	06/95 RFO	Bobbin	NQI		0.43	12TH TSP	+0.89
38	8	06/95 RFO	Bobbin	NQI		0.87	8TH TSP	-0.61
38	19	06/95 RFO	Bobbin	NQI		0.31	9TH TSP	+28.48
		06/95 RFO	Bobbin	ODI	20	0.57	11TH TSP	+4.78
38	34	06/95 RFO	Bobbin	NQI		0.52	13TH TSP	+0.51
38	61	06/95 RFO	Bobbin	NQI		0.27	15TH TSP	+25.62
38	90	06/95 RFO	Bobbin	ODI	48	0.48	7TH TSP	+5.27
38	91	06/95 RFO	Bobbin	NQI		0.35	9TH TSP	+4.74
38	94	06/95 RFO	Bobbin	NQI		0.13	1ST TSP	+0.37
		06/95 RFO	Bobbin	ODI	37	0.24	11TH TSP	+26.72
		06/95 RFO	Bobbin	ODI	44	0.41	11TH TSP	+22.85
38	100	06/95 RFO	Bobbin	NQI		0.45	12TH TSP	+33.41
38	101	06/95 RFO	Bobbin	ODI	38	0.21	13TH TSP	+14.88
38	105	06/95 RFO	Bobbin	NQI		0.27	14TH TSP	+9.99
38	115	06/95 RFO	Bobbin	NQI		0.68	8TH TSP	-0.69
39	1	06/95 RFO	Bobbin	NQI		0.87	15TH TSP	+14.65
		06/95 RFO	Bobbin	ODI	58	0.32	10TH TSP	+20.05
39	7	06/95 RFO	Bobbin	NQI		0.25	13TH TSP	-0.18
39	10	06/95 RFO	Bobbin	NQI		0.39	8TH TSP	+0.64

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 8 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		06/95 RFO	Bobbin	NQI		0.45	9TH TSP	+0.60
		06/95 RFO	Bobbin	NQI		0.92	8TH TSP	-0.75
39	12	06/95 RFO	Bobbin	ADI		3.94	LTSF	+20.82 to +28.95
39	15	06/95 RFO	Bobbin	NQI		0.31	8TH TSP	-0.56
39	23	06/95 RFO	Bobbin	ODI	68	0.45	7TH TSP	+4.24
39	62	06/95 RFO	Bobbin	ODI	11	0.47	15TH TSP	+30.10
		06/95 RFO	Bobbin	ODI	24	0.24	12TH TSP	+31.00
39	69	06/95 RFO	Bobbin	NQI		0.28	LTSF	+24.51
39	70	06/95 RFO	Bobbin	ODI	42	3.73	7TH TSP	+0.68
39	73	06/95 RFO	Bobbin	NQI		0.51	7TH TSP	+0.48
39	75	06/95 RFO	Bobbin	NQI		0.31	7TH TSP	+18.65
		06/95 RFO	Bobbin	NQI		0.38	5TH TSP	+21.16
40	1	06/95 RFO	Bobbin	ODI	12	1.75	14TH TSP	+1.43
		06/95 RFO	Bobbin	ODI	18	1.81	14TH TSP	+1.37
40	2	06/95 RFO	Bobbin	NQI		0.71	10TH TSP	+0.40
40	4	06/95 RFO	Bobbin	NQI		0.79	9TH TSP	+0.67
40	5	06/95 RFO	Bobbin	NQI		0.35	10TH TSP	+0.13
		06/95 RFO	Bobbin	NQI		0.57	10TH TSP	+2.96
40	6	06/95 RFO	Bobbin	NQI		0.28	10TH TSP	+0.38
40	11	06/95 RFO	Bobbin	NQI		0.54	8TH TSP	-0.63
40	80	06/95 RFO	Bobbin	ODI	21	3.48	15TH TSP	+8.17
40	99	06/95 RFO	Bobbin	NQI		0.22	LTSF	+13.64
40	116	06/95 RFO	Bobbin	NQI		0.81	UTSF	+0.43
40	117	06/95 RFO	Bobbin	ODI	27	0.42	15TH TSP	+26.04
41	1	06/95 RFO	Bobbin	NQI		0.67	2ND TSP	+6.95
		06/95 RFO	Bobbin	ODI	7	0.50	15TH TSP	+10.16
41	4	06/95 RFO	Bobbin	ODI	34	0.60	12TH TSP	-0.33
41	5	06/95 RFO	Bobbin	ODI	6	0.63	10TH TSP	+0.62
41	12	06/95 RFO	Bobbin	ADI		15.89	LTSF	+21.05 to +28.94
41	14	06/95 RFO	Bobbin	ODI	28	0.68	7TH TSP	+18.32
41	26	06/95 RFO	Bobbin	NQI		0.29	12TH TSP	+34.17
41	42	06/95 RFO	Bobbin	NQI		0.21	13TH TSP	+14.21
		06/95 RFO	Bobbin	NQI		0.32	13TH TSP	+13.93
		06/95 RFO	Bobbin	ODI	49	0.42	12TH TSP	+18.45
41	55	06/95 RFO	Bobbin	ODI	16	1.79	3RD TSP	+23.65
41	61	06/95 RFO	Bobbin	NQI		0.56	15TH TSP	+45.01
41	62	06/95 RFO	Bobbin	ODI	34	0.35	15TH TSP	+18.60
41	63	06/95 RFO	Bobbin	NQI		0.43	6TH TSP	+13.49
41	86	06/95 RFO	Bobbin	ODI	40	0.42	5TH TSP	+26.41
41	113	06/95 RFO	Bobbin	ODI	29	0.86	8TH TSP	+0.63
42	4	06/95 RFO	Bobbin	ODI	13	0.26	10TH TSP	+0.36
42	5	06/95 RFO	Bobbin	NQI		0.63	9TH TSP	+21.68
		06/95 RFO	Bobbin	ODI	18	0.56	10TH TSP	+0.53
42	7	06/95 RFO	Bobbin	ODI	49	0.85	8TH TSP	+0.69
42	14	06/95 RFO	Bobbin	NQI		0.60	5TH TSP	+32.84
42	25	06/95 RFO	Bobbin	ODI	64	0.48	LTSF	+22.61
42	26	06/95 RFO	Bobbin	ODI	33	0.30	9TH TSP	+3.85
42	48	06/95 RFO	Bobbin	ODI	33	0.38	5TH TSP	+19.89
42	61	06/95 RFO	Bobbin	ODI	17	0.36	15TH TSP	+36.47
42	91	06/95 RFO	Bobbin	ODI	5	0.10	13TH TSP	-0.23
42	100	06/95 RFO	Bobbin	ODI	30	0.57	8TH TSP	-0.52
42	112	06/95 RFO	Bobbin	ADI		5.90	2ND TSP	+21.06 to +29.51
42	114	06/95 RFO	Bobbin	ODI	11	0.20	11TH TSP	+26.37
43	7	06/95 RFO	Bobbin	NQI		0.63	8TH TSP	+0.66
43	21	06/95 RFO	Bobbin	NQI		0.26	9TH TSP	+35.69
		06/95 RFO	Bobbin	ODI	8	0.36	8TH TSP	+0.50
		06/95 RFO	Bobbin	ODI	20	0.53	6TH TSP	+27.70
43	62	06/95 RFO	Bobbin	ODI	18	0.40	10TH TSP	+9.88
43	81	06/95 RFO	Bobbin	ODI	35	0.80	13TH TSP	+5.22
43	86	06/95 RFO	Bobbin	NQI		0.32	10TH TSP	+0.05
43	115	06/95 RFO	Bobbin	ODI	4	0.66	8TH TSP	+0.56
44	16	06/95 RFO	Bobbin	NQI		0.30	5TH TSP	+25.04
44	35	06/95 RFO	Bobbin	ODI	22	0.30	14TH TSP	+23.23
44	40	06/95 RFO	Bobbin	ODI	26	0.36	7TH TSP	+19.59
44	81	06/95 RFO	Bobbin	ODI	9	0.50	8TH TSP	+17.06

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Ocone Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 9 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
44	114	06/95 RFO	Bobbin	NQI		0.42	6TH TSP	-0.61
45	1	06/95 RFO	Bobbin	ODI	19	0.59	14TH TSP	-0.75
		06/95 RFO	Bobbin	ODI	20	0.56	14TH TSP	-0.85
45	2	06/95 RFO	Bobbin	NQI		1.36	14TH TSP	+0.82
		06/95 RFO	Bobbin	ODI	17	1.24	14TH TSP	+0.93
45	5	06/95 RFO	Bobbin	NQI		0.69	9TH TSP	+11.93
45	17	06/95 RFO	Bobbin	NQI		0.36	2ND TSP	+6.65
45	22	06/95 RFO	Bobbin	NQI		0.34	1ST TSP	+3.98
45	23	06/95 RFO	Bobbin	ODI	51	0.87	14TH TSP	+0.61
45	36	06/95 RFO	Bobbin	NQI		0.31	12TH TSP	+18.20
45	42	06/95 RFO	Bobbin	NQI		0.33	LTSP	+42.56
45	47	06/95 RFO	Bobbin	ODI	55	0.38	14TH TSP	-0.25
45	62	06/95 RFO	Bobbin	ODI	34	0.32	9TH TSP	+18.06
45	82	06/95 RFO	Bobbin	ODI	18	0.54	6TH TSP	+37.20
		06/95 RFO	Bobbin	ODI	44	0.81	10TH TSP	+33.57
45	98	06/95 RFO	Bobbin	NQI		1.09	11TH TSP	-0.81
46	4	06/95 RFO	Bobbin	ODI	34	1.81	10TH TSP	+0.67
46	26	06/95 RFO	Bobbin	NQI		0.24	7TH TSP	+28.59
46	40	06/95 RFO	Bobbin	NQI		0.26	11TH TSP	+13.79
		06/95 RFO	Bobbin	ODI	51	0.51	11TH TSP	+14.75
46	42	06/95 RFO	Bobbin	NQI		0.11	10TH TSP	+3.59
		06/95 RFO	Bobbin	NQI		0.17	10TH TSP	+19.68
		06/95 RFO	Bobbin	NQI		0.21	10TH TSP	+16.14
		06/95 RFO	Bobbin	NQI		0.26	10TH TSP	+25.21
		06/95 RFO	Bobbin	NQI		0.29	11TH TSP	+20.59
46	50	06/95 RFO	Bobbin	ODI	32	0.33	13TH TSP	+7.38
46	51	06/95 RFO	Bobbin	NQI		0.85	5TH TSP	+20.96
46	54	06/95 RFO	Bobbin	NQI		0.52	8TH TSP	+25.47
46	65	06/95 RFO	Bobbin	NQI		0.35	2ND TSP	+11.18
46	76	06/95 RFO	Bobbin	NQI		0.37	7TH TSP	+30.51
46	83	06/95 RFO	Bobbin	NQI		0.35	LTSP	+17.95
46	95	06/95 RFO	Bobbin	NQI		0.63	14TH TSP	-0.47
46	99	06/95 RFO	Bobbin	ODI	10	1.06	11TH TSP	-0.69
46	111	06/95 RFO	Bobbin	NQI		0.32	1ST TSP	+30.97
47	1	06/95 RFO	Bobbin	ODI	30	0.41	14TH TSP	-0.81
		06/95 RFO	Bobbin	WAR	73	1.10	13TH TSP	+0.00
47	4	06/95 RFO	Bobbin	ODI	27	1.45	10TH TSP	+0.65
47	6	06/95 RFO	Bobbin	ODI	16	0.36	13TH TSP	+11.49
47	8	06/95 RFO	Bobbin	NQI		0.41	14TH TSP	+5.42
47	24	06/95 RFO	Bobbin	NQI		0.31	15TH TSP	+25.98
47	33	06/95 RFO	Bobbin	ODI	20	0.28	LTSP	+29.57
47	45	06/95 RFO	Bobbin	ODI	70	0.60	15TH TSP	+4.56
47	46	06/95 RFO	Bobbin	ODI	5	0.52	14TH TSP	+0.44
47	75	06/95 RFO	Bobbin	NQI		0.18	7TH TSP	-1.38
		06/95 RFO	Bobbin	NQI		0.19	9TH TSP	+20.67
		06/95 RFO	Bobbin	NQI		0.26	7TH TSP	+23.60
		06/95 RFO	Bobbin	NQI		0.29	6TH TSP	+16.59
		06/95 RFO	Bobbin	NQI		0.29	6TH TSP	+18.79
		06/95 RFO	Bobbin	NQI		0.40	9TH TSP	+30.29
		06/95 RFO	Bobbin	NQI		0.42	8TH TSP	+26.89
		06/95 RFO	Bobbin	NQI		0.20	10TH TSP	+16.67
		06/95 RFO	Bobbin	NQI		0.27	10TH TSP	+4.41
		06/95 RFO	Bobbin	ODI	30	0.20	6TH TSP	+36.24
		06/95 RFO	Bobbin	ODI	10	0.28	11TH TSP	+3.12
		06/95 RFO	Bobbin	ODI	22	0.30	12TH TSP	+31.98
		06/95 RFO	Bobbin	ODI	26	0.44	12TH TSP	+8.45
47	83	06/95 RFO	Bobbin	NQI		0.47	3RD TSP	+17.92
47	90	06/95 RFO	Bobbin	NQI		0.27	13TH TSP	+23.22
47	93	06/95 RFO	Bobbin	NQI		0.26	10TH TSP	+12.72
47	95	06/95 RFO	Bobbin	NQI		0.20	15TH TSP	+17.27
47	103	06/95 RFO	Bobbin	ODI	30	0.44	12TH TSP	+0.46
47	105	06/95 RFO	Bobbin	NQI		0.30	14TH TSP	+2.13
47	114	06/95 RFO	Bobbin	NQI		0.90	UTSF	+13.20
47	122	06/95 RFO	Bobbin	ODI	5	0.59	10TH TSP	+1.22
		06/95 RFO	Bobbin	ODI	22	0.86	15TH TSP	+18.54

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 10 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
48	6	06/95 RFO	Bobbin	NQI		0.48	12TH TSP	+2.11
		06/95 RFO	Bobbin	ODI	24	0.48	11TH TSP	+12.92
48	7	06/95 RFO	Bobbin	ODI	38	0.52	12TH TSP	+0.71
48	26	06/95 RFO	Bobbin	NQI		0.31	8TH TSP	+28.89
		06/95 RFO	Bobbin	ODI	56	0.58	11TH TSP	+25.96
48	29	06/95 RFO	Bobbin	NQI		0.54	5TH TSP	+34.44
48	34	06/95 RFO	Bobbin	ODI	41	0.86	10TH TSP	+4.11
48	44	06/95 RFO	Bobbin	ODI	11	0.20	14TH TSP	-0.40
		06/95 RFO	Bobbin	ODI	20	0.57	14TH TSP	+0.45
48	53	06/95 RFO	Bobbin	NQI		0.34	8TH TSP	+22.09
		06/95 RFO	Bobbin	NQI		0.37	7TH TSP	+27.00
		06/95 RFO	Bobbin	ODI	14	0.46	8TH TSP	+0.45
		06/95 RFO	Bobbin	ODI	16	0.41	7TH TSP	+19.44
		06/95 RFO	Bobbin	ODI	22	0.38	12TH TSP	+14.37
48	63	06/95 RFO	Bobbin	NQI		0.18	14TH TSP	+0.20
48	95	06/95 RFO	Bobbin	NQI		0.36	13TH TSP	+10.86
48	99	06/95 RFO	Bobbin	ODI	17	0.27	11TH TSP	+15.54
48	114	06/95 RFO	Bobbin	ODI	66	0.96	14TH TSP	+28.62
48	123	06/95 RFO	Bobbin	NQI		0.25	15TH TSP	+0.07
		06/95 RFO	Bobbin	NQI		0.32	15TH TSP	+6.99
		06/95 RFO	Bobbin	ODI	31	0.96	15TH TSP	+18.14
49	1	06/95 RFO	Bobbin	ODI	17	0.33	11TH TSP	+2.34
		06/95 RFO	Bobbin	ODI	30	0.35	11TH TSP	+2.17
49	5	06/95 RFO	Bobbin	ODI	2	0.58	9TH TSP	+18.27
49	9	06/95 RFO	Bobbin	ODI	18	1.16	15TH TSP	+28.13
49	48	06/95 RFO	Bobbin	NQI		0.40	13TH TSP	+25.28
49	51	06/95 RFO	Bobbin	NQI		0.62	3RD TSP	-0.78
49	56	06/95 RFO	Bobbin	NQI		0.45	13TH TSP	+32.20
49	73	06/95 RFO	Bobbin	ODI	14	0.13	14TH TSP	-0.28
49	76	06/95 RFO	Bobbin	NQI		0.29	14TH TSP	+0.35
49	82	06/95 RFO	Bobbin	NQI		0.43	LTSP	+16.06
49	107	06/95 RFO	Bobbin	ODI	27	0.20	14TH TSP	+2.40
49	111	06/95 RFO	Bobbin	ODI	30	1.79	14TH TSP	+0.89
49	112	06/95 RFO	Bobbin	ODI	22	0.88	13TH TSP	+0.79
49	113	06/95 RFO	Bobbin	NQI		0.76	11TH TSP	+0.84
49	114	06/95 RFO	Bobbin	ODI	22	2.65	11TH TSP	+1.44
49	119	06/95 RFO	Bobbin	ODI	34	0.75	7TH TSP	+36.14
		06/95 RFO	Bobbin	ODI	32	0.65	15TH TSP	+25.38
49	121	06/95 RFO	Bobbin	ODI	34	0.37	13TH TSP	+1.45
50	3	06/95 RFO	Bobbin	NQI		0.54	9TH TSP	+0.73
		06/95 RFO	Bobbin	NQI		0.61	9TH TSP	+0.63
		06/95 RFO	Bobbin	ODI	12	0.64	9TH TSP	+19.67
		06/95 RFO	Bobbin	ODI	21	0.52	9TH TSP	+19.27
50	4	06/95 RFO	Bobbin	ODI	12	1.25	9TH TSP	+19.09
50	11	06/95 RFO	Bobbin	NQI		0.53	8TH TSP	+7.65
		06/95 RFO	Bobbin	NQI		0.34	11TH TSP	+3.52
		06/95 RFO	Bobbin	ODI	27	0.37	11TH TSP	+26.50
50	29	06/95 RFO	Bobbin	NQI		0.43	13TH TSP	+31.29
50	58	06/95 RFO	Bobbin	NQI		0.30	11TH TSP	+28.95
50	62	06/95 RFO	Bobbin	NQI		0.37	13TH TSP	+0.39
50	107	06/95 RFO	Bobbin	NQI		0.36	14TH TSP	+6.36
50	108	06/95 RFO	Bobbin	ODI	19	0.35	12TH TSP	+6.34
51	3	06/95 RFO	Bobbin	ODI	7	0.58	9TH TSP	+0.63
		06/95 RFO	Bobbin	ODI	14	0.53	9TH TSP	+19.38
		06/95 RFO	Bobbin	ODI	16	0.58	9TH TSP	+19.73
		06/95 RFO	Bobbin	ODI	31	0.59	9TH TSP	+0.78
51	6	06/95 RFO	Bobbin	NQI		0.50	2ND TSP	+2.64
51	45	06/95 RFO	Bobbin	NQI		0.33	13TH TSP	+13.21
		06/95 RFO	Bobbin	ODI	6	0.49	13TH TSP	+14.02
51	47	06/95 RFO	Bobbin	ODI	31	0.36	13TH TSP	+11.36
51	69	06/95 RFO	Bobbin	NQI		0.46	2ND TSP	+13.00
51	74	06/95 RFO	Bobbin	ODI	15	0.30	10TH TSP	+10.21
51	75	06/95 RFO	Bobbin	NQI		0.30	10TH TSP	+31.39
51	77	06/95 RFO	Bobbin	ODI	5	0.26	14TH TSP	+5.52
51	104	06/95 RFO	Bobbin	NQI		0.25	14TH TSP	+1.92

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 11 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
52	4	06/95 RFO	Bobbin	ODI	16	0.52	9TH TSP	+16.30
		06/95 RFO	Bobbin	ODI	19	0.47	9TH TSP	+16.09
52	26	06/95 RFO	Bobbin	NQI		0.91	12TH TSP	+28.55
52	29	06/95 RFO	Bobbin	NQI		0.44	15TH TSP	+12.40
52	35	06/95 RFO	Bobbin	NQI		0.45	LTSF	+21.85
52	54	06/95 RFO	Bobbin	ODI	10	0.20	7TH TSP	+23.29
52	75	06/95 RFO	Bobbin	ODI	38	0.40	11TH TSP	+22.34
52	77	06/95 RFO	Bobbin	NQI		0.13	8TH TSP	+31.64
		06/95 RFO	Bobbin	NQI		0.15	6TH TSP	+25.66
		06/95 RFO	Bobbin	NQI		0.24	6TH TSP	+11.84
		06/95 RFO	Bobbin	NQI		0.26	7TH TSP	+36.20
		06/95 RFO	Bobbin	NQI		0.30	7TH TSP	+25.45
		06/95 RFO	Bobbin	NQI		0.31	7TH TSP	+24.80
		06/95 RFO	Bobbin	NQI		0.33	6TH TSP	+20.64
		06/95 RFO	Bobbin	NQI		0.37	6TH TSP	+26.24
		06/95 RFO	Bobbin	NQI		0.24	15TH TSP	+41.63
		06/95 RFO	Bobbin	ODI	3	0.23	7TH TSP	+9.06
		06/95 RFO	Bobbin	ODI	10	0.15	9TH TSP	+14.41
		06/95 RFO	Bobbin	ODI	10	0.21	9TH TSP	+13.58
		06/95 RFO	Bobbin	ODI	10	0.29	8TH TSP	+7.93
		06/95 RFO	Bobbin	ODI	28	0.15	7TH TSP	+5.20
		06/95 RFO	Bobbin	ODI	31	0.31	3RD TSP	+30.06
		06/95 RFO	Bobbin	ODI	31	0.35	7TH TSP	+34.69
		06/95 RFO	Bobbin	ODI	31	0.41	9TH TSP	+34.08
		06/95 RFO	Bobbin	ODI	34	0.30	9TH TSP	+12.32
		06/95 RFO	Bobbin	ODI	36	0.31	8TH TSP	+30.66
		06/95 RFO	Bobbin	ODI	37	0.21	8TH TSP	+2.01
		06/95 RFO	Bobbin	ODI	37	0.31	9TH TSP	+35.62
		06/95 RFO	Bobbin	ODI	37	0.50	7TH TSP	+3.53
52	98	06/95 RFO	Bobbin	NQI		0.56	14TH TSP	+0.83
52	108	06/95 RFO	Bobbin	ODI	15	0.71	14TH TSP	+0.80
52	124	06/95 RFO	Bobbin	NQI		0.47	10TH TSP	+0.57
53	1	06/95 RFO	Bobbin	ODI	19	0.59	11TH TSP	+0.54
53	3	06/95 RFO	Bobbin	NQI		0.52	13TH TSP	+0.86
53	7	06/95 RFO	Bobbin	NQI		0.38	13TH TSP	+25.27
53	28	06/95 RFO	Bobbin	NQI		0.44	15TH TSP	+31.05
53	54	06/95 RFO	Bobbin	NQI		0.59	14TH TSP	+17.31
53	71	06/95 RFO	Bobbin	ODI	28	0.43	14TH TSP	+0.46
53	77	06/95 RFO	Bobbin	NQI		0.52	3RD TSP	+26.06
53	86	06/95 RFO	Bobbin	ODI	6	0.59	8TH TSP	+8.08
53	91	06/95 RFO	Bobbin	ODI	33	0.49	13TH TSP	+21.20
53	101	06/95 RFO	Bobbin	NQI		0.28	13TH TSP	+0.41
54	3	06/95 RFO	Bobbin	NQI		1.19	14TH TSP	+0.92
54	19	06/95 RFO	Bobbin	NQI		0.25	10TH TSP	+19.26
54	64	06/95 RFO	Bobbin	ODI	27	0.24	8TH TSP	+24.96
54	93	06/95 RFO	Bobbin	NQI		0.46	3RD TSP	+30.55
54	103	06/95 RFO	Bobbin	NQI		0.17	15TH TSP	+14.24
54	126	06/95 RFO	Bobbin	ODI	25	0.36	12TH TSP	+14.82
54	127	06/95 RFO	Bobbin	ODI	23	1.49	15TH TSP	+20.50
		06/95 RFO	Bobbin	ADI		4.11	13TH TSP	+3.05 to +6.04
55	1	06/95 RFO	Bobbin	ADI		1.40	11TH TSP	+3.13
55	29	06/95 RFO	Bobbin	NQI		0.17	7TH TSP	+33.21
		06/95 RFO	Bobbin	NQI		0.24	9TH TSP	+0.38
		06/95 RFO	Bobbin	ODI	16	0.20	8TH TSP	+36.44
55	45	06/95 RFO	Bobbin	NQI		0.42	8TH TSP	+11.19
55	76	06/95 RFO	Bobbin	ODI	10	0.15	14TH TSP	+0.18
55	77	06/95 RFO	Bobbin	ODI	35	0.24	8TH TSP	+0.00
55	85	06/95 RFO	Bobbin	ODI	26	0.26	12TH TSP	+16.00
55	108	06/95 RFO	Bobbin	ODI	8	0.28	14TH TSP	+1.44
55	124	06/95 RFO	Bobbin	ODI	37	6.03	13TH TSP	+0.74
55	125	06/95 RFO	Bobbin	ODI	47	0.81	13TH TSP	+1.03
56	1	06/95 RFO	Bobbin	NQI		0.43	11TH TSP	+4.30
56	14	06/95 RFO	Bobbin	ODI	35	0.22	11TH TSP	+33.72
56	18	06/95 RFO	Bobbin	ODI	37	0.27	9TH TSP	+32.20
56	21	06/95 RFO	Bobbin	NQI		0.23	11TH TSP	+26.46

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 12 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
56	32	06/95 RFO	Bobbin	NQI		0.32	11TH TSP	+33.84
56	39	06/95 RFO	Bobbin	NQI		0.34	12TH TSP	+10.77
57	4	06/95 RFO	Bobbin	NQI		0.47	9TH TSP	+17.73
57	5	06/95 RFO	Bobbin	NQI		0.39	1ST TSP	+3.22
57	55	06/95 RFO	Bobbin	NQI		0.51	LTSF	+3.53
		06/95 RFO	Bobbin	ADI		0.97	13TH TSP	+17.53
57	92	06/95 RFO	Bobbin	ODI	5	0.31	6TH TSP	+34.74
57	93	06/95 RFO	Bobbin	NQI		0.34	8TH TSP	+16.28
57	103	06/95 RFO	Bobbin	NQI		0.52	9TH TSP	+3.33
57	114	06/95 RFO	Bobbin	NQI		0.67	11TH TSP	+7.67
57	126	06/95 RFO	Bobbin	NQI		0.93	14TH TSP	+0.85
57	128	06/95 RFO	Bobbin	ODI	1	0.99	13TH TSP	+2.60
		06/95 RFO	Bobbin	ODI	12	0.63	13TH TSP	+2.16
58	1	06/95 RFO	Bobbin	ODI	24	0.39	14TH TSP	+23.93
		06/95 RFO	Bobbin	ODI	33	0.33	10TH TSP	+32.30
58	3	06/95 RFO	Bobbin	ODI	13	0.34	10TH TSP	+0.35
58	6	06/95 RFO	Bobbin	ODI	31	0.63	13TH TSP	+19.90
58	18	06/95 RFO	Bobbin	ODI	21	1.03	15TH TSP	+0.49
58	62	06/95 RFO	Bobbin	ODI	19	0.50	15TH TSP	+33.25
58	94	06/95 RFO	Bobbin	ODI	32	0.67	2ND TSP	+23.26
58	124	06/95 RFO	Bobbin	ODI	16	0.70	9TH TSP	-0.75
58	125	06/95 RFO	Bobbin	NQI		0.82	9TH TSP	+22.29
58	129	06/95 RFO	Bobbin	ODI	8	0.75	12TH TSP	+2.18
		06/95 RFO	Bobbin	ODI	22	0.66	14TH TSP	+31.29
59	2	06/95 RFO	Bobbin	ODI	41	0.72	10TH TSP	+0.21
59	3	06/95 RFO	Bobbin	ODI	11	1.40	14TH TSP	+0.81
59	4	06/95 RFO	Bobbin	ODI	24	1.22	14TH TSP	+0.96
59	8	06/95 RFO	Bobbin	ODI	3	0.95	9TH TSP	-0.55
59	27	06/95 RFO	Bobbin	NQI		0.47	1ST TSP	+10.71
59	39	06/95 RFO	Bobbin	NQI		0.36	9TH TSP	+24.95
		06/95 RFO	Bobbin	NQI		0.60	15TH TSP	+14.86
59	61	06/95 RFO	Bobbin	NQI		0.36	6TH TSP	+16.58
		06/95 RFO	Bobbin	NQI		0.45	6TH TSP	+17.09
		06/95 RFO	Bobbin	NQI		0.71	6TH TSP	+15.42
		06/95 RFO	Bobbin	ODI	7	0.92	5TH TSP	+31.09
		06/95 RFO	Bobbin	ODI	18	1.25	5TH TSP	+29.77
59	71	06/95 RFO	Bobbin	NQI		0.39	1ST TSP	+17.13
59	96	06/95 RFO	Bobbin	NQI		0.83	13TH TSP	+0.77
59	115	06/95 RFO	Bobbin	NQI		0.27	8TH TSP	+31.86
59	118	06/95 RFO	Bobbin	NQI		0.59	9TH TSP	-0.52
59	122	06/95 RFO	Bobbin	NQI		1.01	9TH TSP	-0.73
59	124	06/95 RFO	Bobbin	NQI		0.32	15TH TSP	-0.39
60	9	06/95 RFO	Bobbin	ODI	37	0.27	15TH TSP	+37.44
60	32	06/95 RFO	Bobbin	NQI		0.26	12TH TSP	+26.31
60	55	06/95 RFO	Bobbin	ODI	36	0.48	8TH TSP	+33.68
60	97	06/95 RFO	Bobbin	NQI		0.46	10TH TSP	+22.02
60	106	06/95 RFO	Bobbin	ODI	24	0.18	13TH TSP	-0.07
60	124	06/95 RFO	Bobbin	NQI		0.76	9TH TSP	-0.80
60	125	06/95 RFO	Bobbin	ODI	2	1.30	9TH TSP	+22.90
60	128	06/95 RFO	Bobbin	NQI		0.52	15TH TSP	-0.41
61	1	06/95 RFO	Bobbin	NQI		0.62	9TH TSP	+30.07
61	2	06/95 RFO	Bobbin	ODI	5	1.21	14TH TSP	+1.29
61	24	06/95 RFO	Bobbin	ODI	50	0.43	10TH TSP	+12.77
61	58	06/95 RFO	Bobbin	ODI	24	0.50	13TH TSP	+0.00
61	88	06/95 RFO	Bobbin	ODI	3	0.36	12TH TSP	+34.34
61	108	06/95 RFO	Bobbin	ODI	13	0.34	13TH TSP	+23.30
61	111	06/95 RFO	Bobbin	ODI	32	0.40	LTSF	+35.09
		06/95 RFO	Bobbin	ODI	32	0.40	LTSF	+35.13
		06/95 RFO	Bobbin	ODI	2	0.71	14TH TSP	+0.72
		06/95 RFO	Bobbin	ODI	2	0.71	14TH TSP	+0.72
61	121	06/95 RFO	Bobbin	NQI		1.36	9TH TSP	-0.76
61	122	06/95 RFO	Bobbin	WAR	14	0.74	9TH TSP	+0.00
61	124	06/95 RFO	Bobbin	NQI		0.92	9TH TSP	-0.76
		06/95 RFO	Bobbin	NQI		0.42	14TH TSP	+1.13
		06/95 RFO	Bobbin	NQI		0.48	10TH TSP	+2.97

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 13 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
61	126	06/95 RFO	Bobbin	ODI	15	0.59	10TH TSP	+20.02
62	1	06/95 RFO	Bobbin	NQI		0.18	15TH TSP	-0.02
62	14	06/95 RFO	Bobbin	ODI	45	0.36	15TH TSP	+33.38
62	24	06/95 RFO	Bobbin	NQI		0.40	11TH TSP	+30.93
62	99	06/95 RFO	Bobbin	NQI		0.39	7TH TSP	+11.54
62	108	06/95 RFO	Bobbin	NQI		0.19	14TH TSP	+0.16
62	115	06/95 RFO	Bobbin	ODI	14	2.70	14TH TSP	+1.27
62	126	06/95 RFO	Bobbin	ADI		1.88	9TH TSP	+21.73 to +34.17
62	127	06/95 RFO	Bobbin	ODI	4	0.41	9TH TSP	-0.14
		06/95 RFO	Bobbin	ODI	18	1.03	14TH TSP	+0.71
		06/95 RFO	Bobbin	ODI	20	0.35	14TH TSP	+0.94
62	129	06/95 RFO	Bobbin	NQI		0.35	3RD TSP	+33.75
		06/95 RFO	Bobbin	ODI	15	0.58	11TH TSP	+6.02
63	1	06/95 RFO	Bobbin	ODI	30	0.37	11TH TSP	+0.50
63	6	06/95 RFO	Bobbin	NQI		0.19	10TH TSP	+8.08
63	15	06/95 RFO	Bobbin	NQI		0.50	3RD TSP	+21.89
		06/95 RFO	Bobbin	NQI		0.23	12TH TSP	+31.20
		06/95 RFO	Bobbin	NQI		0.24	12TH TSP	+31.00
		06/95 RFO	Bobbin	ODI	36	0.41	4TH TSP	+33.21
63	38	06/95 RFO	Bobbin	ODI	36	0.35	10TH TSP	+13.10
63	40	06/95 RFO	Bobbin	ODI	45	0.38	8TH TSP	+26.30
63	42	06/95 RFO	Bobbin	ODI	63	0.71	12TH TSP	+21.55
63	128	06/95 RFO	Bobbin	WAR	33	0.62	9TH TSP	+0.00
64	38	06/95 RFO	Bobbin	ODI	21	0.34	15TH TSP	+23.19
64	48	06/95 RFO	Bobbin	ODI	29	0.25	14TH TSP	+3.77
64	108	06/95 RFO	Bobbin	ODI	72	0.43	11TH TSP	+11.73
64	124	06/95 RFO	Bobbin	WAR	33	0.74	9TH TSP	+0.00
64	125	06/95 RFO	Bobbin	NQI		0.39	9TH TSP	-0.66
		06/95 RFO	Bobbin	ADI		1.32	9TH TSP	+22.41 to +27.46
65	4	06/95 RFO	Bobbin	ODI	24	0.53	9TH TSP	-0.46
65	5	06/95 RFO	Bobbin	ODI	22	1.00	14TH TSP	+0.93
65	12	06/95 RFO	Bobbin	NQI		0.39	13TH TSP	+21.21
65	74	06/95 RFO	Bobbin	NQI		0.28	15TH TSP	+21.15
65	76	06/95 RFO	Bobbin	NQI		0.33	8TH TSP	+19.73
65	95	06/95 RFO	Bobbin	ODI	19	0.57	3RD TSP	+29.28
65	99	06/95 RFO	Bobbin	ODI	29	0.87	9TH TSP	+17.00
65	115	06/95 RFO	Bobbin	ODI	43	1.73	14TH TSP	+0.95
65	121	06/95 RFO	Bobbin	NQI		0.28	11TH TSP	+28.04
65	126	06/95 RFO	Bobbin	WAR	12	0.92	9TH TSP	+0.00
65	127	06/95 RFO	Bobbin	NQI		0.87	7TH TSP	+38.10
		06/95 RFO	Bobbin	NQI		1.18	9TH TSP	+25.90
		06/95 RFO	Bobbin	NQI		1.35	9TH TSP	-0.74
65	128	06/95 RFO	Bobbin	ODI	12	1.03	9TH TSP	-0.16
65	130	06/95 RFO	Bobbin	ODI	12	0.35	10TH TSP	+13.93
66	2	06/95 RFO	Bobbin	ODI	5	0.30	15TH TSP	+33.30
66	29	06/95 RFO	Bobbin	NQI		0.26	14TH TSP	+9.69
		06/95 RFO	Bobbin	NQI		0.28	14TH TSP	+4.31
66	32	06/95 RFO	Bobbin	NQI		0.17	13TH TSP	-0.16
66	57	06/95 RFO	Bobbin	NQI		0.58	8TH TSP	+6.98
66	65	06/95 RFO	Bobbin	ODI	34	0.54	11TH TSP	+21.71
		06/95 RFO	Bobbin	ODI	47	0.53	11TH TSP	+22.96
66	111	06/95 RFO	Bobbin	NQI		0.25	11TH TSP	+25.68
66	127	06/95 RFO	Bobbin	ODI	35	1.03	9TH TSP	+22.86
66	128	06/95 RFO	Bobbin	NQI		0.66	8TH TSP	-0.63
		06/95 RFO	Bobbin	NQI		0.66	8TH TSP	-0.63
66	129	06/95 RFO	Bobbin	ODI	4	0.49	9TH TSP	-0.62
66	131	06/95 RFO	Bobbin	ODI	12	1.10	15TH TSP	+4.90
67	3	06/95 RFO	Bobbin	ODI	9	0.52	14TH TSP	+1.35
67	4	06/95 RFO	Bobbin	NQI		0.33	10TH TSP	+33.88
67	14	06/95 RFO	Bobbin	ODI	51	0.37	9TH TSP	+24.11
67	26	06/95 RFO	Bobbin	ADI		1.63	LTSF	+20.82 to +28.81
67	29	06/95 RFO	Bobbin	ODI	33	0.33	7TH TSP	+17.36
67	30	06/95 RFO	Bobbin	ODI	51	0.64	3RD TSP	+28.51
67	33	06/95 RFO	Bobbin	NQI		0.31	3RD TSP	-0.26
		06/95 RFO	Bobbin	ODI	39	0.39	1ST TSP	+3.64

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 14 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
67	62	06/95 RFO	Bobbin	ODI	29	0.38	12TH TSP	+12.72 FL
67	80	06/95 RFO	Bobbin	ODI	32	0.84	15TH TSP	+32.46 FL
67	84	06/95 RFO	Bobbin	NQI		0.25	6TH TSP	+2.29 FL
67	127	06/95 RFO	Bobbin	NQI		0.65	6TH TSP	-0.59 FL
		06/95 RFO	Bobbin	ODI	31	1.27	8TH TSP	+0.23 FL
67	129	06/95 RFO	Bobbin	NQI		0.77	15TH TSP	-0.52 FL
68	2	06/95 RFO	Bobbin	NQI		0.92	15TH TSP	+0.09 FL
68	7	06/95 RFO	Bobbin	NQI		0.29	11TH TSP	+7.63 FL
68	40	06/95 RFO	Bobbin	ODI	33	0.53	14TH TSP	-0.15 FL
68	82	06/95 RFO	Bobbin	NQI		0.38	13TH TSP	+17.04 FL
68	113	06/95 RFO	Bobbin	NQI		0.40	LTSF	+13.12 FL
68	128	06/95 RFO	Bobbin	ODI	56	1.32	8TH TSP	-0.68 FL
69	1	06/95 RFO	Bobbin	ODI	6	1.10	14TH TSP	+1.64 14TH TSP
69	4	06/95 RFO	Bobbin	NQI		0.33	9TH TSP	-0.77 14TH TSP
69	24	06/95 RFO	Bobbin	NQI		0.42	12TH TSP	+23.97 FL
69	25	06/95 RFO	Bobbin	NQI		0.50	4TH TSP	+6.75 FL
69	79	06/95 RFO	Bobbin	ODI	21	0.29	6TH TSP	+36.65 FL
69	124	06/95 RFO	Bobbin	ODI	27	2.10	14TH TSP	+0.69 FL
69	129	06/95 RFO	Bobbin	ODI	8	0.82	9TH TSP	+23.22 FL
69	132	06/95 RFO	Bobbin	ADI		0.94	14TH TSP	+32.21 FL
70	12	06/95 RFO	Bobbin	NQI		0.33	6TH TSP	-0.78 FL
70	13	06/95 RFO	Bobbin	NQI		0.33	6TH TSP	-0.78 FL
70	94	06/95 RFO	Bobbin	ODI	31	0.44	3RD TSP	+25.95 FL
70	111	06/95 RFO	Bobbin	ODI	39	0.93	6TH TSP	-0.60 FL
70	130	06/95 RFO	Bobbin	WAR	34	0.53	8TH TSP	+0.43 FL
70	131	06/95 RFO	Bobbin	ADI		0.96	10TH TSP	+5.91 FL
		06/95 RFO	Bobbin	ADI		1.45	10TH TSP	+5.10 FL
71	3	06/95 RFO	Bobbin	ODI	6	0.44	10TH TSP	+5.33 14TH TSP
71	5	06/95 RFO	Bobbin	ODI	11	0.72	9TH TSP	-0.66 FL
71	6	06/95 RFO	Bobbin	NQI		0.90	6TH TSP	+7.57 FL
		06/95 RFO	Bobbin	ODI	26	0.32	11TH TSP	+0.48 FL
71	22	06/95 RFO	Bobbin	NQI		0.56	10TH TSP	-0.77 FL
71	29	06/95 RFO	Bobbin	ODI	2	0.35	6TH TSP	+21.33 FL
71	56	06/95 RFO	Bobbin	ODI	51	0.48	10TH TSP	+33.00 FL
71	66	06/95 RFO	Bobbin	NQI		0.53	10TH TSP	+11.26 FL
71	68	06/95 RFO	Bobbin	ODI	10	0.47	1ST TSP	+31.50 FL
71	110	06/95 RFO	Bobbin	ODI	26	0.28	8TH TSP	+20.75 FL
72	3	06/95 RFO	Bobbin	ODI	12	0.60	10TH TSP	+4.77 14TH TSP
72	4	06/95 RFO	Bobbin	NQI		0.50	10TH TSP	+6.51 FL
72	6	06/95 RFO	Bobbin	NQI		0.84	10TH TSP	+9.08 FL
		06/95 RFO	Bobbin	ODI	24	0.25	11TH TSP	+0.00 FL
72	12	06/95 RFO	Bobbin	NQI		0.79	12TH TSP	+0.49 FL
72	13	06/95 RFO	Bobbin	NQI		0.28	12TH TSP	+0.54 FL
		06/95 RFO	Bobbin	ODI	39	0.27	12TH TSP	+0.34 FL
72	15	06/95 RFO	Bobbin	ODI	18	0.36	12TH TSP	-0.54 FL
		06/95 RFO	Bobbin	ODI	34	0.30	12TH TSP	+0.41 FL
72	19	06/95 RFO	Bobbin	NQI		0.48	12TH TSP	+0.49 FL
		06/95 RFO	Bobbin	ODI	25	1.28	11TH TSP	+0.49 FL
72	31	06/95 RFO	Bobbin	NQI		0.36	10TH TSP	+0.29 FL
72	41	06/95 RFO	Bobbin	ODI	20	1.39	10TH TSP	+0.51 FL
72	58	06/95 RFO	Bobbin	ODI	10	0.60	14TH TSP	-0.23 FL
72	72	06/95 RFO	Bobbin	NQI		0.24	8TH TSP	+21.69 FL
72	83	06/95 RFO	Bobbin	NQI		0.47	14TH TSP	+31.82 FL
72	103	06/95 RFO	Bobbin	NQI		0.70	4TH TSP	+34.24 FL
73	5	06/95 RFO	Bobbin	ODI	7	0.38	10TH TSP	+32.88 FL
73	6	06/95 RFO	Bobbin	ODI	8	0.55	12TH TSP	+0.55 FL
73	9	06/95 RFO	Bobbin	ODI	16	0.96	13TH TSP	+0.58 FL
73	10	06/95 RFO	Bobbin	ODI	17	0.74	11TH TSP	+5.60 FL
73	13	06/95 RFO	Bobbin	NQI		0.24	2ND TSP	-0.23 FL
73	29	06/95 RFO	Bobbin	ODI	14	0.40	11TH TSP	+0.46 FL
73	30	06/95 RFO	Bobbin	ODI	35	0.32	3RD TSP	+11.01 FL
73	33	06/95 RFO	Bobbin	ODI	7	0.35	11TH TSP	+13.77 FL
73	44	06/95 RFO	Bobbin	NQI		0.65	8TH TSP	-0.72 FL
73	103	06/95 RFO	Bobbin	ODI	27	0.50	9TH TSP	+27.45 FL
74	31	06/95 RFO	Bobbin	NQI		0.24	4TH TSP	+32.95 FL

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 15 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		06/95 RFO	Bobbin	ODI	31	0.24	4TH TSP	+11.66
		06/95 RFO	Bobbin	ODI	33	0.34	8TH TSP	+10.46
74	33	06/95 RFO	Bobbin	NQI		0.33	10TH TSP	+12.34
74	47	06/95 RFO	Bobbin	ODI	31	0.33	15TH TSP	+13.11
74	63	06/95 RFO	Bobbin	NQI		0.59	6TH TSP	+0.57
74	69	06/95 RFO	Bobbin	NQI		0.62	1ST TSP	+29.32
74	124	06/95 RFO	Bobbin	ODI	39	0.72	14TH TSP	+1.18
75	13	06/95 RFO	Bobbin	ODI	22	0.35	LTSP	+33.36
75	99	06/95 RFO	Bobbin	NQI		0.85	11TH TSP	+33.91
75	112	06/95 RFO	Bobbin	ODI	12	1.11	14TH TSP	+1.05
75	116	06/95 RFO	Bobbin	ODI	16	0.34	8TH TSP	+0.98
75	121	06/95 RFO	Bobbin	NQI		1.21	3RD TSP	-0.77
75	125	06/95 RFO	Bobbin	ODI	16	0.55	9TH TSP	-0.64
76	71	06/95 RFO	Bobbin	NQI		1.29	LTSP	-0.03
76	76	06/95 RFO	Bobbin	NQI		0.20	9TH TSP	+0.45
		06/95 RFO	Bobbin	NQI		0.21	6TH TSP	+12.59
		06/95 RFO	Bobbin	ODI	24	0.21	6TH TSP	+14.40
76	118	06/95 RFO	Bobbin	ODI	1	1.08	11TH TSP	+24.71
		06/95 RFO	Bobbin	ODI	6	0.79	12TH TSP	+28.99
		06/95 RFO	Bobbin	ODI	9	1.25	15TH TSP	+21.62
		06/95 RFO	Bobbin	ODI	12	1.93	14TH TSP	+1.75
		06/95 RFO	Bobbin	ODI	16	0.55	14TH TSP	+14.98
		06/95 RFO	Bobbin	ODI	20	1.16	11TH TSP	+19.82
		06/95 RFO	Bobbin	ODI	26	1.99	11TH TSP	+25.26
		06/95 RFO	Bobbin	ODI	35	0.53	11TH TSP	+21.97
77	25	06/95 RFO	Bobbin	NQI		0.52	11TH TSP	+7.61
77	35	06/95 RFO	Bobbin	ODI	33	0.35	15TH TSP	+0.64
77	44	06/95 RFO	Bobbin	NQI		0.68	3RD TSP	-0.72
77	50	06/95 RFO	Bobbin	NQI		0.37	7TH TSP	-0.76
77	61	06/95 RFO	Bobbin	NQI		0.62	12TH TSP	+16.93
77	66	06/95 RFO	Bobbin	NQI		0.37	15TH TSP	+9.15
77	71	06/95 RFO	Bobbin	NQI		0.44	15TH TSP	+15.19
77	99	06/95 RFO	Bobbin	NQI		0.58	10TH TSP	+27.73
77	108	06/95 RFO	Bobbin	ODI	38	0.52	9TH TSP	+25.52
77	122	06/95 RFO	Bobbin	ODI	25	0.56	14TH TSP	+0.72
77	123	06/95 RFO	Bobbin	NQI		0.28	14TH TSP	+1.23
78	20	06/95 RFO	Bobbin	ODI	12	0.57	11TH TSP	+36.46
78	22	06/95 RFO	Bobbin	ODI	2	0.54	11TH TSP	+34.00
78	34	06/95 RFO	Bobbin	ODI	13	1.04	4TH TSP	-0.66
78	35	06/95 RFO	Bobbin	ODI	3	0.50	11TH TSP	+27.33
78	39	06/95 RFO	Bobbin	NQI		0.57	15TH TSP	+0.48
78	41	06/95 RFO	Bobbin	NQI		0.41	4TH TSP	-0.82
78	42	06/95 RFO	Bobbin	NQI		0.71	4TH TSP	-0.70
78	111	06/95 RFO	Bobbin	ODI	18	0.52	14TH TSP	+1.04
78	116	06/95 RFO	Bobbin	ODI	58	0.46	13TH TSP	+15.33
78	118	06/95 RFO	Bobbin	ODI	33	0.29	13TH TSP	+12.24
78	119	06/95 RFO	Bobbin	ODI	49	2.01	14TH TSP	+0.81
79	15	06/95 RFO	Bobbin	ODI	40	1.34	11TH TSP	+0.58
79	26	06/95 RFO	Bobbin	ODI	33	0.54	15TH TSP	+0.70
79	35	06/95 RFO	Bobbin	NQI		0.51	LTSP	+22.45
		06/95 RFO	Bobbin	NQI		0.28	11TH TSP	+26.47
		06/95 RFO	Bobbin	ODI	1	0.28	13TH TSP	+14.58
79	73	06/95 RFO	Bobbin	NQI		0.67	6TH TSP	+34.96
79	123	06/95 RFO	Bobbin	ODI	52	1.22	14TH TSP	+1.08
79	130	06/95 RFO	Bobbin	ODI	18	0.67	10TH TSP	+14.94
80	7	06/95 RFO	Bobbin	NQI		0.16	1ST TSP	-0.24
80	25	06/95 RFO	Bobbin	NQI		0.45	7TH TSP	-0.80
80	71	06/95 RFO	Bobbin	NQI		3.88	5TH TSP	+30.89
80	108	06/95 RFO	Bobbin	NQI		0.42	10TH TSP	+6.94
80	109	06/95 RFO	Bobbin	ADI		3.58	14TH TSP	+19.00 to +33.23
		06/95 RFO	Bobbin	ADI		5.44	15TH TSP	+2.66 to +2.92
80	123	06/95 RFO	Bobbin	ODI	33	1.20	14TH TSP	+1.83
80	124	06/95 RFO	Bobbin	ODI	24	2.00	14TH TSP	+1.11
80	130	06/95 RFO	Bobbin	NQI		0.72	8TH TSP	-0.60
81	2	06/95 RFO	Bobbin	ODI	9	0.52	12TH TSP	+0.46

14TH TSP

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Ocone Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 16 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
81	3	06/95 RFO	Bobbin	ODI	20	0.98	10TH TSP	+9.30 FL
81	5	06/95 RFO	Bobbin	ODI	3	0.49	10TH TSP	+5.53 FL
81	21	06/95 RFO	Bobbin	ODI	3	0.48	10TH TSP	+17.27 FL
81	23	06/95 RFO	Bobbin	NQI		0.46	10TH TSP	+16.04 FL
81	27	06/95 RFO	Bobbin	ODI	62	0.41	1ST TSP	+30.69 FL
81	29	06/95 RFO	Bobbin	NQI		0.71	10TH TSP	-0.73 FL
81	33	06/95 RFO	Bobbin	NQI		0.45	10TH TSP	-0.65 FL
81	36	06/95 RFO	Bobbin	ODI	27	0.68	10TH TSP	-0.72 FL
81	37	06/95 RFO	Bobbin	NQI		0.41	10TH TSP	-0.75 FL
81	113	06/95 RFO	Bobbin	NQI		0.41	9TH TSP	+8.58 FL
81	123	06/95 RFO	Bobbin	ODI	18	0.44	14TH TSP	+0.39 FL
81	129	06/95 RFO	Bobbin	ODI	20	0.65	10TH TSP	+0.95 FL
82	4	06/95 RFO	Bobbin	ODI	17	1.09	10TH TSP	+5.05 to +9.29 FL
82	5	06/95 RFO	Bobbin	ODI	11	0.82	10TH TSP	+7.45 FL
		06/95 RFO	Bobbin	ODI	11	2.18	10TH TSP	+5.37 FL
82	10	06/95 RFO	Bobbin	NQI		0.50	7TH TSP	+7.89 FL
82	12	06/95 RFO	Bobbin	ODI	12	0.38	10TH TSP	+12.77 FL
82	13	06/95 RFO	Bobbin	NQI		0.32	2ND TSP	+20.74 FL
		06/95 RFO	Bobbin	ODI	16	0.28	10TH TSP	+16.08 FL
82	17	06/95 RFO	Bobbin	ODI	9	0.42	10TH TSP	+17.80 FL
82	21	06/95 RFO	Bobbin	NQI		0.45	10TH TSP	-0.73 FL
82	29	06/95 RFO	Bobbin	ODI	28	0.41	10TH TSP	-0.75 FL
82	53	06/95 RFO	Bobbin	NQI		0.60	14TH TSP	+2.30 FL
82	64	06/95 RFO	Bobbin	ODI	14	0.81	1ST TSP	+1.06 FL
82	110	06/95 RFO	Bobbin	NQI		0.32	11TH TSP	-1.63 FL
82	125	06/95 RFO	Bobbin	ODI	13	0.73	14TH TSP	+1.57 FL
82	128	06/95 RFO	Bobbin	ODI	3	0.38	10TH TSP	+1.01 FL
83	3	06/95 RFO	Bobbin	NQI		0.34	15TH TSP	+1.31 FL
		06/95 RFO	Bobbin	ODI	5	0.97	10TH TSP	+7.24 FL
		06/95 RFO	Bobbin	ODI	11	0.38	10TH TSP	+12.27 FL
		06/95 RFO	Bobbin	ODI	37	0.69	10TH TSP	+8.01 FL
83	4	06/95 RFO	Bobbin	ODI	3	1.03	10TH TSP	+8.86 FL
		06/95 RFO	Bobbin	ODI	19	0.64	10TH TSP	+7.14 FL
83	5	06/95 RFO	Bobbin	ODI	31	0.44	10TH TSP	+5.06 FL
83	6	06/95 RFO	Bobbin	ODI	20	0.91	10TH TSP	+1.60 FL
83	8	06/95 RFO	Bobbin	NQI		0.38	7TH TSP	+19.14 FL
83	12	06/95 RFO	Bobbin	ODI	15	0.64	10TH TSP	-0.57 FL
83	31	06/95 RFO	Bobbin	ODI	14	0.74	10TH TSP	+0.67 FL
83	40	06/95 RFO	Bobbin	NQI		0.50	5TH TSP	-1.02 FL
83	65	06/95 RFO	Bobbin	NQI		2.73	1ST TSP	+0.80 FL
83	66	06/95 RFO	Bobbin	ODI	22	0.55	1ST TSP	+1.21 FL
83	71	06/95 RFO	Bobbin	ODI	2	3.93	8TH TSP	+23.58 FL
83	112	06/95 RFO	Bobbin	NQI		0.46	7TH TSP	-0.06 FL
83	115	06/95 RFO	Bobbin	NQI		0.33	11TH TSP	+21.59 FL
83	127	06/95 RFO	Bobbin	ODI	20	6.94	14TH TSP	+1.33 FL
83	131	06/95 RFO	Bobbin	ODI	13	0.39	11TH TSP	+1.23 FL
83	132	06/95 RFO	Bobbin	ODI	3	2.56	14TH TSP	+0.85 FL
84	1	06/95 RFO	Bobbin	ODI	5	0.37	10TH TSP	+23.57 FL
84	2	06/95 RFO	Bobbin	NQI		0.54	10TH TSP	+7.89 FL
		06/95 RFO	Bobbin	NQI		0.85	10TH TSP	+9.69 FL
84	3	06/95 RFO	Bobbin	ODI	7	0.90	10TH TSP	+6.92 FL
84	5	06/95 RFO	Bobbin	ODI	11	0.59	9TH TSP	+37.46 FL
84	6	06/95 RFO	Bobbin	ODI	11	0.34	12TH TSP	+6.02 FL
84	37	06/95 RFO	Bobbin	ODI	13	0.39	11TH TSP	+36.14 FL
84	56	06/95 RFO	Bobbin	ODI	26	2.39	9TH TSP	+25.25 FL
84	61	06/95 RFO	Bobbin	ODI	4	0.25	LTSP	+14.08 FL
84	68	06/95 RFO	Bobbin	ADI		0.73	8TH TSP	+6.92 FL
84	72	06/95 RFO	Bobbin	NQI		0.54	13TH TSP	+0.55 FL
		06/95 RFO	Bobbin	ODI	5	1.00	14TH TSP	+23.06 FL
84	74	06/95 RFO	Bobbin	ODI	28	0.21	6TH TSP	+34.30 FL
		06/95 RFO	Bobbin	ODI	22	0.84	13TH TSP	+25.14 FL
84	94	06/95 RFO	Bobbin	NQI		0.27	14TH TSP	+0.20 FL
84	104	06/95 RFO	Bobbin	ODI	18	1.69	15TH TSP	+25.31 FL
84	120	06/95 RFO	Bobbin	NQI		0.80	LTSP	+6.06 FL
84	127	06/95 RFO	Bobbin	NQI		0.53	7TH TSP	+36.13 FL

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 17 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
84	128	06/95 RFO	Bobbin	NQI		0.67	7TH TSP	+34.63 FL
85	2	06/95 RFO	Bobbin	NQI		1.30	10TH TSP	+7.66 FL
		06/95 RFO	Bobbin	ODI	13	1.14	10TH TSP	+6.37 FL
85	3	06/95 RFO	Bobbin	ODI	3	1.01	10TH TSP	+2.52 FL
85	5	06/95 RFO	Bobbin	ODI	20	0.40	10TH TSP	+0.62 FL
85	8	06/95 RFO	Bobbin	ODI	28	0.54	12TH TSP	+8.80 FL
85	15	06/95 RFO	Bobbin	NQI		0.36	9TH TSP	+22.72 FL
85	25	06/95 RFO	Bobbin	NQI		0.43	12TH TSP	+8.95 FL
85	44	06/95 RFO	Bobbin	NQI		0.56	5TH TSP	+5.08 FL
85	102	06/95 RFO	Bobbin	NQI		0.47	6TH TSP	+26.09 FL
85	109	06/95 RFO	Bobbin	ODI	16	0.71	3RD TSP	-1.63 FL
86	2	06/95 RFO	Bobbin	ODI	7	0.71	10TH TSP	+6.99 FL
86	3	06/95 RFO	Bobbin	ODI	39	0.95	10TH TSP	+1.98 FL
86	5	06/95 RFO	Bobbin	ODI	24	0.27	10TH TSP	+0.48 FL
		06/95 RFO	Bobbin	ODI	38	1.30	10TH TSP	-0.77 FL
86	20	06/95 RFO	Bobbin	ODI	13	0.34	9TH TSP	+7.54 FL
86	102	06/95 RFO	Bobbin	NQI		0.39	LTSF	+33.72 FL
86	111	06/95 RFO	Bobbin	NQI		3.11	8TH TSP	-1.57 FL
		06/95 RFO	Bobbin	NQI		0.51	14TH TSP	+20.40 FL
		06/95 RFO	Bobbin	NQI		0.63	10TH TSP	+15.95 FL
		06/95 RFO	Bobbin	NQI		0.91	13TH TSP	+14.21 FL
		06/95 RFO	Bobbin	NQI		0.95	13TH TSP	+26.58 FL
86	114	06/95 RFO	Bobbin	ODI	6	0.33	LTSF	+24.66 FL
86	123	06/95 RFO	Bobbin	NQI		0.26	10TH TSP	+19.40 FL
86	128	06/95 RFO	Bobbin	NQI		0.51	6TH TSP	-0.08 FL
86	130	06/95 RFO	Bobbin	NQI		0.31	8TH TSP	+34.39 FL
		06/95 RFO	Bobbin	NQI		0.37	9TH TSP	+0.15 FL
87	1	06/95 RFO	Bobbin	ODI	28	0.53	10TH TSP	+7.29 FL
87	3	06/95 RFO	Bobbin	ODI	27	0.59	12TH TSP	+0.82 FL
87	17	06/95 RFO	Bobbin	NQI		0.47	7TH TSP	+8.01 FL
		06/95 RFO	Bobbin	NQI		0.60	12TH TSP	+13.18 FL
87	22	06/95 RFO	Bobbin	ODI	9	0.29	10TH TSP	+11.41 FL
87	29	06/95 RFO	Bobbin	ODI	20	0.24	10TH TSP	+12.35 FL
87	40	06/95 RFO	Bobbin	ODI	37	0.48	7TH TSP	+24.29 FL
87	43	06/95 RFO	Bobbin	ODI	13	0.22	7TH TSP	+3.50 FL
87	57	06/95 RFO	Bobbin	ODI	5	0.50	9TH TSP	+25.94 FL
87	70	06/95 RFO	Bobbin	ODI	5	3.03	12TH TSP	+11.45 FL
87	130	06/95 RFO	Bobbin	NQI		0.92	8TH TSP	+0.60 FL
88	1	06/95 RFO	Bobbin	NQI		0.53	10TH TSP	+9.20 FL
88	2	06/95 RFO	Bobbin	ADI		3.33	10TH TSP	+5.17 FL
88	27	06/95 RFO	Bobbin	ODI	36	0.38	9TH TSP	+19.01 FL
		06/95 RFO	Bobbin	ODI	24	0.42	14TH TSP	+6.71 FL
88	54	06/95 RFO	Bobbin	ADI		0.42	14TH TSP	+14.38 FL
		06/95 RFO	Bobbin	NQI		0.59	10TH TSP	+32.59 FL
		06/95 RFO	Bobbin	NQI		0.88	13TH TSP	+14.46 FL
		06/95 RFO	Bobbin	NQI		1.18	15TH TSP	+29.66 FL
		06/95 RFO	Bobbin	ODI	15	0.42	12TH TSP	+23.21 FL
		06/95 RFO	Bobbin	ODI	17	0.71	15TH TSP	+18.77 FL
		06/95 RFO	Bobbin	ODI	34	0.54	13TH TSP	+22.83 FL
		06/95 RFO	Bobbin	ODI	63	0.64	13TH TSP	+20.95 FL
88	71	06/95 RFO	Bobbin	NQI		0.48	11TH TSP	+27.58 FL
		06/95 RFO	Bobbin	NQI		0.64	10TH TSP	+19.63 FL
88	94	06/95 RFO	Bobbin	ODI	6	0.25	6TH TSP	+27.38 FL
88	100	06/95 RFO	Bobbin	ODI	8	0.31	14TH TSP	+33.27 FL
88	114	06/95 RFO	Bobbin	ODI	26	0.90	6TH TSP	+32.75 FL
88	129	06/95 RFO	Bobbin	NQI		0.66	8TH TSP	+0.59 FL
		06/95 RFO	Bobbin	ODI	29	2.18	15TH TSP	+34.21 FL
89	2	06/95 RFO	Bobbin	NQI		0.34	11TH TSP	+7.64 FL
		06/95 RFO	Bobbin	ODI	11	1.52	10TH TSP	+4.58 FL
		06/95 RFO	Bobbin	ODI	20	0.52	15TH TSP	+3.24 FL
		06/95 RFO	Bobbin	ODI	28	0.60	15TH TSP	+5.18 FL
		06/95 RFO	Bobbin	ODI	31	0.29	10TH TSP	+32.43 FL
		06/95 RFO	Bobbin	ODI	31	0.43	10TH TSP	+25.61 FL
89	3	06/95 RFO	Bobbin	ODI	24	0.55	9TH TSP	+36.88 FL
89	48	06/95 RFO	Bobbin	NQI		0.95	UTSF	+0.43 FL

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 18 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
89	108	06/95 RFO	Bobbin	NQI		0.23	6TH TSP	-0.05
89	127	06/95 RFO	Bobbin	ODI	20	0.85	14TH TSP	+0.81
89	128	06/95 RFO	Bobbin	NQI		0.79	14TH TSP	+1.29
90	1	06/95 RFO	Bobbin	NQI		0.47	15TH TSP	-0.09
		06/95 RFO	Bobbin	ODI	20	0.95	10TH TSP	+4.46
		06/95 RFO	Bobbin	ODI	29	0.91	10TH TSP	+3.76
		06/95 RFO	Bobbin	ODI	49	0.90	15TH TSP	+2.72
90	5	06/95 RFO	Bobbin	ODI	38	0.39	9TH TSP	+37.10
90	47	06/95 RFO	Bobbin	ODI	13	0.55	12TH TSP	+23.21
90	49	06/95 RFO	Bobbin	ODI	45	1.88	13TH TSP	-0.58
90	75	06/95 RFO	Bobbin	NQI		0.37	5TH TSP	+31.61
		06/95 RFO	Bobbin	NQI		0.38	7TH TSP	-1.39
		06/95 RFO	Bobbin	NQI		0.43	5TH TSP	+32.71
		06/95 RFO	Bobbin	NQI		0.47	6TH TSP	+16.85
		06/95 RFO	Bobbin	ODI	31	0.34	8TH TSP	+21.90
90	85	06/95 RFO	Bobbin	NQI		0.35	2ND TSP	+27.34
90	91	06/95 RFO	Bobbin	ODI	10	0.42	15TH TSP	+15.57
90	94	06/95 RFO	Bobbin	NQI		0.42	7TH TSP	+14.69
90	116	06/95 RFO	Bobbin	ODI	14	1.09	14TH TSP	+0.70
91	3	06/95 RFO	Bobbin	NQI		0.75	14TH TSP	+11.81
91	28	06/95 RFO	Bobbin	ODI	30	0.38	7TH TSP	+8.44
		06/95 RFO	Bobbin	ODI	32	0.47	6TH TSP	+3.63
		06/95 RFO	Bobbin	ODI	67	0.68	5TH TSP	+18.88
91	67	06/95 RFO	Bobbin	NQI		0.43	11TH TSP	+26.00
91	74	06/95 RFO	Bobbin	ODI	23	0.42	5TH TSP	+34.03
91	77	06/95 RFO	Bobbin	ODI	61	0.53	15TH TSP	+4.34
91	88	06/95 RFO	Bobbin	NQI		0.25	9TH TSP	+35.19
		06/95 RFO	Bobbin	NQI		0.36	12TH TSP	+6.09
91	89	06/95 RFO	Bobbin	NQI		0.64	4TH TSP	+34.45
91	108	06/95 RFO	Bobbin	ODI	26	0.47	5TH TSP	+7.01
91	119	06/95 RFO	Bobbin	ODI	14	0.46	14TH TSP	+1.06
91	123	06/95 RFO	Bobbin	NQI		0.52	9TH TSP	-0.67
91	126	06/95 RFO	Bobbin	NQI		0.27	14TH TSP	+1.24
92	1	06/95 RFO	Bobbin	NQI		0.56	15TH TSP	+3.31
		06/95 RFO	Bobbin	NQI		0.85	15TH TSP	+2.38
		06/95 RFO	Bobbin	ODI	2	1.03	10TH TSP	+12.79
		06/95 RFO	Bobbin	ODI	24	0.49	10TH TSP	+6.34
92	35	06/95 RFO	Bobbin	NQI		0.64	8TH TSP	+10.57
		06/95 RFO	Bobbin	ODI	50	0.41	9TH TSP	+5.82
92	113	06/95 RFO	Bobbin	NQI		2.04	14TH TSP	+0.65
92	123	06/95 RFO	Bobbin	NQI		0.85	14TH TSP	+1.00
92	129	06/95 RFO	Bobbin	NQI		0.63	7TH TSP	-0.80
93	21	06/95 RFO	Bobbin	NQI		0.42	7TH TSP	+17.89
		06/95 RFO	Bobbin	NQI		0.52	6TH TSP	+35.37
93	23	06/95 RFO	Bobbin	ODI	5	0.30	8TH TSP	+26.32
93	28	06/95 RFO	Bobbin	NQI		0.62	2ND TSP	+21.32
		06/95 RFO	Bobbin	NQI		0.30	11TH TSP	+24.20
		06/95 RFO	Bobbin	NQI		0.32	13TH TSP	+17.79
93	42	06/95 RFO	Bobbin	NQI		0.71	15TH TSP	+0.31
93	49	06/95 RFO	Bobbin	ODI	2	2.88	8TH TSP	+19.92
93	75	06/95 RFO	Bobbin	ODI	50	0.26	11TH TSP	+22.01
93	93	06/95 RFO	Bobbin	ODI	40	0.48	9TH TSP	+17.76
		06/95 RFO	Bobbin	ODI	47	0.45	6TH TSP	+37.33
93	109	06/95 RFO	Bobbin	ODI	7	0.38	14TH TSP	+1.06
		06/95 RFO	Bobbin	ODI	9	0.90	14TH TSP	+0.78
93	117	06/95 RFO	Bobbin	NQI		0.29	LTSF	+9.65
93	118	06/95 RFO	Bobbin	ODI	33	0.72	14TH TSP	+0.95
94	2	06/95 RFO	Bobbin	NQI		0.52	10TH TSP	+6.26
94	117	06/95 RFO	Bobbin	ODI	12	0.33	1ST TSP	+18.35
94	122	06/95 RFO	Bobbin	ODI	33	0.38	14TH TSP	+0.98
95	66	06/95 RFO	Bobbin	NQI		0.61	12TH TSP	+6.38
95	70	06/95 RFO	Bobbin	NQI		0.48	3RD TSP	+30.27
95	80	06/95 RFO	Bobbin	ODI	31	0.24	6TH TSP	+0.02
95	126	06/95 RFO	Bobbin	ODI	28	0.74	15TH TSP	+17.97
96	1	06/95 RFO	Bobbin	ODI	35	0.88	10TH TSP	+11.50

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 19 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
96	2	06/95 RFO	Bobbin	NQI		0.80	10TH TSP	+0.66 FL
96	40	06/95 RFO	Bobbin	NQI		0.29	11TH TSP	+19.07 FL
96	50	06/95 RFO	Bobbin	ODI	38	0.45	15TH TSP	+28.86 FL
96	101	06/95 RFO	Bobbin	NQI		0.41	7TH TSP	+14.00 FL
96	122	06/95 RFO	Bobbin	ODI	17	0.41	15TH TSP	+30.26 FL
96	127	06/95 RFO	Bobbin	NQI		0.72	8TH TSP	-0.68 FL
97	2	06/95 RFO	Bobbin	NQI		0.59	10TH TSP	+0.72 FL
97	11	06/95 RFO	Bobbin	ODI	55	0.62	10TH TSP	+17.27 FL
97	25	06/95 RFO	Bobbin	ODI	22	0.44	8TH TSP	+11.29 FL
97	64	06/95 RFO	Bobbin	NQI		246.60	UTSF	-0.25 FL
		06/95 RFO	Bobbin	NQI		277.30	LTSF	+0.29 FL
		06/95 RFO	Bobbin	NQI		0.50	6TH TSP	+2.36 FL
97	81	06/95 RFO	Bobbin	NQI		0.26	1ST TSP	+10.69 FL
97	120	06/95 RFO	Bobbin	ODI	27	0.47	1ST TSP	+6.44 FL
98	9	06/95 RFO	Bobbin	NQI		0.41	9TH TSP	+35.43 FL
		06/95 RFO	Bobbin	ODI	13	0.38	9TH TSP	+33.98 FL
		06/95 RFO	Bobbin	ODI	37	0.51	12TH TSP	+5.16 FL
98	26	06/95 RFO	Bobbin	ODI	26	0.22	LTSF	+37.66 FL
98	66	06/95 RFO	Bobbin	ODI	39	0.42	11TH TSP	+17.73 FL
98	70	06/95 RFO	Bobbin	ODI	3	1.31	LTSF	+41.18 FL
98	74	06/95 RFO	Bobbin	ODI	66	0.71	LTSF	+36.87 FL
98	115	06/95 RFO	Bobbin	ODI	47	0.40	12TH TSP	+29.04 FL
98	121	06/95 RFO	Bobbin	ODI	61	0.52	11TH TSP	+28.06 FL
99	1	06/95 RFO	Bobbin	ODI	5	0.47	10TH TSP	+10.99 FL
99	41	06/95 RFO	Bobbin	ODI	39	0.49	13TH TSP	+0.12 FL
99	69	06/95 RFO	Bobbin	NQI		0.29	12TH TSP	+30.17 FL
99	91	06/95 RFO	Bobbin	NQI		0.27	8TH TSP	+19.15 FL
99	115	06/95 RFO	Bobbin	ODI	27	0.42	11TH TSP	+26.43 FL
99	126	06/95 RFO	Bobbin	NQI		0.76	8TH TSP	-0.57 FL
100	28	06/95 RFO	Bobbin	NQI		0.23	10TH TSP	+27.07 FL
100	40	06/95 RFO	Bobbin	ODI	22	0.26	LTSF	+17.73 FL
100	44	06/95 RFO	Bobbin	ODI	65	0.48	4TH TSP	+3.14 FL
100	52	06/95 RFO	Bobbin	NQI		2.51	UTSF	-1.13 FL
100	69	06/95 RFO	Bobbin	NQI		0.51	6TH TSP	+12.27 FL
100	104	06/95 RFO	Bobbin	ODI	52	0.43	8TH TSP	+19.58 FL
100	120	06/95 RFO	Bobbin	ODI	33	0.23	10TH TSP	+6.44 FL
101	1	06/95 RFO	Bobbin	ODI	7	0.43	10TH TSP	+6.79 FL
		06/95 RFO	Bobbin	ODI	22	0.39	10TH TSP	+7.23 FL
101	4	06/95 RFO	Bobbin	ODI	13	0.92	9TH TSP	-0.20 FL
101	28	06/95 RFO	Bobbin	NQI		0.30	13TH TSP	+8.53 FL
101	44	06/95 RFO	Bobbin	ODI	4	0.41	14TH TSP	+0.42 FL
101	66	06/95 RFO	Bobbin	ODI	16	0.53	13TH TSP	+15.56 FL
102	6	06/95 RFO	Bobbin	NQI		0.32	3RD TSP	+28.86 FL
102	20	06/95 RFO	Bobbin	ODI	33	0.48	13TH TSP	+21.63 FL
102	38	06/95 RFO	Bobbin	ODI	55	0.43	1ST TSP	+6.02 FL
102	39	06/95 RFO	Bobbin	ODI	37	0.34	14TH TSP	-0.34 FL
103	16	06/95 RFO	Bobbin	NQI		0.30	15TH TSP	+7.28 FL
		06/95 RFO	Bobbin	ODI	47	0.52	7TH TSP	+26.73 FL
		06/95 RFO	Bobbin	ODI	50	0.49	13TH TSP	+27.72 FL
103	24	06/95 RFO	Bobbin	ODI	14	0.54	13TH TSP	+5.71 FL
		06/95 RFO	Bobbin	ODI	24	0.50	12TH TSP	+15.85 FL
103	27	06/95 RFO	Bobbin	ODI	26	0.11	3RD TSP	+17.36 FL
103	38	06/95 RFO	Bobbin	NQI		0.33	15TH TSP	+17.20 FL
103	40	06/95 RFO	Bobbin	ODI	17	1.62	LTSF	+21.38 to +26.68 FL
104	9	06/95 RFO	Bobbin	ODI	20	0.43	13TH TSP	+25.93 FL
104	18	06/95 RFO	Bobbin	NQI		0.26	8TH TSP	+25.01 FL
104	24	06/95 RFO	Bobbin	ODI	42	0.55	3RD TSP	+9.49 FL
104	38	06/95 RFO	Bobbin	ODI	42	0.56	LTSF	+28.36 FL
104	89	06/95 RFO	Bobbin	ODI	36	0.61	8TH TSP	+21.06 FL
104	93	06/95 RFO	Bobbin	ADI		16.60	LTSF	+21.05 to +32.26 FL
104	119	06/95 RFO	Bobbin	ODI	43	0.40	3RD TSP	+7.77 FL
105	66	06/95 RFO	Bobbin	ODI	19	0.35	7TH TSP	+7.01 FL
105	121	06/95 RFO	Bobbin	ODI	4	0.62	8TH TSP	-0.73 FL
106	4	06/95 RFO	Bobbin	ODI	14	0.87	9TH TSP	-0.50 FL
		06/95 RFO	Bobbin	ODI	33	0.32	15TH TSP	+15.65 FL

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 20 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
106	16	06/95 RFO	Bobbin	NQI		0.67	3RD TSP	+27.27 FL
106	63	06/95 RFO	Bobbin	ODI	36	0.54	9TH TSP	+9.29 FL
106	96	06/95 RFO	Bobbin	NQI		0.30	1ST TSP	+7.05 FL
106	119	06/95 RFO	Bobbin	NQI		0.41	3RD TSP	+24.06 FL
107	20	06/95 RFO	Bobbin	NQI		0.46	7TH TSP	+33.50 FL
107	84	06/95 RFO	Bobbin	NQI		0.41	1ST TSP	+7.02 FL
		06/95 RFO	Bobbin	NQI		0.38	11TH TSP	+1.40 FL
107	113	06/95 RFO	Bobbin	NQI		0.52	8TH TSP	+4.09 FL
108	34	06/95 RFO	Bobbin	NQI		0.83	UTSF	+0.51 FL
108	85	06/95 RFO	Bobbin	ODI	23	0.35	8TH TSP	+24.05 FL
108	115	06/95 RFO	Bobbin	NQI		0.36	1ST TSP	+9.19 FL
109	22	06/95 RFO	Bobbin	NQI		0.66	8TH TSP	+22.97 FL
		06/95 RFO	Bobbin	NQI		0.45	15TH TSP	+25.74 FL
109	31	06/95 RFO	Bobbin	ODI	39	0.45	14TH TSP	-0.52 FL
109	49	06/95 RFO	Bobbin	NQI		0.30	7TH TSP	+18.08 FL
109	69	06/95 RFO	Bobbin	NQI		0.56	15TH TSP	+16.34 FL
110	29	06/95 RFO	Bobbin	ODI	26	0.34	11TH TSP	+15.00 FL
110	61	06/95 RFO	Bobbin	NQI		0.34	9TH TSP	+17.16 FL
111	25	06/95 RFO	Bobbin	NQI		0.45	11TH TSP	+34.31 FL
111	41	06/95 RFO	Bobbin	NQI		0.46	15TH TSP	+32.31 FL
111	78	06/95 RFO	Bobbin	NQI		0.57	3RD TSP	+20.75 FL
111	81	06/95 RFO	Bobbin	ODI	48	0.44	14TH TSP	+19.70 FL
111	82	06/95 RFO	Bobbin	NQI		0.32	2ND TSP	+4.12 FL
112	6	06/95 RFO	Bobbin	NQI		0.28	11TH TSP	+31.02 FL
		06/95 RFO	Bobbin	ODI	49	0.34	11TH TSP	+9.47 FL
112	13	06/95 RFO	Bobbin	NQI		3.04	14TH TSP	+0.75 FL
112	16	06/95 RFO	Bobbin	NQI		0.45	3RD TSP	+8.70 FL
112	20	06/95 RFO	Bobbin	ADI		5.19	LTSF	+21.31 to +28.88 FL
112	43	06/95 RFO	Bobbin	NQI		0.67	4TH TSP	+20.02 FL
112	60	06/95 RFO	Bobbin	NQI		0.45	14TH TSP	+28.97 FL
112	72	06/95 RFO	Bobbin	NQI		0.57	5TH TSP	+8.35 FL
112	104	06/95 RFO	Bobbin	NQI		1.16	LTPF	+17.10 FL
113	20	06/95 RFO	Bobbin	ODI	30	0.62	10TH TSP	+24.56 FL
113	25	06/95 RFO	Bobbin	NQI		0.30	7TH TSP	+20.52 FL
113	36	06/95 RFO	Bobbin	ODI	4	0.75	LTSF	+28.79 FL
		06/95 RFO	Bobbin	ADI		2.83	LTSF	+22.13 to +27.95 FL
113	66	06/95 RFO	Bobbin	NQI		0.41	9TH TSP	+6.87 FL
113	110	06/95 RFO	Bobbin	ODI	9	1.67	8TH TSP	+22.52 FL
114	1	06/95 RFO	Bobbin	ODI	29	0.51	7TH TSP	-0.69 FL
114	5	06/95 RFO	Bobbin	ODI	15	0.46	8TH TSP	+17.17 FL
114	15	06/95 RFO	Bobbin	NQI		0.37	15TH TSP	+20.41 FL
114	18	06/95 RFO	Bobbin	NQI		0.48	7TH TSP	+26.74 FL
		06/95 RFO	Bobbin	ODI	8	0.54	6TH TSP	+19.47 FL
114	56	06/95 RFO	Bobbin	ODI	54	0.61	11TH TSP	+35.83 FL
114	114	06/95 RFO	Bobbin	ODI	25	0.61	10TH TSP	+0.66 FL
115	65	06/95 RFO	Bobbin	NQI		0.39	14TH TSP	+2.44 FL
115	97	06/95 RFO	Bobbin	ODI	34	0.96	14TH TSP	+1.19 FL
115	98	06/95 RFO	Bobbin	NQI		0.53	13TH TSP	+12.74 FL
		06/95 RFO	Bobbin	NQI		1.03	14TH TSP	+0.81 FL
115	110	06/95 RFO	Bobbin	NQI		0.67	9TH TSP	+14.49 FL
115	111	06/95 RFO	Bobbin	ODI	16	3.85	8TH TSP	-0.62 FL
116	17	06/95 RFO	Bobbin	ODI	10	2.62	LTSF	+20.90 to +28.64 FL
116	26	06/95 RFO	Bobbin	ODI	54	1.10	6TH TSP	+26.74 FL
116	49	06/95 RFO	Bobbin	NQI		0.55	12TH TSP	+0.22 FL
116	82	06/95 RFO	Bobbin	NQI		0.36	8TH TSP	+33.97 FL
116	107	06/95 RFO	Bobbin	ODI	37	0.36	8TH TSP	+0.26 FL
116	112	06/95 RFO	Bobbin	ODI	21	0.59	10TH TSP	+3.59 FL
117	19	06/95 RFO	Bobbin	NQI		0.75	4TH TSP	+5.31 FL
117	83	06/95 RFO	Bobbin	ODI	22	1.48	9TH TSP	+7.54 FL
		06/95 RFO	Bobbin	ODI	34	1.91	9TH TSP	+4.04 FL
117	105	06/95 RFO	Bobbin	ODI	17	0.66	14TH TSP	+33.01 FL
117	106	06/95 RFO	Bobbin	ODI	35	0.66	10TH TSP	+0.66 FL
118	79	06/95 RFO	Bobbin	NQI		0.40	8TH TSP	+25.98 FL
118	99	06/95 RFO	Bobbin	ODI	22	1.49	14TH TSP	+27.33 FL
118	106	06/95 RFO	Bobbin	NQI		0.50	14TH TSP	+16.34 FL

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 21 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
119	8	06/95 RFO	Bobbin	ODI	13	0.56	1ST TSP	+18.57
119	15	06/95 RFO	Bobbin	ADI		2.84	LTSF	+20.95 to +28.93
119	88	06/95 RFO	Bobbin	NQI		0.69	14TH TSP	+0.35
119	90	06/95 RFO	Bobbin	ODI	37	0.39	3RD TSP	+34.11
119	98	06/95 RFO	Bobbin	ODI	5	0.44	1ST TSP	+27.46
		06/95 RFO	Bobbin	ODI	32	0.83	1ST TSP	+27.83
119	106	06/95 RFO	Bobbin	ODI	16	1.32	8TH TSP	-0.69
119	107	06/95 RFO	Bobbin	NQI		0.68	15TH TSP	-1.20
120	14	06/95 RFO	Bobbin	NQI		0.28	9TH TSP	+6.80
		06/95 RFO	Bobbin	NQI		0.35	9TH TSP	+10.56
		06/95 RFO	Bobbin	NQI		0.36	8TH TSP	+1.93
		06/95 RFO	Bobbin	NQI		0.48	8TH TSP	+23.74
		06/95 RFO	Bobbin	NQI		0.57	9TH TSP	+4.16
		06/95 RFO	Bobbin	NQI		0.59	9TH TSP	+25.68
		06/95 RFO	Bobbin	NQI		0.21	10TH TSP	+11.44
		06/95 RFO	Bobbin	NQI		0.33	10TH TSP	+14.44
		06/95 RFO	Bobbin	NQI		0.36	10TH TSP	+11.96
		06/95 RFO	Bobbin	NQI		0.47	10TH TSP	+13.84
		06/95 RFO	Bobbin	ODI	14	0.44	9TH TSP	+29.62
		06/95 RFO	Bobbin	ODI	35	0.42	9TH TSP	+9.13
		06/95 RFO	Bobbin	ODI	52	0.75	9TH TSP	+27.77
		06/95 RFO	Bobbin	ODI	70	0.97	8TH TSP	+22.40
		06/95 RFO	Bobbin	ODI	33	0.32	10TH TSP	+9.81
120	17	06/95 RFO	Bobbin	ODI	56	0.72	7TH TSP	+3.43
120	36	06/95 RFO	Bobbin	NQI		4.16	1ST TSP	+15.33
120	53	06/95 RFO	Bobbin	ODI	17	0.39	2ND TSP	+29.63
120	78	06/95 RFO	Bobbin	NQI		0.56	13TH TSP	+0.59
120	105	06/95 RFO	Bobbin	NQI		0.64	10TH TSP	-0.25
		06/95 RFO	Bobbin	ODI	34	2.03	8TH TSP	-0.57
120	107	06/95 RFO	Bobbin	NQI		0.52	8TH TSP	+3.34
		06/95 RFO	Bobbin	NQI		0.77	14TH TSP	+31.94
		06/95 RFO	Bobbin	NQI		0.89	14TH TSP	+31.06
121	10	06/95 RFO	Bobbin	NQI		0.42	8TH TSP	+27.12
		06/95 RFO	Bobbin	NQI		0.52	9TH TSP	+32.79
		06/95 RFO	Bobbin	NQI		0.87	9TH TSP	+36.80
		06/95 RFO	Bobbin	NQI		0.61	10TH TSP	+15.31
121	51	06/95 RFO	Bobbin	ODI	28	0.31	6TH TSP	+22.37
122	1	06/95 RFO	Bobbin	NQI		1.67	15TH TSP	+18.38
122	3	06/95 RFO	Bobbin	NQI		0.54	9TH TSP	-0.61
122	47	06/95 RFO	Bobbin	NQI		0.61	9TH TSP	+6.08
122	58	06/95 RFO	Bobbin	NQI		0.64	13TH TSP	+8.89
122	59	06/95 RFO	Bobbin	NQI		0.56	UTSF	-1.47
		06/95 RFO	Bobbin	NQI		0.45	15TH TSP	+32.10
		06/95 RFO	Bobbin	NQI		0.52	15TH TSP	+42.95
		06/95 RFO	Bobbin	NQI		0.87	14TH TSP	+33.31
122	82	06/95 RFO	Bobbin	NQI		0.50	14TH TSP	+23.94
122	84	06/95 RFO	Bobbin	NQI		0.47	7TH TSP	+10.30
		06/95 RFO	Bobbin	ODI	14	0.35	11TH TSP	+29.56
122	97	06/95 RFO	Bobbin	NQI		5.58	3RD TSP	+5.90
		06/95 RFO	Bobbin	ODI	80	0.79	10TH TSP	+18.68
122	103	06/95 RFO	Bobbin	ODI	2	1.52	8TH TSP	-0.69
122	104	06/95 RFO	Bobbin	ODI	25	0.67	10TH TSP	+0.55
122	105	06/95 RFO	Bobbin	ADI		0.94	14TH TSP	+31.25
		06/95 RFO	Bobbin	ODI	38	1.31	15TH TSP	-0.51
123	3	06/95 RFO	Bobbin	NQI		0.41	9TH TSP	+0.67
123	33	06/95 RFO	Bobbin	ADI		0.62	LTSF	+21.19 to +30.37
123	50	06/95 RFO	Bobbin	NQI		0.30	7TH TSP	+8.48
123	57	06/95 RFO	Bobbin	ODI	33	0.47	11TH TSP	+24.75
123	82	06/95 RFO	Bobbin	ODI	19	0.26	14TH TSP	+24.15
123	98	06/95 RFO	Bobbin	NQI		0.37	9TH TSP	-0.46
123	103	06/95 RFO	Bobbin	NQI		0.47	14TH TSP	+31.08
		06/95 RFO	Bobbin	ODI	2	2.32	14TH TSP	+31.45
124	2	06/95 RFO	Bobbin	ODI	22	0.49	3RD TSP	-0.77
124	3	06/95 RFO	Bobbin	NQI		0.54	9TH TSP	+0.61
124	5	06/95 RFO	Bobbin	ODI	13	0.36	9TH TSP	+36.31

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 22 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
124	6	06/95 RFO	Bobbin	NQI		0.45	12TH TSP	+10.45 FL
124	45	06/95 RFO	Bobbin	NQI		0.29	11TH TSP	+34.59 FL
124	91	06/95 RFO	Bobbin	NQI		0.27	8TH TSP	+30.94 FL
		06/95 RFO	Bobbin	NQI		0.32	8TH TSP	+33.34 FL
124	94	06/95 RFO	Bobbin	ODI	17	1.07	14TH TSP	+1.49 FL
124	99	06/95 RFO	Bobbin	ODI	38	0.91	11TH TSP	+28.11 FL
124	101	06/95 RFO	Bobbin	ADI		1.18	11TH TSP	+4.69 FL
		06/95 RFO	Bobbin	ADI		1.23	14TH TSP	+30.86 FL
125	7	06/95 RFO	Bobbin	ODI	22	0.87	9TH TSP	-0.68 FL
125	27	06/95 RFO	Bobbin	NQI		0.58	3RD TSP	+12.09 FL
125	28	06/95 RFO	Bobbin	ODI	1	1.15	LTSF	+22.03 FL
125	48	06/95 RFO	Bobbin	ODI	16	0.27	5TH TSP	+28.14 FL
125	52	06/95 RFO	Bobbin	NQI		1.52	4TH TSP	-0.76 FL
125	54	06/95 RFO	Bobbin	NQI		1.04	15TH TSP	+11.89 FL
125	56	06/95 RFO	Bobbin	ODI	34	0.69	13TH TSP	+10.02 FL
		06/95 RFO	Bobbin	ODI	36	0.82	13TH TSP	+11.77 FL
125	90	06/95 RFO	Bobbin	NQI		0.67	9TH TSP	+29.62 FL
125	98	06/95 RFO	Bobbin	NQI		0.56	9TH TSP	+18.16 FL
125	100	06/95 RFO	Bobbin	ADI		1.09	10TH TSP	+17.40 FL
		06/95 RFO	Bobbin	ADI		1.69	14TH TSP	+31.59 FL
		06/95 RFO	Bobbin	ODI	1	1.24	10TH TSP	+18.67 FL
126	3	06/95 RFO	Bobbin	ODI	36	0.20	5TH TSP	-0.21 FL
126	8	06/95 RFO	Bobbin	ODI	4	0.47	9TH TSP	+8.67 FL
126	24	06/95 RFO	Bobbin	NQI		0.33	7TH TSP	+19.29 FL
126	56	06/95 RFO	Bobbin	NQI		0.72	13TH TSP	+12.16 FL
126	74	06/95 RFO	Bobbin	NQI		0.35	10TH TSP	+8.96 FL
126	75	06/95 RFO	Bobbin	NQI		0.43	LTSF	+32.28 FL
		06/95 RFO	Bobbin	ODI	17	0.29	14TH TSP	+6.10 FL
126	81	06/95 RFO	Bobbin	ODI	27	0.35	12TH TSP	+24.14 FL
126	84	06/95 RFO	Bobbin	NQI		0.42	2ND TSP	+31.15 FL
126	97	06/95 RFO	Bobbin	ODI	15	0.61	5TH TSP	+1.08 FL
126	99	06/95 RFO	Bobbin	NQI		0.77	14TH TSP	+0.94 FL
		06/95 RFO	Bobbin	ODI	23	0.54	14TH TSP	+1.46 FL
127	9	06/95 RFO	Bobbin	ODI	49	0.59	1ST TSP	+5.59 FL
127	14	06/95 RFO	Bobbin	ODI	14	0.23	8TH TSP	+4.34 FL
127	32	06/95 RFO	Bobbin	ODI	14	0.41	7TH TSP	+9.30 FL
127	49	06/95 RFO	Bobbin	NQI		0.29	7TH TSP	+15.43 FL
127	53	06/95 RFO	Bobbin	NQI		0.41	15TH TSP	+26.56 FL
127	55	06/95 RFO	Bobbin	NQI		0.74	13TH TSP	+20.72 FL
		06/95 RFO	Bobbin	NQI		1.64	13TH TSP	+25.44 FL
127	72	06/95 RFO	Bobbin	NQI		0.35	9TH TSP	+31.64 FL
127	73	06/95 RFO	Bobbin	NQI		0.41	14TH TSP	+28.14 FL
127	74	06/95 RFO	Bobbin	NQI		0.38	LTSF	+21.78 FL
127	75	06/95 RFO	Bobbin	NQI		0.32	14TH TSP	+13.03 FL
128	6	06/95 RFO	Bobbin	NQI		0.42	14TH TSP	+15.39 FL
		06/95 RFO	Bobbin	NQI		1.98	14TH TSP	+15.21 FL
128	16	06/95 RFO	Bobbin	NQI		0.43	14TH TSP	+1.04 FL
128	17	06/95 RFO	Bobbin	ODI	35	0.21	12TH TSP	+30.67 FL
		06/95 RFO	Bobbin	ODI	62	0.27	12TH TSP	+31.79 FL
128	23	06/95 RFO	Bobbin	NQI		0.26	7TH TSP	+16.43 FL
128	52	06/95 RFO	Bobbin	ODI	36	2.65	3RD TSP	+12.72 FL
128	95	06/95 RFO	Bobbin	NQI		0.49	14TH TSP	+32.86 FL
129	2	06/95 RFO	Bobbin	NQI		0.34	10TH TSP	+0.70 FL
129	12	06/95 RFO	Bobbin	NQI		0.32	12TH TSP	+11.29 FL
129	41	06/95 RFO	Bobbin	ODI	35	0.35	13TH TSP	+19.50 FL
129	75	06/95 RFO	Bobbin	ODI	26	0.52	LTSF	+25.14 FL
		06/95 RFO	Bobbin	NQI		0.44	8TH TSP	+22.42 FL
129	93	06/95 RFO	Bobbin	NQI		0.50	8TH TSP	+0.37 FL
129	94	06/95 RFO	Bobbin	NQI		0.44	11TH TSP	+8.65 FL
		06/95 RFO	Bobbin	NQI		1.30	10TH TSP	-0.63 FL
130	4	06/95 RFO	Bobbin	NQI		0.44	3RD TSP	+30.68 FL
130	5	06/95 RFO	Bobbin	ODI	31	0.32	15TH TSP	+30.99 FL
130	9	06/95 RFO	Bobbin	NQI		1.31	4TH TSP	-0.77 FL
130	22	06/95 RFO	Bobbin	ODI	4	0.30	7TH TSP	+18.41 FL
130	46	06/95 RFO	Bobbin	ODI	27	0.20	9TH TSP	+13.69 FL

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 23 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		06/95 RFO	Bobbin	ODI	17	0.25	10TH TSP	+10.94 FL
130	50	06/95 RFO	Bobbin	NQI		0.55	7TH TSP	+17.66 FL
130	57	06/95 RFO	Bobbin	ODI	32	0.32	11TH TSP	+29.31 FL
130	86	06/95 RFO	Bobbin	NQI		0.41	9TH TSP	+34.43 FL
		06/95 RFO	Bobbin	NQI		0.44	11TH TSP	-0.45 FL
130	91	06/95 RFO	Bobbin	ODI	15	0.50	10TH TSP	+0.65 FL
131	22	06/95 RFO	Bobbin	ODI	26	1.54	LTSP	+32.05 FL
131	28	06/95 RFO	Bobbin	ODI	59	0.52	LTSP	+35.29 FL
131	45	06/95 RFO	Bobbin	ODI	45	0.30	14TH TSP	+29.88 FL
131	56	06/95 RFO	Bobbin	NQI		0.53	15TH TSP	+0.45 FL
131	81	06/95 RFO	Bobbin	NQI		0.70	2ND TSP	+16.67 FL
131	82	06/95 RFO	Bobbin	NQI		0.48	9TH TSP	+4.71 FL
131	87	06/95 RFO	Bobbin	ODI	38	0.58	8TH TSP	+35.41 FL
132	1	06/95 RFO	Bobbin	ODI	28	0.94	15TH TSP	-1.15 FL
132	6	06/95 RFO	Bobbin	ODI	29	0.35	10TH TSP	+3.82 FL
132	7	06/95 RFO	Bobbin	NQI		1.11	4TH TSP	-0.81 FL
132	8	06/95 RFO	Bobbin	NQI		0.51	9TH TSP	+14.10 FL
		06/95 RFO	Bobbin	NQI		0.51	9TH TSP	+14.71 FL
132	13	06/95 RFO	Bobbin	NQI		0.59	8TH TSP	+0.50 FL
132	14	06/95 RFO	Bobbin	NQI		0.27	8TH TSP	+23.38 FL
		06/95 RFO	Bobbin	NQI		0.23	10TH TSP	+13.04 FL
		06/95 RFO	Bobbin	NQI		0.25	11TH TSP	+13.76 FL
		06/95 RFO	Bobbin	ODI	5	0.34	9TH TSP	+25.69 FL
		06/95 RFO	Bobbin	ODI	19	0.54	9TH TSP	+24.47 FL
		06/95 RFO	Bobbin	ODI	40	0.59	8TH TSP	+20.14 FL
		06/95 RFO	Bobbin	ODI	33	0.33	10TH TSP	+13.37 FL
		06/95 RFO	Bobbin	ODI	40	0.38	10TH TSP	+6.12 FL
		06/95 RFO	Bobbin	ODI	53	0.64	11TH TSP	+27.33 FL
132	40	06/95 RFO	Bobbin	ODI	36	0.48	14TH TSP	+16.87 FL
132	41	06/95 RFO	Bobbin	ODI	25	0.43	15TH TSP	+39.32 FL
132	67	06/95 RFO	Bobbin	NQI		0.53	7TH TSP	+27.33 FL
132	68	06/95 RFO	Bobbin	NQI		0.41	2ND TSP	+23.77 FL
132	84	06/95 RFO	Bobbin	NQI		0.55	8TH TSP	+0.46 FL
132	85	06/95 RFO	Bobbin	NQI		1.60	15TH TSP	-1.28 FL
		06/95 RFO	Bobbin	ODI	29	0.90	11TH TSP	+0.30 FL
133	5	06/95 RFO	Bobbin	NQI		1.22	10TH TSP	-0.76 FL
		06/95 RFO	Bobbin	ODI	13	0.28	10TH TSP	+0.00 FL
133	7	06/95 RFO	Bobbin	ODI	27	0.61	9TH TSP	+17.48 FL
133	8	06/95 RFO	Bobbin	NQI		0.38	9TH TSP	+14.57 FL
133	9	06/95 RFO	Bobbin	NQI		0.73	9TH TSP	+0.64 FL
133	35	06/95 RFO	Bobbin	ODI	36	1.44	2ND TSP	+16.06 FL
133	57	06/95 RFO	Bobbin	ODI	28	0.37	LTSP	+19.82 FL
133	66	06/95 RFO	Bobbin	NQI		0.50	8TH TSP	-0.29 FL
133	72	06/95 RFO	Bobbin	ODI	19	0.46	6TH TSP	+22.35 FL
134	2	06/95 RFO	Bobbin	ODI	22	0.89	10TH TSP	+5.14 FL
		06/95 RFO	Bobbin	NQI		0.60	14TH TSP	+33.41 10TH TSP
134	6	06/95 RFO	Bobbin	ODI	4	0.55	9TH TSP	+21.28 FL
		06/95 RFO	Bobbin	ODI	6	0.87	9TH TSP	+22.41 FL
134	17	06/95 RFO	Bobbin	ODI	48	0.60	9TH TSP	+17.59 FL
134	33	06/95 RFO	Bobbin	ODI	60	2.08	8TH TSP	+16.88 FL
134	70	06/95 RFO	Bobbin	NQI		0.31	LTSP	+16.42 FL
135	1	06/95 RFO	Bobbin	NQI		0.51	15TH TSP	+0.10 FL
		06/95 RFO	Bobbin	ODI	17	0.82	10TH TSP	+6.01 FL
135	6	06/95 RFO	Bobbin	ADI		1.20	9TH TSP	+19.97 FL
		06/95 RFO	Bobbin	NQI		0.29	10TH TSP	+0.57 FL
		06/95 RFO	Bobbin	ODI	33	0.57	10TH TSP	-0.73 FL
135	12	06/95 RFO	Bobbin	NQI		0.30	7TH TSP	+12.69 FL
135	33	06/95 RFO	Bobbin	ODI	15	0.75	12TH TSP	-1.38 FL
135	43	06/95 RFO	Bobbin	ODI	36	0.48	2ND TSP	+10.86 FL
135	79	06/95 RFO	Bobbin	NQI		0.35	7TH TSP	+35.31 FL
135	80	06/95 RFO	Bobbin	NQI		0.71	3RD TSP	+12.62 FL
136	4	06/95 RFO	Bobbin	ODI	59	0.68	2ND TSP	+10.49 FL
136	7	06/95 RFO	Bobbin	ADI		1.20	9TH TSP	+14.37 to +25.82 FL
136	37	06/95 RFO	Bobbin	NQI		0.56	2ND TSP	+18.35 FL
136	69	06/95 RFO	Bobbin	NQI		1.53	3RD TSP	+0.76 FL

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 24 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
136	70	06/95 RFO	Bobbin	NQI		0.93	3RD TSP	+0.75 FL
136	80	06/95 RFO	Bobbin	NQI		0.52	8TH TSP	-0.56 FL
137	1	06/95 RFO	Bobbin	ODI	36	0.60	11TH TSP	+24.14 FL
137	4	06/95 RFO	Bobbin	ODI	3	0.59	14TH TSP	+33.14 FL
		06/95 RFO	Bobbin	ODI	6	0.97	10TH TSP	+3.02 FL
137	5	06/95 RFO	Bobbin	ODI	18	0.58	10TH TSP	+0.57 FL
137	6	06/95 RFO	Bobbin	NQI		0.89	9TH TSP	+18.25 FL
137	8	06/95 RFO	Bobbin	NQI		0.33	10TH TSP	+0.29 FL
137	10	06/95 RFO	Bobbin	ODI	44	0.37	8TH TSP	+30.62 FL
137	44	06/95 RFO	Bobbin	ODI	20	0.68	15TH TSP	+20.71 FL
137	67	06/95 RFO	Bobbin	NQI		1.78	1ST TSP	+3.84 FL
137	68	06/95 RFO	Bobbin	ADI		2.76	LTSP	+36.72 FL
		06/95 RFO	Bobbin	ADI		1.98	1ST TSP	+3.28 FL
		06/95 RFO	Bobbin	ADI		3.34	2ND TSP	+16.91 FL
		06/95 RFO	Bobbin	ADI		6.36	2ND TSP	+28.45 FL
		06/95 RFO	Bobbin	NQI		1.07	3RD TSP	+0.78 FL
137	71	06/95 RFO	Bobbin	NQI		0.38	9TH TSP	-0.63 FL
138	1	06/95 RFO	Bobbin	NQI		0.33	12TH TSP	+2.76 FL
138	2	06/95 RFO	Bobbin	ODI	5	0.68	11TH TSP	+6.58 FL
		06/95 RFO	Bobbin	ADI		11.02	LTSP	+20.77 to +28.11 FL
138	21	06/95 RFO	Bobbin	NQI		0.42	LTSP	+40.37 FL
138	22	06/95 RFO	Bobbin	NQI		0.27	7TH TSP	-0.55 FL
138	30	06/95 RFO	Bobbin	NQI		0.47	2ND TSP	-0.41 FL
138	53	06/95 RFO	Bobbin	ODI	54	0.59	7TH TSP	+2.39 FL
138	66	06/95 RFO	Bobbin	ADI		1.25	LTSP	+3.39 FL
		06/95 RFO	Bobbin	ODI	23	1.26	LTSP	+10.09 FL
		06/95 RFO	Bobbin	NQI		0.39	13TH TSP	+12.38 FL
138	68	06/95 RFO	Bobbin	NQI		0.61	3RD TSP	+0.81 FL
139	1	06/95 RFO	Bobbin	NQI		0.33	10TH TSP	+21.50 FL
		06/95 RFO	Bobbin	NQI		0.57	14TH TSP	+32.34 FL
		06/95 RFO	Bobbin	NQI		0.96	10TH TSP	+12.02 FL
139	2	06/95 RFO	Bobbin	ODI	12	0.81	11TH TSP	+5.27 FL
139	29	06/95 RFO	Bobbin	ODI	38	1.46	9TH TSP	+7.67 FL
139	73	06/95 RFO	Bobbin	NQI		0.47	10TH TSP	+14.76 FL
140	31	06/95 RFO	Bobbin	ODI	58	0.51	4TH TSP	+3.89 FL
140	51	06/95 RFO	Bobbin	NQI		0.46	15TH TSP	+10.70 FL
140	64	06/95 RFO	Bobbin	NQI		0.43	9TH TSP	-0.40 FL
		06/95 RFO	Bobbin	NQI		0.52	8TH TSP	+14.91 FL
140	71	06/95 RFO	Bobbin	NQI		0.33	8TH TSP	+0.67 FL
		06/95 RFO	Bobbin	NQI		0.41	14TH TSP	+0.76 FL
141	1	06/95 RFO	Bobbin	NQI		1.47	15TH TSP	-1.19 FL
141	3	06/95 RFO	Bobbin	NQI		2.32	14TH TSP	+0.59 FL
141	27	06/95 RFO	Bobbin	ADI		1.21	3RD TSP	+22.58 FL
141	30	06/95 RFO	Bobbin	ODI	19	1.08	LTSP	-0.38 FL
141	45	06/95 RFO	Bobbin	NQI		0.62	LTSP	-0.35 FL
141	61	06/95 RFO	Bobbin	NQI		0.41	7TH TSP	+20.78 FL
		06/95 RFO	Bobbin	NQI		0.57	7TH TSP	+23.71 FL
141	62	06/95 RFO	Bobbin	NQI		2.03	2ND TSP	+10.27 FL
142	1	06/95 RFO	Bobbin	NQI		1.07	15TH TSP	-0.47 FL
		06/95 RFO	Bobbin	ODI	9	2.09	15TH TSP	-1.01 FL
		06/95 RFO	Bobbin	ODI	14	0.52	10TH TSP	+3.94 FL
142	5	06/95 RFO	Bobbin	ODI	17	0.97	9TH TSP	+0.55 FL
142	27	06/95 RFO	Bobbin	NQI		0.46	12TH TSP	+13.02 FL
		06/95 RFO	Bobbin	ODI	18	2.08	5TH TSP	+25.22 FL
142	55	06/95 RFO	Bobbin	ODI	23	0.89	LTPF	+13.45 FL
142	58	06/95 RFO	Bobbin	ODI	5	0.57	9TH TSP	-0.61 FL
142	62	06/95 RFO	Bobbin	NQI		0.32	15TH TSP	+8.12 FL
142	63	06/95 RFO	Bobbin	ODI	28	0.60	5TH TSP	+16.48 FL
143	1	06/95 RFO	Bobbin	NQI		0.31	15TH TSP	-0.35 FL
143	6	06/95 RFO	Bobbin	ODI	23	0.74	3RD TSP	+21.48 FL
143	13	06/95 RFO	Bobbin	NQI		0.74	6TH TSP	-0.46 FL
143	21	06/95 RFO	Bobbin	ODI	33	0.44	LTSP	+11.38 FL
		06/95 RFO	Bobbin	ODI	49	0.39	13TH TSP	+18.44 FL
143	33	06/95 RFO	Bobbin	NQI		0.58	2ND TSP	+36.39 FL
143	61	06/95 RFO	Bobbin	ODI	23	0.62	15TH TSP	+17.23 FL

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 Bobbin

Page 25 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
144	1	06/95 RFO	Bobbin	NQI		0.55	LTSF	-0.40
144	14	06/95 RFO	Bobbin	ODI	13	0.85	9TH TSP	-0.56
		06/95 RFO	Bobbin	ODI	20	0.77	9TH TSP	-0.74
144	23	06/95 RFO	Bobbin	NQI		0.67	LTSF	-0.51
144	40	06/95 RFO	Bobbin	NQI		0.67	LTPF	+8.48
144	56	06/95 RFO	Bobbin	ODI	34	3.77	8TH TSP	+1.47
145	4	06/95 RFO	Bobbin	NQI		0.50	15TH TSP	+7.35
145	5	06/95 RFO	Bobbin	ADI		1.14	8TH TSP	+33.65
145	31	06/95 RFO	Bobbin	NQI		0.29	1ST TSP	+14.18
145	40	06/95 RFO	Bobbin	NQI		0.48	15TH TSP	-0.46
145	41	06/95 RFO	Bobbin	NQI		0.29	9TH TSP	+11.01
		06/95 RFO	Bobbin	NQI		0.32	9TH TSP	+14.14
		06/95 RFO	Bobbin	NQI		0.55	9TH TSP	+0.60
145	49	06/95 RFO	Bobbin	NQI		0.46	9TH TSP	+23.30
		06/95 RFO	Bobbin	ODI	30	0.34	10TH TSP	+0.71
145	51	06/95 RFO	Bobbin	NQI		0.44	10TH TSP	+0.69
146	10	06/95 RFO	Bobbin	NQI		0.37	8TH TSP	+0.46
146	11	06/95 RFO	Bobbin	ODI	21	0.41	14TH TSP	+1.26
146	36	06/95 RFO	Bobbin	ODI	23	0.50	15TH TSP	-1.38
146	37	06/95 RFO	Bobbin	NQI		0.81	15TH TSP	-0.54
146	40	06/95 RFO	Bobbin	ODI	18	0.44	10TH TSP	-0.60
146	41	06/95 RFO	Bobbin	ODI	10	0.72	14TH TSP	+32.38
146	45	06/95 RFO	Bobbin	NQI		1.43	15TH TSP	-0.49
146	47	06/95 RFO	Bobbin	NQI		0.47	10TH TSP	+0.65
146	48	06/95 RFO	Bobbin	ODI	36	0.32	10TH TSP	+0.60
146	49	06/95 RFO	Bobbin	NQI		1.40	15TH TSP	-0.29
147	13	06/95 RFO	Bobbin	NQI		0.71	6TH TSP	-0.51
147	37	06/95 RFO	Bobbin	NQI		0.42	5TH TSP	+4.79
147	43	06/95 RFO	Bobbin	ODI	5	0.84	14TH TSP	+0.99
147	45	06/95 RFO	Bobbin	ODI	16	0.58	14TH TSP	+30.92
147	46	06/95 RFO	Bobbin	ODI	8	1.66	15TH TSP	-1.38
148	23	06/95 RFO	Bobbin	NQI		0.58	11TH TSP	+30.68
148	25	06/95 RFO	Bobbin	ODI	30	0.32	13TH TSP	+5.44
148	34	06/95 RFO	Bobbin	NQI		0.53	9TH TSP	+12.23
148	39	06/95 RFO	Bobbin	ODI	16	0.70	13TH TSP	+2.89
148	40	06/95 RFO	Bobbin	ODI	10	1.26	14TH TSP	+30.64
148	41	06/95 RFO	Bobbin	ODI	2	0.94	14TH TSP	+33.58
149	1	06/95 RFO	Bobbin	ADI		1.05	15TH TSP	+14.36
149	16	06/95 RFO	Bobbin	ODI	16	0.44	10TH TSP	+1.26
149	17	06/95 RFO	Bobbin	ODI	21	0.51	10TH TSP	+1.20
149	25	06/95 RFO	Bobbin	ODI	25	0.78	15TH TSP	-0.12
149	30	06/95 RFO	Bobbin	NQI		0.43	11TH TSP	+0.57
		06/95 RFO	Bobbin	NQI		0.50	10TH TSP	-0.68
149	32	06/95 RFO	Bobbin	NQI		0.56	12TH TSP	+3.08
		06/95 RFO	Bobbin	ODI	9	0.84	11TH TSP	+5.59
		06/95 RFO	Bobbin	ODI	16	0.97	14TH TSP	+2.46
		06/95 RFO	Bobbin	ODI	17	1.60	13TH TSP	+5.31
149	33	06/95 RFO	Bobbin	NQI		0.40	14TH TSP	+3.65
		06/95 RFO	Bobbin	NQI		0.40	15TH TSP	+0.15
		06/95 RFO	Bobbin	NQI		0.68	11TH TSP	+8.85
		06/95 RFO	Bobbin	ODI	3	1.79	13TH TSP	+4.89
		06/95 RFO	Bobbin	ODI	12	1.50	14TH TSP	+3.28
		06/95 RFO	Bobbin	ODI	27	0.73	10TH TSP	+12.42
150	12	06/95 RFO	Bobbin	ODI	61	0.65	10TH TSP	-0.72
150	17	06/95 RFO	Bobbin	ODI	13	0.40	14TH TSP	+5.57
		06/95 RFO	Bobbin	ODI	38	0.41	10TH TSP	+0.57
150	18	06/95 RFO	Bobbin	NQI		0.30	15TH TSP	+8.05
		06/95 RFO	Bobbin	NQI		0.36	15TH TSP	+7.43
		06/95 RFO	Bobbin	NQI		1.25	15TH TSP	-0.34
150	19	06/95 RFO	Bobbin	ODI	2	0.69	15TH TSP	-1.14
		06/95 RFO	Bobbin	ODI	33	0.54	14TH TSP	+33.52
150	20	06/95 RFO	Bobbin	NQI		0.69	15TH TSP	-0.12
150	21	06/95 RFO	Bobbin	NQI		0.41	14TH TSP	+31.84
		06/95 RFO	Bobbin	ODI	11	1.58	15TH TSP	-1.13
150	23	06/95 RFO	Bobbin	NQI		0.44	12TH TSP	+4.06

BWNT TUBAN II (Version 2.1) 07/18/1995 08:54:48
Oconee Nuclear Station - Unit Three
S/G B
06/95 RFO
Bobbin

Page 26 of 26

ATTACHMENT #2 - LIST OF IMPERFECTIONS - BOBBIN

QRY: 07/18/1995 07:59:51

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		06/95 RFO	Bobbin	ODI	5	1.29	14TH TSP	+2.81
		06/95 RFO	Bobbin	ODI	6	0.81	11TH TSP	+3.16
		06/95 RFO	Bobbin	ODI	17	0.70	12TH TSP	+3.73
		06/95 RFO	Bobbin	ODI	17	1.35	13TH TSP	+4.37
150	25	06/95 RFO	Bobbin	ADI		1.16	14TH TSP	+3.66
		06/95 RFO	Bobbin	NQI		0.64	10TH TSP	+8.77
		06/95 RFO	Bobbin	NQI		0.97	12TH TSP	+5.13
		06/95 RFO	Bobbin	ODI	9	0.33	12TH TSP	+5.85
		06/95 RFO	Bobbin	ODI	12	1.51	13TH TSP	+4.74
150	26	06/95 RFO	Bobbin	ODI	23	0.57	12TH TSP	+8.21
		06/95 RFO	Bobbin	ODI	23	0.81	14TH TSP	+4.29
150	27	06/95 RFO	Bobbin	NQI		0.37	13TH TSP	+8.64
		06/95 RFO	Bobbin	ODI	3	0.36	14TH TSP	+4.98
		06/95 RFO	Bobbin	ODI	5	0.68	14TH TSP	+4.39
		06/95 RFO	Bobbin	ODI	8	0.85	14TH TSP	+3.81
		06/95 RFO	Bobbin	ODI	16	0.34	13TH TSP	+8.20
		06/95 RFO	Bobbin	ODI	16	1.04	14TH TSP	+4.09
151	12	06/95 RFO	Bobbin	NQI		0.56	12TH TSP	+1.19
151	13	06/95 RFO	Bobbin	NQI		0.68	15TH TSP	+9.16
151	14	06/95 RFO	Bobbin	ODI	21	0.56	15TH TSP	+2.81
151	16	06/95 RFO	Bobbin	ODI	3	1.95	15TH TSP	-1.18
		06/95 RFO	Bobbin	ODI	6	0.78	13TH TSP	+3.78

Total Indications Found = 1647

Total Tubes Found = 1239

ATTACHMENT 3

8 Pages

BWNT TUBAN II (Version 2.1) 07/18/1995 10:12:09

Oconee Nuclear Station - Unit Three

S/G A

06/95 RFO

MRPC Lane & Wedge, MRPC Slv Upper Roll, Re-expanded MRPC, SPECIAL INTEREST

Page 1 of 8

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC

QRY: 07/18/1995 10:09:34

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
2	1	06/95 RFO	SPECIAL INTEREST	VOL		1.78	15TH TSP	-5.80
2	19	06/95 RFO	SPECIAL INTEREST	VOL		1.86	10TH TSP	+0.53
2	23	06/95 RFO	SPECIAL INTEREST	VOL		3.08	11TH TSP	+3.34
2	26	06/95 RFO	SPECIAL INTEREST	VOL		2.80	14TH TSP	+0.65
		06/95 RFO	SPECIAL INTEREST	VOL		2.94	10TH TSP	+10.85
3	3	06/95 RFO	SPECIAL INTEREST	VOL		4.16	13TH TSP	+4.50
3	6	06/95 RFO	SPECIAL INTEREST	VOL		4.92	15TH TSP	-1.04
3	10	06/95 RFO	SPECIAL INTEREST	VOL		7.80	15TH TSP	-1.28
3	14	06/95 RFO	SPECIAL INTEREST	VOL		4.63	15TH TSP	+0.66
3	27	06/95 RFO	SPECIAL INTEREST	VOL		1.80	3RD TSP	+3.69
4	1	06/95 RFO	SPECIAL INTEREST	VOL		3.73	15TH TSP	+13.51
4	2	06/95 RFO	SPECIAL INTEREST	SAI		4.25	15TH TSP	+23.47 to +25.82
5	2	06/95 RFO	SPECIAL INTEREST	SAI		3.10	15TH TSP	+23.87 to +25.45
5	3	06/95 RFO	SPECIAL INTEREST	SAI		4.22	15TH TSP	+23.89
5	40	06/95 RFO	SPECIAL INTEREST	VOL		2.50	9TH TSP	+0.33
6	34	06/95 RFO	SPECIAL INTEREST	VOL		0.90	9TH TSP	-0.55
7	45	06/95 RFO	SPECIAL INTEREST	VOL		1.39	9TH TSP	-0.66
7	46	06/95 RFO	SPECIAL INTEREST	VOL		3.86	9TH TSP	-0.59
7	54	06/95 RFO	SPECIAL INTEREST	VOL		0.44	14TH TSP	+1.06
8	42	06/95 RFO	SPECIAL INTEREST	VOL		2.38	9TH TSP	-0.53
9	13	06/95 RFO	SPECIAL INTEREST	VOL		1.32	10TH TSP	-16.43
9	15	06/95 RFO	SPECIAL INTEREST	VOL		3.65	9TH TSP	+19.33 to +28.16
9	61	06/95 RFO	SPECIAL INTEREST	MAI		1.65	15TH TSP	+6.59
		06/95 RFO	SPECIAL INTEREST	SAI		1.15	15TH TSP	+7.51
9	62	06/95 RFO	SPECIAL INTEREST	VOL		1.42	11TH TSP	-0.64
		06/95 RFO	SPECIAL INTEREST	VOL		2.74	15TH TSP	+2.07
		06/95 RFO	SPECIAL INTEREST	VOL		3.88	15TH TSP	+2.61
10	13	06/95 RFO	SPECIAL INTEREST	VOL		2.98	LTSP	+18.95
10	44	06/95 RFO	SPECIAL INTEREST	VOL		1.10	9TH TSP	+0.37
10	47	06/95 RFO	SPECIAL INTEREST	VOL		1.97	7TH TSP	+20.01
10	63	06/95 RFO	SPECIAL INTEREST	VOL		1.56	15TH TSP	+0.67
10	65	06/95 RFO	SPECIAL INTEREST	VOL		5.02	15TH TSP	+0.85
11	59	06/95 RFO	SPECIAL INTEREST	VOL		2.44	9TH TSP	+23.03
		06/95 RFO	SPECIAL INTEREST	VOL		2.81	9TH TSP	+22.07
		06/95 RFO	SPECIAL INTEREST	VOL		4.39	10TH TSP	-29.36 to -7.75
11	61	06/95 RFO	SPECIAL INTEREST	VOL		2.59	10TH TSP	-9.93
11	63	06/95 RFO	SPECIAL INTEREST	SAI		1.77	15TH TSP	+3.19
11	64	06/95 RFO	SPECIAL INTEREST	VOL		0.48	10TH TSP	+0.56
		06/95 RFO	SPECIAL INTEREST	VOL		1.39	11TH TSP	-0.86
11	65	06/95 RFO	SPECIAL INTEREST	SAI		2.17	15TH TSP	+3.80
		06/95 RFO	SPECIAL INTEREST	SAI		2.64	15TH TSP	+3.17
11	66	06/95 RFO	SPECIAL INTEREST	SAI		4.02	15TH TSP	+5.58
		06/95 RFO	SPECIAL INTEREST	SAI		4.28	15TH TSP	+4.70
		06/95 RFO	SPECIAL INTEREST	VOL		1.32	14TH TSP	+1.06
12	57	06/95 RFO	SPECIAL INTEREST	VOL		0.87	7TH TSP	-0.76
12	66	06/95 RFO	SPECIAL INTEREST	SAI		0.68	15TH TSP	+3.08
12	67	06/95 RFO	SPECIAL INTEREST	SAI		1.19	15TH TSP	+4.26
12	70	06/95 RFO	SPECIAL INTEREST	VOL		1.02	8TH TSP	-0.66
13	47	06/95 RFO	SPECIAL INTEREST	VOL		1.53	14TH TSP	+1.08
13	63	06/95 RFO	SPECIAL INTEREST	VOL		5.19	9TH TSP	+21.18
13	68	06/95 RFO	SPECIAL INTEREST	SAI		2.14	11TH TSP	+16.56
14	70	06/95 RFO	SPECIAL INTEREST	VOL		1.52	10TH TSP	-7.72
14	71	06/95 RFO	SPECIAL INTEREST	VOL		0.76	10TH TSP	-5.06
15	68	06/95 RFO	SPECIAL INTEREST	VOL		1.58	10TH TSP	-11.66
15	77	06/95 RFO	SPECIAL INTEREST	VOL		0.63	LTSP	+0.59
		06/95 RFO	SPECIAL INTEREST	VOL		0.92	LTSP	+0.07
		06/95 RFO	SPECIAL INTEREST	VOL		0.80	13TH TSP	-9.36
16	30	06/95 RFO	SPECIAL INTEREST	SAI		1.08	9TH TSP	-1.66
		06/95 RFO	SPECIAL INTEREST	SAI		0.64	9TH TSP	+1.34 to +12.42
16	71	06/95 RFO	SPECIAL INTEREST	SAI		0.92	15TH TSP	-1.38
		06/95 RFO	SPECIAL INTEREST	VOL		3.05	9TH TSP	+11.26 to +31.00
16	78	06/95 RFO	SPECIAL INTEREST	VOL		0.95	14TH TSP	+0.75
17	49	06/95 RFO	SPECIAL INTEREST	NQI		5.86	14TH TSP	+0.36
		06/95 RFO	SPECIAL INTEREST	VOL		0.96	14TH TSP	+0.32
17	72	06/95 RFO	SPECIAL INTEREST	VOL		2.79	9TH TSP	+20.73 to +23.29

BWNT TUBAN II (Version 2.1) 07/18/1995 10:12:09
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO

MRPC Lane & Wedge, MRPC Slv Upper Roll, Re-expanded MRPC, SPECIAL INTEREST

Page 2 of 8

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC

QRY: 07/18/1995 10:09:34

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
17	76	06/95 RFO	SPECIAL INTEREST	VOL		2.32	9TH TSP	+24.91
17	78	06/95 RFO	SPECIAL INTEREST	VOL		4.13	9TH TSP	+21.89 to +25.16
17	79	06/95 RFO	SPECIAL INTEREST	VOL		0.89	14TH TSP	+0.84
18	77	06/95 RFO	SPECIAL INTEREST	VOL		0.98	14TH TSP	+0.80
18	79	06/95 RFO	SPECIAL INTEREST	VOL		2.46	10TH TSP	-21.98 to -16.38
22	69	06/95 RFO	SPECIAL INTEREST	VOL		0.82	4TH TSP	-11.67
22	75	06/95 RFO	SPECIAL INTEREST	VOL		0.21	11TH TSP	-9.28
22	91	06/95 RFO	SPECIAL INTEREST	VOL		3.50	10TH TSP	+0.73
23	94	06/95 RFO	SPECIAL INTEREST	VOL		1.50	11TH TSP	-0.78
24	5	06/95 RFO	SPECIAL INTEREST	WAR	9	2.34	9TH TSP	+0.00
25	95	06/95 RFO	SPECIAL INTEREST	VOL		2.79	8TH TSP	+0.65
26	92	06/95 RFO	SPECIAL INTEREST	VOL		2.02	8TH TSP	-0.60
27	30	06/95 RFO	SPECIAL INTEREST	VOL		0.76	14TH TSP	+0.91
27	80	06/95 RFO	SPECIAL INTEREST	VOL		4.46	10TH TSP	-7.06
27	92	06/95 RFO	SPECIAL INTEREST	VOL		2.56	10TH TSP	+11.06
27	98	06/95 RFO	SPECIAL INTEREST	VOL		1.46	11TH TSP	-0.81
28	31	06/95 RFO	SPECIAL INTEREST	VOL		0.34	14TH TSP	+1.10
29	1	06/95 RFO	SPECIAL INTEREST	VOL		3.33	15TH TSP	+0.92
29	56	06/95 RFO	SPECIAL INTEREST	VOL		0.59	14TH TSP	+1.08
29	57	06/95 RFO	SPECIAL INTEREST	VOL		1.55	14TH TSP	+1.03
30	1	06/95 RFO	SPECIAL INTEREST	VOL		3.24	15TH TSP	+1.25
30	27	06/95 RFO	SPECIAL INTEREST	NQI		0.20	14TH TSP	+1.15
		06/95 RFO	SPECIAL INTEREST	VOL		0.33	14TH TSP	+1.17
30	80	06/95 RFO	SPECIAL INTEREST	VOL		1.01	14TH TSP	+1.04
31	57	06/95 RFO	SPECIAL INTEREST	VOL		0.57	14TH TSP	-0.49
31	74	06/95 RFO	SPECIAL INTEREST	VOL		1.01	6TH TSP	+17.60
		06/95 RFO	SPECIAL INTEREST	VOL		0.55	10TH TSP	-16.36
31	90	06/95 RFO	SPECIAL INTEREST	VOL		2.30	7TH TSP	-10.27
32	3	06/95 RFO	SPECIAL INTEREST	VOL		3.27	10TH TSP	+0.63
32	66	06/95 RFO	SPECIAL INTEREST	VOL		1.13	15TH TSP	+6.18
33	21	06/95 RFO	SPECIAL INTEREST	VOL		0.21	14TH TSP	+0.93
33	41	06/95 RFO	SPECIAL INTEREST	VOL		0.42	15TH TSP	+0.45
33	80	06/95 RFO	SPECIAL INTEREST	VOL		0.73	15TH TSP	-8.34
34	64	06/95 RFO	SPECIAL INTEREST	VOL		0.98	4TH TSP	+10.18
35	1	06/95 RFO	SPECIAL INTEREST	VOL		1.56	7TH TSP	+30.61
35	41	06/95 RFO	SPECIAL INTEREST	VOL		0.73	15TH TSP	+0.70
35	42	06/95 RFO	SPECIAL INTEREST	VOL		0.49	14TH TSP	+0.40
35	108	06/95 RFO	SPECIAL INTEREST	VOL		15.32	UTSF	-14.89
36	17	06/95 RFO	SPECIAL INTEREST	VOL		0.25	LTSP	+9.43
36	44	06/95 RFO	SPECIAL INTEREST	VOL		0.39	15TH TSP	+0.41
37	113	06/95 RFO	SPECIAL INTEREST	VOL		5.14	13TH TSP	+1.12
37	114	06/95 RFO	SPECIAL INTEREST	VOL		8.63	11TH TSP	+0.67
38	4	06/95 RFO	SPECIAL INTEREST	VOL		0.57	14TH TSP	+1.19
38	42	06/95 RFO	SPECIAL INTEREST	VOL		0.59	12TH TSP	+30.81
		06/95 RFO	SPECIAL INTEREST	VOL		0.63	12TH TSP	+30.92
		06/95 RFO	SPECIAL INTEREST	VOL		1.06	12TH TSP	+30.77
39	85	06/95 RFO	SPECIAL INTEREST	VOL		0.88	2ND TSP	-5.02
40	76	06/95 RFO	SPECIAL INTEREST	VOL		0.75	14TH TSP	+0.37
40	79	06/95 RFO	SPECIAL INTEREST	VOL		0.48	12TH TSP	-3.09
43	1	06/95 RFO	SPECIAL INTEREST	VOL		0.55	13TH TSP	-0.83
45	72	06/95 RFO	SPECIAL INTEREST	VOL		1.62	11TH TSP	+18.79
46	39	06/95 RFO	SPECIAL INTEREST	VOL		0.49	14TH TSP	+1.03
		06/95 RFO	SPECIAL INTEREST	VOL		0.53	14TH TSP	+0.94
46	59	06/95 RFO	SPECIAL INTEREST	VOL		0.65	15TH TSP	+1.78
		06/95 RFO	SPECIAL INTEREST	VOL		1.37	15TH TSP	+1.75
46	64	06/95 RFO	SPECIAL INTEREST	VOL		1.64	15TH TSP	-7.33
48	15	06/95 RFO	SPECIAL INTEREST	VOL		1.02	12TH TSP	-11.68
48	31	06/95 RFO	SPECIAL INTEREST	VOL		0.34	15TH TSP	+0.52
48	51	06/95 RFO	SPECIAL INTEREST	VOL		1.90	12TH TSP	+17.36
48	123	06/95 RFO	SPECIAL INTEREST	SAI		3.71	15TH TSP	+17.69
49	4	06/95 RFO	SPECIAL INTEREST	VOL		1.48	10TH TSP	-2.37
49	7	06/95 RFO	SPECIAL INTEREST	VOL		3.60	10TH TSP	-15.71
51	62	06/95 RFO	SPECIAL INTEREST	VOL		0.18	13TH TSP	-4.16
51	91	06/95 RFO	SPECIAL INTEREST	VOL		1.41	3RD TSP	+2.91
52	46	06/95 RFO	SPECIAL INTEREST	VOL		0.19	6TH TSP	-2.68

BWNT TUBAN II (Version 2.1) 07/18/1995 10:12:09
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO

MRPC Lane & Wedge, MRPC Slv Upper Roll, Re-expanded MRPC, SPECIAL INTEREST

Page 3 of 8

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC

QRY: 07/18/1995 10:09:34

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
52	52	06/95 RFO	SPECIAL INTEREST	VOL		0.19	15TH TSP	+12.12
52	122	06/95 RFO	SPECIAL INTEREST	VOL		1.05	11TH TSP	-0.70
53	2	06/95 RFO	SPECIAL INTEREST	VOL		1.84	11TH TSP	+0.58
53	70	06/95 RFO	SPECIAL INTEREST	VOL		0.88	10TH TSP	+11.75
53	122	06/95 RFO	SPECIAL INTEREST	VOL		1.67	15TH TSP	+0.14
53	125	06/95 RFO	SPECIAL INTEREST	VOL		1.75	10TH TSP	+18.38
55	1	06/95 RFO	SPECIAL INTEREST	VOL		2.65	12TH TSP	-0.66
55	4	06/95 RFO	SPECIAL INTEREST	VOL		1.02	15TH TSP	+1.98
55	11	06/95 RFO	SPECIAL INTEREST	VOL		1.68	12TH TSP	+2.87
		06/95 RFO	SPECIAL INTEREST	VOL		1.84	11TH TSP	+31.75
56	1	06/95 RFO	SPECIAL INTEREST	VOL		1.14	12TH TSP	+7.13
		06/95 RFO	SPECIAL INTEREST	VOL		2.34	12TH TSP	+7.68
		06/95 RFO	SPECIAL INTEREST	WAR	26	5.50	13TH TSP	+0.00
56	4	06/95 RFO	SPECIAL INTEREST	VOL		1.47	11TH TSP	-0.78
56	71	06/95 RFO	SPECIAL INTEREST	VOL		0.76	15TH TSP	-2.55
57	1	06/95 RFO	SPECIAL INTEREST	VOL		0.45	14TH TSP	+7.55
		06/95 RFO	SPECIAL INTEREST	WAR	13	2.69	14TH TSP	+0.00
57	2	06/95 RFO	SPECIAL INTEREST	WAR	12	2.39	13TH TSP	+0.00
57	3	06/95 RFO	SPECIAL INTEREST	VOL		1.62	14TH TSP	+1.10
57	79	06/95 RFO	SPECIAL INTEREST	VOL		0.94	8TH TSP	+2.84
58	1	06/95 RFO	SPECIAL INTEREST	VOL		0.66	14TH TSP	+7.27
		06/95 RFO	SPECIAL INTEREST	VOL		2.06	14TH TSP	+31.46
58	2	06/95 RFO	SPECIAL INTEREST	WAR	12	2.36	14TH TSP	+0.00
		06/95 RFO	SPECIAL INTEREST	WAR	15	3.01	13TH TSP	+0.00
58	3	06/95 RFO	SPECIAL INTEREST	WAR	14	2.72	11TH TSP	+0.00
58	90	06/95 RFO	SPECIAL INTEREST	VOL		0.95	11TH TSP	+13.60
58	103	06/95 RFO	SPECIAL INTEREST	VOL		0.28	8TH TSP	+5.95
		06/95 RFO	SPECIAL INTEREST	VOL		0.76	8TH TSP	+3.96
58	125	06/95 RFO	SPECIAL INTEREST	WAR	7	1.67	9TH TSP	+0.00
59	3	06/95 RFO	SPECIAL INTEREST	VOL		2.94	15TH TSP	-0.38
59	74	06/95 RFO	SPECIAL INTEREST	SAI		1.93	15TH TSP	-0.54
		06/95 RFO	SPECIAL INTEREST	SAI		2.24	15TH TSP	-0.48
59	81	06/95 RFO	SPECIAL INTEREST	VOL		1.37	11TH TSP	-13.85
		06/95 RFO	SPECIAL INTEREST	VOL		1.83	11TH TSP	-1.76
60	2	06/95 RFO	SPECIAL INTEREST	WAR	16	3.35	11TH TSP	+0.00
		06/95 RFO	SPECIAL INTEREST	WAR	25	5.83	13TH TSP	+0.00
60	3	06/95 RFO	SPECIAL INTEREST	WAR	10	2.14	11TH TSP	+0.00
60	52	06/95 RFO	SPECIAL INTEREST	VOL		0.39	9TH TSP	-3.29
61	1	06/95 RFO	SPECIAL INTEREST	VOL		3.87	14TH TSP	+4.92
		06/95 RFO	SPECIAL INTEREST	WAR	22	5.05	11TH TSP	+0.00
61	2	06/95 RFO	SPECIAL INTEREST	WAR	16	3.42	11TH TSP	+0.00
61	3	06/95 RFO	SPECIAL INTEREST	WAR	12	2.67	13TH TSP	+0.00
61	86	06/95 RFO	SPECIAL INTEREST	VOL		2.95	15TH TSP	+0.85
61	98	06/95 RFO	SPECIAL INTEREST	VOL		0.64	14TH TSP	+15.11
		06/95 RFO	SPECIAL INTEREST	VOL		0.90	15TH TSP	+10.10
63	5	06/95 RFO	SPECIAL INTEREST	VOL		0.51	12TH TSP	+0.87
63	21	06/95 RFO	SPECIAL INTEREST	VOL		0.48	2ND TSP	+13.16
		06/95 RFO	SPECIAL INTEREST	VOL		2.54	3RD TSP	+17.72
64	2	06/95 RFO	SPECIAL INTEREST	WAR	13	2.33	11TH TSP	+0.00
64	12	06/95 RFO	SPECIAL INTEREST	VOL		1.35	UTSF	-0.42
64	40	06/95 RFO	SPECIAL INTEREST	VOL		1.24	8TH TSP	+17.71
64	48	06/95 RFO	SPECIAL INTEREST	VOL		1.05	9TH TSP	-10.34
65	2	06/95 RFO	SPECIAL INTEREST	WAR	17	3.11	11TH TSP	+0.00
67	2	06/95 RFO	SPECIAL INTEREST	VOL		3.71	10TH TSP	+6.97
68	2	06/95 RFO	SPECIAL INTEREST	VOL		1.93	13TH TSP	+15.07
		06/95 RFO	SPECIAL INTEREST	WAR	9	1.45	11TH TSP	+0.00
68	5	06/95 RFO	SPECIAL INTEREST	WAR	8	1.36	10TH TSP	+0.00
68	14	06/95 RFO	SPECIAL INTEREST	VOL		2.37	15TH TSP	+0.21
68	66	06/95 RFO	SPECIAL INTEREST	VOL		4.48	4TH TSP	+0.73
68	100	06/95 RFO	SPECIAL INTEREST	VOL		1.77	15TH TSP	+0.67
68	127	06/95 RFO	SPECIAL INTEREST	VOL		2.16	8TH TSP	+0.05
69	15	06/95 RFO	SPECIAL INTEREST	VOL		2.27	15TH TSP	+1.49
69	44	06/95 RFO	SPECIAL INTEREST	WAR	19	4.14	6TH TSP	+0.00
69	46	06/95 RFO	SPECIAL INTEREST	WAR	19	3.93	6TH TSP	+0.00
69	131	06/95 RFO	SPECIAL INTEREST	VOL		2.29	10TH TSP	+0.74

BWNT TUBAN II (Version 2.1) 07/18/1995 10:12:09
 Oconee Nuclear Station - Unit Three
 S/G A
 06/95 RFO

MRPC Lane & Wedge, MRPC Slv Upper Roll, Re-expanded MRPC, SPECIAL INTEREST

Page 4 of 8

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC

QRY: 07/18/1995 10:09:34

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		06/95 RFO	SPECIAL INTEREST	VOL		2.30	11TH TSP	-0.60
70	3	06/95 RFO	SPECIAL INTEREST	WAR	13	2.36	11TH TSP	+0.00
70	11	06/95 RFO	SPECIAL INTEREST	VOL		2.13	12TH TSP	-1.60
		06/95 RFO	SPECIAL INTEREST	VOL		2.52	14TH TSP	-0.73
70	45	06/95 RFO	SPECIAL INTEREST	WAR	17	3.42	9TH TSP	+0.00
70	65	06/95 RFO	SPECIAL INTEREST	VOL		11.02	12TH TSP	+9.87
70	128	06/95 RFO	SPECIAL INTEREST	VOL		3.77	8TH TSP	-0.72
71	3	06/95 RFO	SPECIAL INTEREST	WAR	16	3.02	13TH TSP	+0.00
71	6	06/95 RFO	SPECIAL INTEREST	WAR	14	2.59	13TH TSP	+0.00
71	9	06/95 RFO	SPECIAL INTEREST	VOL		2.35	12TH TSP	-1.97
		06/95 RFO	SPECIAL INTEREST	WAR	11	2.39	11TH TSP	+0.00
71	11	06/95 RFO	SPECIAL INTEREST	WAR	6	1.34	14TH TSP	+0.00
71	14	06/95 RFO	MRPC Lane & Wedge	VOL		4.16	15TH TSP	-0.75
71	17	06/95 RFO	MRPC Lane & Wedge	VOL		3.04	15TH TSP	-0.74
71	18	06/95 RFO	SPECIAL INTEREST	VOL		2.54	12TH TSP	-1.17
71	19	06/95 RFO	SPECIAL INTEREST	VOL		1.64	12TH TSP	-1.18
71	21	06/95 RFO	SPECIAL INTEREST	VOL		3.51	12TH TSP	+2.41
		06/95 RFO	SPECIAL INTEREST	WAR	12	2.45	10TH TSP	+0.00
71	22	06/95 RFO	SPECIAL INTEREST	VOL		1.17	12TH TSP	+3.77
71	29	06/95 RFO	SPECIAL INTEREST	VOL		1.10	13TH TSP	+0.64
71	30	06/95 RFO	SPECIAL INTEREST	VOL		1.78	10TH TSP	+0.49
71	33	06/95 RFO	SPECIAL INTEREST	VOL		3.37	12TH TSP	+0.53
71	40	06/95 RFO	SPECIAL INTEREST	VOL		2.32	9TH TSP	+0.40
71	44	06/95 RFO	SPECIAL INTEREST	VOL		2.97	9TH TSP	+0.75
71	45	06/95 RFO	SPECIAL INTEREST	VOL		3.13	8TH TSP	+0.75
71	46	06/95 RFO	SPECIAL INTEREST	VOL		1.51	7TH TSP	-0.54
		06/95 RFO	SPECIAL INTEREST	VOL		2.24	8TH TSP	-0.57
		06/95 RFO	SPECIAL INTEREST	VOL		2.28	6TH TSP	+0.68
71	48	06/95 RFO	SPECIAL INTEREST	VOL		1.70	9TH TSP	-0.67
71	60	06/95 RFO	SPECIAL INTEREST	VOL		1.81	2ND TSP	-4.06
71	101	06/95 RFO	SPECIAL INTEREST	VOL		1.76	11TH TSP	-4.32
71	128	06/95 RFO	SPECIAL INTEREST	VOL		2.28	8TH TSP	-0.73
72	4	06/95 RFO	SPECIAL INTEREST	WAR	16	2.87	14TH TSP	+0.00
72	23	06/95 RFO	SPECIAL INTEREST	VOL		2.78	UTSF	-23.39
72	28	06/95 RFO	SPECIAL INTEREST	VOL		1.51	12TH TSP	+8.63
72	31	06/95 RFO	SPECIAL INTEREST	VOL		1.85	12TH TSP	+0.55
		06/95 RFO	SPECIAL INTEREST	VOL		2.54	12TH TSP	+0.29
72	32	06/95 RFO	SPECIAL INTEREST	VOL		1.58	10TH TSP	+0.33
72	39	06/95 RFO	SPECIAL INTEREST	VOL		0.85	12TH TSP	+0.64
72	124	06/95 RFO	SPECIAL INTEREST	VOL		3.29	14TH TSP	+0.78
73	22	06/95 RFO	SPECIAL INTEREST	VOL		2.75	15TH TSP	-0.99
73	24	06/95 RFO	SPECIAL INTEREST	VOL		5.60	UTSF	-0.08
73	46	06/95 RFO	SPECIAL INTEREST	VOL		0.93	10TH TSP	+0.61
73	48	06/95 RFO	SPECIAL INTEREST	VOL		2.34	9TH TSP	+0.60
73	50	06/95 RFO	SPECIAL INTEREST	VOL		2.39	9TH TSP	+0.63
73	52	06/95 RFO	SPECIAL INTEREST	VOL		1.77	UTSF	-9.87
		06/95 RFO	SPECIAL INTEREST	VOL		1.17	8TH TSP	+0.58
73	98	06/95 RFO	SPECIAL INTEREST	VOL		1.92	1ST TSP	-7.76
73	116	06/95 RFO	SPECIAL INTEREST	VOL		1.87	14TH TSP	+13.98
74	47	06/95 RFO	SPECIAL INTEREST	VOL		0.55	15TH TSP	+0.44
74	112	06/95 RFO	SPECIAL INTEREST	VOL		0.59	12TH TSP	-8.31
75	122	06/95 RFO	SPECIAL INTEREST	VOL		0.62	14TH TSP	+1.07
77	126	06/95 RFO	SPECIAL INTEREST	VOL		2.29	14TH TSP	+1.25
78	101	06/95 RFO	SPECIAL INTEREST	VOL		2.02	14TH TSP	+1.32
78	120	06/95 RFO	SPECIAL INTEREST	VOL		0.98	14TH TSP	+1.09
78	126	06/95 RFO	SPECIAL INTEREST	VOL		1.96	8TH TSP	-0.49
		06/95 RFO	SPECIAL INTEREST	VOL		0.76	14TH TSP	+1.08
79	4	06/95 RFO	SPECIAL INTEREST	WAR	13	2.37	14TH TSP	+0.00
79	6	06/95 RFO	SPECIAL INTEREST	WAR	15	2.73	12TH TSP	+0.00
		06/95 RFO	SPECIAL INTEREST	WAR	19	3.54	13TH TSP	+0.00
		06/95 RFO	SPECIAL INTEREST	WAR	23	4.80	14TH TSP	+0.00
79	22	06/95 RFO	SPECIAL INTEREST	VOL		0.62	15TH TSP	+19.35
79	41	06/95 RFO	SPECIAL INTEREST	VOL		1.39	13TH TSP	-8.70
		06/95 RFO	SPECIAL INTEREST	VOL		2.75	13TH TSP	-14.09
79	43	06/95 RFO	MRPC Lane & Wedge	VOL		2.05	15TH TSP	+0.82

BWNT TUBAN II (Version 2.1) 07/18/1995 10:12:09

Oconee Nuclear Station - Unit Three

S/G A

06/95 RFO

MRPC Lane & Wedge, MRPC Slv Upper Roll, Re-expanded MRPC, SPECIAL INTEREST

Page 5 of 8

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC

QRY: 07/18/1995 10:09:34

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
79	117	06/95 RFO	SPECIAL INTEREST	VOL		2.01	7TH TSP	-12.21
79	127	06/95 RFO	SPECIAL INTEREST	VOL		1.81	14TH TSP	+0.60
80	9	06/95 RFO	SPECIAL INTEREST	VOL		1.35	14TH TSP	-0.76
80	10	06/95 RFO	SPECIAL INTEREST	VOL		0.85	14TH TSP	-0.72
		06/95 RFO	SPECIAL INTEREST	VOL		2.14	14TH TSP	-0.55
80	12	06/95 RFO	SPECIAL INTEREST	VOL		1.44	15TH TSP	-0.60
80	13	06/95 RFO	SPECIAL INTEREST	VOL		1.60	12TH TSP	+0.65
		06/95 RFO	SPECIAL INTEREST	VOL		4.80	14TH TSP	-0.44
80	15	06/95 RFO	SPECIAL INTEREST	VOL		3.05	UTSF	-21.01
80	17	06/95 RFO	SPECIAL INTEREST	VOL		1.75	15TH TSP	+20.84
80	20	06/95 RFO	SPECIAL INTEREST	VOL		2.18	15TH TSP	+19.89
80	21	06/95 RFO	SPECIAL INTEREST	VOL		5.90	15TH TSP	+19.90
80	22	06/95 RFO	SPECIAL INTEREST	VOL		2.78	15TH TSP	+19.02
80	23	06/95 RFO	SPECIAL INTEREST	VOL		3.12	15TH TSP	+18.93
80	24	06/95 RFO	SPECIAL INTEREST	VOL		3.48	15TH TSP	+18.28
80	25	06/95 RFO	SPECIAL INTEREST	VOL		3.48	15TH TSP	+17.71
80	27	06/95 RFO	SPECIAL INTEREST	VOL		3.24	15TH TSP	+16.77
80	28	06/95 RFO	SPECIAL INTEREST	VOL		2.25	15TH TSP	+16.01
80	29	06/95 RFO	SPECIAL INTEREST	VOL		4.68	15TH TSP	+16.14
80	30	06/95 RFO	SPECIAL INTEREST	VOL		2.95	15TH TSP	+15.85
80	31	06/95 RFO	SPECIAL INTEREST	VOL		2.01	15TH TSP	+15.60
80	32	06/95 RFO	SPECIAL INTEREST	VOL		0.89	15TH TSP	+15.33
		06/95 RFO	SPECIAL INTEREST	VOL		1.03	15TH TSP	+15.36
80	33	06/95 RFO	SPECIAL INTEREST	VOL		1.98	15TH TSP	+15.27
80	34	06/95 RFO	SPECIAL INTEREST	VOL		2.28	15TH TSP	+15.25
		06/95 RFO	SPECIAL INTEREST	VOL		2.44	15TH TSP	+13.39
80	35	06/95 RFO	SPECIAL INTEREST	VOL		2.30	15TH TSP	+14.76
		06/95 RFO	SPECIAL INTEREST	VOL		2.74	15TH TSP	+14.44
80	36	06/95 RFO	SPECIAL INTEREST	VOL		3.53	15TH TSP	+13.56
		06/95 RFO	SPECIAL INTEREST	VOL		7.05	15TH TSP	+10.59
80	37	06/95 RFO	SPECIAL INTEREST	VOL		2.60	15TH TSP	+14.60
		06/95 RFO	SPECIAL INTEREST	WAR	12	2.32	14TH TSP	-0.57
80	38	06/95 RFO	SPECIAL INTEREST	VOL		1.95	15TH TSP	+14.78
81	5	06/95 RFO	SPECIAL INTEREST	VOL		2.88	11TH TSP	-2.60
81	6	06/95 RFO	SPECIAL INTEREST	WAR	20	3.81	12TH TSP	+0.00
81	7	06/95 RFO	SPECIAL INTEREST	VOL		2.24	11TH TSP	+1.26
81	9	06/95 RFO	SPECIAL INTEREST	VOL		1.46	13TH TSP	-0.69
		06/95 RFO	SPECIAL INTEREST	VOL		2.70	14TH TSP	-0.83
81	10	06/95 RFO	SPECIAL INTEREST	VOL		1.52	13TH TSP	-0.77
81	11	06/95 RFO	SPECIAL INTEREST	VOL		1.99	13TH TSP	-0.73
81	13	06/95 RFO	SPECIAL INTEREST	VOL		2.14	13TH TSP	-0.78
		06/95 RFO	SPECIAL INTEREST	VOL		3.49	13TH TSP	-0.80
81	40	06/95 RFO	SPECIAL INTEREST	WAR	10	1.98	10TH TSP	+0.00
81	42	06/95 RFO	SPECIAL INTEREST	WAR	5	0.77	9TH TSP	+0.00
81	43	06/95 RFO	SPECIAL INTEREST	VOL		5.77	8TH TSP	+0.74
81	56	06/95 RFO	SPECIAL INTEREST	VOL		2.48	7TH TSP	+0.45
81	59	06/95 RFO	SPECIAL INTEREST	VOL		2.97	5TH TSP	+0.72
81	102	06/95 RFO	SPECIAL INTEREST	VOL		0.61	4TH TSP	+10.51
81	120	06/95 RFO	SPECIAL INTEREST	VOL		1.34	1ST TSP	+12.48
82	1	06/95 RFO	SPECIAL INTEREST	WAR	19	3.70	11TH TSP	+0.00
82	5	06/95 RFO	SPECIAL INTEREST	VOL		6.80	11TH TSP	-2.81
82	6	06/95 RFO	SPECIAL INTEREST	VOL		3.33	11TH TSP	+1.60
82	7	06/95 RFO	SPECIAL INTEREST	WAR	12	2.56	10TH TSP	-0.45
82	9	06/95 RFO	SPECIAL INTEREST	VOL		3.01	11TH TSP	+0.73
82	38	06/95 RFO	SPECIAL INTEREST	VOL		1.20	14TH TSP	+18.24
82	42	06/95 RFO	SPECIAL INTEREST	WAR	9	1.70	9TH TSP	+0.00
82	43	06/95 RFO	SPECIAL INTEREST	WAR	20	4.31	9TH TSP	+0.00
		06/95 RFO	SPECIAL INTEREST	WAR	12	2.31	10TH TSP	+0.00
82	63	06/95 RFO	SPECIAL INTEREST	VOL		1.57	7TH TSP	+15.37
83	3	06/95 RFO	SPECIAL INTEREST	WAR	13	2.34	10TH TSP	+0.00
		06/95 RFO	SPECIAL INTEREST	WAR	14	2.40	14TH TSP	+0.00
83	6	06/95 RFO	SPECIAL INTEREST	VOL		0.99	11TH TSP	-2.34
83	8	06/95 RFO	SPECIAL INTEREST	VOL		3.37	10TH TSP	+0.30
		06/95 RFO	SPECIAL INTEREST	VOL		4.31	10TH TSP	-0.02
83	31	06/95 RFO	SPECIAL INTEREST	VOL		2.25	9TH TSP	+0.69

BWNT TUBAN II (Version 2.1) 07/18/1995 10:12:09
 Oconee Nuclear Station - Unit Three
 S/G' A
 06/95 RFO

MRPC Lane & Wedge, MRPC Slv Upper Roll, Re-expanded MRPC, SPECIAL INTEREST

Page 6 of 8

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC

QRY: 07/18/1995 10:09:34

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
83	34	06/95 RFO	SPECIAL INTEREST	VOL		1.36	10TH TSP	+0.61 10TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.71	10TH TSP	+0.56 10TH TSP
83	37	06/95 RFO	SPECIAL INTEREST	VOL		0.70	10TH TSP	+0.51 10TH TSP
83	119	06/95 RFO	SPECIAL INTEREST	VOL		3.29	4TH TSP	-15.84 4TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.11	14TH TSP	+0.81 14TH TSP
84	2	06/95 RFO	SPECIAL INTEREST	WAR	11	1.86	10TH TSP	+0.00 10TH TSP
84	3	06/95 RFO	SPECIAL INTEREST	WAR	12	2.07	10TH TSP	+0.00 10TH TSP
84	6	06/95 RFO	SPECIAL INTEREST	VOL		2.18	10TH TSP	+3.69 10TH TSP
84	8	06/95 RFO	MRPC Lane & Wedge	VOL		1.68	UTSF	+0.99 UTSF
		06/95 RFO	MRPC Lane & Wedge	VOL		2.05	UTSF	-1.99 UTSF
		06/95 RFO	MRPC Lane & Wedge	VOL		4.44	UTSF	-0.98 UTSF
84	19	06/95 RFO	SPECIAL INTEREST	VOL		2.79	11TH TSP	+0.71 11TH TSP
84	26	06/95 RFO	SPECIAL INTEREST	VOL		1.79	10TH TSP	+0.72 10TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		2.08	10TH TSP	+0.49 10TH TSP
84	28	06/95 RFO	SPECIAL INTEREST	VOL		2.46	10TH TSP	+0.46 10TH TSP
84	55	06/95 RFO	SPECIAL INTEREST	VOL		2.76	5TH TSP	+0.74 5TH TSP
84	90	06/95 RFO	SPECIAL INTEREST	VOL		0.69	13TH TSP	-13.89 13TH TSP
84	125	06/95 RFO	SPECIAL INTEREST	VOL		1.98	14TH TSP	+1.24 14TH TSP
84	126	06/95 RFO	SPECIAL INTEREST	VOL		20.99	14TH TSP	+0.65 14TH TSP
84	130	06/95 RFO	SPECIAL INTEREST	VOL		2.27	11TH TSP	+1.10 11TH TSP
85	4	06/95 RFO	SPECIAL INTEREST	VOL		1.24	10TH TSP	+1.84 10TH TSP
85	26	06/95 RFO	SPECIAL INTEREST	VOL		1.34	10TH TSP	+0.00 10TH TSP
85	36	06/95 RFO	SPECIAL INTEREST	NQI		1.24	9TH TSP	-0.73 9TH TSP
85	42	06/95 RFO	SPECIAL INTEREST	WAR	15	2.57	9TH TSP	+0.00 9TH TSP
		06/95 RFO	SPECIAL INTEREST	WAR	18	3.31	8TH TSP	+0.00 8TH TSP
85	44	06/95 RFO	SPECIAL INTEREST	NQI		3.26	8TH TSP	-0.71 8TH TSP
85	123	06/95 RFO	SPECIAL INTEREST	SAI		0.70	15TH TSP	+2.22 15TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		4.36	14TH TSP	+1.19 14TH TSP
85	127	06/95 RFO	SPECIAL INTEREST	VOL		11.28	14TH TSP	+0.80 14TH TSP
86	11	06/95 RFO	SPECIAL INTEREST	VOL		1.46	10TH TSP	-0.58 10TH TSP
86	34	06/95 RFO	SPECIAL INTEREST	WAR	16	2.71	9TH TSP	+0.00 9TH TSP
86	55	06/95 RFO	SPECIAL INTEREST	NQI		2.13	5TH TSP	-0.73 5TH TSP
87	130	06/95 RFO	SPECIAL INTEREST	VOL		3.77	12TH TSP	+15.54 12TH TSP
88	2	06/95 RFO	SPECIAL INTEREST	VOL		3.56	10TH TSP	+5.35 10TH TSP
88	3	06/95 RFO	SPECIAL INTEREST	VOL		1.37	12TH TSP	-0.77 12TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		3.56	11TH TSP	+0.65 11TH TSP
88	9	06/95 RFO	SPECIAL INTEREST	SAI		1.82	13TH TSP	-6.54 13TH TSP
88	127	06/95 RFO	SPECIAL INTEREST	VOL		2.34	14TH TSP	+1.50 14TH TSP
89	117	06/95 RFO	SPECIAL INTEREST	VOL		1.57	14TH TSP	+1.14 14TH TSP
90	43	06/95 RFO	SPECIAL INTEREST	WAR	15	5.79	15TH TSP	+0.00 15TH TSP
90	115	06/95 RFO	SPECIAL INTEREST	VOL		3.47	14TH TSP	+1.10 14TH TSP
91	2	06/95 RFO	SPECIAL INTEREST	VOL		2.12	11TH TSP	+0.54 11TH TSP
91	124	06/95 RFO	SPECIAL INTEREST	VOL		3.92	14TH TSP	+1.33 14TH TSP
91	125	06/95 RFO	SPECIAL INTEREST	VOL		1.38	9TH TSP	+0.88 9TH TSP
92	127	06/95 RFO	SPECIAL INTEREST	VOL		0.63	14TH TSP	+1.18 14TH TSP
93	82	06/95 RFO	SPECIAL INTEREST	SAI		1.54	7TH TSP	-17.67 7TH TSP
		06/95 RFO	SPECIAL INTEREST	SAI		0.70	7TH TSP	+3.45 to +7.20 7TH TSP
93	123	06/95 RFO	SPECIAL INTEREST	VOL		1.91	9TH TSP	+0.95 9TH TSP
94	2	06/95 RFO	SPECIAL INTEREST	VOL		1.66	11TH TSP	+0.68 11TH TSP
94	25	06/95 RFO	SPECIAL INTEREST	VOL		3.17	14TH TSP	+0.98 14TH TSP
94	26	06/95 RFO	SPECIAL INTEREST	WAR	19	7.73	14TH TSP	+0.00 14TH TSP
94	84	06/95 RFO	SPECIAL INTEREST	SAI		0.77	10TH TSP	+1.34 to +4.87 10TH TSP
		06/95 RFO	SPECIAL INTEREST	SAI		0.84	10TH TSP	+12.32 to +22.26 10TH TSP
		06/95 RFO	SPECIAL INTEREST	SAI		0.94	10TH TSP	-15.36 to -0.77 10TH TSP
94	122	06/95 RFO	SPECIAL INTEREST	VOL		2.24	14TH TSP	+1.22 14TH TSP
97	14	06/95 RFO	SPECIAL INTEREST	VOL		5.44	13TH TSP	+19.45 13TH TSP
98	91	06/95 RFO	SPECIAL INTEREST	VOL		1.71	14TH TSP	-11.44 14TH TSP
99	11	06/95 RFO	SPECIAL INTEREST	VOL		1.45	1ST TSP	-5.65 1ST TSP
99	14	06/95 RFO	SPECIAL INTEREST	WAR	11	1.61	14TH TSP	+0.00 14TH TSP
99	53	06/95 RFO	SPECIAL INTEREST	VOL		0.50	14TH TSP	-0.21 14TH TSP
99	56	06/95 RFO	SPECIAL INTEREST	VOL		0.73	11TH TSP	-3.89 11TH TSP
103	72	06/95 RFO	SPECIAL INTEREST	VOL		0.43	4TH TSP	+9.71 4TH TSP
103	104	06/95 RFO	SPECIAL INTEREST	VOL		0.74	3RD TSP	-4.62 3RD TSP
107	58	06/95 RFO	SPECIAL INTEREST	VOL		3.21	LTSP	+4.77 LTSP
108	41	06/95 RFO	SPECIAL INTEREST	VOL		2.68	12TH TSP	+8.34 12TH TSP

BWNT TUBAN II (Version 2.1) 07/18/1995 10:12:09

Oconee Nuclear Station - Unit Three

S/G A

06/95.RFO

MRPC Lane & Wedge,MRPC Slv Upper Roll,Re-expanded MRPC,SPECIAL INTEREST

Page 7 of 8

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC

QRY: 07/18/1995 10:09:34

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
108	93	06/95 RFO	SPECIAL INTEREST	VOL		0.82	3RD TSP	3RD TSP
109	9	06/95 RFO	SPECIAL INTEREST	VOL		2.32	LTSP	LTSP
109	30	06/95 RFO	SPECIAL INTEREST	NQI		4.24	13TH TSP	13TH TSP
109	105	06/95 RFO	SPECIAL INTEREST	VOL		0.57	14TH TSP	14TH TSP
110	105	06/95 RFO	SPECIAL INTEREST	VOL		2.24	14TH TSP	14TH TSP
111	46	06/95 RFO	SPECIAL INTEREST	VOL		3.50	1ST TSP	1ST TSP
111	111	06/95 RFO	SPECIAL INTEREST	VOL		1.75	12TH TSP	12TH TSP
112	1	06/95 RFO	SPECIAL INTEREST	WAR	6	1.64	8TH TSP	8TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		2.01	15TH TSP	15TH TSP
112	116	06/95 RFO	SPECIAL INTEREST	VOL		0.92	14TH TSP	14TH TSP
113	7	06/95 RFO	SPECIAL INTEREST	VOL		2.20	9TH TSP	9TH TSP
113	95	06/95 RFO	SPECIAL INTEREST	VOL		0.78	9TH TSP	9TH TSP
114	115	06/95 RFO	SPECIAL INTEREST	VOL		0.94	10TH TSP	10TH TSP
115	60	06/95 RFO	SPECIAL INTEREST	VOL		0.66	3RD TSP	3RD TSP
		06/95 RFO	SPECIAL INTEREST	VOL		0.78	3RD TSP	3RD TSP
		06/95 RFO	SPECIAL INTEREST	VOL		0.94	3RD TSP	3RD TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.85	3RD TSP	3RD TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.87	3RD TSP	3RD TSP
115	83	06/95 RFO	SPECIAL INTEREST	VOL		1.36	14TH TSP	14TH TSP
115	114	06/95 RFO	SPECIAL INTEREST	VOL		1.10	10TH TSP	10TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.26	10TH TSP	10TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.62	10TH TSP	10TH TSP
116	50	06/95 RFO	SPECIAL INTEREST	VOL		9.28	8TH TSP	8TH TSP
116	107	06/95 RFO	SPECIAL INTEREST	VOL		3.38	9TH TSP	9TH TSP
117	89	06/95 RFO	SPECIAL INTEREST	WAR	5	1.04	15TH TSP	15TH TSP
117	90	06/95 RFO	SPECIAL INTEREST	VOL		0.67	15TH TSP	15TH TSP
117	107	06/95 RFO	SPECIAL INTEREST	VOL		3.23	10TH TSP	10TH TSP
118	100	06/95 RFO	SPECIAL INTEREST	VOL		1.70	10TH TSP	10TH TSP
119	24	06/95 RFO	SPECIAL INTEREST	VOL		1.86	8TH TSP	8TH TSP
119	55	06/95 RFO	SPECIAL INTEREST	VOL		7.94	3RD TSP	3RD TSP
119	69	06/95 RFO	SPECIAL INTEREST	VOL		5.03	2ND TSP	3RD TSP
119	79	06/95 RFO	SPECIAL INTEREST	VOL		0.65	15TH TSP	15TH TSP
119	103	06/95 RFO	SPECIAL INTEREST	VOL		1.38	9TH TSP	9TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		2.20	9TH TSP	9TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		2.32	9TH TSP	9TH TSP
120	69	06/95 RFO	SPECIAL INTEREST	VOL		1.97	4TH TSP	4TH TSP
121	42	06/95 RFO	SPECIAL INTEREST	VOL		0.60	8TH TSP	8TH TSP
121	50	06/95 RFO	SPECIAL INTEREST	VOL		1.37	2ND TSP	2ND TSP
121	104	06/95 RFO	SPECIAL INTEREST	SAI		0.70	10TH TSP	10TH TSP
		06/95 RFO	SPECIAL INTEREST	SAI		1.34	10TH TSP	10TH TSP
		06/95 RFO	SPECIAL INTEREST	SAI		2.40	10TH TSP	10TH TSP
		06/95 RFO	SPECIAL INTEREST	SAI		3.68	12TH TSP	12TH TSP
		06/95 RFO	SPECIAL INTEREST	SAI		1.15	10TH TSP	10TH TSP
121	106	06/95 RFO	SPECIAL INTEREST	SAI		1.66	10TH TSP	10TH TSP
		06/95 RFO	SPECIAL INTEREST	SAI		1.72	10TH TSP	10TH TSP
122	99	06/95 RFO	SPECIAL INTEREST	VOL		2.30	9TH TSP	9TH TSP
122	105	06/95 RFO	SPECIAL INTEREST	VOL		2.33	10TH TSP	10TH TSP
123	61	06/95 RFO	SPECIAL INTEREST	VOL		1.44	12TH TSP	12TH TSP
123	101	06/95 RFO	SPECIAL INTEREST	SAI		1.11	10TH TSP	10TH TSP
124	65	06/95 RFO	SPECIAL INTEREST	VOL		3.39	6TH TSP	6TH TSP
124	85	06/95 RFO	SPECIAL INTEREST	VOL		1.13	3RD TSP	3RD TSP
125	50	06/95 RFO	SPECIAL INTEREST	VOL		0.75	11TH TSP	11TH TSP
125	94	06/95 RFO	SPECIAL INTEREST	SAI		0.91	15TH TSP	15TH TSP
125	99	06/95 RFO	SPECIAL INTEREST	VOL		2.59	10TH TSP	10TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		3.95	11TH TSP	11TH TSP
126	5	06/95 RFO	SPECIAL INTEREST	VOL		0.68	10TH TSP	10TH TSP
126	92	06/95 RFO	SPECIAL INTEREST	VOL		1.60	1ST TSP	1ST TSP
		06/95 RFO	SPECIAL INTEREST	VOL		7.82	13TH TSP	13TH TSP
126	98	06/95 RFO	SPECIAL INTEREST	VOL		1.45	10TH TSP	10TH TSP
127	92	06/95 RFO	SPECIAL INTEREST	VOL		0.37	9TH TSP	9TH TSP
127	98	06/95 RFO	SPECIAL INTEREST	VOL		5.20	11TH TSP	11TH TSP
129	1	06/95 RFO	SPECIAL INTEREST	VOL		1.23	10TH TSP	10TH TSP
130	1	06/95 RFO	SPECIAL INTEREST	VOL		1.95	15TH TSP	15TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		8.31	13TH TSP	13TH TSP
132	82	06/95 RFO	SPECIAL INTEREST	VOL		1.28	9TH TSP	9TH TSP

BWNT TUBAN II (Version 2.1) 07/18/1995 10:12:09

Oconee Nuclear Station - Unit Three

S/G A

06/95 RFO

MRPC Lane & Wedge, MRPC Slv Upper Roll, Re-expanded MRPC, SPECIAL INTEREST

Page 8 of 8

ATTACHMENT #3 - LIST OF IMPERFECTIONS - MRPC

QRY: 07/18/1995 10:09:34

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
133	62	06/95 RFO	SPECIAL INTEREST	VOL		1.78	15TH TSP	-0.55
		06/95 RFO	SPECIAL INTEREST	VOL		1.99	15TH TSP	-0.17
134	84	06/95 RFO	SPECIAL INTEREST	VOL		1.38	10TH TSP	+0.56
135	3	06/95 RFO	SPECIAL INTEREST	VOL		1.55	4TH TSP	+20.07
135	6	06/95 RFO	SPECIAL INTEREST	VOL		1.07	9TH TSP	+0.55
135	81	06/95 RFO	SPECIAL INTEREST	VOL		8.37	10TH TSP	-0.58
136	54	06/95 RFO	SPECIAL INTEREST	VOL		0.54	6TH TSP	+8.05
136	76	06/95 RFO	SPECIAL INTEREST	VOL		1.37	9TH TSP	-0.78
137	78	06/95 RFO	SPECIAL INTEREST	VOL		5.23	10TH TSP	-0.33
138	1	06/95 RFO	SPECIAL INTEREST	WAR	21	3.29	14TH TSP	-0.75
138	74	06/95 RFO	SPECIAL INTEREST	VOL		0.90	8TH TSP	+26.95
140	62	06/95 RFO	SPECIAL INTEREST	VOL		1.69	8TH TSP	-0.82
141	1	06/95 RFO	SPECIAL INTEREST	WAR	18	2.62	14TH TSP	-0.73
141	59	06/95 RFO	SPECIAL INTEREST	VOL		5.20	8TH TSP	-0.71
141	66	06/95 RFO	SPECIAL INTEREST	VOL		1.80	8TH TSP	-5.54
144	31	06/95 RFO	SPECIAL INTEREST	VOL		1.37	1ST TSP	+0.74
144	46	06/95 RFO	SPECIAL INTEREST	VOL		1.28	13TH TSP	+0.85
144	47	06/95 RFO	SPECIAL INTEREST	VOL		0.25	13TH TSP	+0.86
146	36	06/95 RFO	SPECIAL INTEREST	VOL		0.55	6TH TSP	-16.45
146	43	06/95 RFO	SPECIAL INTEREST	VOL		6.75	9TH TSP	+0.53
147	27	06/95 RFO	SPECIAL INTEREST	VOL		4.04	9TH TSP	-0.16
		06/95 RFO	SPECIAL INTEREST	VOL		4.95	9TH TSP	-0.45
148	32	06/95 RFO	SPECIAL INTEREST	VOL		1.54	12TH TSP	+1.09
148	35	06/95 RFO	SPECIAL INTEREST	VOL		4.45	10TH TSP	+0.63
149	25	06/95 RFO	SPECIAL INTEREST	VOL		1.42	10TH TSP	+0.11
149	29	06/95 RFO	SPECIAL INTEREST	VOL		1.98	10TH TSP	+19.12
150	8	06/95 RFO	SPECIAL INTEREST	VOL		1.18	10TH TSP	+0.68
150	9	06/95 RFO	SPECIAL INTEREST	VOL		0.85	10TH TSP	-0.67
150	11	06/95 RFO	SPECIAL INTEREST	VOL		1.74	10TH TSP	+0.74
150	16	06/95 RFO	SPECIAL INTEREST	VOL		2.75	10TH TSP	-0.59
150	18	06/95 RFO	SPECIAL INTEREST	VOL		5.27	10TH TSP	+0.40
151	5	06/95 RFO	SPECIAL INTEREST	WAR	22	3.48	13TH TSP	-0.70
151	16	06/95 RFO	SPECIAL INTEREST	VOL		3.50	13TH TSP	+3.98

Total Indications Found = 488

Total Tubes Found = 399

ATTACHMENT 4

8 Pages

BWNT TUBAN II (Version 2.1) 07/18/1995 10:14:40
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO
 MRPC Lane & Wedge, MRPC Slv Upper Roll, Re-expanded MRPC, SPECIAL INTEREST

Page 1 of 8

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC

QRY: 07/18/1995 10:09:34

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
1	1	06/95 RFO	SPECIAL INTEREST	VOL		2.37	10TH TSP	-0.15
2	5	06/95 RFO	SPECIAL INTEREST	VOL		0.68	15TH TSP	+18.71
3	1	06/95 RFO	SPECIAL INTEREST	VOL		3.52	15TH TSP	+13.99
4	11	06/95 RFO	SPECIAL INTEREST	VOL		3.41	10TH TSP	-2.49
5	6	06/95 RFO	SPECIAL INTEREST	VOL		4.48	10TH TSP	-1.31
5	7	06/95 RFO	SPECIAL INTEREST	VOL		1.36	10TH TSP	-2.10
5	16	06/95 RFO	SPECIAL INTEREST	VOL		2.97	10TH TSP	+2.06
6	6	06/95 RFO	SPECIAL INTEREST	VOL		1.29	10TH TSP	-2.56
6	45	06/95 RFO	SPECIAL INTEREST	VOL		0.42	11TH TSP	-0.73
7	34	06/95 RFO	SPECIAL INTEREST	VOL		1.86	9TH TSP	-0.54
7	45	06/95 RFO	SPECIAL INTEREST	VOL		0.37	11TH TSP	-0.76
8	9	06/95 RFO	SPECIAL INTEREST	VOL		1.74	1ST TSP	-3.97
8	48	06/95 RFO	SPECIAL INTEREST	VOL		2.33	8TH TSP	+0.82
8	57	06/95 RFO	SPECIAL INTEREST	VOL		1.82	15TH TSP	+1.76
9	3	06/95 RFO	SPECIAL INTEREST	VOL		5.37	LTSF	+0.49
		06/95 RFO	SPECIAL INTEREST	VOL		2.80	14TH TSP	+1.15
10	2	06/95 RFO	SPECIAL INTEREST	VOL		2.89	11TH TSP	-0.72
10	7	06/95 RFO	SPECIAL INTEREST	WAR	18	2.50	9TH TSP	+0.00
10	9	06/95 RFO	SPECIAL INTEREST	WAR	18	2.43	9TH TSP	+0.00
10	62	06/95 RFO	SPECIAL INTEREST	SAI		1.04	15TH TSP	+1.39
10	65	06/95 RFO	SPECIAL INTEREST	VOL		1.40	15TH TSP	+13.45
11	20	06/95 RFO	SPECIAL INTEREST	VOL		1.52	8TH TSP	+6.20
12	2	06/95 RFO	SPECIAL INTEREST	VOL		2.62	10TH TSP	-1.43
12	20	06/95 RFO	SPECIAL INTEREST	VOL		1.25	9TH TSP	+0.52
12	68	06/95 RFO	SPECIAL INTEREST	VOL		1.12	9TH TSP	-0.46
12	71	06/95 RFO	SPECIAL INTEREST	VOL		1.02	11TH TSP	+11.40
13	4	06/95 RFO	SPECIAL INTEREST	VOL		1.36	10TH TSP	-1.81
13	19	06/95 RFO	SPECIAL INTEREST	VOL		4.06	7TH TSP	-0.80
13	20	06/95 RFO	SPECIAL INTEREST	VOL		2.23	7TH TSP	-0.81
13	67	06/95 RFO	SPECIAL INTEREST	VOL		0.77	10TH TSP	-4.38
13	71	06/95 RFO	SPECIAL INTEREST	VOL		2.81	10TH TSP	-2.50 to -1.10
14	75	06/95 RFO	SPECIAL INTEREST	VOL		3.41	15TH TSP	-4.06
15	21	06/95 RFO	SPECIAL INTEREST	VOL		2.63	12TH TSP	+6.95
15	68	06/95 RFO	SPECIAL INTEREST	VOL		1.51	9TH TSP	+23.22
15	75	06/95 RFO	SPECIAL INTEREST	VOL		6.07	10TH TSP	-2.75 to -0.75
16	66	06/95 RFO	SPECIAL INTEREST	VOL		1.31	9TH TSP	+0.71
16	81	06/95 RFO	SPECIAL INTEREST	VOL		4.16	15TH TSP	-2.98
17	18	06/95 RFO	SPECIAL INTEREST	VOL		1.83	3RD TSP	-1.57
17	72	06/95 RFO	SPECIAL INTEREST	VOL		5.63	10TH TSP	-18.59 to -13.00
17	73	06/95 RFO	SPECIAL INTEREST	VOL		3.73	9TH TSP	+29.64
17	74	06/95 RFO	SPECIAL INTEREST	VOL		1.94	9TH TSP	+0.87
17	75	06/95 RFO	SPECIAL INTEREST	VOL		2.93	8TH TSP	-0.63
17	78	06/95 RFO	SPECIAL INTEREST	VOL		0.80	10TH TSP	-1.67
18	2	06/95 RFO	SPECIAL INTEREST	WAR	22	3.20	14TH TSP	+0.00
18	22	06/95 RFO	SPECIAL INTEREST	VOL		0.28	13TH TSP	-8.88
18	62	06/95 RFO	SPECIAL INTEREST	VOL		1.97	9TH TSP	+11.17
		06/95 RFO	SPECIAL INTEREST	VOL		3.77	9TH TSP	+7.81
18	75	06/95 RFO	SPECIAL INTEREST	VOL		1.12	10TH TSP	-17.80
18	79	06/95 RFO	SPECIAL INTEREST	VOL		2.91	10TH TSP	+0.08
18	83	06/95 RFO	SPECIAL INTEREST	VOL		0.65	10TH TSP	+9.22
19	5	06/95 RFO	SPECIAL INTEREST	WAR	17	2.20	9TH TSP	+0.00
19	11	06/95 RFO	SPECIAL INTEREST	VOL		1.76	7TH TSP	-0.70
19	33	06/95 RFO	SPECIAL INTEREST	VOL		2.62	15TH TSP	+0.81
19	78	06/95 RFO	SPECIAL INTEREST	VOL		1.31	8TH TSP	-0.66
19	79	06/95 RFO	SPECIAL INTEREST	VOL		0.80	8TH TSP	-0.61
		06/95 RFO	SPECIAL INTEREST	VOL		2.87	9TH TSP	+18.97 to +24.05
19	81	06/95 RFO	SPECIAL INTEREST	VOL		1.99	9TH TSP	+21.45 to +22.52
19	82	06/95 RFO	SPECIAL INTEREST	VOL		4.34	10TH TSP	+0.55
19	86	06/95 RFO	SPECIAL INTEREST	VOL		1.95	15TH TSP	+0.74
		06/95 RFO	SPECIAL INTEREST	VOL		3.41	15TH TSP	+0.76
20	77	06/95 RFO	SPECIAL INTEREST	VOL		1.28	8TH TSP	-0.69
20	78	06/95 RFO	SPECIAL INTEREST	VOL		1.73	9TH TSP	+0.68
		06/95 RFO	SPECIAL INTEREST	VOL		2.60	8TH TSP	-0.67
20	80	06/95 RFO	SPECIAL INTEREST	VOL		1.17	12TH TSP	+1.21
21	5	06/95 RFO	SPECIAL INTEREST	VOL		0.72	8TH TSP	+23.41

BWNT TUBAN II (Version 2.1) 07/18/1995 10:14:40

Oconee Nuclear Station - Unit Three

S/G B

06/95 RFO

MRPC Lane & Wedge, MRPC Slv Upper Roll, Re-expanded MRPC, SPECIAL INTEREST

Page 2 of 8

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC

QRY: 07/18/1995 10:09:34

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
21	15	06/95 RFO	SPECIAL INTEREST	VOL		1.69	7TH TSP	-0.74
21	72	06/95 RFO	SPECIAL INTEREST	VOL		0.55	11TH TSP	-0.80
21	77	06/95 RFO	SPECIAL INTEREST	VOL		1.63	11TH TSP	-0.75
21	78	06/95 RFO	SPECIAL INTEREST	VOL		1.30	9TH TSP	+0.71
21	84	06/95 RFO	SPECIAL INTEREST	VOL		1.72	8TH TSP	-0.70
21	90	06/95 RFO	SPECIAL INTEREST	VOL		2.89	6TH TSP	+0.86
22	2	06/95 RFO	SPECIAL INTEREST	VOL		1.66	10TH TSP	+0.59
22	70	06/95 RFO	SPECIAL INTEREST	VOL		1.01	11TH TSP	-0.74
22	92	06/95 RFO	SPECIAL INTEREST	VOL		2.13	6TH TSP	+1.33
23	55	06/95 RFO	SPECIAL INTEREST	VOL		0.69	11TH TSP	-0.77
24	12	06/95 RFO	SPECIAL INTEREST	VOL		0.52	14TH TSP	+0.74
24	13	06/95 RFO	SPECIAL INTEREST	VOL		1.07	15TH TSP	-14.87
25	3	06/95 RFO	SPECIAL INTEREST	VOL		2.47	9TH TSP	+0.78
25	4	06/95 RFO	SPECIAL INTEREST	VOL		1.05	9TH TSP	+0.79
		06/95 RFO	SPECIAL INTEREST	VOL		1.59	9TH TSP	+14.23 to +15.63
25	96	06/95 RFO	SPECIAL INTEREST	VOL		0.52	8TH TSP	+2.01
		06/95 RFO	SPECIAL INTEREST	VOL		0.79	8TH TSP	-1.45
		06/95 RFO	SPECIAL INTEREST	VOL		1.71	8TH TSP	+5.48
26	56	06/95 RFO	SPECIAL INTEREST	VOL		1.51	13TH TSP	+0.80
26	75	06/95 RFO	SPECIAL INTEREST	VOL		1.84	4TH TSP	+19.27
26	96	06/95 RFO	SPECIAL INTEREST	VOL		0.97	9TH TSP	+9.17
26	98	06/95 RFO	SPECIAL INTEREST	VOL		0.12	12TH TSP	+1.43
27	1	06/95 RFO	SPECIAL INTEREST	VOL		1.69	14TH TSP	+0.69
27	33	06/95 RFO	SPECIAL INTEREST	VOL		3.92	11TH TSP	-0.73
27	100	06/95 RFO	SPECIAL INTEREST	VOL		0.42	10TH TSP	+0.77
28	43	06/95 RFO	SPECIAL INTEREST	VOL		0.51	5TH TSP	+10.53
28	60	06/95 RFO	SPECIAL INTEREST	VOL		0.37	11TH TSP	-0.82
28	87	06/95 RFO	SPECIAL INTEREST	VOL		1.24	13TH TSP	+1.11
29	2	06/95 RFO	SPECIAL INTEREST	VOL		2.08	11TH TSP	+0.47
29	39	06/95 RFO	SPECIAL INTEREST	VOL		0.40	14TH TSP	-0.14
29	83	06/95 RFO	SPECIAL INTEREST	VOL		0.45	11TH TSP	-0.81
29	102	06/95 RFO	SPECIAL INTEREST	VOL		0.47	8TH TSP	+8.89
		06/95 RFO	SPECIAL INTEREST	VOL		0.70	8TH TSP	+25.57
		06/95 RFO	SPECIAL INTEREST	VOL		0.77	8TH TSP	+6.26
		06/95 RFO	SPECIAL INTEREST	VOL		0.85	5TH TSP	+14.15
		06/95 RFO	SPECIAL INTEREST	VOL		1.09	8TH TSP	+5.23
		06/95 RFO	SPECIAL INTEREST	VOL		1.18	8TH TSP	+6.88
		06/95 RFO	SPECIAL INTEREST	VOL		1.20	5TH TSP	-2.17
30	6	06/95 RFO	SPECIAL INTEREST	VOL		1.83	8TH TSP	-0.51
30	38	06/95 RFO	SPECIAL INTEREST	VOL		1.63	3RD TSP	+5.43
31	8	06/95 RFO	SPECIAL INTEREST	VOL		1.66	9TH TSP	+0.57
31	40	06/95 RFO	SPECIAL INTEREST	VOL		2.16	13TH TSP	+0.05
31	49	06/95 RFO	SPECIAL INTEREST	VOL		2.62	7TH TSP	-4.75
31	76	06/95 RFO	SPECIAL INTEREST	VOL		2.51	11TH TSP	-0.82
32	5	06/95 RFO	SPECIAL INTEREST	VOL		2.06	9TH TSP	+0.76
32	6	06/95 RFO	SPECIAL INTEREST	VOL		2.99	8TH TSP	-0.36
32	15	06/95 RFO	SPECIAL INTEREST	VOL		0.93	7TH TSP	-0.71
33	2	06/95 RFO	SPECIAL INTEREST	VOL		1.30	14TH TSP	+0.30
33	4	06/95 RFO	SPECIAL INTEREST	VOL		1.64	10TH TSP	-0.59
33	6	06/95 RFO	SPECIAL INTEREST	VOL		1.57	8TH TSP	-0.30
33	30	06/95 RFO	SPECIAL INTEREST	VOL		1.29	13TH TSP	-0.07
33	107	06/95 RFO	SPECIAL INTEREST	VOL		0.65	8TH TSP	-0.64
34	20	06/95 RFO	SPECIAL INTEREST	VOL		1.48	12TH TSP	+0.80
34	73	06/95 RFO	SPECIAL INTEREST	VOL		6.17	LTSF	+21.73
34	87	06/95 RFO	SPECIAL INTEREST	VOL		1.27	15TH TSP	+0.76
35	73	06/95 RFO	SPECIAL INTEREST	VOL		3.31	13TH TSP	-0.15
35	75	06/95 RFO	SPECIAL INTEREST	VOL		4.59	3RD TSP	-20.44
		06/95 RFO	SPECIAL INTEREST	VOL		6.34	3RD TSP	-18.75
		06/95 RFO	SPECIAL INTEREST	VOL		7.27	3RD TSP	-15.48
35	108	06/95 RFO	SPECIAL INTEREST	VOL		0.67	8TH TSP	+0.46
36	4	06/95 RFO	SPECIAL INTEREST	VOL		1.08	14TH TSP	+1.44
36	8	06/95 RFO	SPECIAL INTEREST	VOL		2.55	8TH TSP	-0.64
36	85	06/95 RFO	SPECIAL INTEREST	VOL		1.63	6TH TSP	+16.86
37	5	06/95 RFO	SPECIAL INTEREST	VOL		2.00	14TH TSP	+1.28
38	3	06/95 RFO	SPECIAL INTEREST	VOL		5.97	14TH TSP	+0.67

BWNT TUBAN II (Version 2.1) 07/18/1995 10:14:40
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO

MRPC Lane & Wedge, MRPC Slv Upper Roll, Re-expanded MRPC, SPECIAL INTEREST

Page 3 of 8

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC

QRY: 07/18/1995 10:09:34

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
38	4	06/95 RFO	SPECIAL INTEREST	VOL		12.69	14TH TSP	+1.29 14TH TSP
38	5	06/95 RFO	SPECIAL INTEREST	VOL		1.76	9TH TSP	+0.54 9TH TSP
38	8	06/95 RFO	SPECIAL INTEREST	VOL		2.25	8TH TSP	-0.66 8TH TSP
38	94	06/95 RFO	SPECIAL INTEREST	VOL		0.32	11TH TSP	+22.49 11TH TSP
39	70	06/95 RFO	SPECIAL INTEREST	VOL		4.72	7TH TSP	+0.70 7TH TSP
39	73	06/95 RFO	SPECIAL INTEREST	VOL		0.70	7TH TSP	+0.50 7TH TSP
40	1	06/95 RFO	SPECIAL INTEREST	VOL		4.24	14TH TSP	+1.38 14TH TSP
40	4	06/95 RFO	SPECIAL INTEREST	VOL		5.17	9TH TSP	+0.61 9TH TSP
40	5	06/95 RFO	SPECIAL INTEREST	VOL		1.29	10TH TSP	+0.20 10TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.37	10TH TSP	+0.68 10TH TSP
41	4	06/95 RFO	SPECIAL INTEREST	VOL		1.58	12TH TSP	-0.32 12TH TSP
41	5	06/95 RFO	SPECIAL INTEREST	VOL		1.78	10TH TSP	+0.54 10TH TSP
41	55	06/95 RFO	SPECIAL INTEREST	VOL		4.53	3RD TSP	+23.82 3RD TSP
42	7	06/95 RFO	SPECIAL INTEREST	VOL		0.63	8TH TSP	+0.72 8TH TSP
42	14	06/95 RFO	SPECIAL INTEREST	VOL		0.69	6TH TSP	-3.43 6TH TSP
42	100	06/95 RFO	SPECIAL INTEREST	VOL		2.79	8TH TSP	-0.59 8TH TSP
43	81	06/95 RFO	SPECIAL INTEREST	VOL		5.02	13TH TSP	+5.38 13TH TSP
45	2	06/95 RFO	SPECIAL INTEREST	VOL		0.95	14TH TSP	+0.77 14TH TSP
45	23	06/95 RFO	SPECIAL INTEREST	VOL		10.51	14TH TSP	+0.68 14TH TSP
45	82	06/95 RFO	SPECIAL INTEREST	VOL		1.80	11TH TSP	-2.20 11TH TSP
47	1	06/95 RFO	SPECIAL INTEREST	WAR	20	2.22	13TH TSP	+0.00 13TH TSP
47	75	06/95 RFO	SPECIAL INTEREST	VOL		0.33	9TH TSP	-11.50 9TH TSP
47	83	06/95 RFO	SPECIAL INTEREST	VOL		2.66	3RD TSP	+23.41 3RD TSP
47	122	06/95 RFO	SPECIAL INTEREST	VOL		1.37	15TH TSP	+19.10 15TH TSP
48	34	06/95 RFO	SPECIAL INTEREST	SAI		1.33	10TH TSP	+4.21 10TH TSP
48	44	06/95 RFO	SPECIAL INTEREST	VOL		2.23	14TH TSP	+0.47 14TH TSP
48	123	06/95 RFO	SPECIAL INTEREST	VOL		0.80	15TH TSP	+18.75 15TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.15	15TH TSP	+0.69 15TH TSP
49	5	06/95 RFO	SPECIAL INTEREST	VOL		4.96	9TH TSP	+18.70 9TH TSP
49	9	06/95 RFO	SPECIAL INTEREST	VOL		2.30	15TH TSP	+28.92 15TH TSP
49	113	06/95 RFO	SPECIAL INTEREST	VOL		4.64	11TH TSP	+0.90 11TH TSP
49	114	06/95 RFO	SPECIAL INTEREST	VOL		6.67	11TH TSP	+1.56 11TH TSP
50	3	06/95 RFO	SPECIAL INTEREST	VOL		2.35	9TH TSP	+0.77 9TH TSP
51	3	06/95 RFO	SPECIAL INTEREST	VOL		2.65	9TH TSP	+0.86 9TH TSP
52	26	06/95 RFO	SPECIAL INTEREST	VOL		0.85	12TH TSP	+28.33 12TH TSP
52	29	06/95 RFO	SPECIAL INTEREST	VOL		1.99	15TH TSP	+12.67 15TH TSP
52	35	06/95 RFO	SPECIAL INTEREST	VOL		0.52	LTSP	+21.67 LTSP
52	98	06/95 RFO	SPECIAL INTEREST	VOL		0.58	14TH TSP	+0.81 14TH TSP
52	124	06/95 RFO	SPECIAL INTEREST	VOL		0.98	10TH TSP	+0.70 10TH TSP
53	54	06/95 RFO	SPECIAL INTEREST	VOL		0.95	14TH TSP	+17.46 14TH TSP
53	77	06/95 RFO	SPECIAL INTEREST	VOL		1.97	4TH TSP	-13.99 4TH TSP
53	86	06/95 RFO	SPECIAL INTEREST	VOL		2.25	8TH TSP	+8.44 8TH TSP
54	3	06/95 RFO	SPECIAL INTEREST	VOL		1.95	14TH TSP	+0.73 14TH TSP
54	127	06/95 RFO	SPECIAL INTEREST	VOL		1.47	15TH TSP	+21.79 15TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		2.73	13TH TSP	+4.52 13TH TSP
55	124	06/95 RFO	SPECIAL INTEREST	VOL		19.53	13TH TSP	+0.89 13TH TSP
57	103	06/95 RFO	SPECIAL INTEREST	VOL		0.32	9TH TSP	+3.35 9TH TSP
57	126	06/95 RFO	SPECIAL INTEREST	VOL		0.37	14TH TSP	+0.98 14TH TSP
57	128	06/95 RFO	SPECIAL INTEREST	VOL		3.16	13TH TSP	+2.23 13TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		3.75	13TH TSP	+2.69 13TH TSP
58	125	06/95 RFO	SPECIAL INTEREST	VOL		1.76	9TH TSP	+23.21 9TH TSP
59	2	06/95 RFO	SPECIAL INTEREST	VOL		2.24	10TH TSP	+0.02 10TH TSP
59	61	06/95 RFO	SPECIAL INTEREST	VOL		0.77	6TH TSP	+16.40 5TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		0.94	6TH TSP	+16.94 5TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.44	5TH TSP	+32.55 5TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		2.26	6TH TSP	+15.27 5TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		2.33	5TH TSP	+31.09 5TH TSP
59	96	06/95 RFO	SPECIAL INTEREST	VOL		0.82	13TH TSP	+0.85 13TH TSP
59	122	06/95 RFO	SPECIAL INTEREST	VOL		0.53	9TH TSP	-0.80 9TH TSP
61	2	06/95 RFO	SPECIAL INTEREST	VOL		1.50	14TH TSP	+1.20 14TH TSP
61	111	06/95 RFO	SPECIAL INTEREST	VOL		1.32	14TH TSP	+0.83 14TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.32	14TH TSP	+0.84 14TH TSP
61	121	06/95 RFO	SPECIAL INTEREST	VOL		2.69	9TH TSP	-0.71 9TH TSP
61	122	06/95 RFO	SPECIAL INTEREST	WAR	14	3.27	9TH TSP	-0.70 9TH TSP
62	127	06/95 RFO	SPECIAL INTEREST	VOL		1.69	14TH TSP	+1.27 14TH TSP

BWNT TUBAN II (Version 2.1) 07/18/1995 10:14:40

Oconee Nuclear Station - Unit Three

S/G B

06/95 RFO

MRPC Lane & Wedge, MRPC Slv Upper Roll, Re-expanded MRPC, SPECIAL INTEREST

Page 4 of 8

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC

QRY: 07/18/1995 10:09:34

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
63	42	06/95 RFO	SPECIAL INTEREST	VOL		1.46	13TH TSP	-15.31 13TH TSP
64	124	06/95 RFO	SPECIAL INTEREST	WAR	14	3.16	9TH TSP	-0.61 9TH TSP
64	125	06/95 RFO	SPECIAL INTEREST	WAR	10	1.89	9TH TSP	+0.00 9TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		8.05	10TH TSP	-17.67 to -13.87 10TH TSP
65	4	06/95 RFO	SPECIAL INTEREST	VOL		0.35	9TH TSP	-0.55 9TH TSP
65	12	06/95 RFO	SPECIAL INTEREST	VOL		2.17	13TH TSP	+22.76 13TH TSP
65	76	06/95 RFO	SPECIAL INTEREST	VOL		1.18	8TH TSP	+20.03 8TH TSP
65	95	06/95 RFO	SPECIAL INTEREST	VOL		0.96	4TH TSP	-10.76 4TH TSP
65	115	06/95 RFO	SPECIAL INTEREST	VOL		1.71	14TH TSP	+0.98 14TH TSP
65	126	06/95 RFO	SPECIAL INTEREST	WAR	10	2.26	9TH TSP	+0.00 9TH TSP
65	127	06/95 RFO	SPECIAL INTEREST	WAR	21	4.27	9TH TSP	+0.00 8TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		2.43	9TH TSP	+21.91 to +27.61 8TH TSP
66	65	06/95 RFO	SPECIAL INTEREST	VOL		1.84	12TH TSP	-15.05 12TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		2.82	12TH TSP	-16.23 12TH TSP
66	128	06/95 RFO	SPECIAL INTEREST	VOL		5.14	8TH TSP	-0.54 8TH TSP
67	30	06/95 RFO	SPECIAL INTEREST	VOL		2.69	4TH TSP	-11.76 4TH TSP
67	33	06/95 RFO	SPECIAL INTEREST	VOL		1.69	1ST TSP	+3.74 1ST TSP
67	62	06/95 RFO	SPECIAL INTEREST	VOL		3.54	12TH TSP	+11.15 12TH TSP
67	80	06/95 RFO	SPECIAL INTEREST	SAI		0.66	UTSF	-14.06 UTSF
67	127	06/95 RFO	SPECIAL INTEREST	WAR	12	2.60	8TH TSP	+0.00 8TH TSP
		06/95 RFO	SPECIAL INTEREST	WAR	16	3.22	6TH TSP	+0.00 6TH TSP
68	2	06/95 RFO	SPECIAL INTEREST	VOL		0.41	15TH TSP	+0.00 15TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		0.76	15TH TSP	-0.67 15TH TSP
68	82	06/95 RFO	SPECIAL INTEREST	VOL		3.67	13TH TSP	+16.37 13TH TSP
68	128	06/95 RFO	SPECIAL INTEREST	WAR	13	2.57	8TH TSP	+0.00 8TH TSP
69	1	06/95 RFO	SPECIAL INTEREST	VOL		5.13	14TH TSP	+1.60 14TH TSP
69	124	06/95 RFO	SPECIAL INTEREST	VOL		1.95	14TH TSP	+0.84 14TH TSP
		06/95 RFO	SPECIAL INTEREST	WAR	12	2.35	14TH TSP	+0.00 14TH TSP
69	132	06/95 RFO	SPECIAL INTEREST	VOL		1.58	15TH TSP	-2.79 15TH TSP
70	94	06/95 RFO	SPECIAL INTEREST	VOL		1.02	3RD TSP	+27.08 3RD TSP
70	131	06/95 RFO	SPECIAL INTEREST	VOL		1.40	10TH TSP	+4.57 10TH TSP
71	5	06/95 RFO	SPECIAL INTEREST	WAR	12	0.35	9TH TSP	+0.00 9TH TSP
71	6	06/95 RFO	SPECIAL INTEREST	VOL		0.93	6TH TSP	+7.82 6TH TSP
72	6	06/95 RFO	SPECIAL INTEREST	VOL		0.19	11TH TSP	+0.47 11TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		0.53	10TH TSP	+9.30 10TH TSP
72	12	06/95 RFO	SPECIAL INTEREST	VOL		3.03	12TH TSP	+0.68 12TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		3.06	12TH TSP	+0.52 12TH TSP
72	13	06/95 RFO	SPECIAL INTEREST	VOL		0.47	12TH TSP	+0.34 12TH TSP
72	15	06/95 RFO	SPECIAL INTEREST	VOL		1.56	12TH TSP	+0.49 12TH TSP
72	19	06/95 RFO	SPECIAL INTEREST	VOL		0.57	11TH TSP	+0.63 11TH TSP
72	41	06/95 RFO	SPECIAL INTEREST	VOL		2.61	10TH TSP	+0.48 10TH TSP
73	6	06/95 RFO	SPECIAL INTEREST	WAR	11	0.33	12TH TSP	+0.00 12TH TSP
73	9	06/95 RFO	SPECIAL INTEREST	WAR	19	0.59	13TH TSP	+0.00 13TH TSP
73	10	06/95 RFO	SPECIAL INTEREST	VOL		0.23	11TH TSP	+5.71 11TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		0.44	11TH TSP	+5.59 11TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		0.90	11TH TSP	+7.24 11TH TSP
73	29	06/95 RFO	SPECIAL INTEREST	VOL		0.84	11TH TSP	+0.53 11TH TSP
73	44	06/95 RFO	SPECIAL INTEREST	VOL		2.06	8TH TSP	-0.90 8TH TSP
73	103	06/95 RFO	SPECIAL INTEREST	VOL		0.81	10TH TSP	-12.71 10TH TSP
74	31	06/95 RFO	SPECIAL INTEREST	VOL		0.15	8TH TSP	+10.59 8TH TSP
74	69	06/95 RFO	SPECIAL INTEREST	VOL		3.50	2ND TSP	-7.69 2ND TSP
75	99	06/95 RFO	SPECIAL INTEREST	VOL		2.37	12TH TSP	-4.04 12TH TSP
75	112	06/95 RFO	SPECIAL INTEREST	VOL		1.13	14TH TSP	+1.21 14TH TSP
75	121	06/95 RFO	SPECIAL INTEREST	WAR	10	1.21	3RD TSP	+0.00 3RD TSP
76	118	06/95 RFO	SPECIAL INTEREST	VOL		1.03	12TH TSP	-16.59 12TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.04	14TH TSP	+15.01 14TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.17	14TH TSP	-1.27 14TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.30	12TH TSP	-18.64 12TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.50	13TH TSP	-8.62 13TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.59	15TH TSP	+21.52 15TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		2.63	14TH TSP	+1.46 14TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		3.59	12TH TSP	-12.80 12TH TSP
77	25	06/95 RFO	SPECIAL INTEREST	VOL		2.81	11TH TSP	+8.12 11TH TSP
77	44	06/95 RFO	SPECIAL INTEREST	WAR	6	1.53	3RD TSP	+0.00 3RD TSP
77	50	06/95 RFO	SPECIAL INTEREST	VOL		1.01	7TH TSP	-0.80 7TH TSP

BWNT TUBAN II (Version 2.1) 07/18/1995 10:14:40

Oconee Nuclear Station - Unit Three

S/G B

06/95 RFO

MRPC Lane & Wedge,MRPC Slv Upper Roll,Re-expanded MRPC,SPECIAL INTEREST

Page 5 of 8

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC

QRY: 07/18/1995 10:09:34

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
77	99	06/95 RFO	SPECIAL INTEREST	SAI		0.24	10TH TSP	+27.73
78	34	06/95 RFO	SPECIAL INTEREST	VOL		0.76	4TH TSP	-0.78
78	42	06/95 RFO	SPECIAL INTEREST	WAR	7	1.91	4TH TSP	+0.00
78	116	06/95 RFO	SPECIAL INTEREST	VOL		0.25	13TH TSP	+15.77
78	119	06/95 RFO	SPECIAL INTEREST	VOL		0.73	14TH TSP	+0.82
		06/95 RFO	SPECIAL INTEREST	VOL		3.84	14TH TSP	+0.87
79	15	06/95 RFO	SPECIAL INTEREST	VOL		1.86	11TH TSP	+0.70
79	25	06/95 RFO	MRPC Lane & Wedge	VOL		2.11	15TH TSP	+0.54
79	26	06/95 RFO	MRPC Lane & Wedge	VOL		1.18	15TH TSP	+0.70
79	35	06/95 RFO	SPECIAL INTEREST	VOL		1.93	13TH TSP	+0.73
79	123	06/95 RFO	SPECIAL INTEREST	VOL		0.11	14TH TSP	+1.23
		06/95 RFO	SPECIAL INTEREST	VOL		1.05	14TH TSP	+1.30
80	71	06/95 RFO	SPECIAL INTEREST	VOL		3.51	6TH TSP	-6.40
		06/95 RFO	SPECIAL INTEREST	VOL		6.61	6TH TSP	-6.20
80	124	06/95 RFO	SPECIAL INTEREST	VOL		1.26	14TH TSP	+1.14
80	130	06/95 RFO	SPECIAL INTEREST	VOL		0.63	8TH TSP	-0.48
		06/95 RFO	SPECIAL INTEREST	VOL		4.87	8TH TSP	-0.54
81	2	06/95 RFO	SPECIAL INTEREST	VOL		2.69	12TH TSP	+0.48
81	13	06/95 RFO	MRPC Lane & Wedge	VOL		0.97	UTSF	-1.18
81	29	06/95 RFO	SPECIAL INTEREST	WAR	10	2.74	10TH TSP	+0.00
81	36	06/95 RFO	SPECIAL INTEREST	WAR	7	1.70	10TH TSP	+0.00
81	37	06/95 RFO	SPECIAL INTEREST	WAR	7	1.78	10TH TSP	+0.00
81	129	06/95 RFO	SPECIAL INTEREST	VOL		2.19	10TH TSP	+1.13
82	4	06/95 RFO	SPECIAL INTEREST	VOL		1.34	10TH TSP	+5.02 to +9.06
82	29	06/95 RFO	SPECIAL INTEREST	WAR	7	1.79	10TH TSP	+0.00
82	53	06/95 RFO	SPECIAL INTEREST	VOL		0.85	14TH TSP	+2.28
83	4	06/95 RFO	SPECIAL INTEREST	VOL		0.48	10TH TSP	+3.45 to +8.68
83	65	06/95 RFO	SPECIAL INTEREST	VOL		2.16	1ST TSP	+0.83
83	71	06/95 RFO	SPECIAL INTEREST	VOL		5.77	9TH TSP	-16.29
83	127	06/95 RFO	SPECIAL INTEREST	VOL		12.81	14TH TSP	+1.44
83	132	06/95 RFO	SPECIAL INTEREST	VOL		3.06	14TH TSP	+0.85
84	2	06/95 RFO	SPECIAL INTEREST	VOL		0.54	10TH TSP	+9.95
84	3	06/95 RFO	SPECIAL INTEREST	VOL		1.49	10TH TSP	+5.03
84	5	06/95 RFO	SPECIAL INTEREST	VOL		0.84	10TH TSP	-1.32
84	37	06/95 RFO	SPECIAL INTEREST	VOL		0.38	12TH TSP	-1.89
84	56	06/95 RFO	SPECIAL INTEREST	VOL		2.92	10TH TSP	-14.09
84	120	06/95 RFO	SPECIAL INTEREST	VOL		0.55	LTSF	+6.22
		06/95 RFO	SPECIAL INTEREST	VOL		3.05	LTSF	+6.35
85	1	06/95 RFO	SPECIAL INTEREST	VOL		0.37	15TH TSP	+0.59
85	2	06/95 RFO	SPECIAL INTEREST	VOL		0.60	10TH TSP	+7.67
		06/95 RFO	SPECIAL INTEREST	VOL		1.10	10TH TSP	+6.36
85	3	06/95 RFO	SPECIAL INTEREST	VOL		0.77	10TH TSP	+2.38
86	2	06/95 RFO	SPECIAL INTEREST	VOL		0.59	10TH TSP	+6.42
86	3	06/95 RFO	SPECIAL INTEREST	VOL		0.51	10TH TSP	+1.96
86	5	06/95 RFO	SPECIAL INTEREST	VOL		0.63	10TH TSP	-0.70
86	111	06/95 RFO	SPECIAL INTEREST	VOL		0.24	13TH TSP	+15.90
86	128	06/95 RFO	SPECIAL INTEREST	VOL		7.67	6TH TSP	+0.74
87	1	06/95 RFO	SPECIAL INTEREST	VOL		1.12	10TH TSP	+7.45
87	3	06/95 RFO	SPECIAL INTEREST	VOL		0.25	12TH TSP	+0.75
87	70	06/95 RFO	SPECIAL INTEREST	VOL		0.87	12TH TSP	+11.87
87	130	06/95 RFO	SPECIAL INTEREST	VOL		1.29	8TH TSP	+0.65
		06/95 RFO	SPECIAL INTEREST	VOL		1.88	8TH TSP	+0.54
88	2	06/95 RFO	SPECIAL INTEREST	VOL		0.70	10TH TSP	+6.05
88	54	06/95 RFO	SPECIAL INTEREST	SAI		0.56	UTSF	-40.61
		06/95 RFO	SPECIAL INTEREST	SAI		0.68	UTSF	-30.41
		06/95 RFO	SPECIAL INTEREST	SAI		0.74	UTSF	-37.16
		06/95 RFO	SPECIAL INTEREST	SAI		0.99	UTSF	-28.96
		06/95 RFO	SPECIAL INTEREST	SAI		1.32	UTSF	-13.66
		06/95 RFO	SPECIAL INTEREST	SAI		2.65	UTSF	-16.91
		06/95 RFO	SPECIAL INTEREST	SAI		0.53	15TH TSP	-17.55
		06/95 RFO	SPECIAL INTEREST	SAI		0.54	15TH TSP	-12.13
		06/95 RFO	SPECIAL INTEREST	SAI		0.55	13TH TSP	-17.18
		06/95 RFO	SPECIAL INTEREST	SAI		0.60	11TH TSP	-3.20
		06/95 RFO	SPECIAL INTEREST	SAI		0.66	15TH TSP	-3.17
		06/95 RFO	SPECIAL INTEREST	SAI		0.69	14TH TSP	-21.48

BWNT TUBAN II (Version 2.1) 07/18/1995 10:14:40
 Oconee Nuclear Station - Unit Three
 S/G B
 06/95 RFO

MRPC Lane & Wedge, MRPC Slv Upper Roll, Re-expanded MRPC, SPECIAL INTEREST

Page 6 of 8

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC
 QRY: 07/18/1995 10:09:34

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
		06/95 RFO	SPECIAL INTEREST	SAI		0.69	15TH TSP	-17.04
		06/95 RFO	SPECIAL INTEREST	SAI		0.77	15TH TSP	-3.85
		06/95 RFO	SPECIAL INTEREST	SAI		0.94	15TH TSP	-9.75
88	71	06/95 RFO	SPECIAL INTEREST	VOL		3.73	10TH TSP	+18.14
88	129	06/95 RFO	SPECIAL INTEREST	VOL		3.59	UTSF	-12.00
		06/95 RFO	SPECIAL INTEREST	VOL		0.91	8TH TSP	+0.57
89	2	06/95 RFO	SPECIAL INTEREST	VOL		0.87	10TH TSP	+2.29
90	1	06/95 RFO	SPECIAL INTEREST	SAI		0.27	15TH TSP	+2.65
		06/95 RFO	SPECIAL INTEREST	VOL		0.86	15TH TSP	-0.51
		06/95 RFO	SPECIAL INTEREST	VOL		1.00	10TH TSP	+3.49
		06/95 RFO	SPECIAL INTEREST	VOL		1.48	10TH TSP	+5.08
		06/95 RFO	SPECIAL INTEREST	VOL		1.92	15TH TSP	-0.16
90	49	06/95 RFO	SPECIAL INTEREST	WAR	11	2.90	13TH TSP	+0.00
90	75	06/95 RFO	SPECIAL INTEREST	VOL		0.51	6TH TSP	-4.29
		06/95 RFO	SPECIAL INTEREST	VOL		0.89	6TH TSP	-5.39
		06/95 RFO	SPECIAL INTEREST	VOL		1.73	6TH TSP	+16.85
		06/95 RFO	SPECIAL INTEREST	VOL		2.31	7TH TSP	-1.39
91	28	06/95 RFO	SPECIAL INTEREST	VOL		1.25	6TH TSP	-18.99
		06/95 RFO	SPECIAL INTEREST	VOL		1.44	7TH TSP	+8.81
		06/95 RFO	SPECIAL INTEREST	VOL		1.53	6TH TSP	-19.13
91	77	06/95 RFO	SPECIAL INTEREST	VOL		0.22	15TH TSP	+4.34
91	119	06/95 RFO	SPECIAL INTEREST	VOL		0.89	14TH TSP	+1.15
91	123	06/95 RFO	SPECIAL INTEREST	VOL		1.08	9TH TSP	-0.61
		06/95 RFO	SPECIAL INTEREST	VOL		4.90	9TH TSP	-0.61
92	1	06/95 RFO	MRPC Lane & Wedge	SAI		2.02	15TH TSP	+2.53
		06/95 RFO	SPECIAL INTEREST	SAI		1.52	15TH TSP	+2.08 to +3.23
		06/95 RFO	SPECIAL INTEREST	SAI		1.79	15TH TSP	+3.99 to +5.06
92	35	06/95 RFO	SPECIAL INTEREST	VOL		1.23	8TH TSP	+10.55
92	113	06/95 RFO	SPECIAL INTEREST	VOL		2.28	14TH TSP	+0.86
92	123	06/95 RFO	SPECIAL INTEREST	VOL		0.16	14TH TSP	+1.15
		06/95 RFO	SPECIAL INTEREST	VOL		0.91	14TH TSP	+1.10
93	21	06/95 RFO	SPECIAL INTEREST	VOL		1.23	7TH TSP	+18.56
93	28	06/95 RFO	SPECIAL INTEREST	VOL		2.19	2ND TSP	+22.60
93	42	06/95 RFO	SPECIAL INTEREST	VOL		1.34	15TH TSP	+0.77
93	49	06/95 RFO	SPECIAL INTEREST	VOL		4.79	8TH TSP	+19.70
93	93	06/95 RFO	SPECIAL INTEREST	VOL		3.03	9TH TSP	+17.21
93	109	06/95 RFO	SPECIAL INTEREST	VOL		2.64	14TH TSP	+0.78
95	66	06/95 RFO	SPECIAL INTEREST	VOL		2.88	12TH TSP	+6.35
95	70	06/95 RFO	SPECIAL INTEREST	VOL		11.29	4TH TSP	-9.57
96	2	06/95 RFO	SPECIAL INTEREST	VOL		2.34	10TH TSP	+0.55
96	127	06/95 RFO	SPECIAL INTEREST	VOL		0.27	8TH TSP	-0.68
		06/95 RFO	SPECIAL INTEREST	VOL		0.34	8TH TSP	-0.62
97	2	06/95 RFO	SPECIAL INTEREST	VOL		3.30	10TH TSP	+0.66
97	25	06/95 RFO	SPECIAL INTEREST	VOL		0.82	8TH TSP	+11.38
98	70	06/95 RFO	SPECIAL INTEREST	VOL		1.81	1ST TSP	-5.05
98	74	06/95 RFO	SPECIAL INTEREST	VOL		0.36	1ST TSP	-8.71
99	41	06/95 RFO	SPECIAL INTEREST	VOL		1.42	13TH TSP	+0.16
99	126	06/95 RFO	SPECIAL INTEREST	VOL		1.94	8TH TSP	-0.73
100	52	06/95 RFO	SPECIAL INTEREST	VOL		3.81	UTSF	-1.22
101	66	06/95 RFO	SPECIAL INTEREST	VOL		0.20	13TH TSP	+15.86
103	40	06/95 RFO	SPECIAL INTEREST	VOL		1.28	LTSF	+7.91
104	9	06/95 RFO	SPECIAL INTEREST	VOL		0.10	13TH TSP	+25.58
104	38	06/95 RFO	SPECIAL INTEREST	VOL		2.13	1ST TSP	-37.86
106	4	06/95 RFO	SPECIAL INTEREST	VOL		4.38	9TH TSP	-0.56
106	63	06/95 RFO	SPECIAL INTEREST	VOL		0.83	9TH TSP	+8.19
		06/95 RFO	SPECIAL INTEREST	VOL		1.26	9TH TSP	+9.13
109	31	06/95 RFO	SPECIAL INTEREST	VOL		0.62	14TH TSP	-0.55
112	13	06/95 RFO	SPECIAL INTEREST	VOL		1.52	14TH TSP	+0.79
112	104	06/95 RFO	SPECIAL INTEREST	VOL		2.54	LTSF	-7.81
113	110	06/95 RFO	SPECIAL INTEREST	VOL		4.56	9TH TSP	-16.33
114	1	06/95 RFO	SPECIAL INTEREST	WAR	11	2.24	7TH TSP	+0.00
114	18	06/95 RFO	SPECIAL INTEREST	VOL		2.47	8TH TSP	-13.52
114	56	06/95 RFO	SPECIAL INTEREST	VOL		0.86	12TH TSP	-2.20
115	98	06/95 RFO	SPECIAL INTEREST	VOL		1.53	14TH TSP	+0.89
115	111	06/95 RFO	SPECIAL INTEREST	VOL		7.24	8TH TSP	-0.62

BWNT TUBAN II (Version 2.1) 07/18/1995 10:14:40

Oconee Nuclear Station - Unit Three

S/G B

06/95 RFO

MRPC Lane & Wedge,MRPC Slv Upper Roll,Re-expanded MRPC,SPECIAL INTEREST

Page 7 of 8

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC

QRY: 07/18/1995 10:09:34

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
116	26	06/95 RFO	SPECIAL INTEREST	VOL		1.63	6TH TSP	+26.50 6TH TSP
117	19	06/95 RFO	SPECIAL INTEREST	VOL		3.59	4TH TSP	+5.08 4TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		4.39	4TH TSP	+0.94 4TH TSP
117	83	06/95 RFO	SPECIAL INTEREST	VOL		1.47	9TH TSP	+4.04 9TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		2.01	9TH TSP	+7.54 9TH TSP
118	99	06/95 RFO	SPECIAL INTEREST	VOL		4.20	15TH TSP	-7.91 15TH TSP
120	17	06/95 RFO	SPECIAL INTEREST	VOL		0.86	7TH TSP	-0.21 7TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.33	7TH TSP	+3.43 7TH TSP
120	36	06/95 RFO	SPECIAL INTEREST	NQI		10.24	1ST TSP	+15.25 1ST TSP
120	78	06/95 RFO	SPECIAL INTEREST	VOL		1.11	13TH TSP	+0.67 13TH TSP
120	105	06/95 RFO	SPECIAL INTEREST	WAR	21	5.71	8TH TSP	+0.00 8TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.72	10TH TSP	-0.20 10TH TSP
121	10	06/95 RFO	SPECIAL INTEREST	VOL		0.76	10TH TSP	-3.11 10TH TSP
122	1	06/95 RFO	SPECIAL INTEREST	VOL		0.97	15TH TSP	+18.19 15TH TSP
122	58	06/95 RFO	SPECIAL INTEREST	VOL		0.23	13TH TSP	+8.04 13TH TSP
122	59	06/95 RFO	SPECIAL INTEREST	SAI		0.61	15TH TSP	+43.38 UTSTF
		06/95 RFO	SPECIAL INTEREST	SAI		1.04	15TH TSP	-1.65 UTSTF
122	82	06/95 RFO	SPECIAL INTEREST	VOL		8.11	15TH TSP	-10.02 15TH TSP
122	84	06/95 RFO	SPECIAL INTEREST	VOL		2.70	7TH TSP	+10.31 7TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		0.40	12TH TSP	-8.13 12TH TSP
122	97	06/95 RFO	SPECIAL INTEREST	VOL		6.04	3RD TSP	+6.45 3RD TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.27	10TH TSP	+18.54 10TH TSP
122	105	06/95 RFO	SPECIAL INTEREST	VOL		3.76	15TH TSP	-3.75 15TH TSP
123	57	06/95 RFO	SPECIAL INTEREST	VOL		1.20	12TH TSP	-13.25 12TH TSP
123	98	06/95 RFO	SPECIAL INTEREST	VOL		2.95	9TH TSP	-0.42 9TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		6.92	9TH TSP	+0.17 9TH TSP
123	103	06/95 RFO	SPECIAL INTEREST	VOL		0.94	15TH TSP	-3.62 15TH TSP
124	3	06/95 RFO	SPECIAL INTEREST	VOL		3.29	9TH TSP	+0.60 9TH TSP
124	94	06/95 RFO	SPECIAL INTEREST	VOL		1.29	14TH TSP	+1.59 14TH TSP
125	28	06/95 RFO	SPECIAL INTEREST	VOL		1.24	LTSF	+17.18 LTSF
125	52	06/95 RFO	SPECIAL INTEREST	VOL		3.33	4TH TSP	-0.77 4TH TSP
125	54	06/95 RFO	SPECIAL INTEREST	VOL		2.11	15TH TSP	+11.34 15TH TSP
125	56	06/95 RFO	SPECIAL INTEREST	VOL		0.64	13TH TSP	+11.77 13TH TSP
125	90	06/95 RFO	SPECIAL INTEREST	VOL		1.42	10TH TSP	-10.19 10TH TSP
125	100	06/95 RFO	SPECIAL INTEREST	VOL		0.81	10TH TSP	+17.64 10TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.02	10TH TSP	+19.22 10TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		1.69	15TH TSP	-3.81 15TH TSP
126	24	06/95 RFO	SPECIAL INTEREST	VOL		0.54	7TH TSP	-0.29 7TH TSP
126	56	06/95 RFO	SPECIAL INTEREST	VOL		0.81	13TH TSP	+12.17 13TH TSP
126	84	06/95 RFO	SPECIAL INTEREST	VOL		1.21	3RD TSP	-8.03 3RD TSP
127	9	06/95 RFO	SPECIAL INTEREST	VOL		0.59	1ST TSP	+5.59 1ST TSP
127	55	06/95 RFO	SPECIAL INTEREST	VOL		1.12	13TH TSP	+20.72 13TH TSP
127	73	06/95 RFO	SPECIAL INTEREST	VOL		3.02	15TH TSP	-6.73 15TH TSP
128	52	06/95 RFO	SPECIAL INTEREST	VOL		4.60	3RD TSP	+13.26 3RD TSP
129	94	06/95 RFO	SPECIAL INTEREST	VOL		0.93	10TH TSP	-0.75 10TH TSP
132	1	06/95 RFO	SPECIAL INTEREST	VOL		4.83	15TH TSP	+0.43 15TH TSP
132	6	06/95 RFO	SPECIAL INTEREST	VOL		2.51	10TH TSP	-0.59 10TH TSP
132	14	06/95 RFO	SPECIAL INTEREST	VOL		0.40	9TH TSP	+24.92 9TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		0.63	8TH TSP	+20.96 8TH TSP
132	84	06/95 RFO	SPECIAL INTEREST	VOL		1.18	8TH TSP	+0.46 8TH TSP
133	5	06/95 RFO	SPECIAL INTEREST	WAR	15	2.48	10TH TSP	+0.00 10TH TSP
133	9	06/95 RFO	SPECIAL INTEREST	VOL		2.95	9TH TSP	+0.75 9TH TSP
133	35	06/95 RFO	SPECIAL INTEREST	VOL		2.02	2ND TSP	+15.83 2ND TSP
134	2	06/95 RFO	SPECIAL INTEREST	VOL		2.72	10TH TSP	+5.13 10TH TSP
134	33	06/95 RFO	SPECIAL INTEREST	VOL		4.83	8TH TSP	+16.29 8TH TSP
135	1	06/95 RFO	SPECIAL INTEREST	VOL		4.52	10TH TSP	+6.08 10TH TSP
135	6	06/95 RFO	SPECIAL INTEREST	VOL		1.68	10TH TSP	-0.55 10TH TSP
		06/95 RFO	SPECIAL INTEREST	VOL		2.75	10TH TSP	-21.20 10TH TSP
136	69	06/95 RFO	SPECIAL INTEREST	VOL		0.28	3RD TSP	+0.90 3RD TSP
136	70	06/95 RFO	SPECIAL INTEREST	VOL		0.56	3RD TSP	+0.81 3RD TSP
136	80	06/95 RFO	SPECIAL INTEREST	VOL		2.49	8TH TSP	-0.56 8TH TSP
137	4	06/95 RFO	SPECIAL INTEREST	VOL		2.03	10TH TSP	+0.75 10TH TSP
137	6	06/95 RFO	SPECIAL INTEREST	VOL		1.69	9TH TSP	+17.89 9TH TSP
137	10	06/95 RFO	SPECIAL INTEREST	VOL		0.15	9TH TSP	-8.13 9TH TSP
137	67	06/95 RFO	SPECIAL INTEREST	VOL		12.67	1ST TSP	+4.22 1ST TSP

BWNT TUBAN II (Version 2.1) 07/18/1995 10:14:40

Oconee Nuclear Station - Unit Three

S/G B

06/95 RFO

MRPC Lane & Wedge, MRPC Slv Upper Roll, Re-expanded MRPC, SPECIAL INTEREST

Page 8 of 8

ATTACHMENT #4 - LIST OF IMPERFECTIONS - MRPC

QRY: 07/18/1995 10:09:34

ROW	COL	OUTAGE	TEST TYPE	IND	%TW	VOLTS	LOCATION	EXTENT1
137	68	06/95 RFO	SPECIAL INTEREST	VOL		5.65	LTSF	+27.00
		06/95 RFO	SPECIAL INTEREST	VOL		6.50	LTSF	+34.51
		06/95 RFO	SPECIAL INTEREST	VOL		8.07	LTSF	+36.78
		06/95 RFO	SPECIAL INTEREST	VOL		8.76	1ST TSP	+2.84
		06/95 RFO	SPECIAL INTEREST	VOL		0.88	3RD TSP	+0.92
		06/95 RFO	SPECIAL INTEREST	VOL		8.57	2ND TSP	+15.68
		06/95 RFO	SPECIAL INTEREST	VOL		12.10	2ND TSP	+17.06
		06/95 RFO	SPECIAL INTEREST	VOL		14.26	2ND TSP	+27.58
		06/95 RFO	SPECIAL INTEREST	VOL		19.89	2ND TSP	+28.97
137	71	06/95 RFO	SPECIAL INTEREST	VOL		2.27	9TH TSP	-0.58
138	2	06/95 RFO	SPECIAL INTEREST	VOL		2.26	11TH TSP	+6.67
138	53	06/95 RFO	SPECIAL INTEREST	VOL		3.33	7TH TSP	+2.62
138	66	06/95 RFO	SPECIAL INTEREST	VOL		7.64	LTSF	+3.16
		06/95 RFO	SPECIAL INTEREST	VOL		8.77	LTSF	+9.89
138	68	06/95 RFO	SPECIAL INTEREST	VOL		0.48	3RD TSP	+0.91
139	1	06/95 RFO	SPECIAL INTEREST	VOL		3.60	10TH TSP	+12.11
139	29	06/95 RFO	SPECIAL INTEREST	VOL		3.02	9TH TSP	+7.37
140	51	06/95 RFO	SPECIAL INTEREST	VOL		2.01	15TH TSP	+9.71
		06/95 RFO	SPECIAL INTEREST	VOL		2.09	15TH TSP	+10.67
140	71	06/95 RFO	SPECIAL INTEREST	VOL		3.63	8TH TSP	+0.53
141	1	06/95 RFO	SPECIAL INTEREST	VOL		1.70	15TH TSP	-1.35
		06/95 RFO	SPECIAL INTEREST	VOL		2.31	15TH TSP	-1.28
141	3	06/95 RFO	SPECIAL INTEREST	VOL		5.67	14TH TSP	+0.70
141	27	06/95 RFO	SPECIAL INTEREST	VOL		4.39	3RD TSP	+21.28 to +21.95
141	30	06/95 RFO	SPECIAL INTEREST	VOL		3.61	LTSF	+0.96
141	62	06/95 RFO	SPECIAL INTEREST	VOL		10.74	2ND TSP	+9.10
		06/95 RFO	SPECIAL INTEREST	VOL		10.91	2ND TSP	+8.06
142	1	06/95 RFO	SPECIAL INTEREST	VOL		5.51	15TH TSP	-1.13
142	5	06/95 RFO	SPECIAL INTEREST	VOL		2.32	9TH TSP	+0.67
142	27	06/95 RFO	SPECIAL INTEREST	VOL		4.83	6TH TSP	-11.26
142	63	06/95 RFO	SPECIAL INTEREST	VOL		1.28	5TH TSP	+17.11
143	13	06/95 RFO	SPECIAL INTEREST	VOL		1.40	6TH TSP	-0.41
144	14	06/95 RFO	SPECIAL INTEREST	VOL		1.43	9TH TSP	-0.55
144	56	06/95 RFO	SPECIAL INTEREST	VOL		2.67	8TH TSP	+1.55
145	41	06/95 RFO	SPECIAL INTEREST	VOL		1.24	9TH TSP	+0.60
145	49	06/95 RFO	SPECIAL INTEREST	VOL		4.21	10TH TSP	+0.65
145	51	06/95 RFO	SPECIAL INTEREST	VOL		0.69	10TH TSP	+0.72
146	10	06/95 RFO	SPECIAL INTEREST	VOL		1.56	8TH TSP	+0.48
146	11	06/95 RFO	SPECIAL INTEREST	VOL		0.39	14TH TSP	+1.23
146	40	06/95 RFO	SPECIAL INTEREST	WAR	8	1.69	10TH TSP	-0.61
146	47	06/95 RFO	SPECIAL INTEREST	VOL		2.46	10TH TSP	+0.67
147	43	06/95 RFO	SPECIAL INTEREST	VOL		1.30	14TH TSP	+1.04
148	23	06/95 RFO	SPECIAL INTEREST	VOL		1.09	11TH TSP	+30.96
149	1	06/95 RFO	SPECIAL INTEREST	VOL		1.31	15TH TSP	+14.84
149	16	06/95 RFO	SPECIAL INTEREST	VOL		1.46	10TH TSP	+1.10
149	17	06/95 RFO	SPECIAL INTEREST	VOL		1.37	10TH TSP	+0.91
149	30	06/95 RFO	SPECIAL INTEREST	VOL		1.55	10TH TSP	-0.72
150	17	06/95 RFO	SPECIAL INTEREST	VOL		2.66	10TH TSP	+0.64
150	18	06/95 RFO	SPECIAL INTEREST	VOL		3.73	15TH TSP	-0.34
150	21	06/95 RFO	SPECIAL INTEREST	VOL		0.86	15TH TSP	-1.10
150	25	06/95 RFO	SPECIAL INTEREST	VOL		1.72	12TH TSP	+5.18
		06/95 RFO	SPECIAL INTEREST	VOL		2.19	10TH TSP	+8.51
150	27	06/95 RFO	SPECIAL INTEREST	VOL		1.54	14TH TSP	+3.64
151	14	06/95 RFO	SPECIAL INTEREST	SAI		2.44	15TH TSP	+3.29
151	16	06/95 RFO	SPECIAL INTEREST	VOL		1.36	13TH TSP	+3.83
		06/95 RFO	SPECIAL INTEREST	VOL		3.93	15TH TSP	-1.35

Total Indications Found = 511

Total Tubes Found = 406

ATTACHMENT 5

3 Pages

BWNT TUBAN II (Version 2.1)

07/18/1995 07:52:43

Oconee Nuclear Station - Unit Three

S/G A

06/95 RFO

Page 1

PLUGGED TUBES - ATTACHMENT #5

COUNT ROW COL

COUNT ROW COL

1.	2	26
2.	4	1
3.	4	2
4.	5	2
5.	5	3
6.	7	46
7.	9	61
8.	10	65
9.	11	63
10.	11	65
11.	11	66
12.	12	66
13.	12	67
14.	13	68
15.	15	49
16.	16	30
17.	16	71
18.	17	46
19.	19	8
20.	21	8
21.	26	26
22.	27	30
23.	27	80
24.	28	31
25.	30	27
26.	32	66
27.	33	41
28.	36	17
29.	36	106
30.	38	1
31.	38	42
32.	38	68
33.	39	73
34.	39	78
35.	39	85
36.	40	103
37.	41	83
38.	42	83
39.	45	19
40.	46	64
41.	47	77
42.	48	123
43.	51	85
44.	51	91
45.	52	76
46.	53	70

47.	55	28
48.	55	107
49.	56	1
50.	56	71
51.	59	74
52.	59	81
53.	60	2
54.	61	2
55.	61	6
56.	62	21
57.	62	29
58.	62	119
59.	64	40
60.	68	14
61.	68	21
62.	68	94
63.	68	112
64.	70	59
65.	70	65
66.	70	108
67.	71	11
68.	72	2
69.	72	4
70.	72	6
71.	73	29
72.	73	52
73.	74	18
74.	74	47
75.	75	87
76.	75	122
77.	78	79
78.	78	89
79.	79	7
80.	79	41
81.	79	43
82.	80	76
83.	80	103
84.	81	91
85.	81	102
86.	82	7
87.	82	11
88.	82	82
89.	82	88
90.	82	106
91.	83	59
92.	83	80

BWNT TUBAN II (Version 2.1)

07/18/1995 07:52:43

Oconee Nuclear Station - Unit Three

S/G A

06/95 RFO

Page 2

PLUGGED TUBES - ATTACHMENT #5

COUNT ROW COL

COUNT ROW COL

93. 83 84
94. 83 118
95. 84 8
96. 84 95
97. 84 102
98. 84 126
99. 85 123
100. 85 127
101. 86 87
102. 88 9
103. 88 107
104. 89 100
105. 89 117
106. 90 55
107. 90 102
108. 91 19
109. 91 124
110. 93 82
111. 93 86
112. 94 25
113. 94 84
114. 96 61
115. 98 11
116. 100 90
117. 102 99
118. 109 2
119. 109 13
120. 109 30
121. 109 105
122. 110 92
123. 110 104
124. 111 72
125. 112 14
126. 112 83
127. 112 95
128. 113 77
129. 113 91
130. 114 14
131. 115 60
132. 115 83
133. 117 5
134. 118 56
135. 119 1
136. 119 69
137. 119 74
138. 119 79

139. 121 104
140. 121 106
141. 122 15
142. 123 61
143. 123 101
144. 124 65
145. 125 94
146. 126 92
147. 127 40
148. 134 19
149. 135 81
150. 139 17
151. 140 62
152. 143 28
153. 144 47
154. 145 46
155. 150 16
156. 150 17
157. 150 18
158. 151 10

BWNT TUBAN II (Version 2.1)

07/18/1995 07:52:43

Ocone Nuclear Station - Unit Three

S/G A

06/95 RFO

Page 3

PLUGGED TUBES - ATTACHMENT #5

COUNT ROW COL

COUNT ROW COL

Total Data Items Found = 158

Total Tubes Found = 158

ATTACHMENT 6

2 Pages

BWNT TUBAN II (Version 2.1)

07/18/1995 07:54:26

Oconee Nuclear Station - Unit Three

S/G B

06/95 RFO

Page 1

PLUGGED TUBES - ATTACHMENT #6

COUNT ROW COL

COUNT ROW COL

1.	7	11
2.	7	12
3.	9	3
4.	10	62
5.	15	75
6.	17	73
7.	19	33
8.	32	6
9.	34	87
10.	36	4
11.	37	2
12.	37	5
13.	37	8
14.	37	21
15.	38	3
16.	38	4
17.	38	90
18.	38	94
19.	39	1
20.	39	23
21.	39	70
22.	40	1
23.	41	42
24.	41	86
25.	42	7
26.	42	25
27.	45	2
28.	45	23
29.	45	47
30.	45	82
31.	46	40
32.	47	45
33.	48	26
34.	48	34
35.	48	114
36.	52	77
37.	55	125
38.	57	126
39.	59	2
40.	61	24
41.	62	14
42.	63	40
43.	63	42
44.	64	108
45.	65	115
46.	66	65

47.	67	14
48.	67	30
49.	67	80
50.	68	128
51.	69	2
52.	71	56
53.	77	99
54.	78	116
55.	78	119
56.	79	15
57.	79	25
58.	79	26
59.	79	123
60.	81	13
61.	81	27
62.	82	4
63.	83	65
64.	83	127
65.	83	132
66.	84	5
67.	85	2
68.	86	5
69.	86	111
70.	88	54
71.	89	2
72.	90	1
73.	90	49
74.	91	28
75.	91	77
76.	91	119
77.	92	1
78.	92	35
79.	92	123
80.	93	75
81.	93	93
82.	95	66
83.	97	11
84.	98	74
85.	98	115
86.	98	121
87.	100	44
88.	100	104
89.	102	38
90.	103	16
91.	103	40
92.	104	24

BWNT TUBAN II (Version 2.1)

07/18/1995 07:54:26

Oconee Nuclear Station - Unit Three

S/G B

06/95 RFO

Page 2

PLUGGED TUBES - ATTACHMENT #6

COUNT ROW COL

COUNT ROW COL

93.	104	38
94.	104	119
95.	111	81
96.	112	6
97.	114	56
98.	116	26
99.	120	14
100.	120	17
101.	122	1
102.	122	59
103.	122	97
104.	127	9
105.	128	17
106.	131	28
107.	131	45
108.	132	14
109.	134	17
110.	134	33
111.	136	4
112.	137	10
113.	138	53
114.	140	31
115.	141	3
116.	143	21
117.	150	12
118.	151	14

Total Data Items Found = 118

Total Tubes Found = 118

ATTACHMENT 7

3 Pages

BWNT TUBAN II (Version 2.1)

07/18/1995 07:57:09

Oconee Nuclear Station - Unit Three

S/G A

06/95 RFO

Page 1 of 3

SLEEVED TUBES - ATTACHMENT #7

COUNT ROW COL

COUNT ROW COL

1.	57	1
2.	57	2
3.	58	1
4.	58	2
5.	58	3
6.	59	3
7.	60	1
8.	60	3
9.	60	4
10.	61	1
11.	61	3
12.	61	4
13.	63	4
14.	64	5
15.	65	5
16.	69	8
17.	69	9
18.	70	8
19.	70	9
20.	71	9
21.	72	9
22.	72	11
23.	72	12
24.	72	13
25.	72	14
26.	72	16
27.	72	18
28.	73	11
29.	73	13
30.	73	14
31.	73	15
32.	73	16
33.	73	17
34.	73	18
35.	73	19
36.	73	20
37.	73	21
38.	73	22
39.	73	23
40.	73	24
41.	73	25
42.	73	26
43.	73	27
44.	73	28
45.	73	29
46.	73	30

47.	73	31
48.	73	32
49.	73	33
50.	73	34
51.	74	30
52.	74	31
53.	74	32
54.	74	33
55.	74	34
56.	74	35
57.	74	36
58.	74	37
59.	74	38
60.	74	39
61.	74	41
62.	78	30
63.	78	31
64.	78	32
65.	78	33
66.	78	34
67.	78	35
68.	78	36
69.	78	37
70.	78	38
71.	78	39
72.	78	40
73.	78	41
74.	79	13
75.	79	14
76.	79	15
77.	79	16
78.	79	17
79.	79	18
80.	79	19
81.	79	20
82.	79	21
83.	79	22
84.	79	23
85.	79	24
86.	79	25
87.	79	26
88.	79	27
89.	79	28
90.	79	29
91.	79	30
92.	79	31

BWNT TUBAN II (Version 2.1)

07/18/1995 07:57:09

Oconee Nuclear Station - Unit Three

S/G A

06/95 RFO

Page 2 of 3

SLEEVED TUBES - ATTACHMENT #7

COUNT ROW COL

COUNT ROW COL

93.	79	32
94.	79	33
95.	79	34
96.	80	9
97.	80	10
98.	80	12
99.	80	13
100.	80	14
101.	80	15
102.	80	16
103.	80	17
104.	80	18
105.	81	8
106.	81	9
107.	81	10
108.	81	11
109.	82	8
110.	82	9
111.	83	7
112.	83	8
113.	84	6
114.	84	7
115.	85	4
116.	85	5
117.	85	6
118.	86	3
119.	86	4
120.	86	5
121.	86	6
122.	87	2
123.	87	3
124.	87	4
125.	88	1
126.	88	2
127.	88	3
128.	88	4
129.	88	5
130.	89	2
131.	89	3
132.	89	4
133.	90	1
134.	90	2
135.	90	3
136.	91	1
137.	91	2
138.	91	3

139.	91	4
140.	92	3
141.	92	4
142.	93	1
143.	93	3
144.	94	1
145.	94	2
146.	94	3
147.	95	1
148.	96	1

BWNT TUBAN II (Version 2.1)

07/18/1995 07:57:09

Ocone Nuclear Station - Unit Three

S/G A

06/95 RFO

Page 3 of 3

SLEEVED TUBES - ATTACHMENT #7

COUNT ROW COL

COUNT ROW COL

Total Data Items Found = 148

Total Tubes Found = 148

ATTACHMENT 8

3 Pages

BWNT TUBAN II (Version 2.1)

07/18/1995 07:59:18

Oconee Nuclear Station - Unit Three

S/G B

06/95 RFO

Page 1 of 3

SLEEVED TUBES - ATTACHMENT #8

COUNT ROW COL

COUNT ROW COL

1.	62	1
2.	63	1
3.	63	2
4.	64	2
5.	65	2
6.	65	4
7.	66	1
8.	66	2
9.	66	4
10.	67	1
11.	67	2
12.	67	3
13.	67	4
14.	67	6
15.	68	1
16.	68	2
17.	68	4
18.	68	5
19.	68	6
20.	68	7
21.	69	6
22.	69	7
23.	69	8
24.	69	9
25.	70	4
26.	70	5
27.	70	6
28.	70	7
29.	70	8
30.	70	9
31.	71	5
32.	71	6
33.	71	7
34.	71	8
35.	71	9
36.	71	10
37.	72	4
38.	72	5
39.	72	6
40.	72	7
41.	72	8
42.	72	9
43.	72	10
44.	72	11
45.	73	5
46.	73	6

47.	73	7
48.	73	8
49.	73	9
50.	73	10
51.	73	11
52.	73	12
53.	74	12
54.	74	13
55.	74	14
56.	74	15
57.	74	16
58.	74	17
59.	74	18
60.	74	19
61.	74	20
62.	74	21
63.	74	22
64.	74	23
65.	74	25
66.	74	26
67.	74	27
68.	74	28
69.	74	29
70.	74	30
71.	74	31
72.	74	32
73.	74	33
74.	74	34
75.	74	35
76.	74	36
77.	74	37
78.	75	31
79.	75	32
80.	75	33
81.	75	34
82.	75	35
83.	75	36
84.	75	37
85.	75	38
86.	75	39
87.	75	40
88.	77	31
89.	77	32
90.	77	33
91.	77	34
92.	77	35

BWNT.TUBAN II (Version 2.1)

07/18/1995 07:59:18

Oconee Nuclear Station - Unit Three

S/G B

06/95 RFO

Page 2 of 3

SLEEVED TUBES - ATTACHMENT #8

COUNT ROW COL

93.	77	36
94.	77	37
95.	77	38
96.	77	39
97.	77	40
98.	78	29
99.	78	34
100.	78	35
101.	78	37
102.	79	8
103.	79	9
104.	79	10
105.	79	11
106.	79	12
107.	80	3
108.	80	4
109.	80	5
110.	80	6
111.	80	7
112.	80	8
113.	80	9
114.	80	10
115.	80	11
116.	81	3
117.	81	4
118.	81	5
119.	81	6
120.	81	7
121.	81	8
122.	81	9
123.	81	10
124.	82	2
125.	82	3
126.	82	5
127.	82	6
128.	82	7
129.	82	8
130.	82	9
131.	83	2
132.	83	3
133.	83	4
134.	83	5
135.	83	6
136.	83	7
137.	83	8
138.	83	9

COUNT ROW COL

139.	84	1
140.	84	2
141.	84	3
142.	84	4
143.	84	6
144.	84	7
145.	85	1
146.	85	3
147.	85	4
148.	85	5
149.	85	6
150.	86	1
151.	86	2
152.	86	3
153.	86	4
154.	87	1
155.	87	3
156.	87	4
157.	88	1
158.	88	2
159.	88	3
160.	88	4
161.	89	1
162.	89	3
163.	90	2

BWNT, TUBAN II (Version 2.1)

07/18/1995 07:59:18

Ocone Nuclear Station - Unit Three

S/G B

06/95 RFO

Page 3 of 3

SLEEVED TUBES - ATTACHMENT #8

COUNT ROW COL

COUNT ROW COL

Total Data Items Found = 163

Total Tubes Found = 163