

DUKE POWER COMPANY
OCONEE 2 CYCLE 15
CORE OPERATING LIMITS REPORT
REVISION 3
QA CONDITION 1

REFERENCE OSC-5785


Prepared by:



Date:

21 SEP 95

Checked by:



Date:

21 SEP 95

Approved by:

R. R. St. Clair

Date:

22 SEP 95

Oconee Nuclear Station

Unit 2 Cycle 15

Core Operating Limits Report

Insertion Sheet for Revision 3

Remove these Revision 2 pages

1-3, 12

Insert these Revision 3 pages

1-3, 12

Oconee Nuclear Station
Unit 2 Cycle 15
Core Operating Limits Report
Revision Log

Revision	Effective Date	Pages Revised	Pages Added	Pages Deleted	Total Effective Pages
0	September 30, 1994	-	1-34	-	34
1	January 30, 1995	1-3, 13, 20, 23-26	-	-	34
2	March 9, 1995	1-3, 13, 20, 23-26	-	-	34
3	September 1995	1-3, 12	-	-	34

Oconee 2 Cycle 15

STEADY STATE OPERATING BAND

	Rod Index		APSR % withdrawn	
	Min	Max	Min	Max
0 to 450 EFPD	292 ± 5	300	30	40
450 to 470 EFPD	292 ± 5	300	100	100