

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9306140247 DOC. DATE: 93/06/07 NOTARIZED: NO

DOCKET #

FACIL: 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co.

05000270

AUTH. NAME AUTHOR AFFILIATION

HAMPTON, J.W. Duke Power Co.

RECIP. NAME RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Submits rept on steam generator tube plugging & repair.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1

TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 LA	1 1	PD2-3 PD	1 1
	WIENS, L	2 2		
INTERNAL:	ACRS	6 6	NRR/DE/EELB	1 1
	NRR/DRCH/HICB	1 1	NRR/DRPW/OTSB	1 1
	NRR/DSSA/SPLB	1 1	NRR/DSSA/SRXB	1 1
	NUDOCS-ABSTRACT	1 1	OC/LEDGB	1 0
	OGC/HDS2	1 0	REG FILE 01	1 1
EXTERNAL:	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 21 ENCL 19

Duke Power Company
Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679

J. W. HAMPTON
Vice President
(803)885-3499 Office
(803)885-3564 Fax



DUKE POWER

June 7, 1993


U.S. Nuclear Regulatory Commission
Attention Document Control Desk
Washington, DC 20555

Subject: Duke Power Company
Oconee Nuclear Station
Docket No. 50-270
Unit 2, EOC 13 Refueling Outage
Steam Generator Tube Plugging and Repair 30 Day Report

Pursuant to Oconee Technical Specification 4.17.6(a), the following is the report on the number of tubes plugged or repaired during the Unit 2, EOC 13 Refueling Outage.

Steam Generator "A" had 35 tubes removed from service by plugging. Steam Generator "B" had 79 tubes removed from service by plugging. No tubes were sleeved in either Steam Generator. The plugging was completed on May 24, 1993.

Very truly yours,


J. W. Hampton
Site Vice-President

xc: Mr. S. D. Ebnetter
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission

Mr. P. E. Harmon
Senior NRC Resident Inspector
Oconee Nuclear Station

Mr. Heyward G. Shealy
Bureau of Radiological Health
SC Dept. of Health & Environmental Control
2600 Bull St.
Columbia, SC 29201

9306140247 930607
PDR ADDCK 05000270
PDR

A001
1/0