

From: [Guzman, Richard](#)
To: [Palmrose, Donald](#); [Grover, Ravinder](#)
Subject: RE: TSTF-284 wording vs Millstone 3 bases wording (TAC MF5092)
Date: Friday, August 28, 2015 2:24:18 PM
Attachments: [image001.png](#)
[ML 15240A146.8.27.15.pdf](#)

Don and Ravi,

For your awareness, attached is Dominion's supplemental letter addressing the Bases error (i.e., opening in lieu of operating). The final SE has been updated and will be issued today. Thanks for your attention on this issue. This closes our review of TAC MF5092.

Thanks,
Rich

Rich Guzman
Sr. Project Manager
NRR/DORL
US NRC
301-415-1030

2015. Craig D. [Signature]
Notary Public

Attachment:

Marked-Up Technical Specification Bases Page

Commitments made in this letter: None

cc: U.S. Nuclear Regulatory Commission
Region I
2100 Renaissance Blvd, Suite 100
King of Prussia, PA 19406-2713

R. V. Guzman
Senior Project Manager, Mail Stop 08 C2
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

NRC Senior Resident Inspector
Millstone Power Station

Director, Radiation Division
Department of Energy and Environmental Protection
79 Elm Street
Hartford, CT 06106-5127

ATTACHMENT

MARKED-UP TECHNICAL SPECIFICATION BASES PAGE

(FOR INFORMATION ONLY)

**DOMINION NUCLEAR CONNECTICUT, INC.
MILLSTONE POWER STATION UNIT 3**

LBDCR No. ~~04-MP3-015~~
~~February 24, 2005~~

REACTOR COOLANT SYSTEM

BASES


RELIEF VALVES (Continued)

The prime importance for the capability to close the block valve is to isolate a stuck-open PORV. Therefore, if the block valve(s) cannot be restored to OPERABLE status within 1 hour, the remedial action is to place the PORV in manual control (i.e., the control switch in the "CLOSE" position) to preclude its automatic opening for an overpressure event and to avoid the potential of a stuck-open PORV at a time that the block valve is inoperable. The time allowed to restore the block valve(s) to OPERABLE status is based upon the remedial action time limits for inoperable PORV per ACTION requirements b. and c. ACTION statement d. does not specify closure of the block valves because such action would not likely be possible when the block valve is inoperable. For the same reasons, reference is not made to ACTION statements b. and c. for the required remedial actions.

+

+

+



SURVEILLANCE REQUIREMENT 4.4.4.2 verifies that a block valve(s) can be opened or closed if necessary. This SURVEILLANCE REQUIREMENT is not required to be performed with the block valve(s) closed in accordance with the ACTIONS of TS 3.4.4. Opening the block valve(s) in this condition increases the risk of an unisolable leak from the RCS since the PORV(s) is already inoperable.