

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8602110056 DOC. DATE: 86/02/05 NOTARIZED: NO DOCKET #  
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269  
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270  
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287  
 AUTH. NAME AUTHOR AFFILIATION  
 TUCKER, H. B. Duke Power Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director (post 851125  
 STOLZ, J. F. PWR Project Directorate 6

SUBJECT: Responds to Generic Ltr 83-28, Items 3.1.1, 3.1.2, 3.2.1, 3.2.2  
 & 4.1, per NRC 851011 SER. Review of B&W Owners Group reactor  
 trip sys components list complete. All components included in  
 Tech Specs & procedures.

DISTRIBUTION CODE: A055D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: OR/Licensing Submittal: Salem ATWS Events GL-83-28

NOTES: AEOD/Ornstein: 1cy. 05000269  
 OL: 02/06/73  
 AEOD/Ornstein: 1cy. 05000270  
 OL: 10/06/73  
 AEOD/Ornstein: 1cy. 05000287  
 OL: 07/19/74

RECIPIENT		COPIES		RECIPIENT		COPIES	
ID CODE/NAME		LTTR	ENCL	ID CODE/NAME		LTTR	ENCL
PWR-B ADTS		1		PWR-B PD6 PD 01		3	8
PWR-B EB		1		PWR-B PEICSB		1	
PWR-B FOB		1		NICOLARAS, H		1	
PWR-B PEICSB		1		PWR-B RSB		1	
INTERNAL: ACRS		6		ADM/LFMB		1	
ELD/HDS4		1		IE/DI		1	
IE/DQAVT		1		NRR BWR ADTS		1	
NRR LASHER, D		1		NRR PWR-A ADTS		1	
NRR PWR-B ADTS		1		NRR/DSRO DIR		1	
NRR/QRAS		1		NRR/TAMB		1	
REG FILE 04		1		RGN2		1	
EXTERNAL: 24X		1		LPDR 03		1	1
NRC PDR 02		1		NSIC 05		1	1
NOTES:		1	1				

*add: D. Crutchfield (ltr only)  
 Eb (W. Johnston)  
 RSB (Thomas)  
 EICSB (Pan)  
 Fob (W. Regan)*

TOTAL NUMBER OF COPIES REQUIRED: LTTR 39 ENCL 0

DUKE POWER COMPANY

P.O. BOX 33189  
CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

TELEPHONE  
(704) 373-4531

February 5, 1986

Mr. Harold R. Denton, Director  
Office of Nuclear Regulatory Commission  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Mr. John F. Stolz, Project Director  
PWR Project Directorate No. 6

Subject: Oconee Nuclear Station  
Docket Nos. 50-269, -270, -287

Dear Sir:

By letter dated October 11, 1985 the NRC issued its Safety Evaluation Report on Duke's response to Generic Letter 83-28 Items 3.1.1, 3.1.2, 3.2.1, 3.2.2 and 4.1. The staff concluded that Duke's responses to these items are acceptable and meet the full intent of Generic Letter 83-28. The NRC requested that Duke Power complete its actions in regard to items 3.1.1, 3.2.2 and 4.1 and submit a statement confirming these actions have been completed.

In regard to item 3.1.1, Duke has completed its review of the reactor trip system components list developed by the B&W Owners Group. All components on the referenced list are included in the Oconee Nuclear Station Technical specifications and procedures.

Duke is currently implementing a substantial review of the vendor information and instruction manuals for consistency and completeness of the in-house copies of the manuals. The review findings will be evaluated to ensure that vendor guidance is appropriately incorporate into plant procedures. Duke anticipates that the current review program will be completed by the end of July, 1987.

8602110056 860205  
PDR ADOCK 05000269  
P PDR

*A053*  
*1/0*


*Add:*

AD - D. CRUTCHFIELD (Ltr only)  
EB (W. JOHNSTON)  
RSB (THOMAS)  
EICSB (PARR)  
FOB (W. REGAN)

Mr. Harold R. Denton, Director  
February 5, 1986  
Page Two

Duke confirms that all modifications related to Reactor Trip System Reliability (Item 4.1) recommended by B&W Owners Group have been completed on all Oconee units. These modifications included the changing of the initial GE-AK-2 reactor trip breaker lubricant to Mobil 28 lubricant.

Very truly yours,



Hal B. Tucker

MAH:slb

cc: Dr. J. Nelson Grace, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Ms. Helen Nicolaras  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. J. C. Bryant  
NRC Resident Inspector  
Oconee Nuclear Station