

# REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8612230232 DDC DATE: 86/12/15 NOTARIZED: NO DOCKET #  
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269  
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270  
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION  
 TUCKER, H. B. Duke Power Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director (post 851125  
 STOLZ, J. F. PWR Project Directorate 6

SUBJECT: Describes mods made to emergency plan & implementing procedures to correct deficiencies identified during review of Rev 85-2, per NRC 861029 request. Lists changes to plan as agreed upon during 861205 meeting. Rev will be distributed.

DISTRIBUTION CODE: A045D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2  
 TITLE: OR Submittal: Emergency Preparedness Plans, Implement'g Procedures, C

NOTES: AEOD/Ornstein: 1cy. S. West, NRR: 1cy. 05000269  
 AEOD/Ornstein: 1cy. S. West, NRR: 1cy. 05000270  
 AEOD/Ornstein: 1cy. S. West, NRR: 1cy. 05000287

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PWR-B PD6 LA	1 0	PWR-B PD6 PD	1 1
PASTIS, H 01	1 1		
INTERNAL: IE/DEPER/EPB 06	2 2	IE/DEPER/IRB 12	1 1
REG FILE 04	1 1	RGN2	1 1
EXTERNAL: LPDR 03	1 1	NRC PDR 02	1 1
NSIC	1 1		
NOTES:	2 2		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 13 ENCL 12

**DUKE POWER COMPANY**

P.O. BOX 33189  
CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

TELEPHONE  
(704) 373-4531

December 15, 1986

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Mr. John F. Stolz, Project Director  
PWR Project Directorate No. 6

Subject: Oconee Nuclear Station  
Docket Nos. 50-269, -270, -287  
Emergency Plan Deficiencies

Dear Sir:

As requested in an October 29, 1986 letter from the NRC/OIE to Duke Power Company, this letter describes modifications which have been made to the Emergency Plan and implementing procedures to correct deficiencies which were identified during a review of Revision 85-2. In a meeting between Duke Power and NRC staff on December 5, 1986, the following changes to the Emergency Plan (Volume A) and Procedure RP/0/B/1000/01 were agreed upon.

- (1) Insert Loss of the Control Room as both an Alert and Site Area Emergency.
- (2) Delete from the Unusual Event category Loss of Most of all annunciators in the Control Room for more than 15 minutes.
- (3) Add Loss of 2 or more Control Room statalarms for more than 15 minutes as an Alert.

These changes have been made and copies of the revision will be distributed by as Revision 86-3 (Volume A) and 86-7 (Volume C).

If there are further questions, please contact us.

Very truly yours,

  
Hal B. Tucker

WHM/47/slb

8612230232	861215
PDR	ADOCK 05000269
F	PDR

A045  
11

Mr. Harold R. Denton, Director

December 15, 1986

Page 2

xc: Ms. Helen Pastis  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. J. C. Bryant  
NRC Resident Inspector  
Oconee Nuclear Station