

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8704070338 DOC. DATE: 87/03/20 NOTARIZED: NO DOCKET #  
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269  
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270  
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME: TUCKER, H. B. AUTHOR AFFILIATION: Duke Power Co.  
 RECIP. NAME: RECIPIENT AFFILIATION: Document Control Branch (Document Control Desk)

SUBJECT: Advises that mods required to correct deficiencies in seismic qualification of emergency feedwater sys scheduled for completion at end of Cycles 11, 10 & 11 for Units 1, 2 & 3, respectively. Projected dates are 890421, 0730 & 900306.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: OR Submittal: General Distribution

NOTES: AEOD/Ornstein:1cy. 05000269  
 AEOD/Ornstein:1cy. 05000270  
 AEOD/Ornstein:1cy. 05000287

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD2-3 LA	1 0	PD2-3 PD	5 5
	PASTIS, H	1 1		
INTERNAL:	ADM/LFMB	1 0	NRR/DEST/ADE	1 1
	NRR/DEST/ADS	1 1	NRR/DLPQ/HFB	1 1
	NRR/DOEA/TSB	1 1	NRR/PMAS/ILRB	1 1
	OGC/HDS2	1 0	<u>REG FILE</u> 01	1 1
EXTERNAL:	EG&G BRUSKE, S	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC	1 1
NOTES:		1 1		

**DUKE POWER COMPANY**

P.O. BOX 33189  
CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

TELEPHONE  
(704) 373-4531

March 20, 1987

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555


Subject: Oconee Nuclear Station  
Docket Nos. 50-269, -270, -287

Gentlemen:

By letter dated January 14, 1987 the NRC issued a Safety Evaluation Report (SER) on seismic qualification of the emergency feedwater system (EFW) at the Oconee Nuclear Station. The SER concludes that seismic qualification of the EFW system has been satisfactorily addressed, and therefore, the criteria for Generic Letter 81-14 and requirements of General Design Criteria 2 and 34 have been met and the Multiplant Action Item C-14 is considered to be completed for Oconee.

As indicated in the SER, Duke has committed to correct the deficiencies identified in the seismic qualification of the EFW system in accordance with the licensing design basis. In a letter dated January 5, 1987 Duke stated that a schedule for implementation for required modifications will be provided by March 20, 1987. Currently, the required modifications are scheduled to be completed during the refueling outages for end of cycles (EOC) 11, 10 and 11 for Oconee Units 1, 2 and 3, respectively. The projected completion dates are April 21, 1989, July 30, 1989 and March 6, 1990 for Units 1, 2 and 3, respectively. However, a slippage of the refueling outages will also affect the schedule for implementation of the EFW system modifications, accordingly.


Very truly yours,



Hal B. Tucker

MAH/15/sbn

Attachment



*Acc 1/10*

U. S. Nuclear Regulatory Commission  
March 20, 1987  
Page Two

xc: Dr. J. Nelson Grace, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Mr. J. C. Bryant  
NRC Resident Inspector  
Oconee Nuclear Station

Ms. Helen Pastis  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555