

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8707140411 DOC. DATE: 87/07/02 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Ocone Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Ocone Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Ocone Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME TUCKER, H. B. AUTHOR AFFILIATION Duke Power Co.
 RECIP. NAME RECIP. AFFILIATION Document Control Branch (Document Control Desk)

SUBJECT: Requests approval of installation of inadequate core cooling (ICC) instrumentation sys & facility emergency guidelines for ICC monitoring instrumentation. Fee paid.

DISTRIBUTION CODE: A002D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR Submittal: Inadequate Core Cooling (Item II.F.2) GL 82-28

NOTES: AEOD/Ornstein: 1cy. 05000269
 AEOD/Ornstein: 1cy. 05000270
 AEOD/Ornstein: 1cy. 05000287

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 LA	1	PD2-3 PD	1
	PASTIS, H	2		
INTERNAL:	ARM/DAF/LFMB	1	NRR KARSCH, R	1
	NRR SCHWENK, G	1	REG FILE 01	1
	RES DEPY GI	1	RES/DE/EIB	1
	RES/DRPS/RPSB	1		
EXTERNAL:	LPDR	1	NRC PDR	1
	NSIC	1		
NOTES:		1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 15 ENCL 0

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

July 2, 1987

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287
Inadequate Core Cooling Instrumentation System

Dear Sir:


By letter dated November 23, 1983, the NRC provided its Safety Evaluation Report of the proposed Inadequate Core Cooling (ICC) Instrumentation for Oconee Nuclear Station. Within the November 23, 1983 letter, Duke Power Company (Duke) was requested to submit an implementation letter report to the NRC (Item 6 of Enclosure 3). Accordingly, the subsequent paragraphs provides the information that was requested to be included in the implementation letter report.

The ICC System has been installed in all three Oconee Nuclear Station Units. Each installed ICC System has been calibrated and tested by Westinghouse Electric Company. The results of the functional test are available at Oconee for NRC review/inspection. The test results indicate that the system performs in accordance with the design expectations and within design error tolerances as defined in a Duke letter dated July 1, 1985. The installed ICC System is consistent with the design description provided by the July 1, 1985 letter.

Submittal of Technical Specification for the ICC System was requested; however, it is Duke's understanding that the NRC Staff is discussing the Technical Specification Requirements for the ICC System with the Babcock & Wilcox Owners Group. Duke will monitor the progress of these discussions and appropriate action will be taken following the conclusion of these discussions. Accordingly, Technical Specifications for the ICC System are not being submitted at this time.

By letter dated June 27, 1986, Duke submitted for NRC review and approval the Oconee Emergency Guidelines for the Inadequate Core Cooling Monitoring Instrumentation - NRC approval of the Guidelines is still pending. The Emergency Operating Procedures will be revised, implemented and operators trained within three months of NRC approval of the Guidelines. The revised procedures will conform to the technical content of the Oconee Emergency Guidelines.

In addition to requesting NRC approval of the Guidelines provided by the June 27, 1986 Duke letter, and in accordance with the December 10, 1982 order, Duke requests



A002
1/10


U. S. Nuclear Regulatory Commission

July 2, 1987

Page Two

NRC approval of the installation of the ICC System at Oconee. Pursuant to 10 CFR 170.12, please find attached the application fee of \$150.00.

Very truly yours,

A handwritten signature in cursive script, appearing to read "Hal B. Tucker".

Hal B. Tucker

PFG/48/sbn

Attachment

xc: Dr. J. Nelson Grace, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Ms. Helen Pastis
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. J. C. Bryant
NRC Resident Inspector
Oconee Nuclear Station